

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2987397 Test Start : 03/04/2024 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:42
Location : 1st FL=Main Office Received: 03/11/2024 @ 10:18
Radon Level : 1.8 pCi/L Analyzed: 03/12/2024 @ 09:08
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989271 Test Start : 03/04/2024 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:42
Location : 1st FL=Room 22 Received: 03/11/2024 @ 10:18
Radon Level : 1.5 pCi/L Analyzed: 03/12/2024 @ 11:32
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987493 Test Start : 03/04/2024 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:42
Location : 1st FL=Room 22 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.3 pCi/L Analyzed: 03/12/2024 @ 11:12
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987423 Test Start : 03/04/2024 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:43
Location : 1st FL=Principal's Office Received: 03/11/2024 @ 10:18
Radon Level : 2.8 pCi/L Analyzed: 03/12/2024 @ 11:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987473 Test Start : 03/04/2024 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:43
Location : 1st FL=Principal's Conf.Rm. Received: 03/11/2024 @ 10:18
Radon Level : 1.6 pCi/L Analyzed: 03/12/2024 @ 09:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987440 Test Start : 03/04/2024 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:45
Location : 1st FL=Room 23 Received: 03/11/2024 @ 10:18
Radon Level : 0.8 pCi/L Analyzed: 03/12/2024 @ 11:34
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2987418 Test Start : 03/04/2024 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:44
Location : 1st FL=Room 55 Received: 03/11/2024 @ 10:18
Radon Level : 1.8 pCi/L Analyzed: 03/12/2024 @ 10:33
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2987388 Test Start : 03/04/2024 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:44
Location : 1st FL=Room 55 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.1 pCi/L Analyzed: 03/12/2024 @ 10:31
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987463 Test Start : 03/04/2024 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:45
Location : 1st FL=Room 56 DP Received: 03/11/2024 @ 10:18
Radon Level : 1.3 pCi/L Analyzed: 03/12/2024 @ 10:56
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2987626 Test Start : 03/04/2024 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:45
Location : 1st FL=Room 56 DP Received: 03/11/2024 @ 10:18
Radon Level : 1.1 pCi/L Analyzed: 03/12/2024 @ 10:31

Average of Side by Side Canisters 1.2 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2987427 Test Start : 03/04/2024 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:46
Location : 1st FL=Room 24 Received: 03/11/2024 @ 10:18
Radon Level : 1.6 pCi/L Analyzed: 03/12/2024 @ 09:08
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2987399 Test Start : 03/04/2024 @ 06:27
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:44
Location : 1st FL=Health Rm Received: 03/11/2024 @ 10:18
Radon Level : 1.4 pCi/L Analyzed: 03/12/2024 @ 10:32



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	2987495	Test Start :	03/04/2024 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:45
Location :	1st FL=Staff Work Rm	Received:	03/11/2024 @ 10:18
Radon Level :	1.7 pCi/L	Analyzed:	03/12/2024 @ 09:03
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2987489	Test Start :	03/04/2024 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:47
Location :	1st FL=Media Ctr. 1	Received:	03/11/2024 @ 10:18
Radon Level :	2.3 pCi/L	Analyzed:	03/12/2024 @ 11:32
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2987400	Test Start :	03/04/2024 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:47
Location :	1st FL=Staff Break Rm	Received:	03/11/2024 @ 10:18
Radon Level :	0.5 pCi/L	Analyzed:	03/12/2024 @ 09:03
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2987406	Test Start :	03/04/2024 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:47
Location :	1st FL=Media Ctr. 2	Received:	03/11/2024 @ 10:18
Radon Level :	2.1 pCi/L	Analyzed:	03/12/2024 @ 11:29
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2989278	Test Start :	03/04/2024 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:47
Location :	1st FL=Media Ctr. BL	Received:	03/11/2024 @ 10:18
Radon Level :	0.6 pCi/L	Analyzed:	03/12/2024 @ 11:09
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2989202	Test Start :	03/04/2024 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:48
Location :	1st FL=Sm.Staff Break Rm	Received:	03/11/2024 @ 10:18
Radon Level :	1.0 pCi/L	Analyzed:	03/12/2024 @ 11:12
Error for Measurement is: \pm	0.6 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2987469 Test Start : 03/04/2024 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:50
Location : 1st FL=Room 32 DP Received: 03/11/2024 @ 10:18
Radon Level : 1.6 pCi/L Analyzed: 03/12/2024 @ 10:53
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2989222 Test Start : 03/04/2024 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:50
Location : 1st FL=Room 32 DP Received: 03/11/2024 @ 10:18
Radon Level : 1.5 pCi/L Analyzed: 03/12/2024 @ 10:51

Average of Side by Side Canisters 1.6 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2987456 Test Start : 03/04/2024 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:47
Location : 1st FL=Room 01 Received: 03/11/2024 @ 10:18
Radon Level : 0.9 pCi/L Analyzed: 03/12/2024 @ 09:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2987494 Test Start : 03/04/2024 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:49
Location : 1st FL=Room 31 Received: 03/11/2024 @ 10:18
Radon Level : 0.4 pCi/L Analyzed: 03/12/2024 @ 11:17
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989294 Test Start : 03/04/2024 @ 06:32
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:50
Location : 1st FL=Media Ctr. Off. Received: 03/11/2024 @ 10:18
Radon Level : 2.5 pCi/L Analyzed: 03/12/2024 @ 10:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2987356 Test Start : 03/04/2024 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:47
Location : 1st FL=Room 01 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.1 pCi/L Analyzed: 03/12/2024 @ 11:34



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2987417	Test Start :	03/04/2024 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:51
Location :	1st FL=Computer Rm DP	Received:	03/11/2024 @ 10:18
Radon Level :	1.8 pCi/L	Analyzed:	03/12/2024 @ 10:32
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2989256	Test Start :	03/04/2024 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:51
Location :	1st FL=Computer Rm DP	Received:	03/11/2024 @ 10:18
Radon Level :	2.8 pCi/L	Analyzed:	03/12/2024 @ 11:12

Average of Side by Side Canisters 2.3 pCi/L

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2989298	Test Start :	03/04/2024 @ 06:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:41
Location :	1st FL=Comp. Rm Study	Received:	03/11/2024 @ 10:18
Radon Level :	4.7 pCi/L	Analyzed:	03/12/2024 @ 09:06
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2989185	Test Start :	03/04/2024 @ 06:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:52
Location :	1st FL=Comp. Rm Off.	Received:	03/11/2024 @ 10:18
Radon Level :	1.7 pCi/L	Analyzed:	03/12/2024 @ 11:32
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2989186	Test Start :	03/04/2024 @ 06:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:51
Location :	1st FL=Room 33	Received:	03/11/2024 @ 10:18
Radon Level :	1.5 pCi/L	Analyzed:	03/12/2024 @ 11:34
Error for Measurement is: ±	0.6 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2989280 Test Start : 03/04/2024 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:49
Location : 1st FL=Gym 1 Received: 03/11/2024 @ 10:18
Radon Level : 0.1 pCi/L Analyzed: 03/12/2024 @ 11:17
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989265 Test Start : 03/04/2024 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:52
Location : 1st FL=Room 34 Received: 03/11/2024 @ 10:18
Radon Level : 0.5 pCi/L Analyzed: 03/12/2024 @ 10:56
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987396 Test Start : 03/04/2024 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:53
Location : 1st FL=Room 45 Received: 03/11/2024 @ 10:18
Radon Level : 0.8 pCi/L Analyzed: 03/12/2024 @ 10:54
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989242 Test Start : 03/04/2024 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:53
Location : 1st FL=Room 45 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.4 pCi/L Analyzed: 03/12/2024 @ 10:53
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2987402 Test Start : 03/04/2024 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:49
Location : 1st FL=Gym 2 Received: 03/11/2024 @ 10:18
Radon Level : 0.5 pCi/L Analyzed: 03/12/2024 @ 09:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989269 Test Start : 03/04/2024 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:55
Location : 1st FL=Room 46 Received: 03/11/2024 @ 10:18
Radon Level : 1.1 pCi/L Analyzed: 03/12/2024 @ 10:35
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Average of Side by Side Canisters 0.6 pCi/L

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	2987483	Test Start :	03/04/2024 @ 06:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:56
Location :	1st FL=Room 47 DP	Received:	03/11/2024 @ 10:18
Radon Level :	0.1 pCi/L	Analyzed:	03/12/2024 @ 11:17
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2987486	Test Start :	03/04/2024 @ 06:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:56
Location :	1st FL=Room 47 DP	Received:	03/11/2024 @ 10:18
Radon Level :	0.8 pCi/L	Analyzed:	03/12/2024 @ 10:35

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2987439	Test Start :	03/04/2024 @ 06:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:55
Location :	1st FL=Room 42	Received:	03/11/2024 @ 10:18
Radon Level :	0.2 pCi/L	Analyzed:	03/12/2024 @ 09:32
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2989224	Test Start :	03/04/2024 @ 06:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:58
Location :	1st FL=Room 48	Received:	03/11/2024 @ 10:18
Radon Level :	0.4 pCi/L	Analyzed:	03/12/2024 @ 11:34
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2989279	Test Start :	03/04/2024 @ 06:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:46
Location :	1st FL=Room 43	Received:	03/11/2024 @ 10:18
Radon Level :	0.1 pCi/L	Analyzed:	03/12/2024 @ 10:31
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2989235 Test Start : 03/04/2024 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:53
Location : 1st FL=Room 05 Received: 03/11/2024 @ 10:18
Radon Level : 0.9 pCi/L Analyzed: 03/12/2024 @ 10:56
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987389 Test Start : 03/04/2024 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:55
Location : 1st FL=Cust. Office Received: 03/11/2024 @ 10:18
Radon Level : 1.5 pCi/L Analyzed: 03/12/2024 @ 10:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989193 Test Start : 03/04/2024 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:58
Location : 1st FL=Room 44 Received: 03/11/2024 @ 10:18
Radon Level : 1.2 pCi/L Analyzed: 03/12/2024 @ 11:14
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989203 Test Start : 03/04/2024 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 06:58
Location : 1st FL=Room 44 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.1 pCi/L Analyzed: 03/12/2024 @ 09:32
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2987435 Test Start : 03/04/2024 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:00
Location : 1st FL=Room 61 DP Received: 03/11/2024 @ 10:18
Radon Level : 0.9 pCi/L Analyzed: 03/12/2024 @ 11:34
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2989272 Test Start : 03/04/2024 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:00
Location : 1st FL=Room 61 DP Received: 03/11/2024 @ 10:18
Radon Level : 0.5 pCi/L Analyzed: 03/12/2024 @ 11:15

Average of Side by Side Canisters 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2987392	Test Start :	03/04/2024 @ 06:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:02
Location :	1st FL=Room 62	Received:	03/11/2024 @ 10:18
Radon Level :	0.9 pCi/L	Analyzed:	03/12/2024 @ 10:51
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2987477	Test Start :	03/04/2024 @ 06:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:02
Location :	1st FL=Room 62 BL	Received:	03/11/2024 @ 10:18
Radon Level :	0.3 pCi/L	Analyzed:	03/12/2024 @ 10:54
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2987488	Test Start :	03/04/2024 @ 06:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:00
Location :	1st FL=Room 51	Received:	03/11/2024 @ 10:18
Radon Level :	1.6 pCi/L	Analyzed:	03/12/2024 @ 10:51
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2987394	Test Start :	03/04/2024 @ 06:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:03
Location :	1st FL=Room 64-A	Received:	03/11/2024 @ 10:18
Radon Level :	25.6 pCi/L	Analyzed:	03/12/2024 @ 10:30
Error for Measurement is: \pm	1.0 pCi/L		

Canister ID# :	2987501	Test Start :	03/04/2024 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 06:59
Location :	1st FL=Cafeteria 1	Received:	03/11/2024 @ 10:18
Radon Level :	0.5 pCi/L	Analyzed:	03/12/2024 @ 11:15
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2987496	Test Start :	03/04/2024 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:01
Location :	1st FL=Room 52 DP	Received:	03/11/2024 @ 10:18
Radon Level :	0.8 pCi/L	Analyzed:	03/12/2024 @ 09:06
Error for Measurement is: \pm	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2989219	Test Start :	03/04/2024 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:01
Location :	1st FL=Room 52 DP	Received:	03/11/2024 @ 10:18
Radon Level :	1.4 pCi/L	Analyzed:	03/12/2024 @ 11:14

Average of Side by Side Canisters 1.1 pCi/L

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	2989253	Test Start :	03/04/2024 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:04
Location :	1st FL=Room 64-B	Received:	03/11/2024 @ 10:18
Radon Level :	25.1 pCi/L	Analyzed:	03/12/2024 @ 10:51

Error for Measurement is: ± 1.0 pCi/L

Canister ID# :	2987295	Test Start :	03/04/2024 @ 06:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:00
Location :	1st FL=Cafeteria 2	Received:	03/11/2024 @ 10:18
Radon Level :	1.3 pCi/L	Analyzed:	03/12/2024 @ 10:56

FOUND DISTURBED

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	2987404	Test Start :	03/04/2024 @ 06:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:02
Location :	1st FL=Room 53	Received:	03/11/2024 @ 10:18
Radon Level :	2.8 pCi/L	Analyzed:	03/12/2024 @ 11:14

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2987448	Test Start :	03/04/2024 @ 06:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:02
Location :	1st FL=Room 53 BL	Received:	03/11/2024 @ 10:18
Radon Level :	1.7 pCi/L	Analyzed:	03/12/2024 @ 10:56

Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2989221 Test Start : 03/04/2024 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:04
Location : 1st FL=Room 54 Received: 03/11/2024 @ 10:18
Radon Level : 1.8 pCi/L Analyzed: 03/12/2024 @ 10:35
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987433 Test Start : 03/04/2024 @ 07:01
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:02
Location : 1st FL=Room 11 Received: 03/11/2024 @ 10:18
Radon Level : 1.1 pCi/L Analyzed: 03/12/2024 @ 11:17
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987467 Test Start : 03/04/2024 @ 07:04
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:05
Location : 1st FL=Room 12 Received: 03/11/2024 @ 10:18
Radon Level : 0.8 pCi/L Analyzed: 03/12/2024 @ 09:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987403 Test Start : 03/04/2024 @ 07:06
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:05
Location : 1st FL=Room 12 BL Received: 03/11/2024 @ 10:18
Radon Level : 0.6 pCi/L Analyzed: 03/12/2024 @ 10:35
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987442 Test Start : 03/04/2024 @ 07:08
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:08
Location : 1st FL=Room 13 Received: 03/11/2024 @ 10:18
Radon Level : 2.4 pCi/L Analyzed: 03/12/2024 @ 11:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987374 Test Start : 03/04/2024 @ 07:15
Canister Type : Charcoal Canister 3 inch Test Stop : 03/06/2024 @ 07:15
Location : 1st FL=Room 14 DP Received: 03/11/2024 @ 10:18
Radon Level : 1.1 pCi/L Analyzed: 03/12/2024 @ 10:53
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2987412	Test Start :	03/04/2024 @ 07:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:15
Location :	1st FL=Room 14 DP	Received:	03/11/2024 @ 10:18
Radon Level :	1.4 pCi/L	Analyzed:	03/12/2024 @ 11:14

Average of Side by Side Canisters 1.3 pCi/L

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2987431	Test Start :	03/04/2024 @ 07:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:20
Location :	1st FL=Room 21 DP	Received:	03/11/2024 @ 10:18
Radon Level :	0.8 pCi/L	Analyzed:	03/12/2024 @ 11:32

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2987449	Test Start :	03/04/2024 @ 07:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/06/2024 @ 07:20
Location :	1st FL=Room 21 DP	Received:	03/11/2024 @ 10:18
Radon Level :	0.3 pCi/L	Analyzed:	03/12/2024 @ 11:34

Average of Side by Side Canisters 0.6 pCi/L

Error for Measurement is: \pm 0.6 pCi/L

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/11/2024

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201