



MINNEAPOLIS
PUBLIC SCHOOLS

Urban Education. Global Citizens.

Environmental Health & Safety

Office: (612) 668-0310

Direct: 612-668-0308

Lee Setter
Manager,

Environmental Health & Safety

MEMORANDUM

To: VaNita Miller, Principal Field School

From: Lee Setter, Manager Environmental Health & Safety

Date: December 01, 2021

**RE: Field School
Lead In Water Testing (Water Flushing Waiver)**

Drinking water was tested at Field School on November 12, 2021. The testing was performed as part of our Lead in Water Safety Program and as recommended by the Minnesota Department of Health. EH&S sampled twelve (12) locations for lead. The purpose of this program is to ensure that school drinking water does not exceed a permissible lead level of 20 parts per billion (ppb).

All water was collected on a **first draw** basis with a minimum of six-hour system stagnation. This method represents the worst case scenario for lead in water concentrations. All drinking water samples collected at Field School had concentrations below 20 ppb (see attached laboratory report).

It is very good news to receive test results identifying all water sources to be below the 20 ppb standard. Based on the laboratory results and upgrades to water fixtures and plumbing lines, Field school is being waived from the water-flushing program. As a good practice, EH&S encourages staff and students to run drinking sources until cool before drinking. The laboratory analysis report will be available to the public on the MPS website:

<https://www.mpschools.org/departments/operations/environmental-health-safety>

If you have any questions, you may contact me at your convenience at 612-668-0307.

Attachment: Laboratory Analysis Report issued dated Nov 17, 2021

CC: Richard St Claire, James Tschida, Shawn Lindell

