



MINNEAPOLIS
PUBLIC SCHOOLS

Urban Education. Global Citizens.

Environmental Health & Safety

Office: (612) 668-0310

Direct (612)-668-0308

Cell: (612) 719-7742

Lee Setter
Manager,

Environmental Health & Safety

MEMORANDUM

To: Bill Gibbs, Principal Kenny School

From: Lee Setter, Manager Environmental Health & Safety

Date: January 13, 2022

RE: Kenny School
Lead In Water Testing

Drinking water was tested at Kenny School on December 17, 2021. The testing was performed as part of our Lead in Water Safety Program and as recommended by the Minnesota Department of Health. The purpose of this program is to ensure that school drinking water does not exceed a permissible lead level of 20 parts per billion (ppb).

All water was collected on a first draw basis with a minimum of six hour system stagnation. This method represents the worst-case scenario for lead in water concentrations. Twenty-six (26) water samples were collected. All drinking water samples collected at Kenny School had first draw concentrations below 20 ppb (see attached laboratory report).

It is very good news to receive test results showing drinking water sources to be below the 20 ppb standard. However, because not all piping at Kenny has been replaced with new piping and potential sources of lead remain; we have determined the safest course of action is for Kenny to continue its participation in the Lead in Water Flushing Program. EH&S has communicated the procedures for proper flushing with your building engineer and the importance to perform these procedures on a daily basis. The laboratory analysis report will be available to the public on the MPS website:

<https://www.mpschools.org/departments/operations/environmental-health-safety>

Please contact me if you have any questions.

Attachment: Laboratory Analysis Report dated January 04, 2022

CC: Chris Schlee, Lee Setter, James Tschida, Joseph Hayes, Shawn Lindell

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID #399073400

Client: Kenny School
 Minneapolis Public Schools
Address: 1225 North 7th Street
 Minneapolis, MN 55411

Report Number: 21-12204
Sample Receipt Date: 12/17/21
Sample Prep. Date: 12/17/21
Sample Prep. Time: 11:00
Report Issue Date: 1/4/22

Twin City Water Clinic Inc.
617 13th Avenue South
Hopkins, MN 55343
Phone: (952)935-3556
Fax: (952)935-5077

X No samples were subcontracted; or the above test result(s) with '*' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Laboratory	Analyte	Sample	Parameter	Sample Collection		Sample Analysis		Test	
Sample ID		Location		Date	Time	Date	Time	Results	Units
21-12204	Lead	DF-BF Hallway Outside M.O.	Drinking Water	12/17/21	03:54	12/27/21	11:10	<2.0	µg/L
21-12205	Lead	Staff Lounge-Sink	Drinking Water	12/17/21	03:56	12/27/21	11:16	<2.0	µg/L
21-12206	Lead	Music Room Sink	Drinking Water	12/17/21	03:58	12/27/21	11:21	<2.0	µg/L
21-12207	Lead	Kinder A	Drinking Water	12/17/21	04:00	12/27/21	11:39	<2.0	µg/L
21-12208	Lead	Kinder C	Drinking Water	12/17/21	04:02	12/27/21	11:55	<2.0	µg/L
21-12209	Lead	DF Room 101	Drinking Water	12/17/21	04:03	12/27/21	12:01	<2.0	µg/L
21-12210	Lead	DF Room 102	Drinking Water	12/17/21	04:05	12/27/21	12:07	<2.0	µg/L
21-12211	Lead	DF Room 103	Drinking Water	12/17/21	04:07	12/27/21	12:12	<2.0	µg/L
21-12212	Lead	DF Room 104	Drinking Water	12/17/21	04:08	12/27/21	12:18	<2.0	µg/L
21-12213	Lead	DF Room 105	Drinking Water	12/17/21	04:09	12/27/21	12:13	<2.0	µg/L
21-12214	Lead	DF Room 106	Drinking Water	12/17/21	04:11	12/27/21	12:30	<2.0	µg/L
21-12215	Lead	DF Room 107	Drinking Water	12/17/21	04:12	12/27/21	12:35	<2.0	µg/L
21-12216	Lead	DF Room 108	Drinking Water	12/17/21	04:14	12/27/21	12:41	<2.0	µg/L
21-12217	Lead	Kitchen 130-Prep Sink	Drinking Water	12/17/21	04:15	12/29/21	11:41	<2.0	µg/L
21-12218	Lead	Kitchen 130-Prep Wash	Drinking Water	12/17/21	04:17	12/29/21	11:47	<2.0	µg/L
21-12219	Lead	DF-BF Hallway Room 115	Drinking Water	12/17/21	04:18	12/29/21	11:53	<2.0	µg/L
21-12220	Lead	DF Room 115	Drinking Water	12/17/21	04:19	12/29/21	11:59	<2.0	µg/L
21-12221	Lead	DF Room 116	Drinking Water	12/17/21	04:21	12/29/21	12:04	<2.0	µg/L
21-12222	Lead	DF Room 117	Drinking Water	12/17/21	04:23	12/29/21	12:10	<2.0	µg/L
21-12223	Lead	DF Room 118	Drinking Water	12/17/21	04:25	12/29/21	12:16	<2.0	µg/L

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant level: Lead, 15.0 µg/L

Sample Collected by: X Client TCWC

Sample Temp.: 2° C

Notes:

Discussion: DF = Drinking Fountain, M.O. = main office

Approved By:


 Bill Van Arsdale
 Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.

