

1005 BOSTON POST ROAD  
MADISON, CT 06443  
Phone 203-245-0568  
FAX 203-318-0830  
Connecticut Certification PH-0535  
www.eclinconline.com



**RECEIVED**

280178

By Tracy Daigle at 10:50 am, Mar 18, 2024

### Report of Analysis

**Name:** Amity Regional School District #5  
25 Newton Road  
Woodbridge, CT 06525  
Attn: Steve Martoni

**Sample ID#:** 169348  
**Sample Type:** Drinking Water  
**Sample Source:** Bethany Middle School - Kitchen Sink  
**Sampler:** ECL - WR  
**PWS ID:** CT0080162

**Sample Date:** 3/11/2024  
**Receipt Date:** 3/11/2024  
**Report Date:** 3/13/2024  
**Sample Site:** KITCHEN

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
<b>Biological</b>						
Coliform, E. Coli	ABSENT	P/A	Colilert-18	0	3/11/2024	MB
Coliform, Total	ABSENT	P/A	Colilert-18	0	3/11/2024	MB
<b>Chemical</b>						
Chlorine- Residual, Total	ND	mg/L	SM4500-Cl G	0.02	3/11/2024	WR

DAVID BARRIS - LABORATORY DIRECTOR

Jordan Barris  
JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

1005 BOSTON POST ROAD  
 MADISON, CT 06443  
 Phone 203-245-0568  
 FAX 203-318-0830  
 Connecticut Certification PH-0535  
 www.eclinonline.com




## Report of Analysis

<b>Name:</b>	Amity Regional School District #5 25 Newton Road Woodbridge, CT 06525 Attn: Steve Martoni	<b>Sample ID#:</b>	169349
		<b>Sample Type:</b>	Drinking Water
		<b>Sample Source:</b>	Bethany Middle School - Kitchen Sink
		<b>Sampler:</b>	ECL - WR
<b>Sample Date:</b>	3/11/2024	<b>PWS ID:</b>	CT0080162
<b>Receipt Date:</b>	3/11/2024		
<b>Report Date:</b>	3/13/2024		
<b>Sample Site:</b>	KITCHEN		

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
<b>Physical</b>						
Color	ND	CU	SM2120B	1	3/11/2024	JB
Odor	ND	TON	SM2150B	1	3/11/2024	JB
PH	7.82	pH	EPA 150.2	1	3/11/2024	JB
Turbidity	1.0	NTU	180.1	0.05	3/11/2024	JB

DAVID BARRIS - LABORATORY DIRECTOR

  
 JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

1005 BOSTON POST ROAD  
MADISON, CT 06443  
Phone 203-245-0568  
FAX 203-318-0830  
Connecticut Certification PH-0535  
www.eclinconline.com



**ENVIRONMENTAL**  
CONSULTING LABORATORIES, INC.

## Report of Analysis

**Name:** Amity Regional School District #5  
25 Newton Road  
Woodbridge, CT 06525  
Attn: Steve Martoni

**Sample ID#:** 169350  
**Sample Type:** Drinking Water  
**Sample Source:** Entry Point  
**Sampler:** ECL - WR  
**PWS ID:** CT0080162

**Sample Date:** 3/11/2024  
**Receipt Date:** 3/11/2024  
**Report Date:** 3/13/2024  
**Sample Site:** 3

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
<b>Chemical</b>						
Nitrate as N	0.21	mg/L	EPA 300.0	0.1	3/12/2024	JB
Nitrite as N	ND	mg/L	EPA 300.0	0.01	3/12/2024	JB

DAVID BARRIS - LABORATORY DIRECTOR

  
JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

