

Lead Tests - Jacksonville Elementary School - Main Building - 20480500						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480500-001KF	20480500-001KF24A	Kitchen - Hand Wash Sink	4/26/2023	4.5	None.
2	20480500-002KF	20480500-002KF24A	Kitchen - Vegetable Prep Sink	4/26/2023	1.0	None.
3	20480500-003KF	20480500-003KF24A	Kitchen - Pre-rinse Sink (Dishwasher Area)	4/26/2023	1.2	None.
N/A	N/A	N/A	Kiln Room - Sink	N/A	N/A	This sink is not operational and has no fixture.
N/A	N/A	N/A	Kiln Room - Sink (In The Bathroom)	N/A	N/A	This sink is not operational.
4	20480500-004DW	20480500-004DW24A	By Cafeteria In The Hallway - Elkay Bottle Filler (Upper)	5/18/2023	ND	New Elkay Bottle filler with DW and filter installed 02/13/2023. Upper and lower share filter.
5	20480500-005VB	20480500-005VB24A	By Cafeteria In The Hallway - Elkay DW (Lower)	5/18/2023	ND	New Elkay Bottle filler with DW and filter installed 02/13/2023. Upper and lower share filter.
6	20480500-006SF	20480500-006SF24A	Staff Lounge Room - Sink	4/26/2023	2.6	None.
7	20480500-007IM	20480500-007IM24A	Staff Lounge Room - Refrigerator Ice Maker (Left)	N/A	N/A	This ice maker has a sediment water filter on it. Ice maker is disconnected 04/26/23.
8	20480500-008IM	20480500-008IM24A	Staff Lounge Room - Refrigerator Ice Maker (Right)	N/A	N/A	This ice maker has a sediment water filter on it. Ice maker is disconnected 04/26/23.
9	20480500-009DW	20480500-009DW24A	Room 1 - Drinking Fountain	4/26/2023	2.9	Changed faucet for children's convenience 10/22/21.
10	20480500-010CF	20480500-010CF24A	Room 1 - Sink	4/26/2023	6.7	None.
11	20480500-011BF	20480500-011BF24A	Room 1 - Restroom Sink	4/26/2023	4.8	None.
12	20480500-012BF	20480500-012BF24A	Boys Restroom Outside Rooms 1/3 - Sink (Left)	4/26/2023	0.6	None.
13	20480500-013BF	20480500-013BF24A	Boys Restroom Outside Rooms 1/3 - Sink (Center)	4/26/2023	1.1	None.
14	20480500-014BF	20480500-014BF24A	Boys Restroom Outside Rooms 1/3 - Sink (Right)	4/26/2023	1.1	None.
15	20480500-015BF	20480500-015BF24A	Girls Restroom Outside Rooms 1/3 - Sink (Left)	4/26/2023	5.0	None.
16	20480500-016BF	20480500-016BF24A	Girls Restroom Outside Rooms 1/3 - Sink (Center)	4/26/2023	4.4	None.
17	20480500-017BF	20480500-017BF24A	Girls Restroom Outside Rooms 1/3 - Sink (Right)	4/26/2023	4.4	None.
18	20480500-018BF	20480500-018BF24A	Staff Restroom Outside Rooms 1/3 - Sink	4/26/2023	3.7	None.
19	20480500-019OT	20480500-019OT24A	Classroom between Room 1 and 3 - Sink	5/18/2023	6.9	Lead filter installed 05/18/2023.
20	20480500-020DW	20480500-020DW24A	Classroom between Room 1 and 3 - Drinking Fountain	4/26/2023	11.3	None.
21	20480500-021DW	20480500-021DW24A	Room 3 - Drinking Fountain	5/12/2023	3.0	Did Mike replace the fixture 05/12/2023?
22	20480500-022CF	20480500-022CF24A	Room 3 - Sink	4/26/2023	9.0	None.
23	20480500-023BF	20480500-023BF24A	Room 3 - Restroom Sink (Left)	4/26/2023	5.1	None.
24	20480500-024BF	20480500-024BF24A	Room 3 - Restroom Sink (Right)	4/26/2023	6.7	None.
25	20480500-025DW	20480500-025DW24A	Room 2 - Drinking Fountain	5/11/2023	3.8	None.
26	20480500-026CF	20480500-026CF24A	Room 2 - Sink	5/11/2023	2.8	None.
27	20480500-027DW	20480500-027DW24A	Room 5 - Drinking Fountain	4/26/2023	6.6	None.
28	20480500-028CF	20480500-028CF24A	Room 5 - Sink	5/11/2023	0.8	None.
29	20480500-029BF	20480500-029BF24A	Room 5 Rest Room - Sink (Left)	4/26/2023	5.8	This sink has a lead filter on it.
30	20480500-030BF	20480500-030BF24A	Room 5 Rest Room - Sink (Right)	6/11/2019	7.0	Room is now closet. Sink turned off and inaccessible 04/26/23.
31	20480500-031DW	20480500-031DW24A	Room 4 - Drinking Fountain	4/26/2023	5.3	None.
32	20480500-032CF	20480500-032CF24A	Room 4 - Sink	4/26/2023	10.8	None.
33	20480500-033DW	20480500-033DW24A	Room 7 - Drinking Fountain	4/26/2023	2.3	This drinking fountain has a lead filter on it.
34	20480500-034CF	20480500-034CF24A	Room 7 - Sink	4/26/2023	8.3	None.
35	20480500-035BF	20480500-035BF24A	Room 7 Rest Room - Sink (Left)	4/26/2023	7.0	None.
36	20480500-036BF	20480500-036BF24A	Room 7 Rest Room - Sink (Right)	4/26/2023	6.5	None.
37	20480500-037DW	20480500-037DW24A	Room 6 - Drinking Fountain	4/26/2023	9.4	None.
38	20480500-038CF	20480500-038CF24A	Room 6 - Sink	4/26/2023	11.1	None.
39	20480500-039SF	20480500-039SF24A	Staff Work Room (By Office) - Sink	4/26/2023	3.3	None.
40	20480500-040NS	20480500-040NS24A	Health Room - Sink	4/26/2023	7.2	None.
41	20480500-041BF	20480500-041BF24A	Health Room Rest Room - Sink	4/26/2023	1.2	None.
42	20480500-042BF	20480500-042BF24A	Girls Restroom By Media Center - Sink (1 - Left To Right)	4/26/2023	2.3	None.
43	20480500-043BF	20480500-043BF24A	Girls Restroom By Media Center - Sink (2 - Left To Right)	4/26/2023	2.5	None.
44	20480500-044BF	20480500-044BF24A	Girls Restroom By Media Center - Sink (3 - Left To Right)	4/26/2023	0.8	None.
45	20480500-045BF	20480500-045BF24A	Girls Restroom By Media Center - Sink (4 - Left To Right)	5/11/2023	6.1	None.
46	20480500-046BF	20480500-046BF24A	Staff Restroom By Media Center - Sink	4/26/2023	2.0	None.
47	20480500-047BF	20480500-047BF24A	Boys Restroom By Media Center - Sink (Left)	4/26/2023	2.4	None.
48	20480500-048BF	20480500-048BF24A	Boys Restroom By Media Center - Sink (Right)	4/26/2023	1.8	None.
49	20480500-049DW	20480500-049DW24A	Outside Room 7 - Drinking Fountain (Outdoor)	5/11/2023	2.8	Added filter 5/11/2023.
50	20480500-050SF	20480500-050SF24A	Media Center Work Room - Sink	5/18/2023	ND	Lead filter installed 05/18/2023.
51	20480500-051CF	20480500-051CF24A	Computer Lab - Sink	4/26/2023	6.7	None.
52	20480500-052CF	20480500-052CF24A	Early Reading Intervention Room (ERI) - Sink	4/26/2023	3.9	The room was previously the photo room and custodial room.
53	20480500-053DW	20480500-053DW24A	Between Media Center and Room 16 - Drinking Fountain	4/26/2023	4.9	None.
54	20480500-054DW	20480500-054DW24A	Room 16 - Drinking Fountain	4/26/2023	2.1	None.
55	20480500-055CF	20480500-055CF24A	Room 16 - Sink	4/26/2023	8.8	None.
56	20480500-056SF	20480500-056SF24A	Art Supply Room - Sink	5/11/2023	4.3	Drinking fountain was removed from this sink 23 June 2016.
57	20480500-057DW	20480500-057DW24A	Room 17 - Drinking Fountain	4/26/2023	2.4	None.
58	20480500-058CF	20480500-058CF24A	Room 17 - Sink	4/26/2023	3.6	None.
59	20480500-059BF	20480500-059BF24A	Girls Restroom Outside Room 17 - Sink	4/26/2023	1.2	None.
60	20480500-060BF	20480500-060BF24A	Boys Restroom Outside Room 17 - Sink	4/26/2023	1.4	None.
61	20480500-061DW	20480500-061DW24A	Outside Room 17 - Drinking Fountain (L)	4/26/2023	6.5	None.
62	20480500-062DW	20480500-062DW24A	Outside Room 17 - Drinking Fountain (R)	4/26/2023	3.2	None.
63	20480500-063DW	20480500-063DW24A	Room 18 - Drinking Fountain	4/26/2023	2.1	None.
64	20480500-064CF	20480500-064CF24A	Room 18 - Sink	4/26/2023	4.9	None.
65	20480500-065DW	20480500-065DW24A	Room 19 - Drinking Fountain	4/26/2023	2.3	None.
66	20480500-066CF	20480500-066CF24A	Room 19 - Sink	4/26/2023	4.8	None.
67	20480500-067DW	20480500-067DW24A	Room 20 - Drinking Fountain	4/26/2023	1.8	None.
68	20480500-068CF	20480500-068CF24A	Room 20 - Sink	4/26/2023	6.7	None.
69	20480500-069BF	20480500-069BF24A	Staff Restroom Outside Room 20 - Sink	4/26/2023	ND	None.
70	20480500-070DW	20480500-070DW24A	Room 21 - Drinking Fountain	4/26/2023	1.7	None.
71	20480500-071CF	20480500-071CF24A	Room 21 - Sink	4/26/2023	7.7	None.
72	20480500-072DW	20480500-072DW24A	Room 8 - Drinking Fountain	4/26/2023	2.8	None.
73	20480500-073CF	20480500-073CF24A	Room 8 - Sink	4/26/2023	3.3	None.
74	20480500-074DW	20480500-074DW24A	Room 10 - Drinking Fountain	4/26/2023	1.8	None.
75	20480500-075CF	20480500-075CF24A	Room 10 - Sink	4/26/2023	1.8	None.
76	20480500-076DW	20480500-076DW24A	Room 9 - Drinking Fountain	4/26/2023	1.8	None.
77	20480500-077CF	20480500-077CF24A	Room 9 - Sink	4/26/2023	3.6	None.

78	20480500-078DW	20480500-078DW24A	Room 11 - Drinking Fountain	4/26/2023	1.6	None.
79	20480500-079CF	20480500-079CF24A	Room 11 - Sink	4/26/2023	2.7	None.
80	20480500-080DW	20480500-080DW24A	Room 12 - Drinking Fountain	4/26/2023	1.6	None.
81	20480500-081CF	20480500-081CF24A	Room 12 - Sink	4/26/2023	3.3	None.
82	20480500-082DW	20480500-082DW24A	Room 14 - Drinking Fountain	4/26/2023	3.7	None.
83	20480500-083CF	20480500-083CF24A	Room 14 - Sink	4/26/2023	2.0	None.
84	20480500-084DW	20480500-084DW24A	Room 13 - Drinking Fountain	4/26/2023	2.2	None.
85	20480500-085CF	20480500-085CF24A	Room 13 - Sink	4/26/2023	1.6	None.
86	20480500-086DW	20480500-086DW24A	Room 15 - Drinking Fountain	4/26/2023	3.2	None.
87	20480500-087CF	20480500-087CF24A	Room 15 - Sink	4/26/2023	2.5	None.
Lead Tests - Jacksonville Elementary School - Gym - 20480501						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480501-001BF	20480501-001BF24A	Breezeway Boys (Outside Gym/Room 14/15) - Sink (Left)	4/26/2023	6.2	None.
2	20480501-002BF	20480501-002BF24A	Breezeway Boys (Outside Gym/Room 14/15) - Sink (Right)	4/26/2023	4.1	None.
3	20480501-003BF	20480501-003BF24A	Breezeway Girls (Outside Gym/Room 14/15) - Sink (Left)	4/26/2023	2.3	None.
4	20480501-004BF	20480501-004BF24A	Breezeway Girls (Outside Gym/Room 14/15) - Sink (Right)	4/26/2023	5.1	None.
5	20480501-005DW	20480501-005DW24A	Breezeway (Outside Gym/Room 14/15) - Drinking Fountain	4/26/2023	2.0	None.
6	20480501-006DW	20480501-006DW24A	Gym - Drinking Fountain (By Laundry Room)	4/26/2023	2.8	None.
N/A	N/A	N/A	Gym (Custodial Supply Room) - Sink	N/A	N/A	This sink is not operational.
N/A	N/A	N/A	Gym (PE Storage Room) - Sink	N/A	N/A	This sink is not operational.
7	20480501-007DW	20480501-007DW24A	Gym - Drinking Fountain (Hallway/North Side)	4/26/2023	6.5	None.
8	20480501-008OT	20480501-008OT24A	Gym (Stage) - Utility Sink	4/26/2023	10.9	None.
9	20480501-009DW	20480501-009DW24A	Main Playground (Outdoor) - Drinking Fountain (Upper)	4/26/2023	3.1	None.
10	20480501-010DW	20480501-010DW24A	Main Playground (Outdoor) - Drinking Fountain (Lower)	4/26/2023	1.4	None.

*None Detected (ND) = 0.515 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.