JURGIEL
JOHN A. JURGIEL & ASSOCIATES, INC.

ST. LOUIS
123 N. Main Street
St. Charles, Missouri 63301
Phone: 636-757-3060

DALLAS/FORT WORTH
2235 St. Andrew Drive
Highland Village, Texas 75077
Phone: 214-735-8055

March 4, 2024

Mr. Michael Smith
Director of Operations
Ritenour School District
2420 Woodson Road
St. Louis, MO 63114

Via: smithm@ritenourschools.org

Re: Lead In Drinking Water Sampling
Ritenour Middle School
December 29, 2023

Dear Michael,

This letter will serve as our report concerning the water sampling conducted at Ritenour Middle School on December 29, 2023, for compliance with the State of Missouri Title XI, Chapter 160.077, "Get The Lead Out of School Drinking Water Act".

Potable water sources for drinking or food preparation such as sinks, faucets, water fountains, ice makers, etc., were identified and first draw water samples were collected after a stagnation period of at least eight hours. Two hundred and fifty milliliter non-preservative plastic containers were utilized for the sample collection. The water samples were analyzed by EPA 200.8 methods at a laboratory accredited for analysis of drinking water by the National Environmental Laboratory Accreditation Program (NELAP) and the Illinois EPA (ILEPA). Results are reported in micrograms per liter (µg/L), which is the same as parts per billion (ppb). Water sample results must be less than (<) 5.0 µg/L or ppb, per the regulation. Results above 5.0 µg/L require corrective actions.

Eighty samples were collected with results ranging from less than the laboratory limit of detection of 1.0 (<1.0) µg/L to 970 µg/L. Twenty-one results were above the mandated threshold of <5.0 µg/L. Corrective actions are warranted for the twenty-one locations. It should be noted that at least seven of these sources did not appear to be in active use. If these sources will be taken out of service, the source and the supply pipe should be removed or disconnected as close as possible to the remaining active pipes to minimize any dead-end lines that could allow for bacteria or Legionella growth. Sample locations and laboratory results are contained in the attached table.

Sincerely,

Gregory K. Young
Senior Project Manager

TABLE 1
Lead Sampling Results
Ritenour Middle School (December 29, 2023)

Sample ID	Location	Results (µg/L)
RMS-1	2nd Floor, Men's Restroom Near Room 221, Left Sink	< 1.00
RMS-2	2nd Floor, Men's Restroom Near Room 221, Right Sink	3.4
RMS-3	2nd Floor, Water Fountain Near Room 223	< 1.00
RMS-4	2nd Floor, Women's Restroom Near Room 221, Left Sink	< 1.00
RMS-5	2nd Floor, Women's Restroom Near Room 221, Right Sink	1.2
RMS-6	2nd Floor, Classroom 225, Island Sink	**9.4**
RMS-7	2nd Floor, Classroom 227, Island Sink	**18.9**
RMS-8	2nd Floor, Classroom 231, Island Sink	**45.3**
RMS-9	2nd Floor, Classroom 201, Island Sink	**18.0**
RMS-10	2nd Floor, Girl's Restroom Near Room 208, Left Sink	< 1.00
RMS-11	2nd Floor, Girl's Restroom Near Room 208, Middle Sink	< 1.00
RMS-12	2nd Floor, Girl's Restroom Near Room 208, Right Sink	< 1.00
RMS-13	2nd Floor, Boy's Restroom Near Room 210, Left Sink	< 1.00
RMS-14	2nd Floor, Boy's Restroom Near Room 210, Middle Sink	< 1.00
RMS-15	2nd Floor, Boy's Restroom Near Room 210, Right Sink	< 1.00
RMS-16	2nd Floor Water Fountain Near Room 210, Left	< 1.00
RMS-17	2nd Floor Water Fountain Near Room 210, Right	< 1.00
RMS-18	1st Floor, Water Fountain Near Room 123 Lounge	< 1.00
RMS-19	1st Floor, Teacher's Lounge 123, Sink	< 1.00
RMS-20	1st Floor, Teacher's Lounge 123, Men's Restroom Sink	2.3
RMS-21	1st Floor, Teacher's Lounge 123, Women's Restroom Sink	1.4
RMS-22	1st Floor, Girl's Restroom Near Room 123 Lounge, Left Sink	< 1.00
RMS-23	1st Floor, Girl's Restroom Near Room 123 Lounge, Right Sink	< 1.00

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Ritenour Middle School (December 29, 2023)

Sample ID	Location	Results (µg/L)
RMS-24	1st Floor, Men's Restroom Near Room 125, Left Sink	< 1.00
RMS-25	1st Floor, Men's Restroom Near Room 125, Right Sink	< 1.00
RMS-26	1st Floor, Staff Workroom, Sink	< 1.00
RMS-27	1st Floor, Staff Workroom, Men's Restroom Sink	< 1.00
RMS-28	1st Floor, Staff Workroom, Women's Restroom Sink	< 1.00
RMS-29	1st Floor, Ladies' Restroom Near Room 110, Left Sink	< 1.00
RMS-30	1st Floor, Ladies' Restroom Near Room 110, Middle Sink	< 1.00
RMS-31	1st Floor, Ladies' Restroom Near Room 110, Right Sink	< 1.00
RMS-32	1st Floor, Boy's Restroom Near Room 110, Left Sink	< 1.00
RMS-33	1st Floor, Boy's Restroom Near Room 110, Middle Sink	< 1.00
RMS-34	1st Floor, Boy's Restroom Near Room 110, Right Sink	< 1.00
RMS-35	1st Floor, Water Fountain Near Room 110, Left	< 1.00
RMS-36	1st Floor, Water Fountain Near Room 110, Right	< 1.00
RMS-37	1st Floor, Nurse's Office Room 111, Sink	**8.9**
RMS-38	1st Floor, Nurse's Office Room 111 Restroom, Sink	2.8
RMS-39	1st Floor, Cafeteria, Water Fountain, Right	< 1.00
RMS-40	1st Floor, Kitchen, Ice Maker	< 1.00
RMS-41	1st Floor, Kitchen, East Handwashing Sink	3.3
RMS-42	1st Floor, Kitchen, Middle Prep Table Sink	**26.9**
RMS-43	1st Floor, Kitchen, West Dishwashing Area, Handwashing Sink	4.7
RMS-44	1st Floor, Kitchen, West Dishwashing Area, Left Sink	3.9
RMS-45	1st Floor, Kitchen, West Dishwashing Area, Right Sink	< 1.00
RMS-46	1st Floor, Kitchen, West Dishwashing Area, Spray Sink	< 1.00

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Ritenour Middle School (December 29, 2023)

Sample ID	Location	Results (µg/L)
RMS-47	1st Floor, Kitchen, Dishwashing Sinks Near Ice Maker, Left Sink	< 1.00
RMS-48	1st Floor, Kitchen, Dishwashing Sinks Near Ice Maker, Right Sink	1.6
RMS-49	1st Floor, Kitchen, Handwashing Sink Near Ice Maker	< 1.00
RMS-50	1st Floor, Kitchen, Pot Filling Wand Near Stove	**5.9**
RMS-51	1st Floor, Kitchen, East Prep Area, Left Sink	1.9
RMS-52	1st Floor, Kitchen, East Prep Area, Middle Sink	3.0
RMS-53	1st Floor, Kitchen, East Prep Area, Right Sink	< 1.00
RMS-54	1st Floor, Kitchen, Restroom Sink	< 1.00
RMS-55	1st Floor, Kitchen, Pot Filling Wand Near Steamer	2.5
RMS-56	Ground Floor, Boy's Locker Room Restroom, Middle Sink	**19.0**
RMS-57	Ground Floor, Boy's Locker Room Restroom, Right Sink	**7.9**
RMS-58	Ground Floor, Boy's Locker Room, Water Fountain, Left	**5.1**
RMS-59	Ground Floor, Boy's Locker Room, Water Fountain, Right	**7.3**
RMS-60	Ground Floor, Room 054, Island Sink	**22.9**
RMS-61	Ground Floor, Water Fountain Near Rooms 25/27	< 1.00
RMS-62	Ground Floor, Women's Restroom Near Room 27, Left Sink	< 1.00
RMS-63	Ground Floor, Women's Restroom Near Room 27, Middle Sink	< 1.00
RMS-64	Ground Floor, Women's Restroom Near Room 27, Right Sink	< 1.00
RMS-65	Ground Floor, Men's Restroom Near Room 27, Left Sink	< 1.00
RMS-66	Ground Floor, Men's Restroom Near Room 27, Middle Sink	1.0
RMS-67	Ground Floor, Men's Restroom Near Room 27, Right Sink	< 1.00
RMS-68	Ground Floor, Old Restroom Used for Storage, Left Sink	**970**
RMS-69	Ground Floor, Old Restroom Used for Storage, Right Sink	**172**

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Ritenour Middle School (December 29, 2023)

Sample ID	Location	Results (µg/L)
RMS-70	Ground Floor, Room 029, Left Sink	1.6
RMS-71	Ground Floor, Room 029, Right Sink	1.6
RMS-72	Ground Floor, Room 025, Left Sink	1.8
RMS-73	Ground Floor, Room 025, Right Sink	< 1.00
RMS-74	Ground Floor, Girl's Locker Room Restroom, Left Sink	**124**
RMS-75	Ground Floor, Girl's Locker Room Restroom, Left Middle Sink	**174**
RMS-76	Ground Floor, Girl's Locker Room Restroom, Middle Sink	**12.1**
RMS-77	Ground Floor, Girl's Locker Room Restroom, Right Middle Sink	**38.1**
RMS-78	Ground Floor, Girl's Locker Room Restroom, Right Sink	**17.6**
RMS-79	Ground Floor, Classroom 31, Sink South	**26.8**
RMS-80	Ground Floor, Classroom 31, Sink North	**13.4**

Note:
µg/L – micrograms per liter

Sources not sampled:
Ritenour Middle School, 2nd Floor, Classroom 211, Sink (inoperable)
Ritenour Middle School, 2nd Floor, Classroom 213, Sink (inoperable)
Ritenour Middle School, 2nd Floor, Classroom 215, Sink (inoperable)
Ritenour Middle School, 2nd Floor, Classroom 217, Sink (inoperable)
Ritenour Middle School, 1st Floor, Gym 120, Water Fountain (inoperable)
Ritenour Middle School, 1st Floor, Cafeteria, Left Water Fountain (inoperable)
Ritenour Middle School, Ground Floor, Boy's Locker Room Restroom, Left Sink (inoperable)

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

February 01, 2024

Greg Young
Jurgiel & Associates, Inc.
123 North Main Street
St. Charles, MO 63301

RE: Ritenour Drinking Water-Ritenour MS

Dear Greg Young:

Please find enclosed the analytical results for the **80** sample(s) the laboratory received on **1/2/24 3:35 pm** and logged in under work order **HA00161**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order HA00161

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

Case Narrative

The drinking water lead analysis was performed at Pace-Ormond Beach, FL. Please refer to the subcontract section of the report for details.

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-01 **Sampled:** 12/29/23 10:00
Name: RMS-1 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-02 **Sampled:** 12/29/23 10:00
Name: RMS-2 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	3.4	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-03 **Sampled:** 12/29/23 10:00
Name: RMS-3 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-04 **Sampled:** 12/29/23 10:00
Name: RMS-4 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-05
Name: RMS-5
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.2	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-06
Name: RMS-6
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	9.4	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-07
Name: RMS-7
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	18.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-08
Name: RMS-8
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	45.3	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-09
Name: RMS-9
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	18.0	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-10
Name: RMS-10
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-11
Name: RMS-11
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-12
Name: RMS-12
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-13
Name: RMS-13
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-14
Name: RMS-14
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-15
Name: RMS-15
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-16
Name: RMS-16
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-17
Name: RMS-17
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-18
Name: RMS-18
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-19
Name: RMS-19
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-20
Name: RMS-20
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	2.3	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-21 **Sampled:** 12/29/23 10:00
Name: RMS-21 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.4	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-22 **Sampled:** 12/29/23 10:00
Name: RMS-22 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-23 **Sampled:** 12/29/23 10:00
Name: RMS-23 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-24 **Sampled:** 12/29/23 10:00
Name: RMS-24 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-25
Name: RMS-25
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-26
Name: RMS-26
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-27
Name: RMS-27
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-28
Name: RMS-28
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-29
Name: RMS-29
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-30
Name: RMS-30
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-31
Name: RMS-31
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-32
Name: RMS-32
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-33
Name: RMS-33
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-34
Name: RMS-34
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-35
Name: RMS-35
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-36
Name: RMS-36
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-37 **Sampled:** 12/29/23 10:00
Name: RMS-37 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	8.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-38 **Sampled:** 12/29/23 10:00
Name: RMS-38 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	2.8	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-39 **Sampled:** 12/29/23 10:00
Name: RMS-39 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-40 **Sampled:** 12/29/23 10:00
Name: RMS-40 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-41
Name: RMS-41
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	3.3	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-42
Name: RMS-42
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	26.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-43
Name: RMS-43
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	4.7	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-44
Name: RMS-44
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	3.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-45
Name: RMS-45
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-46
Name: RMS-46
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-47
Name: RMS-47
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-48
Name: RMS-48
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.6	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-49
Name: RMS-49
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-50
Name: RMS-50
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	5.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-51
Name: RMS-51
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-52
Name: RMS-52
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	3.0	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-53
Name: RMS-53
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-54
Name: RMS-54
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-55
Name: RMS-55
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	2.5	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-56
Name: RMS-56
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	19.0	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-57 **Sampled:** 12/29/23 10:00
Name: RMS-57 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	7.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-58 **Sampled:** 12/29/23 10:00
Name: RMS-58 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	5.1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-59 **Sampled:** 12/29/23 10:00
Name: RMS-59 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	7.3	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-60 **Sampled:** 12/29/23 10:00
Name: RMS-60 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	22.9	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-61
Name: RMS-61
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-62
Name: RMS-62
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-63
Name: RMS-63
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-64
Name: RMS-64
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-65
Name: RMS-65
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-66
Name: RMS-66
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.0	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-67
Name: RMS-67
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-68
Name: RMS-68
Matrix: Drinking Water - Grab
Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	970	ug/L		12/29/23 10:00	1	10		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-69
Name: RMS-69
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	172	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-70
Name: RMS-70
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.6	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-71
Name: RMS-71
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.6	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-72
Name: RMS-72
Matrix: Drinking Water - Grab

Sampled: 12/29/23 10:00
Received: 01/02/24 15:35

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	1.8	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-73 **Sampled:** 12/29/23 10:00
Name: RMS-73 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	< 1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-74 **Sampled:** 12/29/23 10:00
Name: RMS-74 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	124	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-75 **Sampled:** 12/29/23 10:00
Name: RMS-75 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	174	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-76 **Sampled:** 12/29/23 10:00
Name: RMS-76 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	12.1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA00161-77 **Sampled:** 12/29/23 10:00
Name: RMS-77 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	38.1	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-78 **Sampled:** 12/29/23 10:00
Name: RMS-78 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	17.6	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-79 **Sampled:** 12/29/23 10:00
Name: RMS-79 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	26.8	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Sample: HA00161-80 **Sampled:** 12/29/23 10:00
Name: RMS-80 **Received:** 01/02/24 15:35
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Subcontracted Analysis - Pace Analytical - Ormond Beach									
Lead	13.4	ug/L		12/29/23 10:00	1	1		PACE	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050
TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615
TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807
USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050
Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	RITENOUR MS	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	GREG YOUNG	WW-WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

3 ANALYSIS REQUESTED: LEAD (EPA 200.8)

4 (FOR LAB USE ONLY)
LOGIN # HA00161
LOGGED BY: JR
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
RMS-1	12/29/23	8:00AM - 10:00AM	X		DW	1		X	
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL / RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Greg Young	12/29/23			1-2-24	1020
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	1-2-24	1535			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
				1/2/24	1535

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: RITENOUR MS
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young

PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

3 ANALYSIS REQUESTED: LEAD (EPA 200.8)

4 (FOR LAB USE ONLY)
LOGIN # MAD0161 4/8
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
RMS-12	12/29/23	8:00AM - 10:00AM	X		DW	1		X	
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	Greg Young	12/29/23			1-2-24	1020
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
		1-2-24	1535			
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
					1/2/24	1535

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 3

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	RITENOUR MS	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	GREG YOUNG	WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
RMS-23	12/29/23	8:00 AM - 10:00 AM	X		DW	1		X	
24									
25									
26									
27									
28									
29									
30									
31									
32									
33									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

4 (FOR LAB USE ONLY)

LOGIN # HA00161 cyls

LOGGED BY:

CLIENT:

PROJECT:

PROJ. MGR.:

CUSTODY SEAL #:

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH

DATE RESULTS NEEDED:

RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE

EMAIL IF DIFFERENT FROM ABOVE:

PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*

PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	Greg Young	12/29/23		[illegible]	1-2-24	1020
	[illegible]	1-2-24	1835			
	[illegible]					

RECEIVED BY: (SIGNATURE)	DATE	TIME
	1/2/24	1535

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT — °C

TEMPERATURE GUN ID

CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N

SAMPLE(S) RECEIVED ON ICE Y OR N

SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N

DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 4

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	RITENOUR MS	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**		**MATRIX TYPES:**
ST. CHARLES, MO 63301	GREG YOUNG		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
RMS-34	12/29/23	8:00 AM-10:00 AM	X		DW	1		X	
35								1	
36									
37									
38									
39									
40									
41									
42									
43									
44									

4 (FOR LAB USE ONLY)
LOGIN # HA00161495
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL / RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Greg Young	12/29/23		[illegible]	1-2-24	1020
[illegible]	1-2-24	1535			
				1/2/24	1535

8 COMMENTS: (FOR LAB USE ONLY)
SAMPLE TEMPERATURE UPON RECEIPT — °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT Y OR N
REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 5

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

(1) CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: RITENOUR MS
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young
PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

(3) ANALYSIS REQUESTED: LEAD (EPA 200.8)

(4) (FOR LAB USE ONLY)
LOGIN # HA 00161 cyls
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

(2) SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
RMS-45	12/29/23	8:00 am - 10:00 am	X		DW	1		X	
46	"	"	"		"	"		"	
47									
48									
49									
50									
51									
52									
53									
54									
55									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

(5) TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

(6) *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

(7)

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Greg Young	12/29/23			1-2-24	
					1020
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	1-2-24	1635			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
				1/2/24	1535

(8) COMMENTS: (FOR LAB USE ONLY)
SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	RITENOUR MS	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**		**MATRIX TYPES:**
ST. CHARLES, MO 63301	GREG YOUNG		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

3 ANALYSIS REQUESTED

4 (FOR LAB USE ONLY)

LOGIN # HADD161 1/5

LOGGED BY:

CLIENT:

PROJECT:

PROJ. MGR.:

CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
RMS-56	12/29/23	8:00 AM - 0:00 AM	X		DW	1		X	
57									
58									
59									
60									
61									
62									
63									
64									
65									
66									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)

RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE

EMAIL IF DIFFERENT FROM ABOVE:

PHONE # IF DIFFERENT FROM ABOVE:

DATE RESULTS NEEDED

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*

PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7		DATE		8 COMMENTS: (FOR LAB USE ONLY)
RELINQUISHED BY: (SIGNATURE)	Greg Young	12/29/23	RECEIVED BY: (SIGNATURE)	DATE 1-2-24
		TIME		TIME 1020
RELINQUISHED BY: (SIGNATURE)		DATE 1-2-24	RECEIVED BY: (SIGNATURE)	DATE
		TIME 1635		TIME
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE 1/3/24
		TIME		TIME 1535

SAMPLE TEMPERATURE UPON RECEIPT — °C

TEMPERATURE GUN ID

CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N

SAMPLE(S) RECEIVED ON ICE Y OR N

SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N

DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: RITENOUR MS
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young
PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

3 ANALYSIS REQUESTED: LEAD (EPA 200.8)

4 (FOR LAB USE ONLY)
LOGIN # HA00161 415
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
RMS-67	12/29/23	8:00 AM - 10:00 AM	X		DW	1		X	
68									
69									
70									
71									
72									
73									
74									
75									
76									
77									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL / RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7		DATE	TIME		DATE	TIME
RELINQUISHED BY: (SIGNATURE)	Greg Young	12/29/23		RECEIVED BY: (SIGNATURE)		1-2-24 1020
RELINQUISHED BY: (SIGNATURE)		1-2-24	1535	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)				RECEIVED BY: (SIGNATURE)	1/2/24	1535

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 8

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	RITENOUR MS	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**		**MATRIX TYPES:**
ST. CHARLES, MO 63301	GREG YOUNG		WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	4 (FOR LAB USE ONLY) REMARKS
RMS-78	12/29/23	8:00AM - 10:00AM	X		DW	1		X	
79	↓	↓	↓		↓	↓		↓	
80	↓	↓	↓		↓	↓		↓	

4 (FOR LAB USE ONLY)
LOGIN # HA00161 4/5
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7				
RELINQUISHED BY: (SIGNATURE)	DATE 12/29/23	RECEIVED BY: (SIGNATURE)	DATE 1-2-24	8 COMMENTS: (FOR LAB USE ONLY)
Greg Young	TIME	Clerk YM	TIME 1020	
RELINQUISHED BY: (SIGNATURE)	DATE 1-2-24	RECEIVED BY: (SIGNATURE)	DATE	SAMPLE TEMPERATURE UPON RECEIPT — °C
Clerk YM	TIME 1535		TIME	TEMPERATURE GUN ID
RELINQUISHED BY: (SIGNATURE)	DATE	RECEIVED BY: (SIGNATURE)	DATE 1/2/24	CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
	TIME		TIME 1535	SAMPLE(S) RECEIVED ON ICE Y OR N
				SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
				DATE AND TIME TAKEN FROM SAMPLE BOTTLE