

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Sutherland ES Lodi USD
550 Spring River Cir
Stockton, CA 95210

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Jul 27, 2022

Building: Sutherland ES Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information

Address: 550 Spring River Cir

Address:

City/State/ZIP Code: Stockton, CA 95210

Country: United States of America

System Control Unit

Model Number: EST-3

Software Version:

Location: Main Office

Install Date: 06/25/1992

Version Date: 06/20/2007

Current Protection:

IDC Style:

SLC Style:

NAC Style:

Central Station Signal Verification

Test Time/Date: 7/27/22 7:22:30 AM

Restore Time:

Note:

Inspection Completion Date: Jul 27, 2022

Building: Sutherland ES Lodi USD

EC 02.03.05 EP 01 The organization tests supervisory signal devices on the inventory with the following time frames: Quarterly for pressure supervisory indicating devices (including both high- and low-air pressure switches), water level supervisory indicating devices, water temperature supervisory indicating devices, room temperature supervisory indicating devices, and other suppression system supervisory initiating devices. Semiannually for valve supervisory switches. Annually for other supervisory initiating devices. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Supervisory Device	1	1	0	1	1

EC 02.03.05 EP 02 Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Tamper Switch	1	1	0	1	1
Waterflow Switch	1	1	0	1	1

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

Duct Detector	7	7	0	7	7
Heat Detector	33	33	0	33	136
Pull Station	8	8	0	8	8
Smoke Detector	123	123	0	123	123

EC 02.03.05 EP 04 Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

Horn	18	18	0	18	18
Horn/Strobe	35	35	0	35	35
Releasing Device	2	2	0	2	2
Strobe	34	34	0	34	34

EC 02.03.05 EP 05 Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

LS 02.01.34 EP 02 Protected master fire alarm control panel

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1

LS 02.01.34 EP 10 All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Battery	14	12	2	14	14
Power Supply	6	6	0	6	6
Total Device Count: 391					

Inspection & Testing

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left. Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 01	The organization tests supervisory signal devices on the inventory with the following time frames: Quarterly for pressure supervisory indicating devices (including both high- and low-air pressure switches), water level supervisory indicating devices, water temperature supervisory indicating devices, room temperature supervisory indicating devices, and other suppression system supervisory initiating devices. Semiannually for valve supervisory switches. Annually for other supervisory initiating devices. NFPA 72-2010 Table 14.4.5				
	Each initiating device circuit shall be tested for correct indication at the control unit. (2010 ed.) (NFPA 72 Table 14.4.2.2 (13.c))				
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Supervisory Device	1	1	0	1	1
Device Type	Location	ScanID	Address	Q3/22	
Supervisory Device	Outside MU Building, parking lot P.I.V.	49353703	1-4 140	07/26-P	
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Valve shall be operated and signal receipt shall be verified to be within the first two revolutions of the hand wheel or within one-fifth of the travel distance, or per the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14i.1))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Tamper Switch	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Tamper Switch	MU Building, north storage rm		08919954	1-04 0142	07/26-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Vane-type and pressure switch-type waterflow alarm devices shall be tested semiannually. Per NFPA 25, Section 5.3.3.1, mechanical waterflow alarm devices shall be tested quarterly. Water shall be flowed through an inspector's test connection indicating the flow of water equal to that from a single sprinkler of the smallest orifice size installed in the system for wet-pipe systems, or an alarm test bypass connection for dry-pipe, pre-action, or deluge systems. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14j))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Waterflow Switch	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Waterflow Switch	MU Building, Fire Sprinkler Room		05656541	1-04 0141	07/26-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
The detector shall be tested by introducing smoke, other aerosol, or an optical filter into the beam path. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.7))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Beam Detector	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Beam Detector	MU Building, NORTH		20413674	1-04 0139	07/26-P
Beam Detector	MU Building, SOUTH		20413675	1-04 0138	07/26-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
In addition to testing in place to ensure smoke entry into the sensing chamber and an alarm response, duct smoke detectors utilizing sampling tubes shall be tested by verifying the correct pressure differential (within the manufacturer's published ranges) between the inlet and exhaust tubes using a method acceptable to the manufacturer to ensure that the device will properly sample the airstream. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g. 6))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Duct Detector	7	7	0	7	7
Device Type	Location		ScanID	Address	Q3/22
Duct Detector	Admin Building, Main Office, Workroom		69501130	1-04 0269	07/26-P
Duct Detector	Admin Building, Main Office, Workroom		20413696	1-04 0269	07/26-P
Duct Detector	Classroom 20		20413699	1-04 0031	07/26-P
Duct Detector	MU Building, Staff Lounge		69501131	1-04 0086	07/26-P
Duct Detector	MU Building, Staff Lounge		20413697	1-04 0086	07/26-P
Duct Detector	MU Building, Stage		69501107	1-04 0087	07/26-P
Duct Detector	MU Building, Stage		69501125	1-04 0087	07/26-P
Device Total: 7 Return to Executive Summary					

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Heat Detector	33	33	0	33	136

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Bathroom classroom 2 Admin	07257535	1-02 0002	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426818	1-04 0377	07/26-P
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426724	1-04 0377	07/26-P
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426631	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426650	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426652	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426657	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426660	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426675	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426690	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426707	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426715	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426730	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426743	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426749	1-04 0377	
Heat Detector	ADMIN BUILDING ATTIC HEATS	16426750	1-04 0377	
Heat Detector	Bathroom Admin	05656431	1-02 0002	
Heat Detector	Custodian room by Classroom 15	3820494776	1-04 0001	07/26-P
Heat Detector	ESL lab Bathroom Admin	05656434	1-02 0002	
Heat Detector	Kitchen dish washer	20408000	1-04 0144	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501121	1-04 0136	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501120	1-04 0136	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501119	1-04 0137	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501118	1-04 0136	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501117	1-04 0136	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501116	1-04 0136	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501115	1-04 0137	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501114	1-04 0137	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	69501113	1-04 0137	07/26-P
Heat Detector	MU BUILDING ATTIC HEATS	16426716	1-04 0136	
Heat Detector	MU Building, Kitchen Hallway	3820495070	1-04 0076	07/26-P
Heat Detector	MU Building, Staff Lounge, Kitchen	3820505199	1-04 0071	07/26-P
Heat Detector	MU Building, Stage, North	3820492949	1-04 0082	07/26-P
Heat Detector	MU Building, Stage, South	3820496763	1-04 0083	07/26-P
Heat Detector	Princpal office Admin	05656432	1-02 0002	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426586	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426597	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426598	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426599	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426609	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426613	1-04 027	
Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	16426683	1-04 027	
Heat Detector	kindergarten rm 1	16426658	1-4 1	
Heat Detector	kindergarten rm 1	16426739	1-04 0001	
Heat Detector	multipurpose Bathroom.staff	05656478	1-02 0004	
Heat Detector	multipurpose Bathroom.staff.mens	05656479	1-02 0004	
Heat Detector	multipurpose Data rm	69501108	1-02 0004	07/26-P
Heat Detector	multipurpose Kitchen-dishes area	69501109	1-02 0004	07/26-P
Heat Detector	multipurpose Office-kitchen	05656534	1-02 0004	
Heat Detector	multipurpose Stage-closet	69501112	1-02 0004	07/26-P
Heat Detector	multipurpose waterheater area	05656535	1-02 0004	
Heat Detector	Above Ceiling Cafeteria Stage North East	69501122	1-4 0137	07/26-P
Heat Detector	Above Ceiling Cafeteria Stage North West	16426642	1-4 0137	
Heat Detector	Above Ceiling Cafeteria Stage South East	69501123	1-02 04	07/26-P
Heat Detector	Above Ceiling Cafeteria Stage South West	16426663	1-02 04	
Heat Detector	Above Ceiling Classroom 10	16426706	1-02 0003	07/26-P
Heat Detector	Above Ceiling Classroom 11	05656466	1-02 0003	07/26-P
Heat Detector	Above Ceiling Classroom 12	05656465	1	
Heat Detector	Above Ceiling Classroom 13 Building A	05656459	1-03 0008	
Heat Detector	Above Ceiling Classroom 14 Building A	05656460	1-03 0008	
Heat Detector	Above Ceiling Classroom 14 Office Building A	05656461	1-03 0008	
Heat Detector	Above Ceiling Classroom 15	05656452	1-03 0008	
Heat Detector	Above Ceiling Classroom 16	05656451	1-03 0008	
Heat Detector	Above Ceiling Classroom 17 Building A	05656464	1-03 0008	
Heat Detector	Above Ceiling Classroom 20 Building A	05656462	1-03 0008	
Heat Detector	Above Ceiling Classroom 20 Office Building A	05656463	1-03 0008	
Heat Detector	Above Ceiling Classroom 21	05656441	1	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Above Ceiling Classroom 22	05656442	1-03 0002	
Heat Detector	Above Ceiling Classroom 23	05656443	1-03 0002	
Heat Detector	Above Ceiling Classroom 24	05656444	1-03 0002	
Heat Detector	Above Ceiling Classroom 25	05656437	1-03 0002	
Heat Detector	Above Ceiling Classroom 26	05656438	1-03 0002	
Heat Detector	Above Ceiling Classroom 27	05656439	1-03 0002	
Heat Detector	Above Ceiling Classroom 28	05656440	1-03 0002	
Heat Detector	Above Ceiling Classroom 5	16426671	1-02 0003	07/26-P
Heat Detector	Above Ceiling Classroom 6	05656526	1-02 0004	
Heat Detector	Above Ceiling Classroom 7	05656525	1	07/26-P
Heat Detector	Above Ceiling Classroom 8	05656471	1-02 0003	07/26-P
Heat Detector	Above Ceiling Classroom 9	16426629	1-02 0003	07/26-P
Heat Detector	Above Ceiling Conference rm Admin	05656428	1-02 0002	
Heat Detector	Above Ceiling ESL lab Admin	05656435	1-02 0002	
Heat Detector	Above Ceiling Library P.E. rm	05656470	1-02 0003	
Heat Detector	Above Ceiling Library Psy. rm	05656528	1-02 0003	
Heat Detector	Above Ceiling Library music rm	05656469	1-02 0003	
Heat Detector	Above Ceiling Princpal office Admin	05656433	1-02 0002	
Heat Detector	Above Ceiling Reading lab Admin	05656436	1-02 0002	
Heat Detector	Above Ceiling Reception area Admin	05656427	1-02 0002	
Heat Detector	Above Ceiling Wk room Admin	05656429	1-02 0002	
Heat Detector	Above Ceiling multipurpose Classroom 3	05656475	1-02 0004	
Heat Detector	Above Ceiling multipurpose Dry-storage	05656477	1-02 0004	
Heat Detector	Above Ceiling multipurpose Kitchen-office	05656476	1-02 0004	
Heat Detector	Above Ceiling multipurpose Riser rm	05656540	1-02 0004	
Heat Detector	Above Ceiling multipurpose custodian office	05656539	1	
Heat Detector	Across Wk room Office Admin	05656430	1-2 0011	
Heat Detector	Center Classroom 20 work room	16426748	1-04 0128	
Heat Detector	Center Classroom 21	16426805	1-04 0383	
Heat Detector	Center Classroom 22	16426787	1-04 0383	
Heat Detector	Center Classroom 23	16426819	1-04 0383	
Heat Detector	Center Classroom 24	16426792	1-04 0383	
Heat Detector	Center Classroom 25	16426784	1-04 0381	
Heat Detector	Center Classroom 26	16426780	1-04 0381	
Heat Detector	Center Classroom 27	16426817	1-04 0381	
Heat Detector	Center Classroom 28	16426766	1-04 0381	
Heat Detector	Center multipurpose Kitchen	69501110	1-02 0004	07/26-P
Heat Detector	East Bathroom-staff Building A	05656457	1-03 0008	
Heat Detector	East multipurpose staff lounge	16426790	1-02 0004	
Heat Detector	East wall Classroom 15	16426585	1-04 0127	
Heat Detector	East wall Classroom 15	16426604	1-04 0127	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Near rm.15 Bathroom-staff-North	05656449	1-03 0002	
Heat Detector	Near rm.15 Bathroom-staff-South	05656450	1-03 0002	
Heat Detector	Near rm.21 Bathroom-boys-East	05656445	1-03 0002	
Heat Detector	Near rm.21 Bathroom-boys-West	05656448	1-03 0002	
Heat Detector	Near rm.21 Bathroom-girls-East	05656447	1-03 0002	
Heat Detector	Near rm.21 Bathroom-girls-West	05656446	1-03 0002	
Heat Detector	North Bathroom-boys Building A	05656455	1-03 0008	
Heat Detector	North Bathroom-girls Building A	05656454	1-03 0008	
Heat Detector	North Bathroom-staff Building A	05656458	1-03 0008	
Heat Detector	North Classroom 14	16426681	1-04 0127	
Heat Detector	North Kitchen	20407998	1-04 0145	07/26-P
Heat Detector	North multipurpose Kitchen	69501111	1-02 0004	07/26-P
Heat Detector	Northeast Classroom 16	16426583	1-04 0128	
Heat Detector	Northeast wall Classroom 17	16426747	1-04 0128	
Heat Detector	Northwest wall Classroom 16	16426596	1-04 0128	
Heat Detector	South Bathroom-boys Building A	05656456	1-03 0008	
Heat Detector	South Bathroom-girls Building A	05656453	1-03 0008	
Heat Detector	South Classroom 14	16426594	1-04 0127	
Heat Detector	South Kitchen	20407999	1-04 0146	07/26-P
Heat Detector	South multipurpose Kitchen	16426738	1-02 0004	
Heat Detector	South wall Classroom 17	16426584	1-04 0128	
Heat Detector	South wall Classroom 20	16426605	1-04 0128	
Heat Detector	Southeast wall Classroom 16	16426712	1-04 0128	
Heat Detector	Southeast wall Classroom 18	16426590	1-04 0128	
Heat Detector	West multipurpose staff lounge	05656537	1-02 0004	
Heat Detector	West wall Classroom 13	16426589	1-04 0127	
Heat Detector	southwest wall Classroom 16	16426685	1-04 0128	
Heat Detector	Lower-Lobby West wall Classroom 15	05656527	1-04 0127	07/26-P
Device Total: 136 Return to Executive Summary				

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Pull Station	8	8	0	8	8
Device Type	Location		ScanID	Address	Q3/22
Pull Station	Admin Building, Main Office		20413689	1-04 0379	07/26-P
Pull Station	Library Building, South Exit		20413682	1-04 0134	07/26-P
Pull Station	Lirary Building, North Exit		20413683	1-04 0133	07/26-P
Pull Station	MU Building, Cafeteria, East Exit		20413686	1-04 0150	07/26-P
Pull Station	MU Building, Cafeteria, North Exit		20413687	1-04 0147	07/26-P
Pull Station	MU Building, Cafeteria, South Exit		20413688	1-04 0151	07/26-P
Pull Station	MU Building, Stage, North Exit		20413684	1-04 0148	07/26-P
Pull Station	MU Building, Stage, South Exit		20413685	1-04 0149	07/26-P
Device Total: 8		Return to Executive Summary			

EC 02.03.05 EP 03	Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Smoke Detector	123	123	0	123	123
Device Type	Location		ScanID	Address	Q3/22
Smoke Detector	MU high ceiling 1		69501135	1-02 04	07/26-P
Smoke Detector	MU high ceiling 2		69501129	1-02 04	07/26-P
Smoke Detector	MU high ceiling 3		69501134	1-02 04	07/26-P
Smoke Detector	MU high ceiling 4		69501128	1-02 04	07/26-P
Smoke Detector	MU high ceiling 5		69501133	1-02 04	07/26-P
Smoke Detector	MU high ceiling 6		69501127	1-02 04	07/26-P
Smoke Detector	MU high ceiling 7		69501132	1-02 04	07/26-P
Smoke Detector	Admin Building, Nurse's Office		3912355756	1-04 0255	07/26-P
Smoke Detector	Admin Building, Closet Behind Master Clock		3912356333	1-04 0257	07/26-P
Smoke Detector	Admin Building, Conference room		3912364000	1-04 0259	07/26-P
Smoke Detector	Admin Building, Main Office Area		3912355671	1-04 0258	07/26-P
Smoke Detector	Admin Building, Main Office Corridor, east		3912356135	1-04 0252	07/26-P
Smoke Detector	Admin Building, Main Office Corridor, west		3912355558	1-04 0256	07/26-P
Smoke Detector	Admin Building, Main Office Restroom		3912355923	1-04 0253	07/26-P
Smoke Detector	Admin Building, Principals Office		3912355619	1-4 0254	07/26-P
Smoke Detector	Admin Building, Supply Room		3912355411	1-04 0260	07/26-P
Smoke Detector	Admin Building, Workroom		3912355985	1-4 251	07/26-P
Smoke Detector	Boys Restroom by Classroom 15, North		3912037560	1-04 0004	07/26-P
Smoke Detector	Boys Restroom by Classroom 15, South		3912281758	1-04 0005	07/26-P
Smoke Detector	Classroom 1, North		3912355626	1-04 0268	07/26-P
Smoke Detector	Classroom 1, Restroom		3912355718	1-04 0265	07/26-P
Smoke Detector	Classroom 1, South		3912355596	1-04 0267	07/26-P
Smoke Detector	Classroom 1, West		3912355503	1-04 0266	07/26-P
Smoke Detector	Classroom 13		3912038284	1-04 0008	07/26-P
Smoke Detector	Classroom 14 Office		3936052297	1-04 0015	07/26-P
Smoke Detector	Classroom 14 east		3912038406	1-04 0010	07/26-P
Smoke Detector	Classroom 14 west		3912357156	1-04 0014	07/26-P
Smoke Detector	Classroom 15 NORTH-EAST		3912038383	1-04 0009	07/26-P
Smoke Detector	Classroom 15 SOUTH-EAST		3912359150	1-04 0011	07/26-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	Classroom 15 SOUTH-WEST	3912364475	1-04 0012	07/26-P
Smoke Detector	Classroom 16 East	3912038574	1-04 0017	07/26-P
Smoke Detector	Classroom 16 North	3912038338	1-04 0016	07/26-P
Smoke Detector	Classroom 16 South	3912037775	1-04 0018	07/26-P
Smoke Detector	Classroom 16 West	3912353837	1-04 0019	07/26-P
Smoke Detector	Classroom 17 North	3912280928	1-04 0028	07/26-P
Smoke Detector	Classroom 17 South	3912359167	1-04 0026	07/26-P
Smoke Detector	Classroom 17 Southwest	3912281796	1-04 0025	07/26-P
Smoke Detector	Classroom 17 West	3912037584	1-04 0027	07/26-P
Smoke Detector	Classroom 18 East	3912037652	1-04 0023	07/26-P
Smoke Detector	Classroom 18 North	3912037621	1-04 0024	07/26-P
Smoke Detector	Classroom 18 South	3912359204	1-04 0029	07/26-P
Smoke Detector	Classroom 18 West	3912351239	1-04 0030	07/26-P
Smoke Detector	Classroom 2, East	3912355954	1-04 0261	07/26-P
Smoke Detector	Classroom 2, North	3912355930	1-04 0262	07/26-P
Smoke Detector	Classroom 2, Restroom	3912354735	1-04 0264	07/26-P
Smoke Detector	Classroom 2, South	3912355657	1-04 0263	07/26-P
Smoke Detector	Classroom 20 North	3912037638	1-04 0021	07/26-P
Smoke Detector	Classroom 20 Office	3912359815	1-04 0022	07/26-P
Smoke Detector	Classroom 20 South	3912038321	1-04 0020	07/26-P
Smoke Detector	Classroom 21 East	3912355633	1-04 0279	07/26-P
Smoke Detector	Classroom 21 West	3912355268	1-04 0278	07/26-P
Smoke Detector	Classroom 22 East	3912355220	1-04 0280	07/26-P
Smoke Detector	Classroom 22 West	3912355947	1-04 0281	07/26-P
Smoke Detector	Classroom 23 East	3912354742	1-04 0283	07/26-P
Smoke Detector	Classroom 23 West	3912355213	1-04 0282	07/26-P
Smoke Detector	Classroom 24 East	3912355442	1-04 0284	07/26-P
Smoke Detector	Classroom 24 West	3912356340	1-04 0285	07/26-P
Smoke Detector	Classroom 25 East	3912356012	1-04 0270	07/26-P
Smoke Detector	Classroom 25 West	3912355916	1-04 0271	07/26-P
Smoke Detector	Classroom 26 East	3912355565	1-04 0273	07/26-P
Smoke Detector	Classroom 26 West	3912354551	1-04 0272	07/26-P
Smoke Detector	Classroom 27 East	3912355572	1-04 0274	07/26-P
Smoke Detector	Classroom 27 West	3912355527	1-04 0275	07/26-P
Smoke Detector	Classroom 28 East	3912355589	1-04 0276	07/26-P
Smoke Detector	Classroom 28 West	3912355695	1-04 0277	07/26-P
Smoke Detector	Girls Restroom by Classroom 15, North	3912359266	1-04 0003	07/26-P
Smoke Detector	Girls Restroom by Classroom 15, South	3912281253	1-04 0002	07/26-P
Smoke Detector	Library Building, Classroom 10, North	3912272381	1-04 0052	07/26-P
Smoke Detector	Library Building, Classroom 10, South	3912364079	1-04 0053	07/26-P
Smoke Detector	Library Building, Classroom 10, West	3912364062	1-04 0051	07/26-P
Smoke Detector	Library Building, Classroom 11, East	3912351291	1-04 0054	07/26-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	Library Building, Classroom 11, North	3912363997	1-04 0056	07/26-P
Smoke Detector	Library Building, Classroom 11, West	3912361542	1-04 0055	07/26-P
Smoke Detector	Library Building, Classroom 12, East	3912359174	1-04 0058	07/26-P
Smoke Detector	Library Building, Classroom 12, North	3912363737	1-04 0057	07/26-P
Smoke Detector	Library Building, Classroom 12, West	3930162459	1-04 0059	07/26-P
Smoke Detector	Library Building, Classroom 5 South	3926357111	1-4 0033	07/26-P
Smoke Detector	Library Building, Classroom 5, East	3912363812	1-04 0035	07/26-P
Smoke Detector	Library Building, Classroom 5, Northwest	3912363805	1-04 0034	07/26-P
Smoke Detector	Library Building, Classroom 6, East	3912357781	1-04 0036	07/26-P
Smoke Detector	Library Building, Classroom 6, North	3912353882	1-04 0038	07/26-P
Smoke Detector	Library Building, Classroom 6, South	3912359181	1-04 0037	07/26-P
Smoke Detector	Library Building, Classroom 7, East	3912281819	1-04 0040	07/26-P
Smoke Detector	Library Building, Classroom 7, South	20413673	1-04 0041	07/26-P
Smoke Detector	Library Building, Classroom 7, West	3912351260	1-04 0039	07/26-P
Smoke Detector	Library Building, Classroom 8, East	3912281130	1-04 0044	07/26-P
Smoke Detector	Library Building, Classroom 8, South	3912281444	1-04 0042	07/26-P
Smoke Detector	Library Building, Classroom 8, West	3912351253	1-04 0043	07/26-P
Smoke Detector	Library Building, Classroom 9, East	3912353875	1-04 0049	07/26-P
Smoke Detector	Library Building, Classroom 9, North	3912357132	1-04 0048	07/26-P
Smoke Detector	Library Building, Classroom 9, West	3912281673	1-04 0050	07/26-P
Smoke Detector	Library Building, North Exit	3912363829	1-04 0045	07/26-P
Smoke Detector	Library Building, PE specialist room	3934292084	1-04 0046	07/26-P
Smoke Detector	Library Building, Psychologist Office	3926357272	1-4 0032	07/26-P
Smoke Detector	Library Building, South Exit	3912356791	1-04 0060	07/26-P
Smoke Detector	Library Building, South Storage room	3912357545	1-04 0061	07/26-P
Smoke Detector	Library, North-Center	20413677	1-04 0064	07/26-P
Smoke Detector	Library, North-East	20413676	1-04 0067	07/26-P
Smoke Detector	Library, North-West	20413678	1-04 0063	07/26-P
Smoke Detector	Library, South-Center	20413680	1-04 0065	07/26-P
Smoke Detector	Library, South-East	20413681	1-04 0066	07/26-P
Smoke Detector	Library, South-West	20413679	1-04 0062	07/26-P
Smoke Detector	MU Building, Band room, east	3936049624	1-04 0081	07/26-P
Smoke Detector	MU Building, Band room, west	3912280973	1-04 0080	07/26-P
Smoke Detector	MU Building, Custodial room	3912355138	1-04 0078	07/26-P
Smoke Detector	MU Building, Data room	3912355688	1-04 0068	07/26-P
Smoke Detector	MU Building, Kitchen Dry Storage	3912355169	1-04 0077	07/26-P
Smoke Detector	MU Building, Kitchen Office	3912356029	1-04 0075	07/26-P
Smoke Detector	MU Building, Staff Lounge, East	3935510194	1-04 0073	07/26-P
Smoke Detector	MU Building, Staff Lounge, West	61240907	1-04 0072	07/26-P
Smoke Detector	MU Building, Staff Mens Restroom	3912355640	1-04 0069	07/26-P
Smoke Detector	MU Building, Staff Womens Restroom	3912281154	1-04 0070	07/26-P
Smoke Detector	MU Building, Stage storage	3912356203	1-04 0084	07/26-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	MU Building, Stage, by elevator	69501126	1-04 0085	07/26-P
Smoke Detector	MU Building, Stage, by elevator	3912281987	1-04 0085	07/26-P
Smoke Detector	MU Building, storage rm north	3912355992	1-04 0079	07/26-P
Smoke Detector	Restroom Building, Boys Restroom	3912355336	1-04 0287	07/26-P
Smoke Detector	Restroom Building, Girls Restroom	3912355077	1-04 0286	07/26-P
Smoke Detector	Restroom Building, North Staff Restroom	3912354575	1-04 0288	07/26-P
Smoke Detector	Restroom Building, South Staff Restroom	3912355206	1-04 0289	07/26-P
Smoke Detector	South Staff Restroom near Classroom 13	3912037362	1-04 0007	07/26-P
Smoke Detector	West Staff Restroom by Classroom 13	3912037751	1-4 0006	07/26-P
Smoke Detector	rm next to P.E specialist	3912363874	1-04 0047	07/26-P
Device Total: 123 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Bell	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Bell	Outside .multipurpose building north		08919952	1	07/27-P
Device Total: 1		Return to Executive Summary			

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn	18	18	0	18	18
Device Type	Location		ScanID	Address	Q3/22
Horn	Outside Horn, by Boys Restroom near Classroom 13, East		16426195	1	07/26-P
Horn	Outside Horn, by Classroom 16, South		16426201	1	07/26-P
Horn	Outside Horn, near Classroom 20, North		16426196	1	07/26-P
Horn	Outside Horn, Library Bldng, by Classrooms 10&11		16426208	1	07/27-P
Horn	Outside Horn, Library Building, by Classroom 8		16426197	1	07/27-P
Horn	Outside Horn, Library Building, by Classrooms 6&7		16426203	1	07/27-P
Horn	Outside Horn, Library Building, by Classroom 5		16426202	1	07/26-P
Horn	Outside Horn, MU Building, East		16426210	1	07/26-P
Horn	Outside Horn, MU Building, North		16426204	1	07/27-P
Horn	Outside Horn, MU Building, South		16426209	1	07/26-P
Horn	Outside Horn, MU Building, West		16426198	1	07/27-P
Horn	Outside Horn, Retroom building, East		16426211	1	07/26-P
Horn	Outside Horn, Retroom building, West		16426212	1	07/26-P
Horn	Outside Horn, between Classrooms 1&2, South		16426199	1	07/27-P
Horn	Outside Horn, between Classrooms 17&18, West		16426207	1	07/26-P
Horn	Outside Horn, between Classrooms 22&23		16426206	1	07/26-P
Horn	Outside Horn, between Classrooms 26&27		16426200	1	07/26-P
Horn	Outside Horn, by Classroom 1, East		16426205	1	07/27-P
Device Total: 18		Return to Executive Summary			

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18.					
Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	35	35	0	35	35
Device Type	Location	ScanID	Address	Q3/22	
Horn/Strobe	Admin Building, Main Office	16426275	1	07/26-P	
Horn/Strobe	Admin Building, Workroom	16426274	1	07/27-P	
Horn/Strobe	Classroom 1	16426273	1	07/26-P	
Horn/Strobe	Classroom 14	16426265	1	07/26-P	
Horn/Strobe	Classroom 15	16426266	1	07/26-P	
Horn/Strobe	Classroom 16	16426283	1	07/27-P	
Horn/Strobe	Classroom 17	16426264	1	07/26-P	
Horn/Strobe	Classroom 18	16426282	1	07/27-P	
Horn/Strobe	Classroom 2	16426272	1	07/26-P	
Horn/Strobe	Classroom 20	16426213	1	07/26-P	
Horn/Strobe	Classroom 21	16426258	1	07/26-P	
Horn/Strobe	Classroom 22	16426261	1	07/26-P	
Horn/Strobe	Classroom 23	16426257	1	07/26-P	
Horn/Strobe	Classroom 24	16426260	1	07/26-P	
Horn/Strobe	Classroom 25	16426271	1	07/26-P	
Horn/Strobe	Classroom 26	16426268	1	07/26-P	
Horn/Strobe	Classroom 27	16426269	1	07/26-P	
Horn/Strobe	Classroom 28	16426270	1	07/26-P	
Horn/Strobe	Library Building, Classroom 10	16426250	1	07/26-P	
Horn/Strobe	Library Building, Classroom 11	16426263	1	07/26-P	
Horn/Strobe	Library Building, Classroom 12	16426280	1	07/27-P	
Horn/Strobe	Library Building, Classroom 5 South	16426249	1-4 0033	07/27-P	
Horn/Strobe	Library Building, Classroom 6	16426277	1	07/27-P	
Horn/Strobe	Library Building, Classroom 7	16426276	1	07/27-P	
Horn/Strobe	Library Building, Classroom 8	16426262	1	07/26-P	
Horn/Strobe	Library Building, Classroom 9	16426278	1	07/27-P	
Horn/Strobe	Lirary Building, Library, North	16426279	1	07/27-P	
Horn/Strobe	Lirary Building, Library, South	16426281	1	07/27-P	
Horn/Strobe	MU Building, Band Room	16426251	1	07/26-P	
Horn/Strobe	MU Building, Cafeteria North-East	16426254	1	07/26-P	
Horn/Strobe	MU Building, Cafeteria South-West	16426256	1	07/26-P	
Horn/Strobe	MU Building, Kitchen	16426252	1	07/27-P	
Horn/Strobe	MU Building, Staff Lounge	16426255	1	07/26-P	

Device Type	Location	ScanID	Address	Q3/22
Horn/Strobe	MU Building, Stage, South	16426253	1	07/26-P
Horn/Strobe	rm 20	16426284	1	07/26-P
Device Total: 35 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Emergency control functions (i.e. fan control, smoke damper operation, elevator recall, elevator power shutdown, door holder release, shutter release, door unlocking, etc.) shall be tested by operating or simulating alarm signals. (2010 ed.) (NFPA 72 Table 14.4.2.2 (23))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Releasing Device	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Releasing Device	North Stage Hatch Releasing Device Ceiling Set Off By Smoke Detect.		16088915	1	07/26-P
Releasing Device	South Stage Hatch Releasing Device Ceiling Set Off By Smoke Detect.		16088914	1	07/26-P
Device Total: 2 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Strobe	34	34	0	34	34
Device Type	Location		ScanID	Address	Q3/22
Strobe	Admin Building, Conferene room		16426227	1	07/26-P
Strobe	Admin Building, Hallway, East		16426247	1	07/26-P
Strobe	Admin Building, Hallway, West		16426246	1	07/26-P
Strobe	Admin Building, Principals Office		16426248	1	07/26-P
Strobe	Admin Building, Restroom		16426223	1	07/27-P
Strobe	Admin Building, Vice Principals Office		16426228	1	07/26-P
Strobe	Boys Restroom by Classroom 15, North		16426237	1	07/27-P
Strobe	Boys Restroom by Classroom 15, South		16426236	1	07/27-P
Strobe	Classroom 1 Restroom		16426226	1	07/26-P
Strobe	Classroom 13		16426239	1	07/27-P
Strobe	Classroom 14 Office		16426241	1	07/27-P
Strobe	Classroom 2 Restroom		16426225	1	07/26-P
Strobe	Classroom 20 Office		16426214	1	07/27-P
Strobe	East Staff Restroom by Classroom 13		16426238	1	07/27-P
Strobe	Girls Restroom by Classroom 15, North		16426240	1	07/27-P
Strobe	Girls Restroom by Classroom 15, South		16426215	1	07/26-P
Strobe	Library Building, by North Exit		16426218	1	07/27-P
Strobe	Lirary Building, PE Storage		16426232	1	07/26-P
Strobe	Lirary Building, Psychologist Office		16426242	1	07/26-P
Strobe	Lirary Building, by South Exit		16426217	1	07/26-P
Strobe	Lirary Building, by South Storage room		16426243	1	07/26-P
Strobe	MU Building, Kitchen Dishwashing area		16426244	1	07/27-P
Strobe	MU Building, Kitchen Hallway		16426221	1	07/26-P
Strobe	MU Building, Staff Mens Restroom		16426220	1	07/26-P
Strobe	MU Building, Staff Mens Restroom Entry		16426219	1	07/26-P
Strobe	MU Building, Staff Womens Restroom		16426222	1	07/26-P
Strobe	MU Building, Stage by Elevator		16426234	1	07/26-P
Strobe	MU Building, Stage, North		16426233	1	07/26-P
Strobe	Restroom Building, Boys Restroom		16426229	1	07/26-P
Strobe	Restroom Building, Girls Restroom		16426235	1	07/26-P
Strobe	Restroom Building, North Staff Restroom		16426224	1	07/26-P
Strobe	Restroom Building, South Staff Restroom		16426230	1	07/27-P
Strobe	West Staff Restroom by Classroom 13		16426216	1	07/27-P
Strobe	rm next to P.E Specialist		16426231	1	07/26-P
Device Total: 34 Return to Executive Summary					

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Communicator	Main Admin		75935338	1	07/27-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q3/22	
Control Panel			Main Office				14225439		1		07/26-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Battery	14	12	2	14	14
Device Type	Location		ScanID	Address	Q3/22
Battery	Admin Building, Main Office, Workroom BPS		44812219	1	07/27-F
Battery	Admin Building, Main Office, Workroom BPS		44812218	1	07/27-F
Battery	Classroom 21 BPS		54665010	1	07/27-P
Battery	Classroom 21 BPS		54665009	1	07/27-P
Battery	Classroom 25 BPS		53053224	1	07/27-P
Battery	Classroom 25 BPS		53053225	1	07/27-P
Battery	Electrical/Custodial room near Classroom 15 BPS		20414506	1	07/27-P
Battery	Electrical/Custodial room near Classroom 15 BPS		20414507	1	07/27-P
Battery	Library Building, South Storage Room BPS		49353702	1	07/27-P
Battery	Library Building, South Storage Room BPS		49353701	1	07/27-P
Battery	MU Building, Data room BPS		20414508	1	07/27-P
Battery	MUBuilding, Data room BPS		20414509	1	07/27-P
Battery	Main Office at FACP		53053222	1	07/27-P
Battery	Main Office at FACP		53053223	1	07/27-P
Device Total: 14 Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))						
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Device Type		Location		ScanID	Address	Q3/22
Power Supply		Classroom 21 BPS		20413693	1	07/27-P
Power Supply		Classroom 25 BPS		20413694	1	07/27-P
Power Supply		Electrical/Custodial room near Classroom 15 BPS		20413692	1	07/27-P
Power Supply		Library Building, South Storage Room BPS		20413691	1	07/27-P
Power Supply		MUBuilding, Data room BPS		20413690	1	07/27-P
Device Total: 6		Return to Executive Summary				

Service Summary

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		2
<i>Passed</i>		
		12
Beam Detector	Annual	2
Bell	Annual	1
Communicator	Annual	1
Control Panel	Annual	1
Duct Detector	Annual	7
Heat Detector	Annual	33
Horn/Strobe	Annual	35
Horn	Annual	18
Power Supply	Annual	6
Pull Station	Annual	8
Releasing Device	Annual	2
Smoke Detector	Annual	123
Strobe	Annual	34
Supervisory Device	Tested	1
Tamper Switch	Tested	1
Waterflow Switch	Tested	1
		286
<i>Untested</i>		

Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD			Control Panel: 1 - EST EST-3	
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
<i>Passed</i>				
Releasing Device				
	North Stage Hatch Releasing Device Ceiling Set Off By Smoke Detect.	Passed	16088915	☐
	South Stage Hatch Releasing Device Ceiling Set Off By Smoke Detect.	Passed	16088914	☐

Time, Temperature & Level Testing

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD			Control Panel: 1 - EST EST-3			
<i>The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.</i>						
Type	Location	Comment	Sec	Deg	Lvl	ScanID
Passed						
Waterflow Switch						
	MU Building, Fire Sprinkler Room	Passed	40	n/a	n/a	05656541

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD				Control Panel: 1 - EST EST-3			
<i>The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i>							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							

Sealed Lead Acid	Classroom 21 BPS	10.5 AH	12V	13.3	13	80%	100%
Sealed Lead Acid	Classroom 25 BPS	10.5 AH	12V	13.3	13.1	80%	100%
Sealed Lead Acid	Classroom 25 BPS	10.5 AH	12V	13.2	13	80%	100%
Sealed Lead Acid	Electrical/Custodial room near Classroom 15 BPS	10AH	12V	13.2	13	80%	100%
Sealed Lead Acid	Electrical/Custodial room near Classroom 15 BPS	10AH	12V	13.2	13	80%	100%
Sealed Lead Acid	Library Building, South Storage Room BPS	10.5 AH	12V	13.2	13	80%	100%
Sealed Lead Acid	Library Building, South Storage Room BPS	10.5 AH	12V	13.2	13	80%	100%
Sealed Lead Acid	MU Building, Data room BPS	10AH	12V	13.2	12.9	80%	100%
Sealed Lead Acid	MU Building, Data room BPS	10AH	12V	13.3	13	80%	100%
Sealed Lead Acid	Main Office at FACP	26	12	13.4	13.2	80%	80%
Sealed Lead Acid	Main Office at FACP	26	12	13.4	13.2	80%	90%
Failed/Other							

Sealed Lead Acid	Admin Building, Main Office, Workroom BPS	10AH	12V	13.2	13	80%	100%
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	Admin Building, Main Office, Workroom BPS	3ah	120v		26.5		
	Classroom 21 BPS	3	120		26.5		
Breaker	Classroom 25 BPS	3ah	120v		26.4		
Breaker	Electrtrical/Custodial room near Classroom 15 BPS	3ah	120v		26.4		
Breaker	Library Building, South	3ah	120v		26.4		

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
Breaker	Storage Room BPS MUBuilding, Data room BPS	3ah	120v	26.4

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD	Control Panel: 1 - EST EST-3
----------------------------------	------------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Beam Detector	Initiating	0.51%	2
Bell	Indicating	0.26%	1
Communicator	Control	0.26%	1
Control Panel	Control	0.26%	1
Duct Detector	Initiating	1.79%	7
Heat Detector	Initiating	34.78%	136
Horn	Indicating	4.60%	18
Horn/Strobe	Indicating	8.95%	35
Power Supply	Control	1.53%	6
Pull Station	Initiating	2.05%	8
Releasing Device	Auxiliary	0.51%	2
Smoke Detector	Initiating	31.46%	123
Strobe	Indicating	8.70%	34
Supervisory Device	Supervisory	0.26%	1
Tamper Switch	Supervisory	0.26%	1
Waterflow Switch	Initiating	0.26%	1

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 5 Years to 10 Years

Duracell

Power-Sonic

Duracell Ultra

Duracell Ultra

Battery	2	DURA12-10F2	Sealed Lead Acid	10/17/2014
---------	---	-------------	------------------	------------

In Service - 10 Years to 15 Years

Power-Sonic

Battery	2	ps-12100h	Sealed Lead Acid	07/17/2012
---------	---	-----------	------------------	------------

In Service - 15 Years to 25 Years

Releasing Device	2			06/20/2007
------------------	---	--	--	------------

Amseco				
Heat Detector	1	302	Rate-of-Rise	06/20/2007
EST				
Beam Detector	2			06/20/2007
Duct Detector	7			06/20/2007
Heat Detector	3	302		06/20/2007
Heat Detector	5	SIGA-HS		06/20/2007
Horn	18	757-1A-T		06/20/2007
Horn/Strobe	35	G1RF-HDVM		06/20/2007
Power Supply	6			06/20/2007
Pull Station	8	BG-12L		06/20/2007
Smoke Detector	6			06/20/2007
Smoke Detector	1	3912280973	Photoelectric	06/20/2007
Smoke Detector	1	G1RF-HDVM		06/20/2007
Smoke Detector	2	G1RF-VM		06/20/2007
Smoke Detector	1	SIGA PS		06/20/2007
Smoke Detector	96	SIGA-PS		06/20/2007
Smoke Detector	9	SIGA-PS	Photoelectric	06/20/2007
Strobe	34	G1RF-VM		06/20/2007
Potte.c				
Tamper Switch	1	wp175		06/20/2007
Potter Electric				
Bell	1	PBA-12010		06/20/2007
Supervisory Device	1	PCVS-2		06/20/2007
Waterflow Switch	1	VSR-F		06/20/2007
SimplexGrinnell				
Heat Detector	19	2098-9439	Rate-of-Rise	06/20/2007
Heat Detector	48	2098-9440	Rate-of-Rise	06/20/2007
Heat Detector	4	2098-9576		06/20/2007
Smoke Detector	7	2098-9576	Photoelectric	06/20/2007
THERMOTECH				
Heat Detector	1			06/20/2007
Heat Detector	2	302		06/20/2007
Heat Detector	53	302	Rate-of-Rise	06/20/2007
Power-Sonic				
Battery	2	PS-12260 NB	Sealed Lead Acid	01/21/2005
<i>In Service - 25 Years or Older</i>				
EST				
Control Panel	1	EST-3		06/25/1992
Edwards				
Communicator	1	5104	Digital Communicator	06/25/1992

Zone Address Report

Generated by: BuildingReports.com

Building: Sutherland ES Lodi USD			Control Panel: 1 - EST EST-3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0002	Heat Detector	Bathroom classroom 2 Admin	Rate-of-Rise	07257535
0002	Heat Detector	Bathroom Admin	Rate-of-Rise	05656431
0002	Heat Detector	ESL lab Bathroom Admin	Rate-of-Rise	05656434
0002	Heat Detector	Princpal office Admin	Rate-of-Rise	05656432
0002	Heat Detector	Above Ceiling Conference rm Admin	Rate-of-Rise	05656428
0002	Heat Detector	Above Ceiling ESL lab Admin	Rate-of-Rise	05656435
0002	Heat Detector	Above Ceiling Princpal office Admin	Rate-of-Rise	05656433
0002	Heat Detector	Above Ceiling Reading lab Admin	Rate-of-Rise	05656436
0002	Heat Detector	Above Ceiling Reception area Admin	Rate-of-Rise	05656427
0002	Heat Detector	Above Ceiling Wk room Admin	Rate-of-Rise	05656429
0003	Heat Detector	Above Ceiling Classroom 10	Rate-of-Rise	16426706
0003	Heat Detector	Above Ceiling Classroom 11	Rate-of-Rise	05656466
0003	Heat Detector	Above Ceiling Classroom 5	Rate-of-Rise	16426671
0003	Heat Detector	Above Ceiling Classroom 8	Rate-of-Rise	05656471
0003	Heat Detector	Above Ceiling Classroom 9	Rate-of-Rise	16426629
0003	Heat Detector	Above Ceiling Library P.E. rm	Rate-of-Rise	05656470
0003	Heat Detector	Above Ceiling Library Psy. rm	Rate-of-Rise	05656528
0003	Heat Detector	Above Ceiling Library music rm	Rate-of-Rise	05656469
04	Smoke Detector	MU high ceiling 1	Photoelectric	69501135
04	Smoke Detector	MU high ceiling 2	Photoelectric	69501129
04	Smoke Detector	MU high ceiling 3	Photoelectric	69501134
04	Smoke Detector	MU high ceiling 4	Photoelectric	69501128
04	Smoke Detector	MU high ceiling 5	Photoelectric	69501133
04	Smoke Detector	MU high ceiling 6	Photoelectric	69501127
04	Smoke Detector	MU high ceiling 7	Photoelectric	69501132
0004	Heat Detector	multipurpose Bathroom.staff	Rate-of-Rise	05656478
0004	Heat Detector	multipurpose Bathroom.staff.mens	Rate-of-Rise	05656479
0004	Heat Detector	multipurpose Data rm	Rate-of-Rise	69501108
0004	Heat Detector	multipurpose Kitchen-dishes area	Rate-of-Rise	69501109
0004	Heat Detector	multipurpose Office-kitchen	Rate-of-Rise	05656534
0004	Heat Detector	multipurpose Stage-closet	Rate-of-Rise	69501112
0004	Heat Detector	multipurpose waterheater area	Rate-of-Rise	05656535
04	Heat Detector	Above Ceiling Cafeteria Stage South East		69501123
04	Heat Detector	Above Ceiling Cafeteria Stage South West		16426663
0004	Heat Detector	Above Ceiling Classroom 6	Rate-of-Rise	05656526
0004	Heat Detector	Above Ceiling multipurpose Classroom 3	Rate-of-Rise	05656475

Address	Device Type	Location	Type	ScanID
0004	Heat Detector	Above Ceiling multipurpose Dry-storage	Rate-of-Rise	05656477
0004	Heat Detector	Above Ceiling multipurpose Kitchen-office	Rate-of-Rise	05656476
0004	Heat Detector	Above Ceiling multipurpose Riser rm	Rate-of-Rise	05656540
0004	Heat Detector	Center multipurpose Kitchen	Rate-of-Rise	69501110
0004	Heat Detector	East multipurpose staff lounge	Rate-of-Rise	16426790
0004	Heat Detector	North multipurpose Kitchen	Rate-of-Rise	69501111
0004	Heat Detector	South multipurpose Kitchen	Rate-of-Rise	16426738
0004	Heat Detector	West multipurpose staff lounge	Rate-of-Rise	05656537
Zone/Circuit: 2				
0011	Heat Detector	Across Wk room Office Admin	Rate-of-Rise	05656430
Zone/Circuit: 03				
0002	Heat Detector	Above Ceiling Classroom 22	Rate-of-Rise	05656442
0002	Heat Detector	Above Ceiling Classroom 23	Rate-of-Rise	05656443
0002	Heat Detector	Above Ceiling Classroom 24	Rate-of-Rise	05656444
0002	Heat Detector	Above Ceiling Classroom 25	Rate-of-Rise	05656437
0002	Heat Detector	Above Ceiling Classroom 26	Rate-of-Rise	05656438
0002	Heat Detector	Above Ceiling Classroom 27	Rate-of-Rise	05656439
0002	Heat Detector	Above Ceiling Classroom 28	Rate-of-Rise	05656440
0002	Heat Detector	Near rm.15 Bathroom-staff-North	Rate-of-Rise	05656449
0002	Heat Detector	Near rm.15 Bathroom-staff-South	Rate-of-Rise	05656450
0002	Heat Detector	Near rm.21 Bathroom-boys-East	Rate-of-Rise	05656445
0002	Heat Detector	Near rm.21 Bathroom-boys-West	Rate-of-Rise	05656448
0002	Heat Detector	Near rm.21 Bathroom-girls-East	Rate-of-Rise	05656447
0002	Heat Detector	Near rm.21 Bathroom-girls-West	Rate-of-Rise	05656446
0008	Heat Detector	Above Ceiling Classroom 13 Building A	Rate-of-Rise	05656459
0008	Heat Detector	Above Ceiling Classroom 14 Building A	Rate-of-Rise	05656460
0008	Heat Detector	Above Ceiling Classroom 14 Office Building A	Rate-of-Rise	05656461
0008	Heat Detector	Above Ceiling Classroom 15	Rate-of-Rise	05656452
0008	Heat Detector	Above Ceiling Classroom 16	Rate-of-Rise	05656451
0008	Heat Detector	Above Ceiling Classroom 17 Building A	Rate-of-Rise	05656464
0008	Heat Detector	Above Ceiling Classroom 20 Building A	Rate-of-Rise	05656462
0008	Heat Detector	Above Ceiling Classroom 20 Office Building A	Rate-of-Rise	05656463
0008	Heat Detector	East Bathroom-staff Building A	Rate-of-Rise	05656457
0008	Heat Detector	North Bathroom-boys Building A	Rate-of-Rise	05656455
0008	Heat Detector	North Bathroom-girls Building A	Rate-of-Rise	05656454
0008	Heat Detector	North Bathroom-staff Building A	Rate-of-Rise	05656458
0008	Heat Detector	South Bathroom-boys Building A	Rate-of-Rise	05656456
0008	Heat Detector	South Bathroom-girls Building A	Rate-of-Rise	05656453
Zone/Circuit: 04				
0001	Heat Detector	Custodian room by Classroom 15		3820494776
Zone/Circuit: 4				
1	Heat Detector	kindergarten rm 1		16426658
Zone/Circuit: 04				

Address	Device Type	Location	Type	ScanID
0001	Heat Detector	kindergarten rm 1		16426739
0002	Smoke Detector	Girls Restroom by Classroom 15, South		3912281253
0003	Smoke Detector	Girls Restroom by Classroom 15, North		3912359266
0004	Smoke Detector	Boys Restroom by Classroom 15, North		3912037560
0005	Smoke Detector	Boys Restroom by Classroom 15, South		3912281758
Zone/Circuit: 4				
0006	Smoke Detector	West Staff Restroom by Classroom 13		3912037751
Zone/Circuit: 04				
0007	Smoke Detector	South Staff Restroom near Classroom 13		3912037362
0008	Smoke Detector	Classroom 13		3912038284
0009	Smoke Detector	Classroom 15 NORTH-EAST		3912038383
0010	Smoke Detector	Classroom 14 east		3912038406
0011	Smoke Detector	Classroom 15 SOUTH-EAST		3912359150
0012	Smoke Detector	Classroom 15 SOUTH-WEST		3912364475
0014	Smoke Detector	Classroom 14 west		3912357156
0015	Smoke Detector	Classroom 14 Office		3936052297
0016	Smoke Detector	Classroom 16 North		3912038338
0017	Smoke Detector	Classroom 16 East		3912038574
0018	Smoke Detector	Classroom 16 South		3912037775
0019	Smoke Detector	Classroom 16 West		3912353837
0020	Smoke Detector	Classroom 20 South		3912038321
0021	Smoke Detector	Classroom 20 North		3912037638
0022	Smoke Detector	Classroom 20 Office		3912359815
0023	Smoke Detector	Classroom 18 East		3912037652
0024	Smoke Detector	Classroom 18 North		3912037621
0025	Smoke Detector	Classroom 17 Southwest		3912281796
0026	Smoke Detector	Classroom 17 South		3912359167
0027	Smoke Detector	Classroom 17 West		3912037584
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426586
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426597
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426598
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426599
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426609
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426613
027	Heat Detector	RESTROOMS BY CLASSROOM 15 HEATS	Rate-of-Rise	16426683
0028	Smoke Detector	Classroom 17 North		3912280928
0029	Smoke Detector	Classroom 18 South		3912359204
0030	Smoke Detector	Classroom 18 West		3912351239
0031	Duct Detector	Classroom 20		20413699

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 4				
0032	Smoke Detector	Library Building, Psychologist Office		3926357272
0033	Horn/Strobe	Library Building, Classroom 5 South		16426249
0033	Smoke Detector	Library Building, Classroom 5 South		3926357111
Zone/Circuit: 04				
0034	Smoke Detector	Library Building, Classroom 5, Northwest		3912363805
0035	Smoke Detector	Library Building, Classroom 5, East		3912363812
0036	Smoke Detector	Library Building, Classroom 6, East		3912357781
0037	Smoke Detector	Library Building, Classroom 6, South		3912359181
0038	Smoke Detector	Library Building, Classroom 6, North		3912353882
0039	Smoke Detector	Library Building, Classroom 7, West		3912351260
0040	Smoke Detector	Library Building, Classroom 7, East		3912281819
0041	Smoke Detector	Library Building, Classroom 7, South	Photoelectric	20413673
0042	Smoke Detector	Library Building, Classroom 8, South		3912281444
0043	Smoke Detector	Library Building, Classroom 8, West		3912351253
0044	Smoke Detector	Library Building, Classroom 8, East		3912281130
0045	Smoke Detector	Library Building, North Exit		3912363829
0046	Smoke Detector	Library Building, PE specialist room		3934292084
0047	Smoke Detector	rm next to P.E specialist		3912363874
0048	Smoke Detector	Library Building, Classroom 9, North		3912357132
0049	Smoke Detector	Library Building, Classroom 9, East		3912353875
0050	Smoke Detector	Library Building, Classroom 9, West		3912281673
0051	Smoke Detector	Library Building, Classroom 10, West		3912364062
0052	Smoke Detector	Library Building, Classroom 10, North		3912272381
0053	Smoke Detector	Library Building, Classroom 10, South		3912364079
0054	Smoke Detector	Library Building, Classroom 11, East		3912351291
0055	Smoke Detector	Library Building, Classroom 11, West		3912361542
0056	Smoke Detector	Library Building, Classroom 11, North		3912363997
0057	Smoke Detector	Library Building, Classroom 12, North		3912363737
0058	Smoke Detector	Library Building, Classroom 12, East		3912359174
0059	Smoke Detector	Library Building, Classroom 12, West	Photoelectric	3930162459
0060	Smoke Detector	Library Building, South Exit		3912356791
0061	Smoke Detector	Library Building, South Storage room		3912357545
0062	Smoke Detector	Library, South-West		20413679
0063	Smoke Detector	Library, North-West		20413678
0064	Smoke Detector	Library, North-Center		20413677
0065	Smoke Detector	Library, South-Center		20413680
0066	Smoke Detector	Library, South-East		20413681
0067	Smoke Detector	Library, North-East		20413676
0068	Smoke Detector	MU Building, Data room		3912355688
0069	Smoke Detector	MU Building, Staff Mens Restroom		3912355640
0070	Smoke Detector	MU Building, Staff Womens Restroom		3912281154
0071	Heat Detector	MU Building, Staff Lounge, Kitchen		3820505199
0072	Smoke Detector	MU Building, Staff Lounge, West		61240907
0073	Smoke Detector	MU Building, Staff Lounge, East		3935510194

Address	Device Type	Location	Type	ScanID
0075	Smoke Detector	MU Building, Kitchen Office		3912356029
0076	Heat Detector	MU Building, Kitchen Hallway		3820495070
0077	Smoke Detector	MU Building, Kitchen Dry Storage		3912355169
0078	Smoke Detector	MU Building, Custodial room		3912355138
0079	Smoke Detector	MU Building, storage rm north		3912355992
0080	Smoke Detector	MU Building, Band room, west		3912280973
0081	Smoke Detector	MU Building, Band room, east		3936049624
0082	Heat Detector	MU Building, Stage, North		3820492949
0083	Heat Detector	MU Building, Stage, South		3820496763
0084	Smoke Detector	MU Building, Stage storage		3912356203
0085	Smoke Detector	MU Building, Stage, by elevator		3912281987
0085	Smoke Detector	MU Building, Stage, by elevator		69501126
0086	Duct Detector	MU Building, Staff Lounge		20413697
0086	Duct Detector	MU Building, Staff Lounge		69501131
0087	Duct Detector	MU Building, Stage		69501107
0087	Duct Detector	MU Building, Stage		69501125
0127	Heat Detector	East wall Classroom 15	Rate-of-Rise	16426585
0127	Heat Detector	East wall Classroom 15	Rate-of-Rise	16426604
0127	Heat Detector	North Classroom 14	Rate-of-Rise	16426681
0127	Heat Detector	South Classroom 14	Rate-of-Rise	16426594
0127	Heat Detector	West wall Classroom 13	Rate-of-Rise	16426589
0127	Heat Detector	Lower-Lobby West wall Classroom 15	Rate-of-Rise	05656527
0128	Heat Detector	Center Classroom 20 work room	Rate-of-Rise	16426748
0128	Heat Detector	Northeast Classroom 16		16426583
0128	Heat Detector	Northeast wall Classroom 17	Rate-of-Rise	16426747
0128	Heat Detector	Northwest wall Classroom 16	Rate-of-Rise	16426596
0128	Heat Detector	South wall Classroom 17	Rate-of-Rise	16426584
0128	Heat Detector	South wall Classroom 20	Rate-of-Rise	16426605
0128	Heat Detector	Southeast wall Classroom 16	Rate-of-Rise	16426712
0128	Heat Detector	Southeast wall Classroom 18	Rate-of-Rise	16426590
0128	Heat Detector	southwest wall Classroom 16	Rate-of-Rise	16426685
0133	Pull Station	Lirary Building, North Exit		20413683
0134	Pull Station	Library Building, South Exit		20413682
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	16426716
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501116
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501117
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501118
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501120
0136	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501121
0137	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501113
0137	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501114
0137	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501115
0137	Heat Detector	MU BUILDING ATTIC HEATS	Rate-of-Rise	69501119
Zone/Circuit: 4				
0137	Heat Detector	Above Ceiling Cafeteria Stage North East		69501122

Address	Device Type	Location	Type	ScanID
0137	Heat Detector	Above Ceiling Cafeteria Stage North West		16426642
Zone/Circuit: 04				
0138	Beam Detector	MU Building, SOUTH		20413675
0139	Beam Detector	MU Building, NORTH		20413674
Zone/Circuit: 4				
140	Supervisory Device	Outside MU Building, parking lot P.I.V.		49353703
Zone/Circuit: 04				
0141	Waterflow Switch	MU Building, Fire Sprinkler Room		05656541
0142	Tamper Switch	MU Building, north storage rm		08919954
0144	Heat Detector	Kitchen dish washer		20408000
0145	Heat Detector	North Kitchen		20407998
0146	Heat Detector	South Kitchen		20407999
0147	Pull Station	MU Building, Cafeteria, North Exit		20413687
0148	Pull Station	MU Building, Stage, North Exit		20413684
0149	Pull Station	MU Building, Stage, South Exit		20413685
0150	Pull Station	MU Building, Cafeteria, East Exit		20413686
0151	Pull Station	MU Building, Cafeteria, South Exit		20413688
Zone/Circuit: 4				
251	Smoke Detector	Admin Building, Workroom		3912355985
Zone/Circuit: 04				
0252	Smoke Detector	Admin Building, Main Office Corridor, east		3912356135
0253	Smoke Detector	Admin Building, Main Office Restroom		3912355923
Zone/Circuit: 4				
0254	Smoke Detector	Admin Building, Principals Office		3912355619
Zone/Circuit: 04				
0255	Smoke Detector	Admin Building, Nurse's Office		3912355756
0256	Smoke Detector	Admin Building, Main Office Corridor, west		3912355558
0257	Smoke Detector	Admin Building, Closet Behind Master Clock		3912356333
0258	Smoke Detector	Admin Building, Main Office Area		3912355671
0259	Smoke Detector	Admin Building, Conference room		3912364000
0260	Smoke Detector	Admin Building, Supply Room		3912355411
0261	Smoke Detector	Classroom 2, East	Photoelectric	3912355954
0262	Smoke Detector	Classroom 2, North	Photoelectric	3912355930
0263	Smoke Detector	Classroom 2, South	Photoelectric	3912355657
0264	Smoke Detector	Classroom 2, Restroom	Photoelectric	3912354735
0265	Smoke Detector	Classroom 1, Restroom	Photoelectric	3912355718
0266	Smoke Detector	Classroom 1, West	Photoelectric	3912355503
0267	Smoke Detector	Classroom 1, South	Photoelectric	3912355596
0268	Smoke Detector	Classroom 1, North	Photoelectric	3912355626
0269	Duct Detector	Admin Building, Main Office, Workroom		20413696
0269	Duct Detector	Admin Building, Main Office, Workroom		69501130
0270	Smoke Detector	Classroom 25 East		3912356012
0271	Smoke Detector	Classroom 25 West		3912355916
0272	Smoke Detector	Classroom 26 West		3912354551

Address	Device Type	Location	Type	ScanID
0273	Smoke Detector	Classroom 26 East		3912355565
0274	Smoke Detector	Classroom 27 East		3912355572
0275	Smoke Detector	Classroom 27 West		3912355527
0276	Smoke Detector	Classroom 28 East		3912355589
0277	Smoke Detector	Classroom 28 West		3912355695
0278	Smoke Detector	Classroom 21 West		3912355268
0279	Smoke Detector	Classroom 21 East		3912355633
0280	Smoke Detector	Classroom 22 East		3912355220
0281	Smoke Detector	Classroom 22 West		3912355947
0282	Smoke Detector	Classroom 23 West		3912355213
0283	Smoke Detector	Classroom 23 East		3912354742
0284	Smoke Detector	Classroom 24 East		3912355442
0285	Smoke Detector	Classroom 24 West		3912356340
0286	Smoke Detector	Restroom Building, Girls Restroom		3912355077
0287	Smoke Detector	Restroom Building, Boys Restroom		3912355336
0288	Smoke Detector	Restroom Building, North Staff Restroom		3912354575
0289	Smoke Detector	Restroom Building, South Staff Restroom		3912355206
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426631
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426650
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426652
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426657
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426660
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426675
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426690
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426707
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426715
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426724
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426730
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426743
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426749
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426750
0377	Heat Detector	ADMIN BUILDING ATTIC HEATS	Rate-of-Rise	16426818
0379	Pull Station	Admin Building, Main Office		20413689
0381	Heat Detector	Center Classroom 25	Rate-of-Rise	16426784
0381	Heat Detector	Center Classroom 26	Rate-of-Rise	16426780
0381	Heat Detector	Center Classroom 27	Rate-of-Rise	16426817
0381	Heat Detector	Center Classroom 28	Rate-of-Rise	16426766
0383	Heat Detector	Center Classroom 21	Rate-of-Rise	16426805
0383	Heat Detector	Center Classroom 22	Rate-of-Rise	16426787
0383	Heat Detector	Center Classroom 23	Rate-of-Rise	16426819
0383	Heat Detector	Center Classroom 24	Rate-of-Rise	16426792

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Tokay Colony ES Lodi USD
13520 East Live Oak Rd
Lodi, CA 95240

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Sep 9, 2022

Building: Tokay Colony ES Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information

Address: 13520 East Live Oak Rd

Address:

City/State/ZIP Code: Lodi, CA 95240

Country: United States of America

System Control Unit

Model Number: E3 Series

Install Date: 07/01/2020

IDC Style:

Software Version:

Version Date: 07/07/2021

SLC Style:

Location: Bldg A Office

Current Protection:

NAC Style:

Central Station Signal Verification

Test Time/Date: 9/9/22 6:59:50 PM

Restore Time:

Note:

Inspection Completion Date: Sep 9, 2022					
Building: Tokay Colony ES Lodi USD					
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Multi-Sensor Detector	5	5	0	5	5
Smoke Detector	36	36	0	36	36
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
EC 02.03.05 EP 05					
		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
LS 02.01.34 EP 02					
		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
CO Detector	7	7	0	7	7
Power Supply	1	1	0	1	1
Total Device Count: 76					

Inspection & Testing

Generated by: BuildingReports.com

Building: Tokay Colony ES Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left.
Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Heat Detector	18	18	0	18	18
Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Building A Attic Admin Office	69501340	1-01 049	07/07-P	09/09-P
Heat Detector	Building A Attic Classroom 3	69501358	1-01 053	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 3	69501359	1-01 054	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 4	69501354	1-01 056	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 4	69501355	1-01 055	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 5	69501360	1-01 071	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 5	69501361	1-01 070	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 6	69501356	1-01 074	07/08-P	09/09-P
Heat Detector	Building A Attic Classroom 6	69501357	1-01 073	07/08-P	09/09-P
Heat Detector	Building A Attic MP East	69501353	1-01 064	07/08-P	09/09-P
Heat Detector	Building A Attic MP West	69501352	1-01 052	07/08-P	09/09-P
Heat Detector	Building A Custodial	69501330	1-01 015	07/07-P	09/09-P
Heat Detector	Building A MP Staff Kitchen	69501317	1-01 016	07/07-P	09/09-P
Heat Detector	Building A Mechanical Room	69501329	1-01 014	07/07-P	09/09-P
Heat Detector	Building A MP Attic Southeast Exit	69501339	1-01 065	07/07-P	09/09-P
Heat Detector	Building B Custodian Storage	69501332	1-01 047	07/07-P	09/09-P
Heat Detector	Electrical room ceiling	75938071	1-01 020		09/09 Removed
Heat Detector	Portable Attic	69501337	1-01 077	07/07-P	09/09-P
Heat Detector	Portable Attic	69501338	1-01 076	07/07-P	09/09-P
Device Total: 18 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Each of the detection principles present within the detector (e.g. smoke/heat/CO, etc.) shall be tested independently for the specific detection principle, regardless of the configuration status at the time of testing. Each detector shall be tested in accordance with the published manufacturer's instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14k))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Multi-Sensor Detector	5	5	0	5	5	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Multi-Sensor Detector	Building A Classroom 1		69501460	1-01 039	07/07-P	09/09-P
Multi-Sensor Detector	Building A Classroom 6		69501321	1-01 023	07/07-P	09/09-P
Multi-Sensor Detector	Building A MP West		69501334	1-01 005	07/07-P	09/09-P
Multi-Sensor Detector	Building B Classroom 2		69501470	1-01 032	07/07-P	09/09-P
Multi-Sensor Detector	Portable		69501335	1-01 048	07/07-P	09/09-P
Device Total: 5 Return to Executive Summary						

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Smoke Detector	36	36	0	36	36	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Smoke Detector	Building A Admin Restroom		69501302	1-01 079	07/07-P	09/09-P
Smoke Detector	Building A Admin Storage		69501303	1-01 080	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3		69501323	1-01 010	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3		69501322	1-01 006	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3		69501333	1-01 006	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3 Mental Health 1		69501325	1-01 008	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3 Mental Health 2		69501324	1-01 009	07/07-P	09/09-P
Smoke Detector	Building A Classroom 3 Study Room		69501326	1-01 007	07/07-P	09/09-P
Smoke Detector	Building A Classroom 5		69501319	1-01 021	07/07-P	09/09-P
Smoke Detector	Building A Classroom 5 - 6 Workroom		69501320	1-01 022	07/07-P	09/09-P
Smoke Detector	Building A FACP		69501309	1-01 001	07/07-P	09/09-P
Smoke Detector	Building A Girls Restroom		69501331	1-01 019	07/07-P	09/09-P
Smoke Detector	Building A MP Northeast Exit		69501318	1-01 004	07/07-P	09/09-P
Smoke Detector	Building A Main Entry Office		69501313	1-01 004	07/07-P	09/09-P
Smoke Detector	Building A Principal		69501310	1-01 024	07/07-P	09/09-P
Smoke Detector	Building A Principal Storage		69501311	1-01	07/07-P	09/09-P
Smoke Detector	Building A Psychologist Office		69501312	1-01 003	07/07-P	09/09-P
Smoke Detector	Building A Telecom		69501306	1-01 002	07/07-P	09/09-P
Smoke Detector	Building A classroom 4		69501328	1-01 013	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501459	1-01 043	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501456	1-01 036	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501455	1-01 037	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501457	1-01 038	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501454	1-01 045	07/07-P	09/09-P
Smoke Detector	Building B Classroom 1		69501453	1-01 046	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2		69501471	1-01 031	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2		69501472	1-01 030	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2		69501469	1-01 029	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2		69501468	1-01 028	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2		69501467	1-01 033	07/07-P	09/09-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	Building B Classroom 2	69501466	1-01 035	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2	69501465	1-01 034	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2	69501464	1-01 027	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2	69501463	1-01 026	07/07-P	09/09-P
Smoke Detector	Building B Classroom 2	69501458	1-01 044	07/07-P	09/09-P
Smoke Detector	Portable	69501336	1-01 047	07/07-P	09/09-P
Device Total: 36 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). Audible information shall be verified to be distinguishable and understandable. Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15b, c))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Speaker/Strobe	1	1	0	1	1	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Speaker/Strobe	All speaker/strobes inspected and tested		69501343	1-01	07/07-P	09/09-P
Device Total: 1 Return to Executive Summary						

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5					
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))							
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Communicator		1	1	0	1	1	
Device Type	Location		ScanID		Address	Q3/21	Q3/22
Communicator	Bldg A Office		69501342		1-01	07/07-P	09/09-P
Device Total: 1		Return to Executive Summary					

LS 02.01.34 EP 02							Protected master fire alarm control panel								
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))															
Devices				Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity			
Control Panel				1		1		0		1		1			
Device Type				Location				ScanID		Address		Q3/21		Q3/22	
Control Panel				Bldg A Office				69501341		1-01		07/07-P		09/09-P	
Device Total: 1				Return to Executive Summary											

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5					
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))							
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Battery		6	2	4	6	6	
Device Type	Location		ScanID		Address	Q3/21	Q3/22
Battery	Bldg A Office Above FACP		69501349		1-01	07/07-P	09/09-P
Battery	Bldg A Office Above FACP		69501350		1-01	07/07-P	09/09-P
Battery	Bldg A Office Below FACP		69501345		1-01	07/07-P	09/09-F
Battery	Bldg A Office Below FACP		69501344		1-01	07/07-F	09/09-F
Battery	Bldg A Office FACP		69501346		1-01	07/07-P	09/09-F
Battery	Bldg A Office FACP		69501347		1-01	07/07-P	09/09-F
Device Total: 6		Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
The devices shall be tested in place to ensure CO entry to the sensing chamber by introduction of CO gas from the protected area, through the vents, to the sensing chamber. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14h))						
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
CO Detector		7	7	0	7	7
Device Type	Location		ScanID	Address	Q3/21	Q3/22
CO Detector	Building A Classroom 1		69501462	1-01 042	07/07-P	09/09-P
CO Detector	Building A Classroom 4		69501327	1-01 011	07/07-P	09/09-P
CO Detector	Building A Classroom 4		69501461	1-01 040	07/07-P	09/09-P
CO Detector	Building A MP East		69501315	1-01 018	07/07-P	09/09-P
CO Detector	Building A MP Southeast Exit		69501316	1-01 078	07/07-P	09/09-P
CO Detector	Building A MP West		69501314	1-01 018	07/07-P	09/09-P
CO Detector	Building A boys restroom		73111754	1-01 012		09/09-P
Device Total: 7		Return to Executive Summary				

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5					
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))							
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Power Supply		1	1	0	1	1	
Device Type	Location		ScanID		Address	Q3/21	Q3/22
Power Supply	Bldg A Office FACP		69501348		1-01	07/07-P	09/09-P
Device Total: 1		Return to Executive Summary					

Service Summary

Generated by: BuildingReports.com

Building: Tokay Colony ES Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		4
<i>Passed</i>		
		2
CO Detector	Annual	7
Communicator	Annual	1
Control Panel	Annual	1
Heat Detector	Annual	3
Multi-Sensor Detector	Annual	5
Power Supply	Annual	1
Smoke Detector	Annual	36
Speaker/Strobe	Annual	1
		57
<i>Untested</i>		
Heat Detector		15
Total		15
Grand Total		76

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Tokay Colony ES Lodi USD				Control Panel: 1 - Honeywell E3 Series			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	Bldg A Office Above FACP	7	12	13.7	13.4	80%	100%
Sealed Lead Acid	Bldg A Office Above FACP	7	12	13.7	13.4	80%	100%
Failed/Other							
Sealed Lead Acid	Bldg A Office Below FACP	12	12	13.5	13.3	80%	100%
Sealed Lead Acid	Bldg A Office Below FACP	12	12	13.5	12	80%	10%
Sealed Lead Acid	Bldg A Office FACP	18	12	13.5	13.3	80%	70%
Sealed Lead Acid	Bldg A Office FACP	18	12	13.5	13	80%	70%

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Tokay Colony ES Lodi USD	Control Panel: 1 - Honeywell E3 Series
------------------------------------	--

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
CO Detector	Initiating	9.09%	7
Communicator	Control	1.30%	1
Control Panel	Control	1.30%	1
Heat Detector	Initiating	23.38%	18
Multi-Sensor Detector	Initiating	6.49%	5
Power Supply	Control	1.30%	1
Smoke Detector	Initiating	46.75%	36
Sound Test	Indicating	1.30%	1
Speaker/Strobe	Indicating	1.30%	1

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 2 Years to 3 Years

Honeywell

Ultra Tech

Battery	2	UT 12180	Sealed Lead Acid	07/24/2020
Battery	2	UT 1270	Sealed Lead Acid	07/24/2020

In Service - 3 Years to 5 Years

Honeywell

Control Panel	1	E3 Series		07/01/2020
Speaker/Strobe	1	E3 Series		07/01/2020

In Service - 15 Years to 25 Years

Honeywell

CO Detector	7	ASD-PL3		06/19/2007
Heat Detector	18	ASD-PL3		06/19/2007
Multi-Sensor Detector	1	ASD-PL3		06/19/2007
Multi-Sensor Detector	2	ASD-PL3	Smoke/CO	06/19/2007
Multi-Sensor Detector	2	ASD-PL3	Smoke/Gas	06/19/2007
Smoke Detector	36	ASD-PL3		06/19/2007

Zone Address Report

Generated by: BuildingReports.com

Building: Tokay Colony ES Lodi USD			Control Panel: 1 - Honeywell E3 Series	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 01				
001	Smoke Detector	Building A FACP	Smoke/CO	69501309
002	Smoke Detector	Building A Telecom		69501306
003	Smoke Detector	Building A Psychologist Office		69501312
004	Smoke Detector	Building A MP Northeast Exit		69501318
004	Smoke Detector	Building A Main Entry Office		69501313
005	Multi-Sensor Detector	Building A MP West		69501334
006	Smoke Detector	Building A Classroom 3		69501322
006	Smoke Detector	Building A Classroom 3		69501333
007	Smoke Detector	Building A Classroom 3 Study Room		69501326
008	Smoke Detector	Building A Classroom 3 Mental Health 1		69501325
009	Smoke Detector	Building A Classroom 3 Mental Health 2	69501324	
010	Smoke Detector	Building A Classroom 3	69501323	
011	CO Detector	Building A Classroom 4	69501327	
012	CO Detector	Building A boys restroom	73111754	
013	Smoke Detector	Building A classroom 4	69501328	
014	Heat Detector	Building A Mechanical Room	69501329	
015	Heat Detector	Building A Custodial	69501330	
016	Heat Detector	Building A MP Staff Kitchen	69501317	
018	CO Detector	Building A MP East	69501315	
018	CO Detector	Building A MP West	69501314	
019	Smoke Detector	Building A Girls Restroom	69501331	
021	Smoke Detector	Building A Classroom 5	69501319	
022	Smoke Detector	Building A Classroom 5 - 6 Workroom	69501320	
023	Multi-Sensor Detector	Building A Classroom 6	69501321	
024	Smoke Detector	Building A Principal	69501310	
026	Smoke Detector	Building B Classroom 2	69501463	
027	Smoke Detector	Building B Classroom 2	69501464	
028	Smoke Detector	Building B Classroom 2	69501468	
029	Smoke Detector	Building B Classroom 2	69501469	
030	Smoke Detector	Building B Classroom 2	69501472	
031	Smoke Detector	Building B Classroom 2	69501471	
032	Multi-Sensor Detector	Building B Classroom 2	Smoke/Gas	69501470
033	Smoke Detector	Building B Classroom 2	69501467	
034	Smoke Detector	Building B Classroom 2	69501465	
035	Smoke Detector	Building B Classroom 2	69501466	
036	Smoke Detector	Building B Classroom 1	69501456	

Address	Device Type	Location	Type	ScanID
037	Smoke Detector	Building B Classroom 1		69501455
038	Smoke Detector	Building B Classroom 1		69501457
039	Multi-Sensor Detector	Building A Classroom 1	Smoke/Gas	69501460
040	CO Detector	Building A Classroom 4		69501461
042	CO Detector	Building A Classroom 1		69501462
043	Smoke Detector	Building B Classroom 1		69501459
044	Smoke Detector	Building B Classroom 2		69501458
045	Smoke Detector	Building B Classroom 1		69501454
046	Smoke Detector	Building B Classroom 1		69501453
047	Heat Detector	Building B Custodian Storage		69501332
047	Smoke Detector	Portable		69501336
048	Multi-Sensor Detector	Portable	Smoke/CO	69501335
049	Heat Detector	Building A Attic Admin Office		69501340
052	Heat Detector	Building A Attic MP West		69501352
053	Heat Detector	Building A Attic Classroom 3		69501358
054	Heat Detector	Building A Attic Classroom 3		69501359
055	Heat Detector	Building A Attic Classroom 4		69501355
056	Heat Detector	Building A Attic Classroom 4		69501354
064	Heat Detector	Building A Attic MP East		69501353
065	Heat Detector	Building A MP Attic Southeast Exit		69501339
070	Heat Detector	Building A Attic Classroom 5		69501361
071	Heat Detector	Building A Attic Classroom 5		69501360
073	Heat Detector	Building A Attic Classroom 6		69501357
074	Heat Detector	Building A Attic Classroom 6		69501356
076	Heat Detector	Portable Attic		69501338
077	Heat Detector	Portable Attic		69501337
078	CO Detector	Building A MP Southeast Exit		69501316
079	Smoke Detector	Building A Admin Restroom		69501302
080	Smoke Detector	Building A Admin Storage		69501303
	Speaker/Strobe	All speaker/strobes inspected and tested		69501343
	Communicator	Bldg A Office		69501342
	Control Panel	Bldg A Office		69501341
	Battery	Bldg A Office Above FACP	Sealed Lead Acid	69501349
	Battery	Bldg A Office Above FACP	Sealed Lead Acid	69501350
	Battery	Bldg A Office Below FACP	Sealed Lead Acid	69501344
	Battery	Bldg A Office Below FACP	Sealed Lead Acid	69501345
	Battery	Bldg A Office FACP	Sealed Lead Acid	69501346
	Battery	Bldg A Office FACP	Sealed Lead Acid	69501347
	Power Supply	Bldg A Office FACP		69501348
	Smoke Detector	Building A Principal Storage		69501311

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Tokay HS Lodi USD
1111 West Century Blvd
Lodi, CA 95240

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Sep 16, 2022

Building: Tokay HS Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: *BuildingReports.com*

Building Information

Address: 1111 West Century Blvd

Address:

City/State/ZIP Code: Lodi, CA 95240

:

Country: United States of America

System Control Unit

Model Number: EST3

Install Date: 12/31/1969

IDC Style:

Software Version:

Version Date: 12/31/1969

SLC Style:

Location: Admin_Electrical_A19

Current Protection:

NAC Style:

Inspection Completion Date: Sep 16, 2022

Building: Tokay HS Lodi USD

EC 02.03.05 EP 01 The organization tests supervisory signal devices on the inventory with the following time frames: Quarterly for pressure supervisory indicating devices (including both high- and low-air pressure switches), water level supervisory indicating devices, water temperature supervisory indicating devices, room temperature supervisory indicating devices, and other suppression system supervisory initiating devices. Semiannually for valve supervisory switches. Annually for other supervisory initiating devices. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Supervisory Valve	1	1	0	1	1

EC 02.03.05 EP 02 Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Tamper Switch	2	2	0	2	2
Waterflow Switch	2	2	0	2	2

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

Heat Detector	147	142	5	147	445
Multi-Sensor Detector	58	57	1	58	58
Pull Station	22	22	0	22	22
Smoke Detector	606	602	4	606	606

EC 02.03.05 EP 04 Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

Horn	40	38	2	40	40
Horn/Strobe	315	306	9	315	315
Strobe	6	6	0	6	6

EC 02.03.05 EP 05 Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

LS 02.01.34 EP 02 Protected master fire alarm control panel

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	13	13	0	13	13

LS 02.01.34 EP 10 All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5

Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
---------	---------------------	------	------	-------------------	----------------

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Battery	62	38	24	62	62
Power Supply	17	17	0	17	17
Total Device Count: 1599					

Inspection & Testing

Generated by: BuildingReports.com

Building: Tokay HS Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left. Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 01	The organization tests supervisory signal devices on the inventory with the following time frames: Quarterly for pressure supervisory indicating devices (including both high- and low-air pressure switches), water level supervisory indicating devices, water temperature supervisory indicating devices, room temperature supervisory indicating devices, and other suppression system supervisory initiating devices. Semiannually for valve supervisory switches. Annually for other supervisory initiating devices. NFPA 72-2010 Table 14.4.5				
	Valve shall be operated and signal receipt shall be verified to be within the first two revolutions of the hand wheel or within one-fifth of the travel distance, or per the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14i.1))				
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Supervisory Valve	1	1	0	1	1
Device Type	Location	ScanID	Address	Q3/21	Q3/22
Supervisory Valve	South of BLDG T	75938208	16-02 0133		09/15-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.				
Valve shall be operated and signal receipt shall be verified to be within the first two revolutions of the hand wheel or within one-fifth of the travel distance, or per the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14i.1))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Tamper Switch	2	2	0	2	2	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Tamper Switch	Practice Gym Fire Riser		75938186	15-02 0134		09/14-P
Tamper Switch	1st floor fire riser		75938126	16-02 0136		09/13-P
Device Total: 2 Return to Executive Summary						

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.					
Vane-type and pressure switch-type waterflow alarm devices shall be tested semiannually. Per NFPA 25, Section 5.3.3.1, mechanical waterflow alarm devices shall be tested quarterly. Water shall be flowed through an inspector's test connection indicating the flow of water equal to that from a single sprinkler of the smallest orifice size installed in the system for wet-pipe systems, or an alarm test bypass connection for dry-pipe, pre-action, or deluge systems. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14j))							
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Waterflow Switch		2	2	0	2	2	
Device Type	Location		ScanID		Address	Q3/21	Q3/22
Waterflow Switch	Practice Gym Fire Riser		75938187		15-02 0133		09/14-P
Waterflow Switch	1st floor fire riser		75938125		16-02 0135		09/13-P
Device Total: 2		Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
The detector shall be tested by introducing smoke, other aerosol, or an optical filter into the beam path. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.7))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Beam Detector	6	6	0	6	6	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Beam Detector	Main Practice Gym East		75938194	15-02 0127		09/14-P
Beam Detector	Main Practice Gym West		75938195	15-02 0126		09/14-P
Beam Detector	Gym west end beam detector		14226391	12-02 0132	07/13-P	09/15-P
Beam Detector	gym east beam detector		14226393	12-02 0135	07/13-P	09/15-P
Beam Detector	gym east/center beam detector		14226394	12-02 0134	07/13-P	09/15-P
Beam Detector	gym west/center beam detector		14226392	12-02 0133	07/13-P	09/15-P
Device Total: 6		Return to Executive Summary				

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Heat Detector	147	142	5	147	445	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Heat Detector	1st attic boys restroom by T115		75938201	16-02 0154		09/15-P
Heat Detector	1st attic girls restroom by T115		75938202	16-02 0153		09/15-P
Heat Detector	1st BLDG T Attic outside of Fire riser		75938199	16-02 0131		09/15-P
Heat Detector	1st BLDG T Attic outside of T107		75938200	16-02 0132		09/15-P
Heat Detector	2nd T201&203 workroomAttic center		75938166	16-02 0389		09/13-P
Heat Detector	2nd T201Attic center		75938164	16-02 0391		09/13-P
Heat Detector	2nd T201Attic east		75938165	16-02 0390		09/13-P
Heat Detector	2nd T201Attic west		75938163	16-02 0392		09/13-P
Heat Detector	2nd T203 Attic east		75938169	16-02 0386		09/13-P
Heat Detector	2nd T203 Attic center		75938168	16-02 0387		09/13-P
Heat Detector	2nd T203 Attic west		75938167	16-02 0388		09/13-P
Heat Detector	2nd T204 Attic southeast		75938170	16-02 0386		09/13-P
Heat Detector	2nd T204 Attic northwest		75938171	16-02 0385		09/13-P
Heat Detector	2nd T205 Attic northwest		75938173	16-02 0383		09/13-P
Heat Detector	2nd T205 Attic southeast		75938172	16-02 0382		09/13-P
Heat Detector	2nd T206 Attic northwest		75938175	16-02 0380		09/13-P
Heat Detector	2nd T206 Attic southeast		75938174	16-02 0379		09/13-P
Heat Detector	2nd T207 Attic northwest		75938177	16-02 0378		09/13-P
Heat Detector	2nd T207 Attic southeast		75938176	16-02 0377		09/13-P
Heat Detector	2nd T215 Attic northwest		75938179	16-02 0396		09/13-P
Heat Detector	2nd T215 Attic southeast		75938178	16-02 0395		09/13-P
Heat Detector	2nd T216 Attic northwest		75938181	16-02 0398		09/13-P
Heat Detector	2nd T216 Attic southeast		75938180	16-02 0397		09/13-P
Heat Detector	2nd T217 Attic Southeast		75938182	16-02 0399		09/13-P
Heat Detector	2nd T217 Attic northwest		75938183	16-02 0400		09/13-P
Heat Detector	2nd T218 Attic northwest		75938185	16-02 0402		09/13-P
Heat Detector	2nd T218 Attic southeast		75938184	16-02 0401		09/13-P
Heat Detector	Attic HEAT ATTIC: BLDG. S 9D027 STORAGE S8 inside S7		09163109	9-02 0027		
Heat Detector	Attic attic heat : MATH 8D004 ROOM 4 WEST		09163125	8-02 0004		07/15-P
Heat Detector	Attic attic heat : MATH 8D021 SOUTH LOCKER CORRIDOR		09163755	8-02 0021		07/15-P
Heat Detector	Attic attic heat: MATH 8D010 ROOM 2 SOUTH/WEST		09163128	8-02 0010		07/15-P
Heat Detector	Attic attic heat: MATH 8D016 ROOM		69506050	8-02 0016		07/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	8 NORTH/EAST				
Heat Detector	Attic attic heat: MATH 8D025 ROOM	09163117	8-02 0025	07/15-P	
	2 NORTH/EAST				
Heat Detector	Attic attic heat: MATH 8D029 ROOM	09163749	8-02 0029	07/15-P	
	6 SOUTH/EAST				
Heat Detector	Attic attic heat: MATH 8D032 ROOM	09163118	8-02 0032	07/15-P	
	3 NORTH/EAST				
Heat Detector	Attic attic heat: MATH 8D035	09163745	8-02 0035	07/15-P	
	NORTH LOCKER CORRIDOR				
Heat Detector	Attic english attic heat north weast e5	09163943	9-02 0017		
Heat Detector	Attic english attic heat north east e10	09164107	9-02 0017		
Heat Detector	Attic english attic heat north east e4	09163947	9-02 0017		
Heat Detector	Attic english attic heat north east e5	09163944	9-02 0017		
Heat Detector	Attic english attic heat north east e6	09164090	9-02 0017		
Heat Detector	Attic english attic heat north east e7	09164097	9-02 0017		
Heat Detector	Attic english attic heat north east e8	09164098	9-02 0017		
Heat Detector	Attic english attic heat north east e9	09164106	9-02 0017		
Heat Detector	Attic english attic heat north weast e6	09164091	9-02 0017		
Heat Detector	Attic english attic heat north west e10	09164108	9-02 0017		
Heat Detector	Attic english attic heat north west e4	09163946	9-02 0017	07/13-P	09/15-P
Heat Detector	Attic english attic heat north west e7	09164099	9-02 0017		
Heat Detector	Attic english attic heat north west e8	09164100	9-02 0017		
Heat Detector	Attic english attic heat north west e9	09164103	9-02 0017		
Heat Detector	Attic english attic heat northeast e11	09164210	9-02 0017		
Heat Detector	Attic english attic heat sout east e7	09164096	9-02 0017		
Heat Detector	Attic english attic heat south weast e5	09163942	9-02 0017		
Heat Detector	Attic english attic heat south east e10	09163940	9-02 0017		
Heat Detector	Attic english attic heat south east e4	09163927	9-02 0017		
Heat Detector	Attic english attic heat south east e5	09163945	9-02 0017		
Heat Detector	Attic english attic heat south east e6	09164093	9-02 0017		
Heat Detector	Attic english attic heat south east e8	09164102	9-02 0017		
Heat Detector	Attic english attic heat south east e9	09164105	9-02 0017		
Heat Detector	Attic english attic heat south weast e6	09164092	9-02 0017		
Heat Detector	Attic english attic heat south west e10	09164283	9-02 0017		
Heat Detector	Attic english attic heat south west e4	09163926	9-02 0017		
Heat Detector	Attic english attic heat south west e7	09164095	9-02 0017	07/13-P	09/15-P
Heat Detector	Attic english attic heat south west e8	09164101	9-02 0017		
Heat Detector	Attic english attic heat south west e9	09164104	9-02 0017		
Heat Detector	Attic english attic heat southeast e11	09164211	9-02 0017		
Heat Detector	Attic english attic heat southwest e11	09164212	9-02 0017		
Heat Detector	Attic heat attic : MATH 8D027 ROOM	09163753	8-02 0027	07/15-P	
	7 NORTH/WEST				
Heat Detector	Attic heat attic room 5 west. : MATH	09163744	8-02 0040	07/15-P	

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	8D040 ROOM 5 WEST				
Heat Detector	Attic heat attic: MATH 8D015 ROOM 8 SOUTH/EAST	09163787	8-02 0015	07/15-P	
Heat Detector	Attic heat attic: MATH 8D041 ROOM 4 EAST	09163743	8-02 0041	07/15-P	
Heat Detector	Attic heat attic: ADMIN 1D018FACULTY PREP 41 S/E	09163789	1-02 0018		
Heat Detector	Attic heat attic: ADMIN 1D045MENS ROOM 15	09163760	1-02 0045		
Heat Detector	Attic heat attic: ADMIN 1D048HALLWAY 17 NORTH	09163756	1-02 0048		
Heat Detector	Attic heat attic: BLDG. S 9D028 STORAGE S7	09163115	9-02 0128		
Heat Detector	Attic heat attic: BLDG. S 9D029 CLASSROOM 6 N/W	09163111	9-02 0029		
Heat Detector	Attic heat attic: BLDG. S 9D030 CLASSROOM 6 N/E	09163113	9-02 0030		
Heat Detector	Attic heat attic: BLDG. S 9D031 CLASSROOM 6 S/E	09163112	9-02 0031		
Heat Detector	Attic heat attic: BLDG. S 9D032 CLASSROOM 6 S/W	09163114	9-02 0032		
Heat Detector	Attic heat attic: MATH 8D005 NORTH LOCKER CORRIDOR	09163124	8-02 0005	07/15-P	
Heat Detector	Attic heat attic: MATH 8D007 ROOM 3 NORTH/WEST	09163127	8-02 0007	07/15-P	
Heat Detector	Attic heat attic: MATH 8D009 ROOM 2 NORTH/WEST	69506049	8-02 0009	07/15-P	
Heat Detector	Attic heat attic: MATH 8D011 ROOM 1 NORTH/WEST	09163130	8-02 0011	07/15-P	
Heat Detector	Attic heat attic: MATH 8D012 ROOM 1 SOUTH/EAST	09163116	8-02 0012	07/15-P	
Heat Detector	Attic heat attic: MATH 8D012 ROOM 1 SOUTH/WEST	09163120	8-02 0012	07/15-P	
Heat Detector	Attic heat attic: MATH 8D014 ROOM 8 SOUTH/WEST	09163799	8-02 0014	07/15-P	
Heat Detector	Attic heat attic: MATH 8D019 SOUTH LOCKER CORRIDOR	09163121	8-02 0019	07/15-P	
Heat Detector	Attic heat attic: MATH 8D022 ROOM 7 SOUTH/EAST	09163751	8-02 0022	07/15-P	
Heat Detector	Attic heat attic: MATH 8D023 ROOM 7 SOUTH/WEST	09163754	8-02 0023	07/15-P	
Heat Detector	Attic heat attic: MATH 8D024 ROOM 2 SOUTH/EAST	09163122	8-02 0024	07/15-P	
Heat Detector	Attic heat attic: MATH 8D028 ROOM 7 NORTH/EAST	09163752	8-02 0028	07/15-P	
Heat Detector	Attic heat attic: MATH 8D030 ROOM	09163750	8-02 0030	07/15-P	

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	6 SOUTH/WEST				
Heat Detector	Attic heat attic: MATH 8D033 ROOM	09163748	8-02 0033	07/15-P	
	6 NORTH/WEST				
Heat Detector	Attic heat attic: MATH 8D034 ROOM	09163747	8-02 0034	07/15-P	
	6 NORTH/EAST				
Heat Detector	Attic heat attic: MATH 8D036 ROOM	09163746	8-02 0036	07/15-P	
	5 EAST				
Heat Detector	Attic heat attic: english e3 north east	09163923	8-02 0017		
Heat Detector	Attic heat attic: english e3 north west	09163922	8-02 0017		
Heat Detector	Attic heat attic: english e3 south east	09163920	8-02 0017		
Heat Detector	Attic heat attic: english e3 south west	09163921	8-02 0017		
Heat Detector	Attic heat attic: english meeting room north	09163925	8-02 0017		
Heat Detector	Attic heat attic: english meeting room south	09163924	8-02 0017		
Heat Detector	Attic heat attic: MATH 8D018 ROOM	09163129	8-02 0018	07/15-P	
	1 NORTH/EAST				
Heat Detector	Attic heat-snackbar c4-attic	09164179	9-02 0021		
Heat Detector	Attic loft-maint-storage-c35-attic	09164175	9-02 0021		
Heat Detector	Attic loft-maint-storage-c35-attic-north	09164177	9-02 0021		
Heat Detector	Attic loft-maint-storage-c35-attic-south	09164176	9-02 0021		
Heat Detector	Attic portable p11 attic heat north	09164208	9-02 0017		09/15 Removed
Heat Detector	Attic portable p11 attic heat south	09164209	9-02 0017		09/15 Removed
Heat Detector	Attic portable p12 attic heat north	09164206	9-02 0017		09/15 Removed
Heat Detector	Attic portable p12 attic heat south	09164207	9-02 0017		09/15 Removed
Heat Detector	Attic portable p13 attic heat north	09164204	9-02 0017		09/15 Removed
Heat Detector	Attic portable p13 attic heat south	09164205	9-02 0017		09/15 Removed
Heat Detector	Attic portable p14 attic heat south	09164203	9-02 0017		09/15 Removed
Heat Detector	Attic B3 NE	09163612	5-02 0128		
Heat Detector	Attic BLDG.H attic girls restroom	09157876	10-02 0075		
Heat Detector	Attic BLDG.H room IA7 attic north	09157875	10-02 0075		
Heat Detector	Attic BLDG.H room IA7 attic south	09157874	10-02 0075		
Heat Detector	Attic BLDG.H west classroom IA10 attic north	09157869	10-02 0075		
Heat Detector	Attic BLDG.H west classroom IA10 attic south	09157870	10-02 0075		
Heat Detector	Attic BLDG.H west classroom IA11 attic north	09157868	10-02 0075		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Attic BLDG.H west classroom IA11 attic south	09157867	10-02 0075		
Heat Detector	Attic BLDG.H west hallway attic by north exit	09157866	10-02 0075		
Heat Detector	Attic BLDG.H west hallway attic by room IA12	09157865	10-02 0075		
Heat Detector	Attic BLDG.H west hallway attic by room IA14	09157864	10-02 0075		
Heat Detector	Attic P1 north	09163889	5-02 0131		
Heat Detector	Attic attic heat portable p10 north	09163908	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p10 south	09163907	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p2 north	09163894	5-02 0131		09/15 Removed
Heat Detector	Attic attic heat portable p2 south	09163893	5-02 0131		09/15 Removed
Heat Detector	Attic attic heat portable p3 north	09163892	5-02 0131		09/15 Removed
Heat Detector	Attic attic heat portable p3 south	09163891	5-02 0131		09/15 Removed
Heat Detector	Attic attic heat portable p4 north	09163896	5-02 0132		09/15 Removed
Heat Detector	Attic attic heat portable p4 south	09163895	5-02 0131		09/15 Removed
Heat Detector	Attic attic heat portable p5 north	09163897	5-02 0027		09/15 Removed
Heat Detector	Attic attic heat portable p5 south	09163898	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p6 north	09163899	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p6 south	09163900	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p7 north	09163901	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p7 south	09163902	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p8 north	09163903	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p8 south	09163904	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p9 north	09163905	5-02 0130		09/15 Removed
Heat Detector	Attic attic heat portable p9 south	09163906	5-02 0130		09/15 Removed
Heat Detector	Attic english e1 attic heat northeast	09163911	9-02 0016		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Attic english e1 attic heat northwest	09163912	9-02 0016		
Heat Detector	Attic english e1 attic heat southeast	09163910	9-02 0016		
Heat Detector	Attic english e1 attic heat southwest	09163909	9-02 0016		
Heat Detector	Attic english e12 hallway attic heat north	09163918	9-02 0016		
Heat Detector	Attic english e12 hallway attic heat south	09163917	9-02 0016		
Heat Detector	Attic english e2 attic heat northeast	09163916	9-02 0016		
Heat Detector	Attic english e2 attic heat northwest	09163915	9-02 0016		
Heat Detector	Attic english e2 attic heat southeast	09163913	9-02 0016		
Heat Detector	Attic english e2 attic heat southwest	09163914	9-02 0016		
Heat Detector	Attic Bldg. 0 Library attic work experience office L14	09163141	4-02 0057	07/13-P	09/15-P
Heat Detector	Attic Bldg. 0 Library attic workroom L9 east	09163139	4-02 0057		
Heat Detector	Attic Bldg. 0 Library attic workroom L9 west	09163138	4-02 0057		
Heat Detector	Attic Bldg. 0 Library in main entrance attic	09163137	4-02 0057		
Heat Detector	Attic Bldg. 0 attic Library storage L11	09163140	4-02 0057	07/13-P	09/15-P
Heat Detector	Attic Bldg. F classroom SS1 attic N/E	09163374	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS1 attic N/W	09163375	4-02 0057	07/13-P	09/15-P
Heat Detector	Attic Bldg. F classroom SS1 attic S/E	09163373	3-02 0128		
Heat Detector	Attic Bldg. F classroom SS1 attic S/W	09163372	3-02 0128		
Heat Detector	Attic Bldg. F classroom SS10 attic N /E	09163404	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS10 attic N /W	09163407	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS10 attic S /E	09163405	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS10 attic S /W	09163406	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS11 attic N /E	09163411	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS11 attic N /W	09163409	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS11 attic S /E	09163410	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS11 attic S /W	09163408	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS2 attic N/E	09163378	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS2 attic N/W	09163377	4-02 0057	07/13-P	09/15-P
Heat Detector	Attic Bldg. F classroom SS2 attic S/E	09163379	3-02 0128		
Heat Detector	Attic Bldg. F classroom SS2 attic S/W	09163376	3-02 0127		
Heat Detector	Attic Bldg. F classroom SS3 attic N/E	09163384	4-02 0057		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Attic Bldg. F classroom SS3 attic N/W	09163383	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS3 attic S/E	09163385	3-02 0127		
Heat Detector	Attic Bldg. F classroom SS3 attic S/W	09163382	3-02 0127		
Heat Detector	Attic Bldg. F classroom SS4 attic N/E	09163389	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS4 attic N/W	09163388	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS4 attic S/E	09163386	3-02 0127		
Heat Detector	Attic Bldg. F classroom SS4 attic S/W	09163387	3-02 0127		
Heat Detector	Attic Bldg. F classroom SS5 attic N/E	09163395	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS5 attic N/W	09163394	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS5 attic S/E	09163393	3-02 0126		
Heat Detector	Attic Bldg. F classroom SS5 attic S/W	09163392	3-02 0126		
Heat Detector	Attic Bldg. F classroom SS6 attic N/E	09163397	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS6 attic N/W	09163398	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS6 attic S/E	09163396	3-02 0126		
Heat Detector	Attic Bldg. F classroom SS6 attic S/W	09163399	3-02 0126		
Heat Detector	Attic Bldg. F classroom SS7 attic N/E	09163092	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS7 attic N/W	09163095	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS7 attic S/E	09163093	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS7 attic S/W	09163094	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS8 attic N/E	09163099	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS8 attic N/W	09163096	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS8 attic S/E	09163098	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS8 attic S/W	09163097	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS9 attic N/E	09163403	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS9 attic N/W	09163400	4-02 0057		
Heat Detector	Attic Bldg. F classroom SS9 attic S/E	09163402	4-02 0057	07/13-P	09/14-P
Heat Detector	Attic Bldg. F classroom SS9 attic S/W	09163401	4-02 0057		
Heat Detector	Attic Bldg. F east locker corridor attic south	09163390	4-02 0057		
Heat Detector	Attic Bldg. J Lounge room east attic	09163276	4-02 0057	07/13-P	09/14-P
Heat Detector	Attic Bldg. J Lounge room west attic	09163275	4-02 0057	07/13-P	09/14-P
Heat Detector	Attic Bldg. J Classroom HE1 Center /E attic	09163273	2-02 0126		
Heat Detector	Attic Bldg. J Classroom HE1 N/E attic	09163272	4-02 0057		
Heat Detector	Attic Bldg. J Classroom HE1 N/W attic	09163270	4-02 0057		
Heat Detector	Attic Bldg. J Classroom HE1 S/E attic	09163274	2-02 0126		
Heat Detector	Attic Bldg. J Classroom HE1 S/W attic	09163271	2-02 0126		
Heat Detector	Attic Bldg. J classroom HE11 attic S /E.	09163281	4-02 0057	07/13-P	09/14-P
Heat Detector	Attic Bldg. J classroom HE3 attic N /Center	09163284	4-02 0057		
Heat Detector	Attic Bldg. J classroom HE3 attic N/E	09163285	4-02 0057		
Heat Detector	Attic Bldg. J classroom HE3 attic S	09163283	2-02 0127		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	/Center				
Heat Detector	Attic Bldg. J classroom HE3 attic S/E	09163286	2-02 0127		
Heat Detector	Attic Bldg. J classroom HE3 attic S/W	09163282	2-02 0127		
Heat Detector	Attic Bldg. J classroom HE4 east attic	09163292	4-02 0057		
Heat Detector	Attic Bldg. J classroom HE4 west attic	09163291	4-02 0057		
Heat Detector	Attic Bldg. J classroom HE5 east attic	09163290	2-02 0127		
Heat Detector	Attic Bldg. J classroom HE5 west attic	09163289	2-02 0127		
Heat Detector	Attic Bldg. J classroom HE6 attic N	09163279	2-02 0126		
	/Center				
Heat Detector	Attic Bldg. J classroom HE6 attic N/W	09163280	4-02 0057		
Heat Detector	Attic Bldg. J classroom HE6 attic S	09163278	4-02 0057	07/13-P	09/14-P
	/Center				
Heat Detector	Attic Bldg. J classroom HE6 attic S/W	09163277	2-02 0126		
Heat Detector	Attic Bldg. J west locker corridor north attic	09163269	4-02 0057	07/13-P	09/14-P
Heat Detector	Attic Bldg. J west locker corridor south attic	09163266	4-02 0057		
Heat Detector	Attic home economics East locker corridor north attic	09163288	4-02 0057		
Heat Detector	Attic home economics East locker corridor south attic	09163287	4-02 0057		
Heat Detector	Attic social science east locker corridor attic north	09163391	4-02 0057		
Heat Detector	.boys-shower-G8	09164085	5-02 0018	07/06-P	
Heat Detector	.heat BLDG. S 9D016 CLASSROOM 3 N/W	09163563	9-02 0016	07/14-P	09/15-P
Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N /E	09163569	9-02 0021	07/14-P	09/15-P
Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N /E	09163486	9-02 0021		
Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N /E	09163487	9-02 0021		
Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N /E	09163488	9-02 0021		
Heat Detector	: BUSINESS 5D011ROOM 8 SOUTH /WEST	09163587	5-02 0011		
Heat Detector	: BUSINESS 5D012ROOM 8 SOUTH /EAST	09163588	5-02 00126		
Heat Detector	: BUSINESS 5D013ROOM 8 NORTH /EAST	09163585	5-02 0013		
Heat Detector	: BUSINESS 5D019ROOM 7 SOUTH /EAST	09163601	5-02 0127		
Heat Detector	: BUSINESS 5D041ROOM 2 NORTH /EAST over duct	61237518	5-02 0041	07/14-P	
Heat Detector	: BUSINESS 5D041ROOM 2 NORTH	09163593	5-02 0041		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	/WEST : BUSINESS 5D043ROOM 2 SOUTH	09163595	5-02 0043		
Heat Detector	/EAST : BUSINESS 5D045BUSINESS	09163591	5-02 0045		
Heat Detector	MACHINE WEST : BUSINESS 5D046BUSINESS	09163592	5-02 0127		
Heat Detector	MACHINE EAST : Heat: BLDG. S 9D021	09163104	9-02 0021		
Heat Detector	CLASSROOM 4 N/E : Sc8 portable, S/W	3815888016	11-02 0063	07/13-P	09/15 Removed
Heat Detector	:PERFORMING ARTS10D044	09164466	10-02 0044		
Heat Detector	UNIFORM ROOM BLDG. S 9D002CLASSROOM 2 N/W	09163551	9-02 0002	07/14-P	09/15-P
Heat Detector	BLDG. S 9D003CLASSROOM 2 S/W	09163552	9-02 0003	07/14-P	09/15-P
Heat Detector	BLDG. S 9D006CLASSROOM 1 S/W	09163544	9-02 0006	07/14-P	09/15-P
Heat Detector	BLDG. S 9D012 CLASSROOM 2 N/E	09163550	9-02 0012	07/14-P	09/15-P
Heat Detector	BLDG. S 9D012 CLASSROOM s2	09163554	9-02 0004	07/14-P	09/15-P
Heat Detector	BLDG. S 9D014 CLASSROOM 3 S/E	09163561	9-02 0014	07/14-P	09/15-P
Heat Detector	BLDG. S 9D015 CLASSROOM 3 S/W	09163564	9-02 0015	07/14-P	09/15-P
Heat Detector	BLDG. S 9D017 CLASSROOM 3 N/E	09163562	9-02 0017	07/14-P	09/15-P
Heat Detector	BUSINESS 5D010ROOM 8 NORTH	09163586	5-02 0010		
Heat Detector	/WEST BUSINESS 5D042ROOM 2 NORTH	09163594	5-02 0042	07/13-P	09/15-P
Heat Detector	/EAST HEAT...: BLDG. S 9D016	09163101	9-02 0016	07/14-P	
Heat Detector	CLASSROOM 3 N/W				
Heat Detector	HEAT: SC7 center east	09164343	12-02 0047		
Heat Detector	HEAT: SC7 east	09164344	12-02 0047		
Heat Detector	HEAT: SC7 west	09164341	12-02 0047		
Heat Detector	HEAT: SC7 west south	09164342	12-02 0047		
Heat Detector	HEAT: 4D010 SHOP IA1 CNTR	3808417438	4-02 0009	07/14-P	09/16-P
Heat Detector	/EAST HEAT: 4D066 SHOPCLASSROOM 6	3808418367	4-02 0066	07/14-P	09/16-P
Heat Detector	ISSUE IA35 rm				
Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6	3808419340	4-02 0069	07/14-P	09/16-P
Heat Detector	N/E				
Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6	3808418145	4-02 0068		09/16-P
Heat Detector	S/E				
Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6	3808417728	4-02 0071		09/16-P
Heat Detector	S/W				
Heat Detector	HEAT: 4D070 SHOPCLASSROOM 6	3808418152	4-02 0070	07/14-P	09/16-P
Heat Detector	S/W				
Heat Detector	HEAT: 4D075 SHOPCLASSROOM 4	3964742382	4-02 0075	07/12-P	
	N/E				

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	HEAT: 4D077 SHOPCLASSROOM 4 S/W	3964716802	4-02 0077	07/12-P	09/16-F
Heat Detector	HEAT: BLDG. S 9D001STORAGE ROOM S13	09163103	9-02 0001		
Heat Detector	HEAT: BLDG. S 9D010DARKROOM s10 between S1 & S2	09163557	9-02 0010	07/14-P	09/15-P
Heat Detector	HEAT: BLDG. S 9D010DARKROOM C3 S10 inside S11	09163622	9-02 0010		
Heat Detector	HEAT: BLDG. S 9D011WORKROOM CLOSET next to Darkroom between S1 & S2	09163556	9-02 0011	07/14-P	09/15-P
Heat Detector	HEAT: BLDG. S 9D014 CLASSROOM 3 S/E	09163134	9-02 0014		
Heat Detector	HEAT: BLDG. S 9D015 CLASSROOM 3 S/W	09163100	9-02 0015		
Heat Detector	HEAT: BLDG. S 9D018 CLASSROOM 4 S/E	09163132	9-02 0018		
Heat Detector	HEAT: BLDG. S 9D022 STORAGE S9	09163131	9-02 0022		
Heat Detector	HEAT: BLDG. S 9D025 CLASSROOM 5 N/E	09163107	9-02 0025		
Heat Detector	HEAT: CAFETERIA D032 GIRLS M12	69506106	7-02 0032	07/14-P	09/15-P
Heat Detector	HEAT: CAFETERIA D040 BOYS M11	69506105	7-02 0040	07/14-P	09/15-P
Heat Detector	HEAT: ENGLISH 11D022 WEST ROOF ACCESS Locker Area closet between E2 and Girls Restroom	09163919	11-02 0022	07/14-P	09/15-P
Heat Detector	HEAT: GYM 12D047 TOWEL ROOM N43	69506109	12-02 0047	07/14-P	09/15-P
Heat Detector	HEAT: GYM 12D048 LAUNDRY (SOUTH ROOM)	69506107	12-02 0048	07/14-P	09/15-P
Heat Detector	HEAT: PERFORMING ARTSROOF ACCESS	69506108	10-02 0041	07/14-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D068 ROOM 4 SOUTH/EAST	09164291	11-02 0068	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D069 ROOM 4 SOUTH/WEST	09164292	11-02 0069	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D070 ROOM 5 SOUTH/EAST	09164261	11-02 0070	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D071 ROOM 5 SOUTH/WEST	09164263	11-02 0071	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D072 ROOM 6 SOUTH/EAST	09164270	11-02 0072	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D073 ROOM 6 SOUTH/WEST	09164272	11-02 0073	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D074 ROOM 6 NORTH/WEST	09164271	11-02 0074	07/13-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	HEAT: SCIENCE 11D075 ROOM 6 NORTH/EAST	09164264	11-02 0075	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D076 ROOM 5 NORTH/WEST	14226342	11-02 0076	07/14-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D077 ROOM 5 NORTH/EAST	09164290	11-02 0077	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D078 ROOM 4 NORTH/WEST	09164293	11-02 0078	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D079 ROOM 4 NORTH/EAST	09164294	11-02 0079	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D106 ROOM 3 NORTH/EAST	09164297	11-02 0106	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D107 ROOM 3 NORTH/WEST	09164296	11-02 0107	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D108 ROOM 2 NORTH/EAST	09164167	11-02 0108	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D109 ROOM 2 NORTH/WEST	09164166	11-02 0109	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D110 ROOM 1 NORTH/EAST	09164171	11-02 0110	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D111 ROOM 1 NORTH/WEST	09164170	11-02 0111	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D112 ROOM 1 SOUTH/WEST	09164173	11-02 0112	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D113 ROOM 1 SOUTH/EAST	09164172	11-02 0113	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D114 ROOM 2 SOUTH/WEST	09164169	11-02 0114	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D115 ROOM 2 SOUTH/EAST	09164168	11-02 0115	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D116 ROOM 3 SOUTH/WEST	09164165	11-02 0116	07/13-P	09/15-P
Heat Detector	HEAT: SCIENCE 11D117 ROOM 3 SOUTH/EAST	09164164	11-02 0117	07/13-P	09/15-P
Heat Detector	HEAT: shop IA #1 NE	75938209	4-02 0010		09/16-P
Heat Detector	HEAT: shop IA #1 SE	3808418404	4-02 0011		09/16-P
Heat Detector	HEAT: shop IA #1 South center	3808418190	4-02 0008		09/16-P
Heat Detector	HEAT: shop IA #1 South west	3808417681	4-02 0007		09/16-P
Heat Detector	HEAT: shop IA #1 north west	3808417612	4-02 0006		09/16-P
Heat Detector	HEAt....: BLDG. S 9D026 CLASSROOM 5 S/E	09163106	9-02 0026		
Heat Detector	HEat BLDG. S 9D020 CLASSROOM 4 N/W	09163102	9-02 0020		
Heat Detector	HEat: BLDG. S 9D023 CLASSROOM 5 S/W	09163110	9-02 0023		
Heat Detector	Heat: BLDG. S 9D017 CLASSROOM	09163133	9-02 0017		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	3 N/E				
Heat Detector	Heat: BLDG. S 9D019 CLASSROOM 4 S/W	09163105	9-02 0019		
Heat Detector	SMOKE: 4D016 SHOPCLASSROOM 3 WEST	3809861346	4-02 0016	07/12-P	09/16-P
Heat Detector	SMOKE: 4D017 SHOPCLASSROOM 3 WEST	3809862039	4-02 0017	07/12-P	09/16-P
Heat Detector	SMOKE: 4D018 SHOPCLASSROOM 3 EAST	3809861377	4-02 0018	07/12-P	09/16-P
Heat Detector	SMOKE: 4D019 SHOPCLASSROOM 3 EAST	3809875268	4-02 0019	07/12-P	09/16-P
Heat Detector	SMOKE: BLDG. S 9D007CLASSROOM 1 S/E	09163545	9-02 0007	07/14-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D008CLASSROOM 1 N/E	09163546	9-02 0008	07/14-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D009CLASSROOM 1 N/W	3808873739	9-02 0009	07/14-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D012 CLASSROOM s1	09163553	9-02 0012	07/14-P	09/15-F
Heat Detector	SMOKE: BLDG. S 9D018 CLASSROOM 4 S/E	09163568	9-02 0018	07/14-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D019 CLASSROOM 4 S/W	09163567	9-02 0019	07/06-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D020 CLASSROOM 4 N/W	09163566	9-02 0020	07/06-P	09/15-P
Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM 4 N/E	09163123	9-02 0021	07/15-P	
Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM 4 N/E	09163485	1-02 0021		
Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM s/w /E	09163126	9-02 0021	07/15-P	
Heat Detector	SMOKE: BUSINESS 5D018ROOM 7 SOUTH/WEST	09163600	5-02 0127		
Heat Detector	building -N-mens-staff-shower	09164080	5-02 0018	07/14-P	
Heat Detector	building N -gym-by G45- .girls locker shower l . l -girls locker room	09164235	5-02 0018	07/13-P	
Heat Detector	c26 kitchen by dry storage	09164023	7-02 0047	07/08-P	
Heat Detector	c26 kitchen by office	09164022	7-02 0047	07/08-P	
Heat Detector	c27 custodian	09164024	7-02 0047	07/14-F	
Heat Detector	english attic heat north west e11	09164213	9-02 0017		
Heat Detector	heat BUSINESS 5D020ROOM 7 NORTH/EAST	09163602	5-02 0127		
Heat Detector	heat BLDG. S 9D002CLASSROOM 2 N/W	09163625	9-02 0002		
Heat Detector	heat BLDG. S 9D003CLASSROOM 2 S/W	09163626	9-02 0003		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	heat BLDG. S 9D012 CLASSROOM 2 N/E	09163624	9-02 0012		
Heat Detector	heat BUSINESS 5D025ROOM 5 SOUTH/WEST	09163605	5-02 0128		
Heat Detector	heat BUSINESS 5D026ROOM 5 SOUTH/EAST	09163604	5-02 0128		
Heat Detector	heat BUSINESS 5D027ROOM 5 NORTH/EAST	09163607	5-02 0027		
Heat Detector	heat BUSINESS 5D029ROOM 4 SOUTH/WEST	09163610	5-02 0128		
Heat Detector	heat BUSINESS 5D031ROOM 4 NORTH/EAST	09163608	5-02 0128		
Heat Detector	heat BUSINESS 5D032ROOM 4 NORTH/WEST	09163609	5-02 0128		
Heat Detector	heat-shower-G31	09164224	9-02 0003	07/13-P	
Heat Detector	heat-shower-by G40-bldg N	09164229	9-02 0003	07/13-P	
Heat Detector	heat: BLDG. S 9D005WORKROOM S11 SOUTH	09163621	9-02 0005		
Heat Detector	heat: BLDG. S 9D006CLASSROOM 1 S/W	09163618	9-02 0006		
Heat Detector	heat: BLDG. S 9D007CLASSROOM 1 S/E	09163620	9-02 0007		
Heat Detector	heat: BLDG. S 9D008CLASSROOM 1 N/E	09163619	9-02 0008		
Heat Detector	heat: BLDG. S 9D008CLASSROOM s2 N/w	09163623	9-02 0008		
Heat Detector	heat: BLDG. S 9D009CLASSROOM 1 N/W	09163616	9-02 0009		
Heat Detector	heat: BLDG. S 9D013 OFFICE C5	09163135	9-02 0136		
Heat Detector	heat: BLDG. S 9D024 CLASSROOM 5 N/W	09163108	9-02 0024		
Heat Detector	heat: BUSINESS 5D021ROOM 7 NORTH/WEST	09163603	5-02 0127		
Heat Detector	heat: BUSINESS 5D028ROOM 5 NORTH/WEST	09163606	5-02 0128		
Heat Detector	heat: BUSINESS 5D030ROOM 4 SOUTH/EAST	09163611	5-02 0128		
Heat Detector	heat: PORTABLE SC7 NORTH/EAST	09164340	11-02 0064	07/13-P	09/15 Removed
Heat Detector	heat: PORTABLE SC7 NORTH /WEST	3815898503	11-02 0065		09/15 Removed
Heat Detector	heat: PORTABLE SC7 NORTH /WEST	3892078195	11-02 0067	07/13-P	09/15 Removed
Heat Detector	heat: PORTABLE SC7 SOUTH/EAST	09164337	11-02 0066	07/13-P	09/15 Removed
Heat Detector	heat: PORTABLE SC7 SOUTH	3815888054	11-02 0067	07/13-P	09/15

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	/WEST				Removed
Heat Detector	portable p14 north	09164258	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p15 north	09164180	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p15 south	09164181	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p16 east	09164183	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p16 west	09164182	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p17 east	09164185	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p17 west	09164184	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p18 east	09164187	12-02 0047	07/14-P	09/15 Removed
Heat Detector	portable p18 west	09164186	12-02 0047	07/14-P	09/15 Removed
Heat Detector	sc8 8 S/W	3815622429	11-02 0061	07/14-P	09/16-F
Heat Detector	sc8 8 n/w	3815898466	11-02 0060	07/14-P	09/16-F
Heat Detector	sc8 8 s/e	3815888351	11-02 0062	07/13-P	09/16-F
Heat Detector	servery C4 snack bar inside dry storage i	09164192	7-02 0047		
Heat Detector	servery C4 snack bar inside dry storage i	09164250	7-02 0047		
Heat Detector	servery c24 between ovens	09164019	7-02 0047	07/14-P	
Heat Detector	servery c25rollup door	09164020	7-02 0047	07/08-P	
Heat Detector	servery c26 kitchen by freezer	09164021	7-02 0047	07/14-P	
Heat Detector	servery c28 kitchen inside dry storage i	09164247	7-02 0047		
Heat Detector	Press Box North	75938191	14-02 0132		09/14-P
Heat Detector	Press Box center	75938190	14-02 0133		09/14-P
Heat Detector	Press Box south	75938192	14-02 0134		09/14-P
Heat Detector	B Bookroom (Access west of B21 Storage (in 4))	09163617	5-(unknown)	07/12-P	
Heat Detector	B North hall	20411027	5-02 0128	07/12-P	
Heat Detector	B19	61237509	5-(unknown)	07/12-P	09/13-P
Heat Detector	B21 Storage (in 4)	61237506	5-(unknown)	07/12-P	
Heat Detector	B3 SE	09163614	5-02 0128		
Heat Detector	B3 SW	09163615	5-02 0128		
Heat Detector	BLDG.H east hallway by ladies room	09157872	10-02 0075		
Heat Detector	BLDG.H east hallway by mens room	09157871	10-02 0075		
Heat Detector	BLDG.H east hallway by rm. IA8	09157873	10-02 0075		
Heat Detector	Business 6 East	09163598	5-02 0127		

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Business 6 West	09163597	5-02 0022		
Heat Detector	attic heat portable p1 south	09163890	5-02 0131		09/15 Removed
Heat Detector	mens locker office staff shower hallway	3808255481	5-02 0018	07/14-P	09/16-P
Heat Detector	. HEAT:portable sc8 center east	09164329	11-02 0130		09/15 Removed
Heat Detector	. HEAT:portable sc8 n/e	09164328	12-02 0047		09/15 Removed
Heat Detector	. HEAT:portable sc8 n/w	09164327	12-02 0047		09/15 Removed
Heat Detector	B3 NE	09163613	5-02 0128		
Heat Detector	Bldg. 0 Library center .row north	09163086	4-02 0057	07/14-P	
Heat Detector	Bldg. 0 Library center .row south	09163083	4-02 0057	07/14-P	
Heat Detector	Bldg. 0 Library center .row south /center	09163084	4-02 0057	07/14-P	
Heat Detector	Bldg. 0 Library textbook storage room L6 IN north storage rm	09163091	4-02 0057		
Heat Detector	Bldg. 0 Library textbook storage room L6 IN south storage rm	09163136	4-02 0057		
Heat Detector	Bldg. 0 Library textbook storage room L6 N/E	09163090	4-02 0057		
Heat Detector	Bldg. 0 Library textbook storage room L6 N/W	09163089	4-02 0057		
Heat Detector	Bldg. 0 Library textbook storage room L6 S/E	09163087	4-02 0057		
Heat Detector	Bldg. 0 Library textbook storage room L6 S/W	09163088	4-02 0057		
Heat Detector	Bldg. F Classroom SS1 N/W	09163293	3-02 0043	07/08-P	09/13-P
Heat Detector	Bldg. F west locker corridor north	09163381	4-02 0057		
Heat Detector	Bldg. F west locker corridor south	09163380	4-02 0057		
Heat Detector	Bldg. J Classroom HE3 N/E	09163219	2-02 0128	07/08-P	
Heat Detector	Bldg. J Classroom HE3 N/W	09163218	2-02 0128	07/08-P	
Heat Detector	Bldg. J Classroom HE3 storage S/W by exit	09163220	4-02 0057	07/08-P	
Heat Detector	Bldg. J Classroom HE3 storage north by exit	09163223	4-02 0057	07/14-P	09/16-P
Heat Detector	Bldg. J Classroom HE1 N/E	09163258	2-02 0128	07/08-P	
Heat Detector	Bldg. J Classroom HE1 N/W	09163259	4-02 0057	07/08-P	
Heat Detector	Bldg. J Classroom HE1 storage S/W	09163249	4-02 0057	07/08-P	09/13-P
Heat Detector	Bldg. J Classroom HE1 storage north	09163248	2-02 0020	07/08-P	09/16-P
Heat Detector	Bldg. J Classroom HE6 N/E eastside	09163237	2-02 0128	07/14-P	
Heat Detector	Bldg. J Classroom HE6 S/E eastside	09163236	2-02 0128	07/14-P	
Heat Detector	Bldg. J Classroom HE6 fire control panel rm N/W	09163246	4-02 0057	07/08-P	

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	Bldg. J Classroom HE6 storage East	09163247	2-02 0005	07/14-P	09/16-P
Heat Detector	Bldg. J custodian room HE15 inside Lounge area	09163235	4-02 0057	07/08-P	
Heat Detector	Southeast HEAT: SC1	09164302	12-02 0047		
Heat Detector	Southwest HEAT: SC2	09164306	12-02 0047		
Heat Detector	northeast center HEAT: SC5	09164321	12-02 0047		
Heat Detector	northeast center HEAT: SC4	09164324	12-02 0047		
Heat Detector	northeast. HEAT: SC5	09164313	12-02 0047		
Heat Detector	northheast center HEAT: SC6	09164315	12-02 0047		
Heat Detector	northheast. HEAT: SC4	09164312	12-02 0047		
Heat Detector	northheast. HEAT: SC6	09164316	12-02 0047		
Heat Detector	northwest HEAT: SC4	09164322	12-02 0047		
Heat Detector	northwest HEAT: SC5	09164319	12-02 0047		
Heat Detector	northwest HEAT: SC6	09164318	12-02 0047		
Heat Detector	northwest center HEAT: SC4	09164323	12-02 0047		
Heat Detector	northwest center HEAT: SC5	09164320	12-02 0047		
Heat Detector	northwest center HEAT: SC6	09164317	12-02 0047		
Heat Detector	portable sc8 center/ w WC west HEAT:	09164326	11-02 0130		09/15 Removed
Heat Detector	portable sc8 south East HEAT:	09164330	12-02 0047		09/15 Removed
Heat Detector	portable sc8 south west HEAT:	09164325	12-02 0047		09/15 Removed
Heat Detector	sguthwest HEAT: SC1	09164299	12-02 0047		
Heat Detector	south West center HEAT: SC3	09164308	12-02 0047		
Heat Detector	southWest HEAT: SC2	09164303	12-02 0047		
Heat Detector	southWest HEAT: SC3	09164307	12-02 0047		
Heat Detector	southeast center HEAT: SC1	09164301	12-02 0047		
Heat Detector	southeast center HEAT: SC2	09164305	12-02 0047		
Heat Detector	southeast center HEAT: SC3	09164309	12-02 0047		
Heat Detector	southeast. HEAT: SC3	09164310	12-02 0047		
Heat Detector	southwest center HEAT: SC1	09164300	12-02 0047		
Heat Detector	sovthWest center HEAT: SC2	09164304	12-02 0047		
Heat Detector	1st Floor T05 Attic southwest	75938152	16-02 0142		09/13-P
Heat Detector	1st Floor T06 Attic northwest	75938151	16-02 0140		09/13-P
Heat Detector	1st Floor T06 Attic southeast	75938150	16-02 0139		09/13-P
Heat Detector	1st Floor T07 Attic northwest	75938149	16-02 0138		09/13-P
Heat Detector	1st Floor T07 Attic southeast	75938148	16-02 0137		09/13-P
Heat Detector	1st Floor T102 Attic center	75938161	16-02 0151		09/13-P
Heat Detector	1st Floor T102 Attic east	75938160	16-02 0150		09/13-P
Heat Detector	1st Floor T102 Attic west	75938162	16-02 0152		09/13-P
Heat Detector	1st Floor T103 & 102 workroom Attic center	75938159	16-02 0149		09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Heat Detector	1st Floor T103 Attic center	75938156	16-02 0147		09/13-P
Heat Detector	1st Floor T103 Attic east	75938158	16-02 0147		09/13-P
Heat Detector	1st Floor T103 Attic west	75938157	16-02 0147		09/13-P
Heat Detector	1st Floor T104 Attic northwest	75938155	16-02 0145		09/13-P
Heat Detector	1st Floor T104 Attic southwest	75938154	16-02 0144		09/13-P
Heat Detector	1st Floor T105 Attic northwest	75938153	16-02 0143		09/13-P
Heat Detector	1st Floor T115 Attic northwest	75938147	16-02 0156		09/13-P
Heat Detector	1st Floor T115 Attic southeast	75938146	16-02 0155		09/13-P
Heat Detector	1st Floor T116 Attic northwest	75938145	16-02 0158		09/13-P
Heat Detector	1st Floor T116 Attic southeast	75938144	16-02 0157		09/13-P
Heat Detector	1st Floor T117 Attic Southeast	75938142	16-02 0159		09/13-P
Heat Detector	1st Floor T117 Attic northwest	75938143	16-02 0160		09/13-P
Heat Detector	1st Floor T118 Attic Northwest	75938141	16-02 0162		09/13-P
Heat Detector	1st Floor T118 Attic Southeast	75938140	16-02 0161		09/13-P
Heat Detector	1st floor elevator machine room	3828163964	16-02 0009		09/13-P
Heat Detector	2nd floor attic boys restroom by T215	75938207	16-02 0394		09/15-P
Heat Detector	2nd floor attic girls restroom by T215	75938206	16-02 0393		09/15-P
Heat Detector	2nd floor BLDG T Attic outside electrical rm	75938204	16-02 0424		09/15-P
Heat Detector	2nd floor BLDG T Attic outside of T207	75938203	16-02 0423		09/15-P
Heat Detector	Attic Hatch SMOKE: BUSINESS 5D024NORTH LOCKER CORRIDOR	09163599	5-02 0128		
Heat Detector	Attic Hatch B18 Storage (in B19) East	61237508	5-02 0127		
Heat Detector	Attic Hatch B18 Storage (in B19) West	61237507	5-02 0127		
Heat Detector	Attic Hatch Business South Hall East	09163589	5-02 0126		
Heat Detector	Attic Hatch Business South Hall West	09163590	5-02 0126		
Heat Detector	Attic Hatch Business South hall	61237504	5-02 0050	07/12-P	09/13-P
Device Total: 445 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Each of the detection principles present within the detector (e.g. smoke/heat/CO, etc.) shall be tested independently for the specific detection principle, regardless of the configuration status at the time of testing. Each detector shall be tested in accordance with the published manufacturer's instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14k))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Multi-Sensor Detector	58	57	1	58	58	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Multi-Sensor Detector	1st floor T101 Northeast		3110850411	16-02 0021		09/13-P
Multi-Sensor Detector	1st floor T101 Northwest		3110937709	16-02 0022		09/13-P
Multi-Sensor Detector	1st floor T101 Southeast		3111079170	16-02 0023		09/13-P
Multi-Sensor Detector	1st floor T101 Southwest		3110848616	16-02 0024		09/13-P
Multi-Sensor Detector	1st floor T102 North		3110849095	16-02 0019		09/13-P
Multi-Sensor Detector	1st floor T102 south		3110853672	16-02 0020		09/13-P
Multi-Sensor Detector	1st floor T103 Southeast		3110854563	16-02 0017		09/13-P
Multi-Sensor Detector	1st floor T103 Southwest		3110854358	16-02 0018		09/13-P
Multi-Sensor Detector	1st floor T103 northeast		3110851159	16-02 0015		09/13-P
Multi-Sensor Detector	1st floor T103 northwest		3110856574	16-02 0015		09/13-P
Multi-Sensor Detector	1st floor T104 north		3110846865	16-02 0013		09/13-P
Multi-Sensor Detector	1st floor T104 south		3110851883	16-02 0014		09/13-P
Multi-Sensor Detector	1st floor T105 north		3110849057	16-02 0011		09/13-P
Multi-Sensor Detector	1st floor T105 south		3110849132	16-02 0012		09/13-P
Multi-Sensor Detector	1st floor T106 north		3110848685	16-02 0007		09/13-P
Multi-Sensor Detector	1st floor T106 south		3110853023	16-02 0008		09/13-P
Multi-Sensor Detector	1st floor T107 north		3110854945	16-02 0005		09/13-P
Multi-Sensor Detector	1st floor T107 south		3110846957	16-02 0006		09/13-P
Multi-Sensor Detector	1st floor T115 east		3110857755	16-02 0028		09/13-P
Multi-Sensor Detector	1st floor T115 west		3110849484	16-02 0029		09/13-P
Multi-Sensor Detector	1st floor T116 east		3110846315	16-02 0030		09/13-P
Multi-Sensor Detector	1st floor T116 west		3110846780	16-02 0031		09/13-P
Multi-Sensor Detector	1st floor T117 east		3110854679	16-02 0032		09/13-P
Multi-Sensor Detector	1st floor T117 west		3110854617	16-02 0033		09/13-P
Multi-Sensor Detector	1st floor T118 West		3110850220	16-02 0035		09/13-P
Multi-Sensor Detector	1st floor T118 east		3110854877	16-02 0034		09/13-P
Multi-Sensor Detector	2nd floor IDF by T215		3931672841	16-02 0252		09/13-P
Multi-Sensor Detector	2nd floor T201 Northeast		3110854693	16-02 0269		09/13-P
Multi-Sensor Detector	2nd floor T201 Northwest		3110849415	16-02 0270		09/13-P
Multi-Sensor Detector	2nd floor T201 Southeast		3110851517	16-02 0271		09/13-P
Multi-Sensor Detector	2nd floor T201 Southwest		3110850329	16-02 0272		09/13-P
Multi-Sensor Detector	2nd floor T202 north		3111285465	16-02 0267		09/13-P
Multi-Sensor Detector	2nd floor T202 south		3106246150	16-02 0268		09/13-F
Multi-Sensor Detector	2nd floor T203 Northeast		3110850305	16-02 0263		09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Multi-Sensor Detector	2nd floor T203 Northwest	3110853795	16-02 0264		09/13-P
Multi-Sensor Detector	2nd floor T203 Southeast	3110855126	16-02 0265		09/13-P
Multi-Sensor Detector	2nd floor T203 Southwest	3110855171	16-02 0266		09/13-P
Multi-Sensor Detector	2nd floor T204 north	3110852286	16-02 0261		09/13-P
Multi-Sensor Detector	2nd floor T204 south	3110854907	16-02 0262		09/13-P
Multi-Sensor Detector	2nd floor T205 north	3110848425	16-02 0259		09/13-P
Multi-Sensor Detector	2nd floor T205 south	3110854198	16-02 0260		09/13-P
Multi-Sensor Detector	2nd floor T206 north	3110854396	16-02 0256		09/13-P
Multi-Sensor Detector	2nd floor T206 south	3110844328	16-02 0257		09/13-P
Multi-Sensor Detector	2nd floor T207 north	3110851081	16-02 0254		09/13-P
Multi-Sensor Detector	2nd floor T207 south	3110850299	16-02 0255		09/13-P
Multi-Sensor Detector	2nd floor T215 east	3110854730	16-02 0276		09/13-P
Multi-Sensor Detector	2nd floor T215 west	3110851227	16-02 0277		09/13-P
Multi-Sensor Detector	2nd floor T216 east	3110850114	16-02 0278		09/13-P
Multi-Sensor Detector	2nd floor T216 west	3110846896	16-02 0279		09/13-P
Multi-Sensor Detector	2nd floor T217 east	3110855133	16-02 0280		09/13-P
Multi-Sensor Detector	2nd floor T217 west	3110850206	16-02 0281		09/13-P
Multi-Sensor Detector	2nd floor T218 east	3110850169	16-02 0282		09/13-P
Multi-Sensor Detector	2nd floor T218 west	3110849729	16-02 0283		09/13-P
Multi-Sensor Detector	2nd floor boys restroom by T215	3931672568	16-02 0275		09/13-P
Multi-Sensor Detector	2nd floor electrical by T215	3931672261	16-02 0251		09/13-P
Multi-Sensor Detector	2nd floor girls restroom by T215	3931672834	16-02 0274		09/13-P
Multi-Sensor Detector	2nd floor janitor by T215	3931672124	16-02 0253		09/13-P
Multi-Sensor Detector	2nd floor staff restroom by T215	3931673053	16-02 0273		09/13-P
Device Total: 58 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Pull Station	22	22	0	22	22	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Pull Station	Lobby building L admin.main office near announcer		09163646	1-02 0128	07/14-P	09/16-P
Pull Station	Lobby multipurpose		09163949	5-02 0018	07/06-P	09/14-P
Pull Station	:PERFORMING ARTS10D054 S/E CORRIDOR		09164456	10-02 0054	07/06-P	09/14-P
Pull Station	C12 multipurpose		09163969	5-02 0018	07/06-P	09/14-P
Pull Station	Main Practice Gym		75938193	15-02 0128		09/14-P
Pull Station	Press Box		75938189	14-02 0131		09/14-P
Pull Station	double door-by .lobby-athletic director bldg. N-gym		09164160	5-02 0018	07/16-P	09/15-P
Pull Station	double door-lobby bldg. N-gym		09164153	5-02 0018	07/06-P	09/15-P
Pull Station	double door-north multipurpose		09163991	5-02 0018	07/06-P	09/14-P
Pull Station	Administration Counseling East		3953797799	1-02 0031	07/16-P	09/16-P
Pull Station	Bldg. 0 Inside library main entrance		09163152	6-02 0129	07/08-P	09/14-P
Pull Station	Bldg. 0 library north exit		09163172	4-02 0130	07/08-P	09/14-P
Pull Station	East :PERFORMING audience exit CORRIDOR		09164459	10-02 0054	07/06-P	09/14-P
Pull Station	East Lobby bldg. k .performing art		09164355	11-02 0117	07/06-P	09/14-P
Pull Station	West :PERFORMING audience exit CORRIDOR		09164458	10-02 0054	07/06-P	09/14-P
Pull Station	West Lobby bldg. k .performing art		09164353	11-02 0117	07/06-P	09/14-P
Pull Station	gym. center-east G1		09164196	5-02 0018	07/06-P	09/15-P
Pull Station	gym. east G1		09164199	5-02 0018	07/06-P	09/15-P
Pull Station	gym. southeast G1		09164200	5-02 0018	07/06-P	09/15-P
Pull Station	gym. southeast G1		09164198	5-02 0018	07/06-P	09/15-P
Pull Station	gym. southwest G1		09164202	5-02 0018	07/06-P	09/15-P
Pull Station	gym. west G1		09164254	5-02 0018	07/06-P	09/15-P
Device Total: 22 Return to Executive Summary						

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Smoke Detector	606	602	4	606	606	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Smoke Detector	:PERFORMING ARTS10D068 PRACTICE RM 10		09164443	10-02 0068	07/13-P	09/14-P
Smoke Detector	ADMIN 1D027COUNSELING WEST		09163677	1-02 0027	07/13-P	09/15-P
Smoke Detector	ADMIN 1D053MAIN ADMIN OFFICE		09163639	1-02 0053	07/13-P	09/15-P
Smoke Detector	ADMIN STORAGE A2		09163676	1-02 0028	07/14-P	09/16-P
Smoke Detector	ADMIN1D006ATTENDANCE WEST		09163707	1-02 0006	07/13-P	09/15-P
Smoke Detector	ADMIN1D007ATTENDANCE EAST		09163708	1-02 0007	07/13-P	09/15-P
Smoke Detector	CAFETERIA D021STUDENT DINING MIDDLEEAST		09163993	7-02 0021	07/13-P	09/15-P
Smoke Detector	CAFETERIA D022STUDENT DINING MIDDLEWEST		09163992	7-02 0022	07/13-P	09/15-P
Smoke Detector	CAFETERIA D038FACULTY DINING NORTH		09164028	7-02 0038	07/13-P	09/15-P
Smoke Detector	CAFETERIA D055BOILER ROOM M35		09164009	7-02 0055	07/13-P	09/15-P
Smoke Detector	CAFETERIAD025MAINT.. SHOP S		09164010	7-02 0025	07/13-P	09/15-P
Smoke Detector	ENGLISH boys room D028SOUTH /EAST		20411021	11-02 0027	07/06-P	09/16-P
Smoke Detector	GYM 12D034 WRESTLING NORTH /WEST		09164114	12-02 0034	07/13-P	09/15-P
Smoke Detector	GYM 12D036 WRESTLING SOUTH /CENTER/EAST		14227182	12-02 0072	07/13-P	09/15-P
Smoke Detector	GYM 12D036 WRESTLING SOUTH /CENTER/WEST		09164115	12-02 0036	07/13-P	09/15-P
Smoke Detector	GYM 12D040 DANCE SOUTH/WEST		09164149	12-02 0040	07/13-P	09/15-P
Smoke Detector	GYM 12D071WRESTLING CENTER /WEST		09164119	12-02 0071	07/13-P	09/15-P
Smoke Detector	GYM 12D072WRESTLING CENTER /EAST		09164140	12-02 0072	07/13-P	09/15-P
Smoke Detector	GYM boys locker restroom		20411025	12-02 0013	07/06-P	09/15-P
Smoke Detector	HEAT: 4D074 SHOPCLASSROOM 4 S/E		3964742405	4-02 0074	07/12-P	09/16-F
Smoke Detector	HEAT: 4D076 SHOPCLASSROOM 4 N/W		3964742528	4-02 0076	07/12-P	09/16-F

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	PERFORMING ARTS PA4 OFFICE	09164378	10-02 0016	07/06-P	09/14-P
Smoke Detector	PERFORMING ARTS10D005 COSTUME ROOM	09164415	10-02 0005	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D013 MAIN SPEECH RM N/W	09164384	10-02 0013	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D017 PA4 ROOM center storage	09164376	10-02 0017	07/06-P	09/14-P
Smoke Detector	PERFORMING ARTS10D020 MAIN SPEECH RM S/W	09164381	10-02 0020	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D036 SCENE SHOP N/E	09164396	10-02 0036	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D037 SCENE SHOP N/W	09164395	10-02 0037	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D038 SCENE SHOP S/W	09164394	10-02 0038	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D059 CHORAL RM N/E	09164460	10-02 0059	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D060 CHORAL NORTH	09164462	10-02 0060	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D062 CHORAL RM N/W	09164463	10-02 0062	07/13-P	09/15-P
Smoke Detector	PERFORMING ARTS10D063 CHORAL RM S/W	09164464	10-02 0063	07/13-P	09/15-P
Smoke Detector	PORTABLE P16 north	20411018	11-02 0096	07/13-P	09/15 Removed
Smoke Detector	SHOPCLASSROOM 2	3964743600	4-02 0014	07/14-P	09/13-P
Smoke Detector	SHOPSTORAGE ROOM 48	3953704469	4-02 0002	07/12-P	09/16-P
Smoke Detector	SMOKE ADMIN 1D024CHILD WELFARE OFFICE	09163710	1-02 0024	07/08-P	09/15-P
Smoke Detector	SMOKE: SHOPMAIN HALL (CENTER)	3953704858	4-02 0054	07/12-P	09/13-P
Smoke Detector	SMOKE: SHOPMAIN HALL (CENTER)	3953704179	4-02 0055	07/12-P	09/13-P
Smoke Detector	SMOKE: SHOPMAIN HALL (East)	3953703936	4-02 0056	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D001 SHOPFIRE PANEL ROOM	3953700478	4-02 0001	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D001 SHOPFIRE PANEL ROOM	20414658	4-02 0028	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D003 SHOPCLASSROOM 1 NORTH	3953700515	4-02 0003	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D004 SHOPCLASSROOM 1 TOOLS	3953701871	4-02 0004	07/13-P	09/16-P
Smoke Detector	SMOKE: 4D005 SHOPCLASSROOM 1 OFFICE	3953704360	4-02 0005	07/12-P	09/16-P
Smoke Detector	SMOKE: 4D020 SHOPCLASSROOM 3 N/E	3953711832	4-02 0020	07/12-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: 4D021 SHOPCLASSROOM 3 OFFICE	3953700546	4-02 0021	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D022 SHOPCLASSROOM 3 PARTS	3953711856	4-02 0022	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D023 SHOPCLASSROOM 3 STORAGE	3953703868	4-02 0023	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D024 SHOPCLASSROOM 2 STORAGE	3953711771	4-02 0024	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D025 SHOPCLASSROOM 2 NORTH	3953703875	4-02 0025	07/14-P	09/13-P
Smoke Detector	SMOKE: 4D026 SHOPCLASSROOM 2 OFFICE	3953701925	4-02 0026	07/14-P	09/13-P
Smoke Detector	SMOKE: 4D027 SHOPCLASSROOM 2 STORAGE	3953701024	4-02 0027	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D034 SHOPCLASSROOM 13 SUPPLY	3953711801	4-02 0034	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D035 SHOPCLASSROOM 13 SUPPLY	3953711665	4-02 0035	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D036 SHOPCLASSRM 13 W STORAGE	3953702762	4-02 0036	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D040 SHOPNORTH /WEST CORRIDOR	3953703219	4-02 0040	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D043 SHOPCLASSROOM 12 CENTER/E	3953700553	4-02 0043	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D044 SHOPCLASSROOM 12 CENTER/W	3953785178	4-02 0044	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D045 SHOPNORTH /WEST CORRIDOR	3953784997	4-02 0045	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D046 SHOPCLASSROOM 12 S/W	3953530259	4-02 0046	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D047 SHOPCLASSROOM 11 NORTH	3953784720	4-02 0047	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D049 SHOPCLASSROOM 10 SOUTH	3953704315	4-02 0049	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D050 SHOPCLASSROOM 11 SOUTH	3953704971	4-02 0050	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D051 SHOPCLASSROOM 12 STUDY RM	3953702809	4-02 0051	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D052 IA SHOPNORTH /WEST CORRIDOR	3953701055	4-02 0052	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D053 SHOPMAIN HALL (CENTER)	3953703035	4-02 0053	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D063 SHOPCLASSROOM 5 LIBRARY	3953575854	4-02 0063	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D064 SHOPEAST VESTIBULE	3953711719	4-02 0064	07/12-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: 4D065 SHOPCLASSROOM 6 OFFICE	3953702014	4-02 0065	07/14-P	09/13-P
Smoke Detector	SMOKE: 4D067 SHOPCLASSROOM 6 STORAGE	3953785314	4-02 0067	07/14-P	09/13-P
Smoke Detector	SMOKE: 4D072 SHOPCLASSROOM 5 NORTH	3953783976	4-02 0072	07/12-P	09/16-P
Smoke Detector	SMOKE: 4D073 SHOPCLASSROOM 5 SOUTH	3953783990	4-02 0073	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D078 SHOPMAIN HALL (EAST)	3953785406	4-02 0078	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D079 SHOPMAIN HALL (EAST)	3953784812	4-02 0079	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D086 SHOPN/E CORRIDOR	3953782054	4-02 0086	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D089 SHOPWOMENS RESTROOM	3953718398	4-02 0089	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D091 SHOP GIRLS' RESTROOM	3953735630	4-02 0091	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D092 SHOPCLASSRM. 10 PRINT DRY	3953799038	4-02 0092	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D093 SHOPROOM 10 DARKRM ENTRY	3953798826	4-02 0093	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D096 SHOPCLASSROOM 9 S/W	3953785000	4-02 0096	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D099 SHOPCLASSROOM 9 S/E	3953797607	4-02 0099	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D100 SHOPN/E CORRIDOR	3953797461	4-02 0100	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D101 SHOPN/E CORRIDOR	3953798444	4-02 0101	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D102 SHOPCLASSROOM 9 storage room	3953797522	4-02 0090	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D103 SHOPCLASSROOM 8 S/W	3953745141	4-02 0103	07/12-P	09/13-P
Smoke Detector	SMOKE: 4D104 SHOPCLASSROOM 8 S/E	3953721176	4-02 0104	07/12-P	09/13-P
Smoke Detector	SMOKE: ADMIN counselor A14	09163657	1-02 0038	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D001TELEPHONE ROOM 46	09163688	1-02 0001	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D002CUSTODIAN 35	09163689	1-02 0002	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D003DEANS OFFICE 34	09163717	1-02 0003	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D004CONFERENCE ROOM 33	09163714	1-02 0004	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D005DEANS	09163713	1-02 0005	07/08-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	OFFICE 32 SMOKE: ADMIN 1D009CUSTODIAN SUPPLY 40	09163691	1-02 0009	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D010CONFERENCE 39	09163720	1-02 0010	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D011WORK ROOM 38	09163705	1-02 0011	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D012FACULTY PREP 41 S/W	09163703	1-02 0012	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D013FACULTY PREP 41 N/W	09163701	1-02 0013	07/13-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D017FACULTY PREP 41 N/E	09163702	1-02 0017	07/13-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D018FACULTY PREP 41 S/E	09163704	1-02 0018	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D019MAIN HALL EAST	09163692	1-02 0019	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D020MAIN HALL CENTER	09163690	1-02 0020	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D021MAIN HALL CENTER	09163687	1-02 0021	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D022MAIN HALL WEST	09163684	1-02 0022	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D023MAIN HALL WEST CLOSET	09163686	1-02 0023	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D026REGISTRAR	09163674	1-02 0026	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D028COUNSELING CONFERENCE	09163673	1-02 0028	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D029COUNSEL 8	09163670	1-02 0029	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D030COUNSEL 9	09163669	1-02 0030	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D031COUNSELING EAST	09163678	1-02 0031	07/13-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D032GENERAL OFFICE N/W	09163682	1-02 0032	07/13-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D033 conferance rm A	09163665	1-02 0033	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D034COUNSEL 10	09163666	1-02 0034	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D035COUNSEL 11	09163658	1-02 0035	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D036COUNSEL HALL	09163663	1-02 0036	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D037COUNSEL 20	09163661	1-02 0037	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D039COUNSEL 12	09163654	1-02 0039	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D040LOUNGE 13	09163649	1-02 0040	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D041STORAGE A16	09163653	1-02 0041	07/08-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: ADMIN 1D042ELECTRICAL ROOM 45	3953799083	1-02 0042	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D043OUTSIDE ELEC. RM. 45	09163648	1-02 0043	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D044WOMENS ROOM 14	09163652	1-02 0044	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D047HALLWAY 17 STORAGE	09163637	1-02 0047	07/14-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D048HALLWAY 17 NORTH	09163628	1-02 0048	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN 1D051PRINCIPAL 28	09163644	1-2 51	07/14-P	09/16-P
Smoke Detector	SMOKE: ADMIN 1D052SECRETARY 27	09163643	1-02 0052	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN HALLWAY STORAGE A21	09163638	1-02 0047	07/08-P	09/16-P
Smoke Detector	SMOKE: ADMIN LOUNGE A28	09163696	5-02 0004	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN Vice Principle	09163633	1-02 0026	07/08-P	09/15-P
Smoke Detector	SMOKE: ADMIN WORKROOM A24	09163629	1-02 0048	07/08-P	09/16-P
Smoke Detector	SMOKE: BLDG. S 9D001STORAGE ROOM S13	09163560	9-02 0001	07/14-P	09/16-P
Smoke Detector	SMOKE: BLDG. S 9D005WORKROOM C2 SOUTH	09163548	9-02 0005	07/14-P	09/16-P
Smoke Detector	SMOKE: BLDG. S 9D013 OFFICE C5	09163559	9-02 0013	07/14-P	09/16-P
Smoke Detector	SMOKE: BLDG. S 9D022 STORAGE C9	09163571	9-02 0022	07/14-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D023 CLASSROOM 5 S/W	09163575	9-02 0023	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D024 CLASSROOM 5 N/W	09163574	9-02 0024	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D025 CLASSROOM 5 N/E	09163573	9-02 0025	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D026 CLASSROOM 5 S/E	09163572	9-02 0026	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D027 STORAGE S8	09163579	9-02 0027	07/14-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D028 STORAGE C12	09163578	9-02 0028	07/14-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D029 CLASSROOM 6 N/W	09163580	9-02 0029	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D030 CLASSROOM 6 N/E	09163583	9-02 0030	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D031 CLASSROOM 6 S/E	09163582	9-02 0031	07/06-P	09/14-P
Smoke Detector	SMOKE: BLDG. S 9D032 CLASSROOM 6 S/W	09163581	9-02 0032	07/14-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: BUSINESS 5D001CUSTODIAN B12	09163492	5-02 0001	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D003GIRLS Bathroom EAST	09163495	5-02 0003	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D003GIRLS bathroom	08851418	5-02 0003	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D004WEST WOMENS ROOM	08851417	5-02 0004	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D005ROOM 1 NORTH/WEST	08851414	5-02 0005	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D006ROOM 1 SOUTH/WEST	09163472	5-02 0006	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D007ROOM 1 SOUTH/EAST	08851416	5-02 0007	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D008ROOM 1 NORTH/EAST	08851415	5-02 0008	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D009STORAGE FOR DB 13 ROOM 1&8	09163473	5-02 0009	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D010ROOM B8 NORTH/WEST	09163475	5-02 0010	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D011ROOMB 8 SOUTH/WEST	09163476	5-02 0011	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D012ROOMB8 SOUTH/EAST	09163477	5-02 0012	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D013ROOMB8 NORTH/EAST	09163474	5-02 0013	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D016EAST MENS ROOM	09163539	5-02 0016	07/12-P	09/16-P
Smoke Detector	SMOKE: BUSINESS 5D017SOUTH LOCKER SOUTHWEST B17CORRIDOR	09163490	5-02 0017	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D018ROOM 7 SOUTH/WEST	09163533	5-02 0018	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D019ROOM 7 SOUTH/EAST	09163536	5-02 0019	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D020ROOM 7 NORTH/EAST	09163534	5-02 0020	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D021ROOM 7 NORTH/WEST	09163535	5-02 0021	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D022ROOM 6 WEST	09163530	5-02 0022	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D023ROOM 6 EAST	09163529	5-02 0023	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D024NORTH LOCKER CORRIDOR	09163507	5-02 0024	07/12-P	09/13-P
Smoke Detector	SMOKE: BUSINESS 5D025ROOM 5	09163528	5-02 0025	07/12-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SOUTH/WEST SMOKE: BUSINESS 5D026ROOM 5	09163525	5-02 0026	07/12-P	09/13-P
Smoke Detector	SOUTH/EAST SMOKE: BUSINESS 5D027ROOM 5	09163526	5-02 0027	07/12-P	09/13-P
Smoke Detector	NORTH/EAST SMOKE: BUSINESS 5D028ROOM 5	09163527	5-02 0028	07/12-P	09/13-P
Smoke Detector	NORTH/WEST SMOKE: BUSINESS 5D029ROOM 4	09163519	5-02 0029	07/12-P	09/13-P
Smoke Detector	SOUTH/WEST SMOKE: BUSINESS 5D030ROOM 4	09163520	5-02 0030	07/12-P	09/13-P
Smoke Detector	SOUTH/EAST SMOKE: BUSINESS 5D031ROOM 4	09163521	5-02 0031	07/12-P	09/13-P
Smoke Detector	NORTH/EAST SMOKE: BUSINESS 5D032ROOM 4	09163518	5-02 0032	07/12-P	09/13-P
Smoke Detector	NORTH/WEST SMOKE: BUSINESS 5D033ROOM 4	09163517	5-02 0033	07/12-P	09/13-P
Smoke Detector	STORAGE SMOKE: BUSINESS	09163515	5-02 0034	07/12-P	09/13-P
Smoke Detector	5D034BOOKSTORE SMOKE: BUSINESS 5D035ROOM 3	09163513	5-02 0035	07/12-P	09/13-P
Smoke Detector	NORTH/WEST SMOKE: BUSINESS 5D036ROOM 3	09163512	5-02 0036	07/12-P	09/13-P
Smoke Detector	NORTH/EAST SMOKE: BUSINESS 5D037ROOM 3	09163511	5-02 0037	07/12-P	09/13-P
Smoke Detector	SOUTH/EAST SMOKE: BUSINESS 5D038ROOM 3	09163510	5-02 0038	07/12-P	09/13-P
Smoke Detector	SOUTH/WEST SMOKE: BUSINESS 5D039NORTH	09163506	5-02 0039	07/12-P	09/13-P
Smoke Detector	LOCKER CORRIDOR SMOKE: BUSINESS 5D041ROOM 2	09163500	5-02 0041	07/12-P	09/13-P
Smoke Detector	NORTH/WEST SMOKE: BUSINESS 5D042ROOM 2	09163502	5-02 0042	07/12-P	09/13-P
Smoke Detector	NORTH/EAST SMOKE: BUSINESS 5D043ROOM 2	09163503	5-02 0043	07/12-P	09/13-P
Smoke Detector	SOUTH/EAST SMOKE: BUSINESS 5D044ROOM 2	09163501	5-02 0044	07/14-P	09/13-P
Smoke Detector	SOUTH/WEST SMOKE: BUSINESS	09163496	5-02 0045	07/12-P	09/13-P
Smoke Detector	5D045BUSINESS MACHINE WEST SMOKE: BUSINESS	09163497	5-02 0046	07/12-P	09/13-P
Smoke Detector	5D046BUSINESS MACHINE EAST SMOKE: BUSINESS 5D048WEST	09163494	5-02 0048	07/12-P	09/13-P
Smoke Detector	STORAGE ROOM SMOKE: BUSINESS 5D049SOUTH	09163489	5-02 0049	07/12-P	09/13-P
Smoke Detector	LOCKER B17westCORRIDOR SMOKE: CAFETERIA	09163983	7-02 0001	07/06-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	D001JANITOR M2				
Smoke Detector	SMOKE: CAFETERIA D005STUDENT DINING NORTH	09163986	7-02 0005	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D006STUDENT DINING NORTH	09163987	7-02 0006	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D007STUDENT DINING NORTH	09163988	7-02 0007	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D008STUDENT DINING NORTH	09163974	7-02 0008	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D009NORTH TRIANGLE ROOM	09163973	7-02 0009	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D010STUDENT CENTER N/W	09163985	7-02 0010	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D011STUDENT CENTER N/E	09163970	7-02 0011	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D012STUDENT CENTER MID/E	09163965	7-02 0012	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D017STUDENT CENTER S/E	09163958	7-02 0017	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D019STUDENT CENTER MID/W	09163968	7-02 0019	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D020STUDENT DINING MIDDLE	09163975	7-02 0020	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D023STUDENT DINING MIDDLE	09163981	7-02 0023	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D026STUDENT DINING SOUTH	09163999	7-02 0026	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D027STUDENT DINING SOUTH	09163979	7-02 0027	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D028STUDENT DINING SOUTH	09163978	7-02 0028	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D029STUDENT DINING SOUTH	09163976	7-02 0029	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D030EAST ENTRY WAY	09163950	7-02 0030	07/06-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D031GIRLS M12	09163952	7-02 0031	07/06-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D033RESTROOM ENTRY	09164063	7-02 0033	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D034MENS ROOM M15	09164031	7-02 0034	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D035WOMENS ROOM M16	09164032	7-02 0035	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D036FACULTY LOUNGE M18	09164027	7-02 0036	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA	09164026	7-02 0037	07/08-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	D037FACULTY DINING SOUTH SMOKE: CAFETERIA D039BOYS M11	09163955	7-02 0039	07/06-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D041SERVERY N/E	09163996	7-02 0041	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D042STORAGE M22	09163994	7-02 0042	07/06-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D043SERVERY N/W	09163997	7-02 0043	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D044SERVERY M25	09163998	7-02 0044	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D045CORRIDOR N/E M19	09164036	7-02 0045	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D046CORRIDOR S/E M19	09164025	7-02 0046	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D047CORRIDOR S/W M19	09164017	7-02 0047	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D048CORRIDOR N/W M19	09164035	7-02 0048	07/08-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D049JANITOR M26	09164018	7-02 0049	07/14-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D051TRASH ROOM M28	09164016	7-02 0051	07/14-P	09/16-P
Smoke Detector	SMOKE: CAFETERIA D053LOCKER M30	09164005	7-02 0053	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D054TOILET M28	09164008	7-02 0054	07/08-P	09/14-P
Smoke Detector	SMOKE: CAFETERIA D058STUDENT CNTR SUPPLY	09163984	7-02 0058	07/08-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D001FIRE PANEL ROOM	09163827	11-02 0001	07/13-P	09/16-P
Smoke Detector	SMOKE: ENGLISH 11D002ROOM 9 SOUTH/WEST	09163874	11-02 0002	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D003ROOM 9 NORTH/WEST	09163873	11-02 0003	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D004WEST LOCKER CORRIDOR	09163826	11-02 0004	07/13-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D005ROOM 10 SOUTH/EAST	09163881	11-02 0005	07/13-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D006ROOM 10 NORTH/EAST	09163878	11-02 0006	07/13-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D007ROOM 10 NORTH/WEST	09163879	11-02 0007	07/13-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D008ROOM 10 SOUTH/WEST	09163880	11-02 0008	07/13-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D009ROOM	09163885	11-02 0009	07/13-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	11 SOUTH/EAST SMOKE: ENGLISH 11D010ROOM	09163886	11-02 0010	07/13-P	09/14-P
Smoke Detector	11 NORTH/EAST SMOKE: ENGLISH 11D011ROOM	09163883	11-02 0011	07/06-P	09/14-P
Smoke Detector	11 NORTH/WEST SMOKE: ENGLISH 11D012ROOM	09163884	11-02 0012	07/13-P	09/14-P
Smoke Detector	11 SOUTH/WEST SMOKE: ENGLISH 11D013ROOM 1	09163817	11-02 0013	07/06-P	09/14-P
Smoke Detector	NORTH/WEST SMOKE: ENGLISH 11D014ROOM 1	09163814	11-02 0014	07/06-P	09/14-P
Smoke Detector	SOUTH/WEST SMOKE: ENGLISH 11D015ROOM 1	09163815	11-02 0015	07/06-P	09/14-P
Smoke Detector	SOUTH/EAST SMOKE: ENGLISH 11D016ROOM 1	09163816	11-02 0016	07/06-P	09/14-P
Smoke Detector	NORTH/EAST SMOKE: ENGLISH 11D017ROOM 2	09163821	11-02 0017	07/06-P	09/14-P
Smoke Detector	NORTH/WEST SMOKE: ENGLISH 11D018ROOM 2	09163822	11-02 0018	07/06-P	09/14-P
Smoke Detector	SOUTH/WEST SMOKE: ENGLISH 11D019ROOM 2	09163819	11-02 0019	07/06-P	09/14-P
Smoke Detector	SOUTH/EAST SMOKE: ENGLISH 11D020ROOM 2	09163820	11-02 0020	07/06-P	09/14-P
Smoke Detector	NORTH/EAST SMOKE: ENGLISH 11D021WEST	09163825	11-02 0021	07/13-P	09/16-P
Smoke Detector	LOCKER CORRIDOR SMOKE: ENGLISH 11D023SOUTH	09163830	11-02 0023	07/06-P	09/16-P
Smoke Detector	/WEST VESTIBULE SMOKE: ENGLISH 11D025SOUTH	09163832	11-02 0025	07/06-P	09/16-P
Smoke Detector	WOMENS ROOM SMOKE: ENGLISH 11D028SOUTH	09163837	11-02 0028	07/06-P	09/16-P
Smoke Detector	/EAST VESTIBULE SMOKE: ENGLISH 11D029ROOM 3	09163842	11-02 0029	07/06-P	09/14-P
Smoke Detector	SOUTH/WEST SMOKE: ENGLISH 11D030ROOM 3	09163841	11-02 0030	07/06-P	09/14-P
Smoke Detector	NORTH/WEST SMOKE: ENGLISH 11D031ROOM 3	09163840	11-02 0031	07/06-P	09/14-P
Smoke Detector	NORTH/EAST SMOKE: ENGLISH 11D032ROOM 3	09163839	11-02 0032	07/06-P	09/14-P
Smoke Detector	SOUTH/EAST SMOKE: ENGLISH 11D033EAST	09163846	11-02 0033	07/06-P	09/14-P
Smoke Detector	LOCKER CORRIDOR Workability room.				
Smoke Detector	SMOKE: ENGLISH 11D035ROOM 4	09163851	11-02 0035	07/06-P	09/14-P
Smoke Detector	NORTH/WEST SMOKE: ENGLISH 11D036ROOM 4	09163848	11-02 0036	07/06-P	09/14-P
	SOUTH/WEST				

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: ENGLISH 11D037ROOM 4 SOUTH/EAST	09163849	11-02 0037	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D038ROOM 4 NORTH/EAST	09163850	11-02 0038	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D039ROOM 5 NORTH/WEST	09163855	11-02 0039	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D040ROOM 5 SOUTH/WEST	09163856	11-02 0040	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D041ROOM 5 SOUTH/EAST	09163853	11-02 0041	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D042ROOM 5 NORTH/EAST	09163854	11-02 0042	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D043ROOM 6 SOUTH/EAST	09163861	11-02 0043	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D044ROOM 6 NORTH/EAST	09163858	11-02 0044	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D045ROOM 6 NORTH/WEST	09163859	11-02 0045	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D046ROOM 6 SOUTH/WEST	09163860	11-02 0046	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D047ROOM 7 SOUTH/EAST	09163865	11-02 0047	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D048ROOM 7 NORTH/EAST	09163866	11-02 0048	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D049ROOM 7 NORTH/WEST	09163863	11-02 0049	07/06-F	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D050ROOM 7 SOUTH/WEST	09163864	11-02 0050	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D051EAST LOCKER .CORRIDOR Workability room.	09163845	11-02 0051	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D052ROOM 8 NORTH/EAST	09163867	11-02 0052	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D053ROOM 8 SOUTH/EAST	09163871	11-02 0053	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D054ROOM 8 SOUTH/WEST	09163870	11-02 0054	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D055ROOM 8 NORTH/WEST	09163869	11-02 0055	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D056ROOM 9 NORTH/EAST	09163876	11-02 0056	07/06-P	09/14-P
Smoke Detector	SMOKE: ENGLISH 11D057ROOM 9 SOUTH/EAST	09163875	11-02 0057	07/06-P	09/14-P
Smoke Detector	SMOKE: GYM Girls Locker Room Entrance	09164245	12-02 0069	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D002 BOYS LOCKER MID/NORTH	69506028	12-02 0002	07/13-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: GYM 12D007 BOYS LOCKER N/W	69506030	12-02 0007	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D009 BOYS LOCKER S/E	69506029	12-02 0009	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D011 VESTIBULE N18	09164110	12-02 0011	07/13-P	09/16-P
Smoke Detector	SMOKE: GYM 12D015 INSTRUCTOR OFFICE N53	09164076	12-02 0015	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D017 FIRST AID N26	09164121	12-02 0017	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D018 TOILET N24	09164079	12-02 0018	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D020 BOYS LOCKER N/W	69506026	12-02 0020	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D021 BOYS LOCKER S/W	69506027	12-02 0021	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D022 BOYS LOCKER S/E	69506033	12-02 0022	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D023 BOYS LOCKER N/E	69506032	12-02 0023	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D024 CUSTODIAN N14	09164088	12-02 0024	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D025 VESTIBULE N13	09164111	12-02 0025	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D026 VESTIBULE N15	09164087	12-02 0026	07/13-P	09/16-P
Smoke Detector	SMOKE: GYM 12D031 LOBBY NORTH	09164150	12-02 0031	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D032 LOBBY SOUTH	09164151	12-02 0032	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D037 WRESTLING NORTH	09164118	12-02 0037	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D038 WRESTLING NORTH/EAST	09164117	12-02 0038	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D039 WRESTLING SOUTH/EAST	09164116	12-02 0039	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D041 DANCE NORTH/WEST	09164141	12-02 0041	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D042 DANCE NORTH/CENTER	09164142	12-02 0042	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D043 DANCE SOUTH/CENTER	09164147	12-02 0043	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D044 DANCE SOUTH/EAST	09164146	12-02 0044	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D045 DANCE NORTH/EAST	09164145	12-02 0045	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D050 GIRLS	09164228	12-02 0050	07/06-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	LOCKER WEST				
Smoke Detector	SMOKE: GYM 12D051 GIRLS LOCKER EAST	09164227	12-02 0051	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D052 GIRLS LOCKER EAST	09164226	12-02 0052	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D053 GIRLS LOCKER WEST	09164225	12-02 0053	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D054 TEACHING SPACE WEST	09164220	12-02 0054	07/13-P	09/16-P
Smoke Detector	SMOKE: GYM 12D055 TEACHING SPACE EAST	09164219	12-02 0055	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D060 CUSTODIAN	09164215	12-02 0060	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D061 GIRLS LOCKER W ENTRY	09164222	12-02 0061	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D062 GIRLS LOCKER WEST	09164230	12-02 0062	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D063 GIRLS LOCKER EAST	09164231	12-02 0063	07/06-P	09/15-P
Smoke Detector	SMOKE: GYM 12D065 INSTRUCTOR OFFICE N53	09164237	12-02 0065	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D067 DRESSING AREA N50	09164240	12-02 0067	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D068 TOILET N49	09164243	12-02 0068	07/06-P	09/16-P
Smoke Detector	SMOKE: GYM 12D073DANCE CENTER/EAST	09164148	12-02 0073	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM 12D074DANCE CENTER/WEST	09164143	12-02 0074	07/13-P	09/15-P
Smoke Detector	SMOKE: GYM BOYS LOCKER MID /NORTH	69506031	12-02 0008	07/13-P	09/15-P
Smoke Detector	SMOKE: PORTABLE P11 EAST	20414659	11-02 0084	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P11 WEST	09164045	11-02 0085	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P12 EAST	09164048	11-02 0086	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P12 WEST	09164047	11-02 0087	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P13 EAST	09164051	11-02 0088	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P13 WEST	09164050	11-02 0089	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P14 EAST	09164054	11-02 0090	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P14 EAST	3926414456	11-02 0091	07/13-P	09/15 Removed
Smoke Detector	SMOKE: PORTABLE P14 WEST	09164053	11-02 0091	07/13-P	09/15

Device Type	Location	ScanID	Address	Q3/21	Q3/22
					Removed
Smoke Detector	SMOKE: PORTABLE P15 EAST	09164057	11-02 0092	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P15 WEST	09164056	11-02 0093	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P16 E	3974405239	11-2 96	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P16 W	20411019	11-2 97	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P17 E	09164062	11-02 0099	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P17 E	09164064	11-02 0098	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P17 NORTH	09164060	11-02 0096	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P19 EAST	09163812	5-gbc h nb 2 0051	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P19 WEST	09163811	5-02 0052	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P20 EAST	09163809	5-02 0053	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P20 WEST	09163808	5-02 0054	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P21 EAST	09163806	5-02 0055	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P21 WEST	3926329118	5-02 0056	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P22 EAST	09163802	5-02 0057	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P22 WEST	09163801	5-02 0058	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P23 EAST	09163800	5-02 0059	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P23 WEST	09163742	5-02 0060	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P24 EAST	09163740	5-02 0061	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P24 WEST	09163739	5-02 0062	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P25 EAST	09163735	5-02 0069	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P25 WEST	09163736	5-02 0070	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P26 EAST	09163733	5-02 0067	07/13-P	09/15
					Removed
Smoke Detector	SMOKE: PORTABLE P27 EAST	09163729	5-02 0065	07/13-P	09/15

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	SMOKE: PORTABLE P27 WEST	09163730	5-02 0066	07/13-P	Removed 09/15
Smoke Detector	SMOKE: SCIENCE 11D080UTILITY /ELEC. ROOM east of sc4	09164260	11-02 0080	07/13-P	Removed 09/16-P
Smoke Detector	SMOKE: SCIENCE 11D081RESOURCE ROOM	09164267	11-02 0081	07/13-P	09/16-P
Smoke Detector	SMOKE: SCIENCE 11D082RESOURCE ROOM	09164257	11-02 0082	07/13-P	09/16-P
Smoke Detector	SMOKE: SCIENCE 11D083RESOURCE ROOM	09164266	11-02 0083	07/13-P	09/16-P
Smoke Detector	SMOKE: SCIENCE 11D104RESOURCE ROOM	09164269	11-02 0104	07/13-P	09/16-P
Smoke Detector	SMOKE:PERFORMING ARTS10D001 HALL(GREEN RM)	09164402	10-02 0001	07/14-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D002 N/W CORRIDOR	09164386	10-02 0002	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D003 N/W OFFICE	09164416	10-02 0003	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D004 ELECTRICAL RM.	09164390	10-02 0004	07/14-P	09/16-P
Smoke Detector	SMOKE:PERFORMING ARTS10D006 GIRLS DRESSING	09164411	10-02 0006	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D007 N/W WOMENS RM	09164409	10-02 0007	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D008 N/W MENS ROOM	09164407	10-02 0008	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D009 BOYS DRESSING	09164405	10-02 0009	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D010 MAKE-UP ROOM	09164404	10-02 0010	07/14-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D011 GREEN ROOM	09164388	10-02 0011	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D014 MAIN SPEECH RM	09164383	10-02 0014	07/14-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D015 SPEECH ROOM	09164379	10-02 0015	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D018 SPEECH ROOM	09164373	10-02 0018	07/14-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D019 MAIN SPEECH RM	09164382	10-02 0019	07/14-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D021 N/E CORRIDOR	09164372	10-02 0021	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING ARTS10D021 N/E CORRIDOR	3980643304	10-02 0021	07/06-P	09/14-P
Smoke Detector	SMOKE:PERFORMING	09164369	10-02 0022	07/14-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	ARTS10D022 N/E VESTIBULE SMOKE:PERFORMING	09164365	10-02 0024	07/06-P	09/14-P
Smoke Detector	ARTS10D024 N/E WOMENS RM SMOKE:PERFORMING	09164363	10-02 0025	07/06-P	09/14-P
Smoke Detector	ARTS10D025 N/E MENS ROOM SMOKE:PERFORMING	09164368	10-02 0026	07/06-P	09/14-P
Smoke Detector	ARTS10D026 N/E CORRIDOR SMOKE:PERFORMING	09164356	10-02 0027	07/13-P	09/14-P
Smoke Detector	ARTS10D027 FRONT LOBBY SMOKE:PERFORMING	09164357	10-02 0028	07/13-P	09/14-P
Smoke Detector	ARTS10D028 TICKET BOOTH SMOKE:PERFORMING	09164358	10-02 0029	07/13-P	09/16-P
Smoke Detector	ARTS10D029 CONTROL ENTRY SMOKE:PERFORMING	09164360	10-02 0030	07/13-P	09/14-P
Smoke Detector	ARTS10D030 CONTROL ROOM SMOKE:PERFORMING	69506040	10-02 0031	07/14-P	09/15-P
Smoke Detector	ARTS10D031 AUDITORIUM N/E SMOKE:PERFORMING	69506046	10-02 0040	07/14-P	09/15-P
Smoke Detector	ARTS10D040 SCENE STORAGE SMOKE:PERFORMING	69506045	10-02 0042	07/14-P	09/15-P
Smoke Detector	ARTS10D042 SCENE RM STAIR SMOKE:PERFORMING	09164422	10-02 0044	07/13-P	09/16-P
Smoke Detector	ARTS10D044 UNIFORM ROOM SMOKE:PERFORMING	09164417	10-02 0045	07/13-P	09/16-P
Smoke Detector	ARTS10D045 PLATFORM RM. SMOKE:PERFORMING	09164418	10-02 0046	07/13-P	09/16-P
Smoke Detector	ARTS10D046 PLATFORM RM. SMOKE:PERFORMING	09164350	10-02 0053	07/06-P	09/14-P
Smoke Detector	ARTS10D053 FRONT LOBBY SMOKE:PERFORMING	09164455	10-02 0054	07/13-P	09/14-P
Smoke Detector	ARTS10D054 S/E CORRIDOR SMOKE:PERFORMING	09164452	10-02 0055	07/06-P	09/14-P
Smoke Detector	ARTS10D055 CHORAL STORAGE SMOKE:PERFORMING	09164451	10-02 0056	07/13-P	09/14-P
Smoke Detector	ARTS10D056 CHORAL OFFICE SMOKE:PERFORMING	09164450	10-02 0057	07/06-P	09/14-P
Smoke Detector	ARTS10D057 MUSIC PREP SMOKE:PERFORMING	09164461	10-02 0058	07/13-P	09/15-P
Smoke Detector	ARTS10D058 CHORAL RM S/E SMOKE:PERFORMING	09164453	10-02 0061	07/13-P	09/14-P
Smoke Detector	ARTS10D061 SOUTH CORRIDOR SMOKE:PERFORMING	09164436	10-02 0064	07/13-P	09/16-P
Smoke Detector	ARTS10D064 PRACTICE RM 6 SMOKE:PERFORMING	09164437	10-02 0065	07/13-P	09/14-P
Smoke Detector	ARTS10D065 PRACTICE RM 7 SMOKE:PERFORMING	09164439	10-02 0066	07/06-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	ARTS10D066 PRACTICE RM 8 SMOKE:PERFORMING	09164442	10-02 0067	07/06-P	09/14-P
Smoke Detector	ARTS10D067 PRACTICE RM 9 SMOKE:PERFORMING	09164445	10-02 0069	07/13-P	09/14-P
Smoke Detector	ARTS10D069 ENSEMBLE SMOKE:PERFORMING	69506048	10-02 0069	07/14-P	09/15-P
Smoke Detector	ARTS10D069 ENSEMBLE SMOKE:PERFORMING	09164425	10-02 0070	07/06-P	09/14-P
Smoke Detector	ARTS10D070 SOUTH CORRIDOR SMOKE:PERFORMING	09164429	10-02 0071	07/13-P	09/15-P
Smoke Detector	ARTS10D071 BAND RM. N/E SMOKE:PERFORMING	09164428	10-02 0072	07/13-P	09/15-P
Smoke Detector	ARTS10D072 BAND RM. S/E SMOKE:PERFORMING	09164427	10-02 0073	07/13-P	09/15-P
Smoke Detector	ARTS10D073 BAND RM. S/W SMOKE:PERFORMING	09164426	10-02 0074	07/13-P	09/15-P
Smoke Detector	ARTS10D074 BAND RM. N/W SMOKE:PERFORMING	09164423	10-02 0075	07/06-P	09/14-P
Smoke Detector	ARTS10D075 SOUTH CORRIDOR SMOKE:PERFORMING	09164432	10-02 0076	07/06-P	09/14-P
Smoke Detector	ARTS10D076 INSTRUMENT RM. SMOKE:PERFORMING	09164433	10-02 0077	07/13-P	09/14-P
Smoke Detector	ARTS10D077 BAND RM OFFICE SMOKE:PERFORMING	09164434	10-02 0078	07/06-P	09/14-P
Smoke Detector	ARTS10D078 MUSIC STORAGE SMOKE:PERFORMING	09164435	10-02 0079	07/06-P	09/14-P
Smoke Detector	ARTS10D079 BAND STORAGE SMOKE:PERFORMING	69506041	10-02 0080	07/14-P	09/15-P
Smoke Detector	ARTS10D080 SCENE SHOP SMOKE:PERFORMING	09164413	10-02 0082	07/06-P	09/16-P
Smoke Detector	ARTS10D082 COSTUME STORAG Smoke: 4D012 SHOPCLASSROOM	3964741569	4-02 0012	07/14-P	09/13-P
Smoke Detector	2 WEST Smoke: 4D013 SHOPCLASSROOM	3964741378	4-02 0013	07/14-P	09/13-P
Smoke Detector	2 WEST Smoke: 4D014 SHOPCLASSROOM	3964742221	4-02 0014	07/14-P	09/13-P
Smoke Detector	2 EAST girls locker restroom	20411024	12-02 0059	07/06-P	09/15-P
Smoke Detector	gym-bldg-N-east	09164071	5-02 0006	07/13-P	09/15-P
Smoke Detector	Main Practice Gym Storage	3931672988	15-02 0003		09/14-P
Smoke Detector	P.E Classroom north center	3931673503	15-02 0018		09/14-P
Smoke Detector	P.E Classroom northeast	3931672810	15-02 0019		09/14-P
Smoke Detector	P.E Classroom northwest	3931672063	15-02 0015		09/14-P
Smoke Detector	P.E Classroom south center	3931672001	15-02 0017		09/14-P
Smoke Detector	P.E Classroom southeast	3931672162	15-02 0016		09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	P.E Classroom southwest	3931672018	15-02 0014		09/14-P
Smoke Detector	P.E Classroom storage	3931671974	15-02 0002		09/14-P
Smoke Detector	Practice Gym Fire Riser	3931672780	15-02 0024		09/14-P
Smoke Detector	Practice Gym IDF	3931672513	15-02 0013		09/14-P
Smoke Detector	Practice Gym Lobby East	3931672483	15-02 0020		09/14-P
Smoke Detector	Practice Gym Lobby Mens Restroom	3931672735	15-02 0007		09/14-P
Smoke Detector	Practice Gym Lobby West	3931673770	15-02 0004		09/14-P
Smoke Detector	Practice Gym Lobby janitor	3931681621	15-02 0021		09/14-P
Smoke Detector	Practice Gym Lobby staff restroom	3931673848	15-02 0022		09/14-P
Smoke Detector	Practice Gym Lobby women restroom	3931673534	15-02 0006		09/14-P
Smoke Detector	Practice Gym Team Room 1 North	3930793264	15-02 00031		09/14-P
Smoke Detector	Practice Gym Team Room 1 South	3930792533	15-02 00032		09/14-P
Smoke Detector	Practice Gym Team Room 1 Storage	3930781582	15-02 00030		09/14-P
Smoke Detector	Practice Gym Team Room 2 South	3931672797	15-02 00025		09/14-P
Smoke Detector	Practice Gym Team room 2 storage	3931673527	15-02 00027		09/14-P
Smoke Detector	Practice Gym electrical room	3931681942	15-02 0001		09/14-P
Smoke Detector	Practice Gym Concessions	3930791819	15-02 0029		09/14-P
Smoke Detector	Practice Gym Outside Mens restroom North	3931672278	15-02 0012		09/14-P
Smoke Detector	Practice Gym Outside Mens restroom South	3931673589	15-02 0008		09/14-P
Smoke Detector	Practice Gym Outside Staff Restroom south	3931673411	15-02 0011		09/14-P
Smoke Detector	Practice Gym Outside Womens Restroom North	3931681843	15-02 0010		09/14-P
Smoke Detector	Practice Gym Outside Womens Restroom south	3931673565	15-02 0009		09/14-P
Smoke Detector	Practice Gym Tickets	3931682543	15-02 0028		09/14-P
Smoke Detector	Practice Gym lobby for team room 1	3931672971	15-02 0005		09/14-P
Smoke Detector	Practice Gym lobby for team room 2	3931673480	15-02 0023		09/14-P
Smoke Detector	Practice Gym team room 2 North	3931681904	15-02 0025		09/14-P
Smoke Detector	Press Box Center	3933165273	14-02 0002		09/14-P
Smoke Detector	Press Box North	3933163033	14-02 0001		09/14-P
Smoke Detector	Press Box South	3933389495	14-02 0003		09/14-P
Smoke Detector	second 2 of 2 SMOKE: PERFORMING ARTS10D080 SCENE SHOP	69506042	10-02 0080	07/14-P	09/15-P
Smoke Detector	Shop Main Hall Near room IA21	3953703073	4-02 0029	07/12-P	09/13-P
Smoke Detector	Shop Main Hall West exit	3953703905	4-02 0030	07/12-P	09/13-P
Smoke Detector	BLDG.K performing arts auditorium N /E .	14227194	10-02 0032	07/13-P	09/15-P
Smoke Detector	BLDG.K performing arts auditorium N /W .	14227193	10-02 0050	07/13-P	09/15-P
Smoke Detector	BLDG.K performing arts auditorium S	14227196	10-02 0031	07/13-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	/E .				
Smoke Detector	BLDG.K performing arts auditorium S	14227195	10-02 0051	07/13-P	09/15-P
Smoke Detector	/W .				
Smoke Detector	BLDG.K performing arts platform E	09164279	4-02 0053	07/13-P	09/15-P
Smoke Detector	/CENTER .				
Smoke Detector	BLDG.K performing arts platform N/E	09164280	4-02 0053	07/13-P	09/15-P
Smoke Detector	.				
Smoke Detector	BLDG.K performing arts platform N	09164277	4-02 0053	07/13-P	09/15-P
Smoke Detector	/W .				
Smoke Detector	BLDG.K performing arts platform S/E	09164278	4-02 0053	07/13-P	09/15-P
Smoke Detector	.				
Smoke Detector	BLDG.K performing arts platform S	09164281	4-02 0053	07/13-P	09/15-P
Smoke Detector	/W .				
Smoke Detector	BLDG.K performing arts platform W	09164282	4-02 0053	07/13-P	09/15-P
Smoke Detector	/CENTER .				
Smoke Detector	Bldg. 0 Classroom MC2 N/W	09163198	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Classroom MC2 S/W	09163199	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Eastside Center/W	09163194	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Eastside N/E	09163196	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Eastside N/W	09163193	4-02 0057	07/16-P	09/15-P
Smoke Detector	Bldg. 0 Library Eastside S/E	09163197	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Eastside S/W	09163195	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Westside N/E	09163190	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Westside N/W	09163189	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Westside S/E	09163192	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library Westside S/W	09163191	4-02 0057	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Library center .row north	09163163	6-02 0030	07/08-P	09/14-P
Smoke Detector	Bldg. 0 Library center .row north	09163162	1-02 0029	07/08-P	09/14-P
Smoke Detector	/center				
Smoke Detector	Bldg. 0 Library center .row south	09163161	6-02 0003	07/08-P	09/16-P
Smoke Detector	/center				
Smoke Detector	Bldg. 0 Library north office L4	09163165	4-02 0057	07/13-P	09/14-P
Smoke Detector	Bldg. 0 Library office L10 inside	09163156	6-02 0008	07/08-P	09/14-P
Smoke Detector	workroom L9				
Smoke Detector	Bldg. 0 Library storage L11	09163142	6-02 0011	07/08-P	09/14-P
Smoke Detector	Bldg. 0 Library textbook storage	09163168	6-02 0031	07/08-P	09/16-P
Smoke Detector	room L6 N/E				
Smoke Detector	Bldg. 0 Library textbook storage	09163169	6-02 0032	07/08-P	09/14-P
Smoke Detector	room L6 N/W				
Smoke Detector	Bldg. 0 Library textbook storage	09163167	6-02 0036	07/08-P	09/16-P
Smoke Detector	room L6 S/E				
Smoke Detector	Bldg. 0 Library textbook storage	09163166	6-02 0035	07/08-P	09/14-P
Smoke Detector	room L6 S/W				
Smoke Detector	Bldg. 0 Library work experience	09163159	6-02 0013	07/08-P	09/14-P
Smoke Detector	office L14				

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	Bldg. 0 Library workroom L9 east	09163154	6-02 0007	07/13-P	09/14-P
Smoke Detector	Bldg. 0 Library workroom L9 west	09163155	6-02 0006	07/08-P	09/14-P
Smoke Detector	Bldg. 0 custodian room L16	09163185	6-02 0015	07/08-P	09/16-P
Smoke Detector	Bldg. 0 Classroom MC2 N/E	69506034	6-02 0023	07/13-P	09/15-P
Smoke Detector	Bldg. 0 Classroom MC2 S/E	09163176	6-02 0020	07/08-P	09/16-P
Smoke Detector	Bldg. 0 Library textbook storage room L6 south storage	09163171	6-02 0034	07/08-P	09/14-P
Smoke Detector	Bldg. 0 Library in main entrance	09163181	6-02 0010	07/08-P	09/14-P
Smoke Detector	Bldg. 0 girls restroom by custodian room L16	09163182	6-02 0014	07/08-P	09/16-P
Smoke Detector	Bldg. 0 insideClassroom MC2 workroom center	69506036	6-02 0025	07/13-P	09/15-P
Smoke Detector	Bldg. 0 insideClassroom MC2 workroom east	69506035	6-02 0024	07/13-P	09/15-P
Smoke Detector	Bldg. 0 insideClassroom MC2 workroom west	69506037	6-02 0026	07/13-P	09/15-P
Smoke Detector	Bldg. F bySS8 boys Restroom-north	09163351	3-02 0020	07/08-P	09/13-P
Smoke Detector	Bldg. F bySS8 boys Restroom-south	09163350	3-02 0027	07/08-P	09/13-P
Smoke Detector	Bldg. F bySS8 girls Restroom-north	09163340	3-02 0023	07/08-P	09/13-P
Smoke Detector	Bldg. F bySS8 girls Restroom-south	09163342	3-02 0024	07/08-P	09/13-P
Smoke Detector	Bldg. F bySS8 mens Restroom-south	09163346	3-02 0026	07/08-P	09/13-P
Smoke Detector	Bldg. F bySS8 women Restroom-south	09163343	3-02 0025	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS1 N/E	09163294	3-02 0046	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS1 S/E	09163295	3-02 0045	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS1 S/W	09163296	3-02 0044	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS2 N/E	09163299	3-02 0050	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS2 N/W	09163302	3-02 0047	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS2 S/E	09163300	3-02 0049	07/08-P	09/13-P
Smoke Detector	Bldg. F Classroom SS2 S/W	09163301	3-02 0048	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS10 N/E	09163360	3-02 0036	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS10 N/W	09163359	3-02 0037	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS10 S/E	09163357	3-02 0035	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS10 S/W	09163358	3-02 0038	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS11 N/E	09163363	3-02 0040	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS11 N/W	09163366	3-02 0042	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS11 S/E	09163364	3-02 0039	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS11 S/W	09163365	3-02 0042	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS3 N/E	09163309	3-02 0054	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS3 N/W	09163308	3-02 0053	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS3 S/E	09163310	3-02 0055	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS3 S/W	09163311	3-02 0052	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS4 N/E	09163315	3-02 0002	07/08-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	Bldg. F classroom SS4 N/W	09163314	3-02 0057	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS4 S/E	09163312	3-02 0003	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS4 S/W	09163313	3-02 0056	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS5 N/E	09163325	3-02 0008	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS5 N/W	09163326	3-02 0005	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS5 S/E	09163324	3-02 0007	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS5 S/W	09163323	3-02 0006	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS6 N/E	09163330	3-02 0009	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS6 N/W	09163329	3-02 0012	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS6 S/E	09163331	3-02 0010	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS6 S/W	09163332	3-02 0011	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS7 N/E	09163337	3-02 0014	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS7 N/W	09163334	3-02 0015	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS7 S/E	09163336	3-02 0013	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS7 S/W	09163335	3-02 0016	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS8 N/E	09163368	3-02 0018	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS8 N/W	09163367	3-02 0019	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS8 S/E	09163369	3-02 0020	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS8 S/W	09163370	3-02 0017	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS9 N/E	09163355	3-02 0029	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS9 N/W	09163354	3-02 0032	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS9 S/E	09163356	3-02 0030	07/08-P	09/13-P
Smoke Detector	Bldg. F classroom SS9 S/W	09163353	3-02 0031	07/08-P	09/13-P
Smoke Detector	Bldg. F east locker corridor custodian room SS19	09163322	3-02 0001	07/08-P	09/13-P
Smoke Detector	Bldg. F east locker corridor north	09163319	3-02 0021	07/08-P	09/13-P
Smoke Detector	Bldg. F east locker corridor south	09163318	3-02 0004	07/08-P	09/13-P
Smoke Detector	Bldg. F west locker corridor north	09163304	3-02 0033	07/08-P	09/13-P
Smoke Detector	Bldg. F west locker corridor south	09163303	3-02 0051	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE3 N/E by washer and dryer area	09163213	2-02 0031	07/08-P	09/16-P
Smoke Detector	Bldg. J Classroom HE3 N/W by clock	09163214	2-02 0026	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE3 S/E by exit door	09163212	2-02 0029	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE3 S/W by ironing board area	09163215	2-02 0025	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE3 storage S/E by exit	09163222	2-02 0027	07/08-P	09/16-P
Smoke Detector	Bldg. J Classroom HE3 storage S/W by exit	09163221	2-02 0020	07/14-P	09/16-P
Smoke Detector	Bldg. J Classroom HE4 east	09163210	2-02 0036	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE4 west	09163211	2-02 0035	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE5 east	09163207	2-02 0037	07/08-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	Bldg. J Classroom HE5 west	09163206	2-02 0038	07/08-P	09/13-P
Smoke Detector	Bldg. J East locker corridor north	09163202	2-02 0032	07/08-P	09/13-P
Smoke Detector	Bldg. J East locker corridor south	09163203	2-02 0034	07/08-P	09/13-P
Smoke Detector	Bldg. J Lounge area between restrooms	09163228	2-02 0012	07/08-P	09/13-P
Smoke Detector	Bldg. J Lounge area mens restroom	09163230	2-02 0013	07/08-P	09/13-P
Smoke Detector	Bldg. J Lounge area womens restroom	09163229	2-02 0014	07/08-P	09/13-P
Smoke Detector	Bldg. J Lounge room east	09163225	2-02 0024	07/08-P	09/13-P
Smoke Detector	Bldg. J Lounge room west	09163224	2-02 0009	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 N/E	09163254	2-02 0015	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 N/W	09163253	2-02 0021	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 S/E	09163255	2-02 0016	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 S/W by exit	09163252	2-02 0019	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 storage S/E	09163251	2-02 0017	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE1 storage S/W	09163250	2-02 0018	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE6 N/E	09163240	2-02 0006	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE6 N/W by exit	09163241	2-02 0004	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE6 S/E	09163239	2-02 0008	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE6 S/W	09163242	2-02 0007	07/08-P	09/13-P
Smoke Detector	Bldg. J Classroom HE6 storage N/W	09163245	2-02 0003	07/08-P	09/16-P
Smoke Detector	Bldg. J Classroom HE6 storage S/W	09163244	2-02 0002	07/08-P	09/13-P
Smoke Detector	Bldg. J custodian room HE15 inside Lounge area	09163234	2-02 0011	07/08-P	09/16-P
Smoke Detector	Bldg. J office HE16 inside Lounge area	09163233	2-02 0010	07/08-P	09/13-P
Smoke Detector	Bldg. J water heater room outside by classroom HE6	09163264	2-02 0001	07/14-P	09/16-P
Smoke Detector	Bldg. J west locker corridor north	09163261	2-02 0023	07/12-P	09/13-P
Smoke Detector	Bldg. J west locker corridor south	09163260	2-02 0022	07/08-P	09/13-P
Smoke Detector	Bldg.D Locker east cordor-north	09163444	8-02 0005	07/13-P	09/16-P
Smoke Detector	Bldg.D Locker east cordor-sout.h	09163445	8-02 0035	07/13-P	09/16-P
Smoke Detector	Bldg.D Locker west cordor-north	09163418	8-02 0019	07/12-P	09/13-P
Smoke Detector	Bldg.D Locker west cordor-south	09163419	8-02 0021	07/12-P	09/16-P
Smoke Detector	Bldg.D classroom center office	09163427	8-02 0026	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M1 N/E	09163414	8-02 0011	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M1 N/W	09163415	8-02 0012	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M1 S./W	09163416	8-02 0013	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M1 S/E	09163417	8-02 0018	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M13 in M5	09163464	8-02 0038	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M16 electrical rm. inside M4	09163455	8-02 0001	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M17 storage	09163453	8-02 0002	07/13-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Smoke Detector	Bldg.D classroom M2 N/E	09163426	8-02 0009	07/12-P	09/15-P
Smoke Detector	Bldg.D classroom M2 N/W	09163423	8-02 0010	07/12-P	09/16-P
Smoke Detector	Bldg.D classroom M2 S/E	09163425	8-02 0025	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M2 S/W	09163424	8-02 0024	07/12-P	09/16-P
Smoke Detector	Bldg.D classroom M3 N/W	09163442	8-02 0032	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M4 break area	09163450	8-02 0003	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M4 north	09163451	8-02 0004	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M4 south	09163452	8-02 0041	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M5 computer lab	09163461	8-02 0037	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M5 north	09163460	8-02 0036	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M5 south	09163459	8-02 0040	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M6 N/E	09163435	8-02 0033	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M6 N/E	09163443	8-02 0031	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M6 S/E	09163436	8-02 0034	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M6 S/W	09163437	8-02 0029	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M6 S/W	09163434	8-02 0030	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M6 S/W	09163440	8-02 0007	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M7 N/E	09163433	4-02 0027	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M7 S/E	09163432	8-02 0028	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M7 S/W	09163431	8-02 0022	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M7. N/W	09163430	8-02 0023	07/12-P	09/13-P
Smoke Detector	Bldg.D classroom M8 N/E	09163468	8-02 0017	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M8 N/W	09163469	8-02 0014	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M8 S/E	3996415810	8-2 16	07/13-P	09/13-P
Smoke Detector	Bldg.D classroom M8 S/W	3955350732	8-2 14	07/13-P	09/13-P
Smoke Detector	Bldg.D storage M14 in M5	09163465	8-02 0039	07/13-P	09/13-P
Smoke Detector	North building -p18	3953760274	11-02 0100	07/13-P	09/15-F
Smoke Detector	Northwest SMOKE: ADMIN 1D032GENERAL OFFICE	09163681	1-02 0032	07/08-P	09/15-P
Smoke Detector	South ENGLISH girls restroom	20411020	11-02 0024	07/06-P	09/16-P
Smoke Detector	South building -p18	3953757373	11-02 0101	07/13-P	09/15-F
Smoke Detector	West :PERFORMING audience coatroom	09164351	10-02 0052	07/14-P	09/14-P
Smoke Detector	1st floor IDF by T115	3931672070	16-02 0003		09/13-P
Smoke Detector	1st floor boys restroom next to T115	3931672100	16-02 0027		09/13-P
Smoke Detector	1st floor electrical by T115	3931672827	16-02 0002		09/13-P
Smoke Detector	1st floor elevator machine room	3931682178	16-02 0010		09/13-P
Smoke Detector	1st floor fire riser by T115	3931671882	16-02 0001		09/13-P
Smoke Detector	1st floor girls restroom by T115	3931653666	16-02 0026		09/13-P
Smoke Detector	1st floor girls restroom by T115	75938127	16-02 0026		09/13-P
Smoke Detector	1st floor janitor by T115	3931681492	16-02 0004		09/13-P
Smoke Detector	1st floor staff restroom by T115	3931673862	16-02 0025		09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5					
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))							
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Bell		2	1	1	2	2	
Device Type	Location		ScanID		Address	Q3/21	Q3/22
Bell	Practice Gym Fire Riser		75938188		15		09/14-F
Bell	1st floor fire riser		75938124		16		09/13-P
Device Total: 2		Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Horn	40	38	2	40	40	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Horn	: .outside -multipurpose-north		09164039	5-02 0006	07/06-P	09/16-P
Horn	: .outside -multipurpose-south		09164038	5-02 0006	07/16-P	09/16-P
Horn	: .outside -p11		09164040	5-02 0006	07/13-P	09/15-F
Horn	: .outside -p19		09164065	5-02 0006	07/16-P	09/15-F
Horn	: OUTSIDE maint. storage-C35		09164042	5-02 0006	07/16-P	09/16-P
Horn	: BUSINESS 5D006 CLASS B20 OUTSIDE		09163505	5-02 0006	07/12-P	09/13-P
Horn	: BUSINESS 5D006 CLASS B6 OUTSIDE		09163532	5-02 0006	07/12-P	09/13-P
Horn	: BUSINESS 5D006 CLASS s1 OUTSIDE		09163558	5-02 0006	07/14-P	09/16-P
Horn	: BUSINESS 5D006 CLASS s6 OUTSIDE		09163577	5-02 0006	07/16-P	09/16-P
Horn	building L admin outside north		09163723	5-02 0018	07/16-P	09/16-P
Horn	building L admin outside south		09163722	5-02 0018	07/16-P	09/16-P
Horn	building L admin outside south		45709322	5-2 18	07/16-P	09/16-P
Horn	g37-laundry/ storage		09164191	9-02 0017	07/16-P	09/15-P
Horn	gym-bldg-N-.outside-lobby		09164073	5-02 0006	07/06-P	09/15-P
Horn	gym-bldg-N-.outside-west		09164074	5-02 0006	07/16-P	09/16-P
Horn	gym-bldg-N-east		14226390	5-02 0006	07/13-P	09/15-P
Horn	gym-bldg-N-south		09164072	5-02 0006	07/16-P	09/16-P
Horn	.outside multipurpose-eastside		09163948	5-02 0006	07/16-P	09/16-P
Horn	BLDG.H outside classroom IA12		09163797	10-02 0075	07/12-P	09/16-P
Horn	BLDG.H outside classroom IA14		09163795	10-02 0075	07/16-P	09/16-P
Horn	BLDG.H outside classroom IA3		09163796	10-02 0075	07/12-P	09/16-P
Horn	BLDG.H East outside IA8		09163798	10-02 0075	07/16-P	09/16-P
Horn	english north		09163887	5-02 0018	07/06-P	09/16-P
Horn	english south		09163888	5-02 0018	07/06-P	09/14-P
Horn	new science bldg.-between SC2 and SC1		09164298	5-02 0018	07/16-P	09/16-P
Horn	new science bldg.-outside back sc8		09164347	5-02 0018	07/13-P	09/16-P
Horn	new science bldg.-outside front sc8		09164345	5-02 0018	07/13-P	09/16-P
Horn	portables outside p10		09163725	5-02 0018	07/13-P	09/15 Removed

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn	portables outside p3	09163724	5-02 0018	07/16-P	09/15 Removed
Horn	Bldg. O Outside Classroom MC2	09163186	4-02 0057	07/16-P	09/16-P
Horn	Bldg. O Outside Library north entrance	09163187	4-02 0057	07/16-P	09/14-P
Horn	Bldg. O Outside library main entrance	09163150	4-02 0057	07/08-P	09/16-P
Horn	Bldg. F outside classroom SS4	09163317	4-02 0057	07/08-P	09/13-P
Horn	Bldg. F outside classroom SS7	09163338	4-02 0057	07/08-P	09/13-P
Horn	Bldg. J Outside East by locker side	09163201	4-02 0057	07/16-P	09/16-P
Horn	Bldg. J Outside West by locker side	09163200	4-02 0057	07/16-P	09/16-P
Horn	Bldg.D outside east	09163466	4-02 0057	07/16-P	09/16-P
Horn	Bldg.D outside west	09163412	4-02 0057	07/13-P	09/16-P
Horn	East outside building k	09164349	5-02 0018	07/13-P	09/16-P
Horn	North outside building k	09164348	5-02 0018	07/06-P	09/16-P
Horn	Northeast outside gym	09164070	5-02 0006	07/16-P	09/15-P
Horn	West outside building k	09164346	5-02 0018	07/16-P	09/16-P
Device Total: 40 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18. Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Horn/Strobe	315	306	9	315	315	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Horn/Strobe	2nd West lighting control room bldg. k .performing art		09164359	11-02 0117	07/06-P	09/14-P
Horn/Strobe	-boys-locker-outside-G24		09164128	5-02 0018	07/06-P	09/16-P
Horn/Strobe	-boys-locker-outside-G24-north shower		09164126	5-02 0018	07/13-P	09/16-P
Horn/Strobe	-boys-locker-outside-G24-north shower		09164127	5-02 0018	07/14-P	09/16-P
Horn/Strobe	-boys-locker-outside-G28		09164113	5-02 0018	07/06-P	09/16-P
Horn/Strobe	-boys-locker-team room-G27-east		09164129	5-02 0018	07/16-P	09/16-P
Horn/Strobe	-boys-locker-team room-G27-west		09164134	5-02 0018	07/16-P	09/16-P
Horn/Strobe	-wrestling room-G28-		09164136	5-02 0018	07/06-P	09/16-P
Horn/Strobe	.:PERFORMING ARTS10D064 PRACTICE RM 6		09164457	10-02 0064	07/16-P	09/16-P
Horn/Strobe	.boys-shower-G8		09164084	5-02 0018	07/16-P	09/16-P
Horn/Strobe	.sc1		09164163	11-02 0117	07/13-P	09/16-P
Horn/Strobe	.sc3		09164295	11-02 0117	07/13-P	09/16-P
Horn/Strobe	: BUSINESS 5D006 CLASS B2		09163504	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 CLASS B20		09163499	5-02 0006	07/12-P	09/13-P
Horn/Strobe	: BUSINESS 5D006 NORTH LOCKER CORIdor east .		09163509	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 NORTH LOCKER CORIdor west .		09163508	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 b5 class .		09163524	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 bookstore .		09163516	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 class b3 .		09163514	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 mens room .		09163538	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 room .b4 n/w .		09163523	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 room .b4 s/w .		09163522	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006 room b5 .		09163531	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006GIRLG SROOM		08851420	5-02 0006	07/12-P	09/13-P
Horn/Strobe	: BUSINESS 5D006ROOM B 1 WEST		08851419	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006ROOM B 17NORTHWEST		09163493	5-02 0006	07/12-P	09/15-P
Horn/Strobe	: BUSINESS 5D006ROOM B 17SOUTHWEST		09163491	5-02 0006	07/12-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	: BUSINESS 5D006ROOM B 8 WEST	09163478	5-02 0006	07/12-P	09/13-P
Horn/Strobe	: BUSINESS 5D006ROOM GIRLS REST ROOM BY TOILET	09163484	5-02 0006	07/12-P	09/13-P
Horn/Strobe	:PERFORMING ARTS10D007 N/W WOMENS RM	09164410	10-02 0007	07/06-P	09/16-P
Horn/Strobe	:PERFORMING ARTS10D008 N/W MENS ROOM	09164408	10-02 0008	07/06-P	09/16-P
Horn/Strobe	:PERFORMING ARTS10D009 BOYS DRESSING	09164406	10-02 0009	07/06-P	09/16-P
Horn/Strobe	:PERFORMING ARTS10D025 N/E MENS ROOM	09164364	10-02 0025	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D025 N/E womens ROOM	09164366	10-02 0025	07/06-P	09/16-P
Horn/Strobe	:PERFORMING ARTS10D025 N/E womens outsi.de ROOM	09164367	10-02 0025	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D065 PRACTICE RM 7	09164438	10-02 0065	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D066 PRACTICE RM 8	09164440	10-02 0066	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D068 PRACTICE RM 10	09164444	10-02 0068	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D075 SOUTH CORRIDOR	09164424	10-02 0075	07/06-P	09/14-P
Horn/Strobe	:PERFORMING ARTS10D082 COSTUME STORAG	09164414	10-02 0082	07/16-P	09/14-P
Horn/Strobe	Gym Wrestling Room	14226374	5-02 0018	07/06-P	09/16-P
Horn/Strobe	PERFORMING ARTS10D001 HALL (GREEN RM)	09164403	10-02 0001	07/06-P	09/16-P
Horn/Strobe	PERFORMING ARTS10D002 N/W CORRIDOR	09164387	10-02 0002	07/06-P	09/16-P
Horn/Strobe	PERFORMING ARTS10D011 GREEN ROOM	09164389	10-02 0011	07/06-P	09/14-P
Horn/Strobe	PERFORMING ARTS10D022 N/E VESTIBULE	09164370	10-02 0022	07/06-P	09/14-P
Horn/Strobe	PERFORMING ARTS10D040 SCENE STORAGE	09164397	10-02 0040	07/13-P	09/15-P
Horn/Strobe	PERFORMING ARTS10D061 SOUTH CORRIDOR	09164454	10-02 0061	07/13-P	09/14-P
Horn/Strobe	SCIENCE RESOURCE ROOM	09164259	11-.	07/16-P	09/16-P
Horn/Strobe	SCIENCE RESOURCE ROOM	14227180	11-02 0082	07/16-P	09/16-P
Horn/Strobe	SMOKE: BUSINESS 5D0 s s 11 storageroom	09163549	5-02 0018	07/14-P	09/14-P
Horn/Strobe	SMOKE: BUSINESS 5D0 s s s2	09163555	5-02 0018	07/14-P	09/15-P
Horn/Strobe	SMOKE: BUSINESS 5D0 s s s4	09163570	5-02 0018	07/06-P	09/15-P
Horn/Strobe	SMOKE: BUSINESS 5D0 s s s5	09163576	5-02 0018	07/06-P	09/14-P
Horn/Strobe	SMOKE: BUSINESS 5D0 s s s6	09163584	5-02 0018	07/14-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	SMOKE: BUSINESS 5D0 s3	09163565	5-02 0018	07/14-P	09/15-P
Horn/Strobe	SMOKE: BUSINESS 5D004WEST WOMENS ROOM	09163790	5-02 0004	07/12-P	09/13-P
Horn/Strobe	SMOKE: SCIENCE-west 11D104RESOURCE ROOM	09164268	11-.	07/13-P	09/16-P
Horn/Strobe	SMOKE:PERFORMING ARTS10D006 GIRLS DRESSING	09164412	10-02 0006	07/06-P	09/16-P
Horn/Strobe	SMOKE:PERFORMING ARTS10D067 PRACTICE RM 9	09164441	10-02 0067	07/06-P	09/14-P
Horn/Strobe	between restroom-lobby -	09164157	5-02 0018	07/06-P	09/15-P
Horn/Strobe	boys-locker first aide	14227184	5-02 0018	07/06-P	09/16-P
Horn/Strobe	boys-locker-outside-custodial-G11	09164086	5-02 0018	07/06-P	09/16-P
Horn/Strobe	boys-locker-outside-office	09164094	5-02 0018	07/06-P	09/16-P
Horn/Strobe	boys-locker-outside-office N	14227183	5-02 0018	07/06-P	09/16-P
Horn/Strobe	boys-locker-restroom	09164089	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building -multipurpose-inside G4- . snack bar . l -girls locker room	09164252	5-02 0018	07/06-P	09/14-P
Horn/Strobe	building gym.-inside dancer room-g29 -inside G4- .snack bar . l -girls locker room	09164256	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building -N-mens-staff-shower	09164077	5-02 0018	07/14-P	09/16-P
Horn/Strobe	building -N-mens-staff-shower-restroom	09164078	5-02 0018	07/06-P	09/15-P
Horn/Strobe	building -N-outside-office-G17	09164075	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building -multipurpse-C18 mens restroom	09164033	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C18 staff dining-north	09164029	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C18 staff dining-north	09164030	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C18 womens restroom	09164034	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building -multipurpse-C21 kitchen	09164015	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C26 kitchen-east	09164002	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building -multipurpse-C26 kitchen-restroom	09164006	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C26 kitchen-restroom inside	09164007	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building -multipurpse-C26 kitchen-roll up door	09164004	5-02 0018	07/08-P	09/14-P
Horn/Strobe	building -multipurpse-C35 maint.	09164014	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building -multipurpse-C35 maint. - restroom	09164013	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building -p11	09164041	5-02 0018	07/16-P	09/15-F

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	building -p12	09164046	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p13	09164049	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p14	09164052	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p15	09164055	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p16	09164058	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p17	09164061	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p18	09164066	5-02 0018	07/13-P	09/15-F
Horn/Strobe	building -p19	09164067	5-02 0018	07/16-P	09/15-F
Horn/Strobe	building L admin assistant principal a38	09163712	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin assistant principal a39	09163715	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin assistant principal a40	09163716	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin conference room a	09163664	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin conference room a33	09163721	5-02 0018	07/16-P	09/15-P
Horn/Strobe	building L admin conference room b	09163672	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counseling room west	09163679	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a10	09163667	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a11	09163660	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a12	09163659	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a14	09163656	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a15	09163655	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a6	09163671	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin counselor a7	09163668	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin duplicating room a8	09163680	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin hall west boys restroom	09163694	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building L admin hall west girls restroom	09163698	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin hall west lounge room a28	09163699	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin hall west north	09163685	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin hall west north outside registrar	14227181	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building L admin hall west south	09163693	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin hallway near counselor a10	09163662	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin intake office a31	09163700	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building L admin nurse a32	09163706	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin registan a3	09163675	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin storage a37	09163719	5-02 0018	07/08-P	09/16-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	building L admin student services	09163709	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building L admin teacher prep room a13	09163683	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin welfare office	09163711	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin. main office east wall	09163640	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin. main office southwest wall	09163642	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin. in work room a24	09163630	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building L admin. mens restroom	09163631	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin. nearwork room a24	09163627	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin. principal a26	09163645	5-02 0018	07/08-P	09/16-P
Horn/Strobe	building L admin. vice prin a25	09163635	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin.girls restroom	09163651	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building L admin.lounge 17	09163650	5-02 0018	07/08-P	09/15-P
Horn/Strobe	building N -gym outside - .girls locker l . l -girls locker room	09164244	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-by G31 -girls locker room	09164217	5-02 0018	07/13-P	09/16-P
Horn/Strobe	building N -gym-by G45- .girls locker shower l . l -girls locker room	09164236	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-by exit and .girls locker restroom l . l -girls locker room	09164221	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-by exit and .girls locker shower l . l -girls locker room	09164223	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-by exit inside g46 l . l -girls locker room	09164233	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building N -gym-by exit outside g45 l . l -girls locker room	09164234	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-inside G45- .girls locker l . l -girls locker room	09164238	5-02 0018	07/16-P	09/16-P
Horn/Strobe	building N -gym-inside G45- . womens staff locker l . l -girls locker room	09164241	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-inside G45- . womens staff toilet l . l -girls locker room	09164242	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-restroom -girls	09164214	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building N -gym-west	09164201	5-02 0018	07/06-P	09/16-P
Horn/Strobe	building h class ia1	09164470	4-02 0064	07/12-P	09/13-P
Horn/Strobe	building h class ia1 north wall	09164472	4-02 0064	07/16-P	09/16-P
Horn/Strobe	building h class in hallway	09164471	4-02 0064	07/12-P	09/13-P
Horn/Strobe	east-dancer room-G28-	09164138	5-02 0018	07/13-P	09/16-P
Horn/Strobe	kitchen servin.g area S kitchen	09164037	5-02 0018	07/08-P	09/16-P
Horn/Strobe	kitchen servin.g area by freezer kitchen	14227188	5-02 0018	07/08-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	kitchen serving area W	09163995	5-02 0018	07/08-P	09/16-P
Horn/Strobe	kitchen serving area middle wall	09164000	5-02 0018	07/08-P	09/16-P
Horn/Strobe	mens restroom-lobby -	09164158	5-02 0018	07/16-P	09/16-P
Horn/Strobe	mens restroom-lobby -	09164156	5-02 0018	07/16-P	09/16-P
Horn/Strobe	outside-boys-locker--G11	09164112	5-02 0018	07/06-P	09/16-P
Horn/Strobe	outside-boys-locker-boiler room-G25-	09164135	5-02 0018	07/16-P	09/16-P
Horn/Strobe	portable sc7	09164336	11-.	07/13-P	09/15 Removed
Horn/Strobe	portable sc8	09164335	11-.	07/13-P	09/15 Removed
Horn/Strobe	sc2	09164273	11-02 0117	07/13-P	09/16-P
Horn/Strobe	sc4	09164274	11-02 0117	07/13-P	09/16-P
Horn/Strobe	sc5	09164275	11-02 0117	07/13-P	09/16-P
Horn/Strobe	sc6	09164276	11-02 0117	07/13-P	09/16-P
Horn/Strobe	stage east	14227185	10-02 0082	07/16-P	09/16-P
Horn/Strobe	stage west	09164419	10-02 0082	07/16-P	09/14-P
Horn/Strobe	west-dancer room-G28-	09164137	5-02 0018	07/13-P	09/16-P
Horn/Strobe	double door-by .lobby-athletic director bldg. N-gym	09164161	5-02 0018	07/16-P	09/15-P
Horn/Strobe	prop room PERFORMING ARTS10D001 HALL(GREEN RM)	09164400	10-02 0001	07/16-P	09/14-P
Horn/Strobe	BLDG.H .boys restroom	09163775	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA10	09163777	10-02 0075	07/16-P	09/16-P
Horn/Strobe	BLDG.H classroom IA10 darkroom	09163778	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA11	09163779	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA8	09163771	10-02 0075	07/12-P	09/15-P
Horn/Strobe	BLDG.H classroom IA9	09163772	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H girls restroom	09163776	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H mens restroom	09163774	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H office IA12 north wall	09163783	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H office IA12 west wall	09163782	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H office IA49	09163781	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H womens restroom	09163773	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA13 east	09163791	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA13 west	09163792	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA14east	09163794	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA14west	09163793	10-02 0075	07/16-P	09/16-P
Horn/Strobe	BLDG.H classroom IA2 .by exit	09163757	4-02 0064	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA2 .east wall	09163758	4-02 0064	07/16-P	09/15-P
Horn/Strobe	BLDG.H classroom IA3 .by exit	09163759	4-02 0064	07/12-P	09/15-P
Horn/Strobe	BLDG.H classroom IA4 by exit	09163762	4-02 0064	07/16-P	09/15-P
Horn/Strobe	BLDG.H classroom IA4 north wall	09163763	4-02 0064	07/12-P	09/15-P
Horn/Strobe	BLDG.H west hallway across office	09163780	10-02 0075	07/12-P	09/16-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
	IA49				
Horn/Strobe	BLDG.H west hallway by IA13	09163784	10-02 0075	07/12-P	09/16-P
Horn/Strobe	BLDG.H classroom IA5 east wall	09163764	10-02 0075	07/16-P	09/15-P
Horn/Strobe	BLDG.H classroom IA5 storage room	09163765	10-02 0075	07/16-P	09/15-P
	IA32				
Horn/Strobe	BLDG.H classroom IA6 west wall	09163766	10-02 0075	07/16-P	09/15-P
Horn/Strobe	BLDG.H classroom IA7 back room	09163768	10-02 0075	07/12-P	09/15-P
Horn/Strobe	BLDG.H classroom IA7 west wall	09163767	10-02 0075	07/12-P	09/15-P
Horn/Strobe	BLDG.H classroom east hallway across classroom IA8	09163770	10-02 0075	07/12-P	09/15-P
Horn/Strobe	BLDG.H classroom east hallway across mens restroom	09163769	10-02 0075	07/12-P	09/15-P
Horn/Strobe	english boys small restroom	09163833	5-02 0018	07/06-P	09/14-P
Horn/Strobe	english e1	09163813	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e10	09163877	5-02 0018	07/13-P	09/16-P
Horn/Strobe	english e11	09163882	5-02 0018	07/13-P	09/16-P
Horn/Strobe	english e2	09163818	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e3	09163838	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e4.	09163847	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e5	09163852	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e6	09163857	5-02 0018	07/06-P	09/14-P
Horn/Strobe	english e7	09163862	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e8	09163868	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english e9	09163872	5-02 0018	07/06-P	09/14-P
Horn/Strobe	english east hallway north	09163824	5-02 0018	07/13-P	09/14-P
Horn/Strobe	english east hallway south	09163823	5-02 0018	07/13-P	09/14-P
Horn/Strobe	english girls large restroom by .sink	09163829	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english girls large restroom by door	09163828	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english girls small restroom	09163831	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english large large restroom by door	09163835	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english large large restroom by toilet	09163836	5-02 0018	07/16-P	09/16-P
Horn/Strobe	english meeting room north	09163844	5-02 0018	07/06-P	09/16-P
Horn/Strobe	english meeting room south	09163843	5-02 0018	07/06-P	09/16-P
Horn/Strobe	gym. west near boys lockeroom G1	09164194	5-02 0018	07/06-P	09/15-P
Horn/Strobe	gym. west center G1	09164193	5-02 0018	07/06-P	09/16-P
Horn/Strobe	multipurpose- -by .double doors- northside	09163989	5-02 0018	07/06-P	09/14-P
Horn/Strobe	multipurpose- -by .window-westside	09163982	5-02 0018	07/06-P	09/14-P
Horn/Strobe	multipurpose- -by servery and trophy case	09163980	5-02 0018	07/06-P	09/14-P
Horn/Strobe	multipurpose- C21-by servery.	09163977	5-02 0018	07/06-P	09/14-P
Horn/Strobe	multipurpose- C8-conflict mgmt.	09163971	5-02 0018	07/08-P	09/14-P
Horn/Strobe	multipurpose- Lobby	09163967	5-02 0018	07/06-P	09/14-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	multipurpose-C12-storage	09163964	5-02 0018	07/16-P	09/15-P
Horn/Strobe	multipurpose-boys Lobby-restroom	09163954	5-02 0018	07/06-P	09/15-P
Horn/Strobe	multipurpose-girls Lobby-restroom	09163951	5-02 0018	07/06-P	09/15-P
Horn/Strobe	multipurpose-student lounge-C12-student govern.	09163961	5-02 0018	07/08-P	09/14-P
Horn/Strobe	multipurpose-student lounge-C9-north	09163956	5-02 0018	07/06-P	09/14-P
Horn/Strobe	multipurpose-student lounge-C9-south	09163957	5-02 0018	07/06-P	09/14-P
Horn/Strobe	pa4 :PERFORMING	09164380	10-02 0022	07/06-P	09/14-P
Horn/Strobe	portable 1	09163726	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 10	09163810	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 2	09163731	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 3	09163732	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 4	09163737	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 6	09163741	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable 6	09163803	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable5	09163738	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable8	09163804	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	portable9	09163807	5-02 0018	07/13-P	09/15 Removed
Horn/Strobe	Bldg. 0 Inside library main entrance	09163151	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. 0 Inside library main entrance by storage room L11	09163153	4-02 0057	07/08-P	09/14-P
Horn/Strobe	Bldg. 0 Classroom MC2 south wall	09163175	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. 0 Library Library biography area	45709339	4-02 0057	07/08-P	09/14-P
Horn/Strobe	Bldg. 0 Library center on pole by check out stand	09163174	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. 0 Library east wall	09163173	4-02 0057	07/15-P	09/14-P
Horn/Strobe	Bldg. 0 Library east wall by north exit	09163164	4-02 0057	07/08-P	09/14-P
Horn/Strobe	Bldg. 0 Library eastside south wall by clock	09163158	4-02 0057	07/08-P	09/14-P
Horn/Strobe	Bldg. 0 Library westside north wall	09163157	4-02 0057	07/15-P	09/15-P
Horn/Strobe	Bldg. 0 Library workroom L9 west wall	09163188	4-02 0057	07/08-P	09/14-P
Horn/Strobe	Bldg. 0 custodian room L16	09163184	4-02 0057	07/08-P	09/16-P
Horn/Strobe	Bldg. 0 girls restroom by custodian room L16	09163183	4-02 0057	07/08-P	09/15-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	Bldg. D. . M13in M5	09163463	4-02 0057	07/13-P	09/13-P
Horn/Strobe	Bldg. D. classroom . M5	09163458	4-02 0057	07/13-P	09/15-P
Horn/Strobe	Bldg. D. classroom . M5 storage	09163462	4-02 0057	07/13-P	09/13-P
Horn/Strobe	Bldg. D. classroom . M8	09163471	4-02 0057	07/12-P	09/13-P
Horn/Strobe	Bldg. D. center office	09163428	4-02 0057	07/12-P	09/13-P
Horn/Strobe	Bldg. D. east cordor- north	09163446	4-02 0057	07/13-P	09/15-P
Horn/Strobe	Bldg. D. east cordor- south	09163447	4-02 0057	07/13-P	09/15-P
Horn/Strobe	Bldg. D. storage M17	09163454	4-02 0057	07/13-P	09/13-P
Horn/Strobe	Bldg. D. teachers work area. M15	09163457	4-02 0057	07/13-P	09/13-P
Horn/Strobe	Bldg. D. west cordor- north	09163420	4-02 0057	07/12-P	09/13-P
Horn/Strobe	Bldg. D.Classroom M1	09163413	4-02 0057	07/13-P	09/15-P
Horn/Strobe	Bldg. D.Classroom M2	09163422	4-02 0057	07/12-P	09/15-P
Horn/Strobe	Bldg. D.Classroom M3	09163439	4-02 0057	07/12-P	09/15-P
Horn/Strobe	Bldg. D.Classroom M4	09163448	4-02 0057	07/13-P	09/15-P
Horn/Strobe	Bldg. D.Classroom M4 break area	09163449	4-02 0057	07/13-P	09/13-P
Horn/Strobe	Bldg. D.Classroom M6	09163438	4-02 0057	07/12-P	09/15-P
Horn/Strobe	Bldg. D.Classroom M7	09163429	4-02 0057	07/12-P	09/13-P
Horn/Strobe	Bldg. D.west cordor- south	09163421	4-02 0057	07/12-P	09/13-P
Horn/Strobe	Bldg. F Classroom SS1	09163297	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F Classroom SS2	09163298	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F classroom SS10	09163361	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F classroom SS11 N/W	09163362	3-02 0041	07/08-P	09/15-P
Horn/Strobe	Bldg. F classroom SS3	09163307	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F classroom SS4	09163316	4-02 0057	07/16-P	09/15-P
Horn/Strobe	Bldg. F classroom SS5	09163327	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F classroom SS6	09163328	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F classroom SS7	09163333	4-02 0057	07/14-P	09/15-P
Horn/Strobe	Bldg. F classroom SS8	09163371	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F classroom SS9	09163352	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F east locker corridor north	09163320	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F east locker corridor south	09163321	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F girls restroom by SS8 and entrance	09163339	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F girls restroom by SS8 and toilet	09163341	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F girls restroom by SS8 and toilet-north	09163347	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F girls restroom by SS8 and toilet-south	09163349	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F mens restroom by SS8 and toilet	09163345	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. F west locker corridor west wall north	09163305	4-02 0057	07/08-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	Bldg. F west locker corridor west wall south	09163306	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. F womens restroom by SS8 and toilet	09163344	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. J Classroom HE3 N/W wall	09163217	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE3 S/W wall	09163216	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE4	09163209	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE5	09163208	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J East locker corridor east wall	09163204	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J East locker corridor west wall	09163205	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Lounge area mens restroom	09163231	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Lounge area north wall between restrooms	09163227	4-02 0057	07/16-P	09/13-P
Horn/Strobe	Bldg. J Lounge area north wall by clock	09163226	4-02 0057	07/16-P	09/13-P
Horn/Strobe	Bldg. J Lounge area womens restroom	09163232	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE1 eastwall north	09163257	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE1 eastwall south	09163256	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE1 storage S/E	09163267	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. J Classroom HE3 storage S/W	09163268	4-02 0057	07/08-P	09/13-P
Horn/Strobe	Bldg. J Classroom HE6 south wall by clock	09163243	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE6 south wall eastside	09163238	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J Classroom HE6 storage S/W	09163265	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J west locker corridor west wall north	09163262	4-02 0057	07/08-P	09/15-P
Horn/Strobe	Bldg. J west locker corridor west wall south	09163263	4-02 0057	07/08-P	09/15-P
Horn/Strobe	East audience	09164420	10-02 0082	07/16-P	09/16-P
Horn/Strobe	East industrial arts	09164469	4-02 0064	07/16-P	09/13-P
Horn/Strobe	East pa2	09164430	10-02 0075	07/13-P	09/16-P
Horn/Strobe	East pa4 :PERFORMING center	09164375	10-02 0022	07/06-P	09/16-P
Horn/Strobe	East Lobby bldg. k .performing art	09164354	11-02 0117	07/06-P	09/14-P
Horn/Strobe	East outside cafeteria	20411023	1	07/16-P	09/16-P
Horn/Strobe	East pa1 :PERFORMING ARTS10D064 PRACTICE RM 6	09164447	10-02 0064	07/06-P	09/16-P
Horn/Strobe	East pa4 :PERFORMING	09164374	10-02 0022	07/14-P	09/16-P
Horn/Strobe	South pa1 :PERFORMING ARTS10D064 PRACTICE RM 6	09164449	10-02 0064	07/06-P	09/14-P
Horn/Strobe	West audience	09164421	10-02 0082	07/16-P	09/14-P
Horn/Strobe	West industrial arts	09164467	4-02 0064	07/12-P	09/16-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Horn/Strobe	West pa2	09164431	10-02 0075	07/06-P	09/16-P
Horn/Strobe	West pa4 :PERFORMING .	09164377	10-02 0022	07/06-P	09/14-P
Horn/Strobe	West Lobby bldg. k .performing art	09164352	11-02 0117	07/06-P	09/14-P
Horn/Strobe	middle industrial arts	09164468	4-02 0064	07/12-P	09/13-P
Horn/Strobe	north pa1 .:PERFORMING ARTS10D064 PRACTICE RM 6	09164448	10-02 0064	07/06-P	09/16-P
Horn/Strobe	gym. east- above water fountain G1	09164195	5-02 0018	07/06-P	09/16-P
Horn/Strobe	gym. center east G1	09164197	5-02 0018	07/13-P	09/15-P
Device Total: 315 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Strobe	6	6	0	6	6	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Strobe	Bldg.N main gym center of gym CENTER/EAST		09164285	4-02 0057	07/13-P	09/15-P
Strobe	Bldg.N main gym center of gym CENTER/WEST		09164288	4-02 0057	07/13-P	09/15-P
Strobe	Bldg.N main gym center of gym N/E		09164286	4-02 0057	07/13-P	09/15-P
Strobe	Bldg.N main gym center of gym N/W		09164289	4-02 0057	07/13-P	09/15-P
Strobe	Bldg.N main gym center of gym S/E		09164284	4-02 0057	07/13-P	09/15-P
Strobe	Bldg.N main gym center of gym S/W		09164287	4-02 0057	07/13-P	09/15-P
Device Total: 6		Return to Executive Summary				

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5				
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))						
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Communication Line		1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Communication Line	BLDG.H classroom IA3 east wall		09163761	4-02 0064	07/12-P	09/16-P
Device Total: 1 Return to Executive Summary						

LS 02.01.34 EP 02 Protected master fire alarm control panel					
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Control Panel	13	13	0	13	13
Device Type	Location	ScanID	Address	Q3/21	Q3/22
Control Panel	Admin_Electrical_A19	08474598	1-control panel	07/16-P	09/16-P
Control Panel	B12_Custodian Storage_Corridor	08474657	5	07/15-P	09/13-P
Control Panel	C2_Janitor closet_Cafeteria	08474609	7	07/16-P	09/14-P
Control Panel	E13_Custodian Storage_Corridor	08474639	11	07/15-P	09/13-P
Control Panel	G25_Outside Boiler Room_Near Wrestling	08474628	12	07/16-P	09/13-P
Control Panel	HE6_Storage	08474669	2	07/15-P	09/13-P
Control Panel	IA20_Electrical_Corridor	08474678	4		09/13-P
Control Panel	L6_Text Book Storage	08474621	6	07/16-P	09/13-P
Control Panel	M4_Soundproof Booth M16	08474645	8	07/15-P	09/13-P
Control Panel	PA_Costume Rm in Make up Room (North Entrance)	08474612	10	07/16-P	09/14-P
Control Panel	S Bldg_Outside Storage (by S3)	08474651	9	07/15-P	09/13-P
Control Panel	SS19 East Hall Custodian Storage	08474663	3	07/15-P	09/13-P
Control Panel	T-Electrical	75938137	13		09/13-P
Device Total: 13 Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
The correct operation and identification of annunciators shall be verified. If provided, the correct operation of annunciator under a fault condition shall be verified. (2010 ed.) (NFPA 72 Table 14.4.2.2 (11))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Annunciator	1	1	0	1	1	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Annunciator	Admin Office next to Principle Office		54661823	1	07/16-P	09/16-P
Device Total: 1		Return to Executive Summary				

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))						
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity	
Battery	62	38	24	62	62	
Device Type	Location		ScanID	Address	Q3/21	Q3/22
Battery	2nd T-Electrical		75938197	5		09/14-P
Battery	2nd T-Electrical		75938198	5		09/14-P
Battery	A19_Electrical		45703900	1	07/16-F	09/13-F
Battery	A19_Electrical		45703901	1	07/16-P	09/13-F
Battery	A19_Electrical_BPS		45703903	1	07/16-F	09/13-F
Battery	A19_Electrical_BPS		45703902	1	07/16-F	09/13-F
Battery	B12_Custodian Storage_Corridor		45703916	5	07/15-F	09/13-P
Battery	B12_Custodian Storage_Corridor		45703917	5	07/15-F	09/13-P
Battery	B12_Custodian Storage_Corridor_BPS		45703918	5	07/15-F	09/13-F
Battery	B12_Custodian Storage_Corridor_BPS		45703919	5	07/15-F	09/13-F
Battery	C2_Janitor closet_Cafeteria		45703947	7	07/16-F	09/14-F
Battery	C2_Janitor closet_Cafeteria		45703946	7	07/16-P	09/14-F
Battery	C2_Janitor closet_Cafeteria_BPS		45703948	7	07/16-P	09/14-P
Battery	C2_Janitor closet_Cafeteria_BPS		45703949	7	07/16-P	09/14-P
Battery	E13_Custodian Storage_Corridor		45703921	11	07/15-F	09/13-F
Battery	E13_Custodian Storage_Corridor		45703920	11	07/15-F	09/13-F
Battery	E13_Custodian Storage_Corridor_BPS		45703923	11	07/15-P	09/13-P
Battery	E13_Custodian Storage_Corridor_BPS		45703922	11	07/15-P	09/13-P
Battery	G25_Outside Boiler Room_BPS_Near Wrestling		45703940	12	07/16-P	09/13-P
Battery	G25_Outside Boiler Room_BPS_Near Wrestling		45703941	12	07/16-P	09/13-P
Battery	G25_Outside Boiler Room_BPS_Near Wrestling		45703938	12	07/16-P	09/13-P
Battery	G25_Outside Boiler Room_BPS_Near Wrestling		45703939	12	07/16-P	09/13-P
Battery	G25_Outside Boiler Room_Near Wrestling		45703936	12	07/16-P	09/13-P
Battery	G25_Outside Boiler Room_Near Wrestling		45703937	12	07/16-P	09/13-P
Battery	HE6_Storage		45703898	2	07/15-P	09/13-F
Battery	HE6_Storage		45703899	2	07/15-P	09/13-F
Battery	HE6_Storage_BPS		45703897	2	07/15-P	09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22
Battery	HE6_Storage_BPS	45703896	2	07/15-P	09/13-P
Battery	IA20_Electrical_Corridor	45703910	4		09/13-F
Battery	IA20_Electrical_Corridor	45703911	4		09/13-F
Battery	IA20_Electrical_Corridor_BPS	45703913	4		09/13-F
Battery	IA20_Electrical_Corridor_BPS	45703912	4		09/13-F
Battery	L6_Text Book Storage	45703950	6	07/16-F	09/13-P
Battery	L6_Text Book Storage	45703951	6	07/16-P	09/13-P
Battery	L6_Text Book Storage_BPS	45703952	6	07/16-P	09/13-P
Battery	L6_Text Book Storage_BPS	45703953	6	07/16-P	09/13-P
Battery	M4_Soundproof Booth M16	45703932	12	07/15-F	09/13-F
Battery	M4_Soundproof Booth M16	45703933	12	07/15-F	09/13-F
Battery	M4_Soundproof Booth M16_BPS	45703935	8	07/15-F	09/13-P
Battery	M4_Soundproof Booth M16_BPS	45703934	8	07/15-F	09/13-P
Battery	PA_Costume Rm (North Entrance)	45703943	10	07/16-F	09/14-F
Battery	PA_Costume Rm (North Entrance)	45703942	10	07/16-F	09/14-F
Battery	PA_Costume Rm_BPS (North Entrance)	45703944	10	07/16-P	09/14-P
Battery	PA_Costume Rm_BPS (North Entrance)	45703945	10	07/16-P	09/14-P
Battery	Portable P16_BPS	45703924	11	07/16-F	09/15 Removed
Battery	Portable P16_BPS	45703925	11	07/16-F	09/15 Removed
Battery	Portable P5_BPS	45703914	5	07/15-P	09/14-F
Battery	Portable P5_BPS	45703915	5	07/15-F	09/14-F
Battery	S Bldg_Outside Storage (by S3)	45703928	9	07/15-F	09/13-P
Battery	S Bldg_Outside Storage (by S3)	45703929	9	07/15-F	09/13-P
Battery	S Bldg_Outside Storage_BPS (by S3)	45703931	9	07/15-P	09/14-P
Battery	S Bldg_Outside Storage_BPS (by S3)	45703930	9	07/15-P	09/14-P
Battery	SC 8	45709326	11	07/15-P	09/14-F
Battery	SC 8	45709327	11	07/15-P	09/14-F
Battery	SS19 East Hall Custodian Storage	45703906	3	07/15-F	09/13-P
Battery	SS19 East Hall Custodian Storage	45703907	3	07/15-F	09/13-P
Battery	Science bldg_Outside Electrical (East)	45703927	11	07/16-P	09/14-P
Battery	Science bldg_Outside Electrical (East)	45703926	11	07/16-F	09/14-P
Battery	BPS SS19 East Hall Custodian Storage	45703909	3	07/15-P	09/13-P
Battery	BPS SS19 East Hall Custodian Storage	45703908	3	07/15-F	09/13-P
Battery	T-Electrical	75938132	5		09/13-P
Battery	T-Electrical	75938131	5		09/13-P
Battery	T-Electrical	75938134	5		09/13-P

Device Type	Location	ScanID	Address	Q3/21	Q3/22

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Power Supply	17	17	0	17	17
Device Type	Location	ScanID	Address	Q3/21	
Power Supply		75938196	1		
Power Supply	A19_Electrical_BPS	08474603	1	07/16-P	09/13-P
Power Supply	B12_Custodian Storage_Corridor_BPS	08474662	5	07/15-P	09/13-P
Power Supply	C2_Janitor closet_Cafeteria_BPS	08474606	1	07/16-P	09/14-P
Power Supply	E13_Custodian Storage_Corridor_BPS	08474642	11	07/15-P	09/13-P
Power Supply	G25_Outside Boiler Room_BPS_Near Wrestling	08474631	12	07/16-P	09/13-P
Power Supply	G25_Outside Boiler Room_BPS_Near Wrestling	08474636	3	07/16-P	09/13-P
Power Supply	HE6 NW corner storage	08474673	2	07/15-P	09/13-P
Power Supply	IA20_Electrical_Corridor	08474672	4		09/13-P
Power Supply	L6_Text Book Storage_BPS	08474620	6	07/16-P	09/13-P
Power Supply	M4_Soundproof Booth M16_BPS	08474650	8	07/15-P	09/13-P
Power Supply	PA_Costume Rm_BPS (North Entrance)	08474617	10	07/16-P	09/14-P
Power Supply	Portable P16_BPS	08474632	11	07/16-P	09/15 Removed
Power Supply	Portable P5_BPS	08474684	5	07/15-P	09/15 Removed
Power Supply	Portable SC8_BPS	08474638	11	07/15-P	09/15 Removed
Power Supply	S Bldg_Outside Storage_BPS (by S3)	08474652	9	07/15-P	09/14-P
Power Supply	SS19 East Hall Custodian Storage	08474666	7	07/15-P	09/13-P
Power Supply	Science bldg_Outside Electrical (East)	09163147	11	07/16-P	09/14-P
Power Supply	T-Electrical	75938136	1		09/13-P
Power Supply	T-Electrical	75938135	1		09/13-P
Device Total: 17 Return to Executive Summary					

Service Summary

Generated by: BuildingReports.com

Building: Tokay HS Lodi USD		
The Service Summary section provides an overview of the services performed in this report.		
Device Type	Service	Quantity
Failed/Other		

Battery	Tested	22
Bell	Annual	1
Heat Detector	Annual	5
Horn/Strobe	Annual	9
Horn	Annual	2
Multi-Sensor Detector	Annual	1
Smoke Detector	Annual	4

Passed		
Annunciator	Annual	1
Battery	Tested	38
Beam Detector	Annual	6
Bell	Annual	1
Communication Line	Annual	1
Control Panel	Annual	2
Control Panel	Tested	11
Heat Detector	Annual	142
Horn/Strobe	Annual	306
Horn	Annual	38
Multi-Sensor Detector	Annual	57
Power Supply	Annual	3
Power Supply	Tested	14
Pull Station	Annual	22
Smoke Detector	Annual	602
Strobe	Annual	6
Supervisory Valve	Tested	1
Tamper Switch	Tested	2
Waterflow Switch	Tested	2
Total		1255

Untested		
Heat Detector		298
Total		298

Device Type	Service	Quantity
Grand Total		1599

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Tokay HS Lodi USD				Control Panel: 1 - EST EST3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Failed/Other							
Sealed Lead Acid	A19_Electrical	26Ah	12V				
Sealed Lead Acid	A19_Electrical_BPS	7Ah	12V	13.2		80	60
Sealed Lead Acid	A19_Electrical_BPS	7Ah	12V				
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	A19_Electrical_BPS	10	120				
Breaker	C2_Janitor closet_Cafeteria_BPS	10	120				
Breaker	T-Electrical	10	120				
Breaker	T-Electrical	10	120				
Building: Tokay HS Lodi USD				Control Panel: 2 - EST EST3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	HE6_Storage_BPS	7Ah	12V	13.4	13.1	80	100
Failed/Other							
Lead Acid	HE6_Storage	26Ah	12V				
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	HE6 NW corner storage	10	120				
Building: Tokay HS Lodi USD				Control Panel: 3 - EST EST3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
<i>Passed</i>							

Sealed Lead Acid	SS19 East Hall Custodian Storage	26Ah	12V	13.4	13.2	80	100
Sealed Lead Acid	BPS SS19 East Hall Custodian Storage	7Ah	12V	13.3	13.1	80	80
Sealed Lead Acid	BPS SS19 East Hall Custodian Storage	7Ah	12V	13.3	13.1	80	80

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
Power Supply				

<i>Passed</i>				
Breaker	G25_Outside Boiler Room_BPS_Near Wrestling	10	120	

Building: Tokay HS Lodi USD				Control Panel: 4 - EST EST3			
<i>The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i>							

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
<i>Failed/Other</i>							

Sealed Lead Acid	IA20_Electrical_Corridor	26Ah	12V				
Sealed Lead Acid	IA20_Electrical_Corridor_BPS	7Ah	12V				
Sealed Lead Acid	IA20_Electrical_Corridor_BPS	7Ah	12V				

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
Power Supply				

<i>Passed</i>				
Breaker	IA20_Electrical_Corridor	10	120	

Building: Tokay HS Lodi USD				Control Panel: 5 - EST EST3			
<i>The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i>							

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
<i>Passed</i>							

Sealed Lead Acid	2nd T-Electrical	65Ah	12V	13.2	12.9	80	100
Sealed Lead Acid	2nd T-Electrical	65Ah	12V	13.2	13	80	100
Sealed Lead Acid	B12_Custodian Storage_Corridor	26Ah	12V	13.2	13	80	80
Sealed Lead Acid	B12_Custodian	26Ah	12V	13.2	13	80	80

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Sealed Lead Acid	T-Electrical	7Ah	12V	13.4	13.2	80	100
Sealed Lead Acid	T-Electrical	7Ah	12V	13.4	13.2	80	100
Sealed Lead Acid	T-Electrical	65Ah	12V	13.4	13.2	80	100
Sealed Lead Acid	T-Electrical	65Ah	12V	13.4	13.2	80	100
Failed/Other							

Sealed Lead Acid	B12_Custodian Storage_Corridor_BPS	7Ah	12V				
Sealed Lead Acid	Portable P5_BPS	7Ah	12V				
Sealed Lead Acid	Portable P5_BPS	7Ah	12V				
Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage			
Power Supply							
Passed							
Breaker	B12_Custodian Storage_Corridor_BPS	10	120				

Building: Tokay HS Lodi USD

Control Panel: 6 - EST EST3

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							

Sealed Lead Acid	L6_Text Book Storage	26Ah	12V	13.5	13.1	80	100
Sealed Lead Acid	L6_Text Book Storage_BPS	7Ah	12V	13.4	13.1	80	100
Sealed Lead Acid	L6_Text Book Storage_BPS	7Ah	12V	13.4	13.1	80	100
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	L6_Text Book Storage_BPS	10	120				

Building: Tokay HS Lodi USD

Control Panel: 7 - EST EST3

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							

Sealed Lead Acid	C2_Janitor closet_Cafeteria_BPS	7Ah	12V	13.2	12.9	80	80
Sealed Lead Acid	C2_Janitor	7Ah	12V	13.2	12.9	80	80

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
------	----------	----------	-------------	----------	-----------	--------	-----------

Failed/Other

Sealed Lead Acid	C2_Janitor closet_Cafeteria	26Ah	12V	13.1	12.8	80	70
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		

Power Supply

Passed

Breaker	SS19 East Hall Custodian Storage	10	120				
---------	----------------------------------	----	-----	--	--	--	--

Building: Tokay HS Lodi USD

Control Panel: 8 - EST EST3

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
------	----------	----------	-------------	----------	-----------	--------	-----------

Battery

Passed

Sealed Lead Acid	M4_Soundproof Booth M16_BPS	7Ah	12V	13.3	13	80	80
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		

Power Supply

Passed

Breaker	M4_Soundproof Booth M16_BPS	10	120				
---------	-----------------------------	----	-----	--	--	--	--

Building: Tokay HS Lodi USD

Control Panel: 9 - EST EST3

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
------	----------	----------	-------------	----------	-----------	--------	-----------

Battery

Passed

Sealed Lead Acid	S Bldg_Outside Storage (by S3)	26	12	13.2	12.9	80	80
Sealed Lead Acid	S Bldg_Outside Storage_BPS (by S3)	7.2	12	13.3	13.1	80	80
Sealed Lead Acid	S Bldg_Outside Storage_BPS (by S3)	7.2	12	13.3	13.1	80	80
Protection Type	Location	Rated Ah	Rated Volts			Charging Voltage	
Power Supply							

Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Passed							
Breaker	S Bldg_Outside Storage_BPS (by S3)	10	120				
Building: Tokay HS Lodi USD				Control Panel: 10 - EST EST3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							

Sealed Lead Acid	PA_Costume Rm_BPS (North Entrance)	7Ah	12V	13.2	12.8	80	80
Failed/Other							

Sealed Lead Acid	PA_Costume Rm (North Entrance)	26Ah	12V	10.7	10.5	80	10
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	PA_Costume Rm_BPS (North Entrance)	10	120				
Building: Tokay HS Lodi USD				Control Panel: 11 - EST EST3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							

Sealed Lead Acid	E13_Custodian Storage_Corridor_BPS	7Ah	12V	13.4	13.1	80	100
Sealed Lead Acid	Science bldg_Outside Electrical (East)	7	12	13.4	13.1	80	80
Sealed Lead Acid	Science bldg_Outside Electrical (East)	7	12	13.4	13	80	80
Failed/Other							
Sealed Lead Acid	E13_Custodian Storage_Corridor	26Ah	12V	12.6		80	0%
Sealed Lead Acid	E13_Custodian Storage_Corridor	26Ah	12V				

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
------	----------	----------	-------------	----------	-----------	--------	-----------

Sealed Lead Acid	SC 8	7	12				
------------------	------	---	----	--	--	--	--

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
-----------------	----------	----------	-------------	------------------

Power Supply				
--------------	--	--	--	--

Passed				
--------	--	--	--	--

Breaker	Science bldg_Outside Electrical (East)	10	120				
---------	---	----	-----	--	--	--	--

Building: Tokay HS Lodi USD	Control Panel: 12 - EST EST3
-----------------------------	------------------------------

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
------	----------	----------	-------------	----------	-----------	--------	-----------

Battery							
---------	--	--	--	--	--	--	--

Passed							
--------	--	--	--	--	--	--	--

Sealed Lead Acid	G25_Outside Boiler	7Ah	12V	13.2	13	80	80
	Room_BPS_Near Wrestling						
Sealed Lead Acid	G25_Outside Boiler	7Ah	12V	13.3	13	80	80
	Room_BPS_Near Wrestling						
Sealed Lead Acid	G25_Outside Boiler	7Ah	12V	13.3	13	80	80
	Room_BPS_Near Wrestling						
Sealed Lead Acid	G25_Outside Boiler	26Ah	12V	13.6	13.3	80	100
	Room_Near Wrestling						
Sealed Lead Acid	G25_Outside Boiler	26Ah	12V	13.4	13	80	80
	Room_Near Wrestling						

Failed/Other							
--------------	--	--	--	--	--	--	--

Sealed Lead Acid	M4_Soundproof Booth M16	26Ah	12V				
------------------	-------------------------	------	-----	--	--	--	--

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
-----------------	----------	----------	-------------	------------------

Power Supply				
--------------	--	--	--	--

Passed				
--------	--	--	--	--

	G25_Outside Boiler	10	120				
	Room_BPS_Near Wrestling						

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Tokay HS Lodi USD	Control Panel: 1 - EST EST3
-----------------------------	-----------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Battery	Control	3.88%	62
Beam Detector	Initiating	0.38%	6
Bell	Indicating	0.13%	2
Communication Line	Control	0.06%	1
Control Panel	Control	0.81%	13
Heat Detector	Initiating	27.83%	445
Horn	Indicating	2.50%	40
Horn/Strobe	Indicating	19.70%	315
Multi-Sensor Detector	Initiating	3.63%	58
Power Supply	Control	1.06%	17
Pull Station	Initiating	1.38%	22
Smoke Detector	Initiating	37.90%	606
Strobe	Indicating	0.38%	6
Supervisory Valve	Supervisory	0.06%	1
Tamper Switch	Supervisory	0.13%	2
Waterflow Switch	Initiating	0.13%	2

Type	Qty	Model #	Description	Install Date
<i>In Service - 5 Years to 10 Years</i>				
Duracell Ultra				

Power-Sonic

<i>In Service - 25 Years or Older</i>
--

EST				
Annunciator	1	EST3		12/31/1969
Control Panel	1	EST3		12/31/1969
Heat Detector	1	302		12/31/1969
Horn/Strobe	1	G1RF-HDVM		12/31/1969
Power Supply	5	BPS10AC		12/31/1969
Smoke Detector	44	SIGA-PS		12/31/1969
Fire-Lite				
Pull Station	2	BG-12L		12/31/1969
GE Security				
Smoke Detector	6	SIGA-PS		12/31/1969

Termotech				
Heat Detector	3	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 2 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 3 Years to 5 Years				
Power sonic				
Battery	2	PS - 1270 F1	Sealed Lead Acid	08/14/2018
In Service - 5 Years to 10 Years				
Power-Sonic				
Battery	2	PS-12260 NB	Lead Acid	04/03/2014
In Service - 25 Years or Older				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	5	282B		12/31/1969
Heat Detector	2	SIGA-HRS		12/31/1969
Power Supply	1	BPS10AC		12/31/1969
Smoke Detector	34	SIGA-PS		12/31/1969
Termotech				
Heat Detector	10	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 3 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 3 Years to 5 Years				
Power-Sonic				
Battery	2	PS12260	Sealed Lead Acid	08/27/2018
In Service - 5 Years to 10 Years				
Power-Sonic				
Battery	2	PS-1270 F1	Sealed Lead Acid	08/01/2017
In Service - 25 Years or Older				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	1	SIGA-HRS		12/31/1969
Horn/Strobe	1	G1RF-HDVM		12/31/1969
Power Supply	1	BPS6		12/31/1969
Smoke Detector	54	SIGA-PS		12/31/1969
Termotech				

Heat Detector	12	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 4 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 3 Years to 5 Years				
Yuasa				
Battery	2	NP712	Sealed Lead Acid	07/07/2018
In Service - 5 Years to 10 Years				
Power-Sonic				
Battery	2	PS12260	Sealed Lead Acid	04/14/2016
In Service - 25 Years or Older				
EST				
Communication Line	1	G1RF-HDVM		12/31/1969
Control Panel	1	EST3		12/31/1969
Heat Detector	5	282B		12/31/1969
Heat Detector	1	DNE		12/31/1969
Heat Detector	17	SIGA-HRS		12/31/1969
Horn	5	757-1A- T		12/31/1969
Horn	4	757-1A-T		12/31/1969
Horn/Strobe	80	G1RF-HDVM		12/31/1969
Power Supply	1	BPS10AC		12/31/1969
Smoke Detector	2	G1RF-HDVM		12/31/1969
Smoke Detector	2	SIGA-HRS		12/31/1969
Smoke Detector	71	SIGA-PS		12/31/1969
Strobe	6	G1RF-HDVM		12/31/1969
Fire-Lite				
Pull Station	1	BG-12L		12/31/1969
GE Security				
Smoke Detector	3	SIGA-PS		12/31/1969
Termotech				
Heat Detector	65	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 5 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 5 Years to 10 Years				
Power-Sonic				
Battery	2	ps-12260	Sealed Lead Acid	12/11/2015

Battery	2	ps-1270	Sealed Lead Acid	12/09/2015
In Service - 10 Years to 15 Years				
Power-Sonic				
Battery	6	PS-1270 F1	Sealed Lead Acid	01/09/2013
Battery	2	dne	Sealed Lead Acid	01/09/2013
In Service - 25 Years or Older				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	3	282B		12/31/1969
Heat Detector	1	302		12/31/1969
Heat Detector	1	SIGA-HRS		12/31/1969
Heat Detector	1	SIGA-HRS	Combination	12/31/1969
Horn	9	757-1A- T		12/31/1969
Horn	14	757-1A-T		12/31/1969
Horn	1	757-1a-t		12/31/1969
Horn	2	dne		12/31/1969
Horn/Strobe	1	282B		12/31/1969
Horn/Strobe	1	G1R-HDVM		12/31/1969
Horn/Strobe	149	G1RF-HDVM		12/31/1969
Horn/Strobe	8	dne		12/31/1969
Power Supply	1	BPS10AC		12/31/1969
Smoke Detector	47	SIGA-PS		12/31/1969
Fire-Lite				
Pull Station	11	BG-12L		12/31/1969
GE Security				
Horn/Strobe	2	G1R-HDVM		12/31/1969
Horn/Strobe	1	dne		12/31/1969
Simplex				
Heat Detector	3	302		12/31/1969
Termotech				
Heat Detector	27	302		12/31/1969
Heat Detector	7	302	Combination	12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 6 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 3 Years to 5 Years				
Power-Sonic				
Battery	2	PS-1270	Sealed Lead Acid	08/27/2018
In Service - 25 Years or Older				
EST				

Control Panel	1	EST3	12/31/1969
Power Supply	1	BPS10AC	12/31/1969
Smoke Detector	20	SIGA-PS	12/31/1969

Fire-Lite

Pull Station	1	BG-12L	12/31/1969
--------------	---	--------	------------

Power-Sonic

Battery	2	PS-12260	Sealed Lead Acid	12/31/1969
---------	---	----------	------------------	------------

Building: Tokay HS Lodi USD Control Panel: 7 - EST EST3

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 25 Years or Older

EST

Control Panel	1	EST3	12/31/1969
Heat Detector	9	282B	12/31/1969
Heat Detector	2	SIGA-HRS	12/31/1969
Power Supply	1	BPS10AC	12/31/1969
Smoke Detector	43	SIGA-PS	12/31/1969

Power sonic

Battery	2	PS-1270 F1	Sealed Lead Acid	12/31/1969
---------	---	------------	------------------	------------

Werker

Battery	2	WKA12-26NB	Sealed Lead Acid	12/31/1969
---------	---	------------	------------------	------------

Building: Tokay HS Lodi USD Control Panel: 8 - EST EST3

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 5 Years to 10 Years

Duracell

Battery	2	DURA12-7F	Sealed Lead Acid	09/21/2017
---------	---	-----------	------------------	------------

In Service - 25 Years or Older

EST

Control Panel	1	EST3	12/31/1969
Heat Detector	2	304	12/31/1969
Heat Detector	2	SIGA-HRS	12/31/1969
Power Supply	1	BPS10AC	12/31/1969
Smoke Detector	37	SIGA-PS	12/31/1969

Termotech

Heat Detector	31	302	12/31/1969
---------------	----	-----	------------

Building: Tokay HS Lodi USD Control Panel: 9 - EST EST3

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
<i>In Service - 3 Years to 5 Years</i>				
Power-Sonic				
Battery	2	PS1270	Sealed Lead Acid	08/27/2018
<i>In Service - 10 Years to 15 Years</i>				
Power-Sonic				
Battery	2	PS-12260 NB	Sealed Lead Acid	09/12/2012
<i>In Service - 25 Years or Older</i>				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	2	282B		12/31/1969
Heat Detector	1	DNE		12/31/1969
Heat Detector	18	SIGA-HRS		12/31/1969
Horn	1	757757-1A-T		12/31/1969
Power Supply	1	BPS10AC		12/31/1969
Smoke Detector	14	SIGA-PS		12/31/1969
Termotech				
Heat Detector	81	302		12/31/1969
Heat Detector	1	302	Rate-of-Rise	12/31/1969

Building: Tokay HS Lodi USD

Control Panel: 10 - EST EST3

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
<i>In Service - 3 Years to 5 Years</i>				
Power-Sonic				
Battery	2	PS1270	Sealed Lead Acid	08/27/2018
<i>In Service - 5 Years to 10 Years</i>				
Duracell Ultra				
Battery	2	DURA12-26NB	Sealed Lead Acid	02/08/2016
<i>In Service - 25 Years or Older</i>				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	1	SIGA-HRS		12/31/1969
Horn	4	757-1A-T		12/31/1969
Horn/Strobe	56	G1RF-HDVM		12/31/1969
Horn/Strobe	3	SIGA-PS		12/31/1969
Power Supply	1	45703945		12/31/1969

Smoke Detector	1	G1RF-HDVM		12/31/1969
Smoke Detector	70	SIGA-PS		12/31/1969
Fire-Lite				
Pull Station	3	BG-12L		12/31/1969
GE Security				
Smoke Detector	3	SIGA-PS		12/31/1969
Termotech				
Heat Detector	14	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 11 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 3 Years to 5 Years				
Power-Sonic				
Battery	2	ps-12260	Sealed Lead Acid	12/12/2018
In Service - 5 Years to 10 Years				
Power-Sonic				
Battery	2	DNE	Sealed Lead Acid	11/20/2017
Battery	2	PS-1270	Sealed Lead Acid	11/20/2017
Duracell Ultra				
Battery	2	DURA12-7F	Sealed Lead Acid	12/09/2015
In Service - 25 Years or Older				
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	3	DNE		12/31/1969
Heat Detector	25	SIGA-HRS		12/31/1969
Horn/Strobe	11	G1RF-HDVM		12/31/1969
Horn/Strobe	1	SIGA-PS		12/31/1969
Power Supply	2	BPS10A		12/31/1969
Smoke Detector	59	SIGA-PS		12/31/1969
Smoke Detector	1	dne		12/31/1969
Fire-Lite				
Pull Station	2	BG-12L		12/31/1969
GE Security				
Smoke Detector	1	SIGA-PS		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 12 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date

In Service - 5 Years to 10 Years				
Power-sonic				
Battery	4	PS-1270 F1	Sealed Lead Acid	10/03/2017
Power-Sonic				
Battery	2	PS-12260 NB	Sealed Lead Acid	09/21/2017
In Service - 10 Years to 15 Years				
Power-Sonic				
Battery	2	PS-12260 NB	Sealed Lead Acid	01/02/2013
In Service - 25 Years or Older				
Beam Detector	4			12/31/1969
EST				
Control Panel	1	EST3		12/31/1969
Heat Detector	2	SIGA-HRS		12/31/1969
Power Supply	1	BPS10AC		12/31/1969
Smoke Detector	48	SIGA-PS		12/31/1969
GE Security				
Smoke Detector	1	SIGA-PS		12/31/1969
Termotech				
Heat Detector	28	302		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 13 - EST EST3	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 25 Years or Older				
EST				
Control Panel	1	EST3		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 14	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Type	Qty	Model #	Description	Install Date
In Service - 25 Years or Older				
Est				
Pull Station	1	siga-278		12/31/1969
Smoke Detector	3	siga-osd		12/31/1969
System Sensor				
Heat Detector	3	5602		12/31/1969
Building: Tokay HS Lodi USD			Control Panel: 15	
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last				

year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
<i>In Service - 25 Years or Older</i>				
Beam Detector	2			12/31/1969
Bell	1			12/31/1969
EST				
Smoke Detector	10	Siga-OSD	Photoelectric	12/31/1969
Est				
Pull Station	1	siga-278		12/31/1969
Smoke Detector	22	siga-osd		12/31/1969
Potter				
Waterflow Switch	1	VSR		12/31/1969
TYCO				
Tamper Switch	1	BFV-300		12/31/1969
Building: Tokay HS Lodi USD				Control Panel: 16
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<i>In Service - 2 Years to 3 Years</i>				
Bell	1			02/11/2021
Edwards				
Heat Detector	1	SIGA-HRD	Fixed/ROR	02/11/2021
Multi-Sensor Detector	57	SIGA-OSCD	SMOKE/CO	02/11/2021
Smoke Detector	10	SIGA-OSD	Photoelectric	02/11/2021
Potter				
Waterflow Switch	1	VSR		02/11/2021
Victaulic				
Tamper Switch	1	705		02/11/2021
<i>In Service - 25 Years or Older</i>				
Edwards				
Multi-Sensor Detector	1	SIGA-OSCD	SMOKE/CO	12/31/1969
Protectowire				
Heat Detector	4	XCR	Line / fixed temperature	12/31/1969
System Sensor				
Heat Detector	37	5602	Fixed Temperature/rate of rise	12/31/1969
Supervisory Valve	1	pibv2		12/31/1969
System sensor				
Heat Detector	13	5602	Fixed Temperature/rate of rise	12/31/1969

Zone Address Report

Generated by: BuildingReports.com

Building: Tokay HS Lodi USD			Control Panel: 1 - EST EST3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	SMOKE: ADMIN 1D001TELEPHONE ROOM 46		09163688
0002	Smoke Detector	SMOKE: ADMIN 1D002CUSTODIAN 35		09163689
0003	Smoke Detector	SMOKE: ADMIN 1D003DEANS OFFICE 34		09163717
0004	Smoke Detector	SMOKE: ADMIN 1D004CONFERENCE ROOM 33		09163714
0005	Smoke Detector	SMOKE: ADMIN 1D005DEANS OFFICE 32		09163713
0006	Smoke Detector	ADMIN1D006ATTENDANCE WEST		09163707
0007	Smoke Detector	ADMIN1D007ATTENDANCE EAST		09163708
0009	Smoke Detector	SMOKE: ADMIN 1D009CUSTODIAN SUPPLY 40		09163691
0010	Smoke Detector	SMOKE: ADMIN 1D010CONFERENCE 39		09163720
0011	Smoke Detector	SMOKE: ADMIN 1D011WORK ROOM 38		09163705
0012	Smoke Detector	SMOKE: ADMIN 1D012FACULTY PREP 41 S/W		09163703
0013	Smoke Detector	SMOKE: ADMIN 1D013FACULTY PREP 41 N/W		09163701
0017	Smoke Detector	SMOKE: ADMIN 1D017FACULTY PREP 41 N/E		09163702
0018	Heat Detector	Attic heat attic: ADMIN 1D018FACULTY PREP 41 S/E		09163789
0018	Smoke Detector	SMOKE: ADMIN 1D018FACULTY PREP 41 S/E		09163704
0019	Smoke Detector	SMOKE: ADMIN 1D019MAIN HALL EAST		09163692
0020	Smoke Detector	SMOKE: ADMIN 1D020MAIN HALL CENTER		09163690
0021	Smoke Detector	SMOKE: ADMIN 1D021MAIN HALL CENTER		09163687
0021	Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM 4 N/E		09163485
0022	Smoke Detector	SMOKE: ADMIN 1D022MAIN HALL WEST		09163684
0023	Smoke Detector	SMOKE: ADMIN 1D023MAIN HALL WEST CLOSET		09163686
0024	Smoke Detector	SMOKE ADMIN 1D024CHILD WELFARE		09163710

Address	Device Type	Location	Type	ScanID
		OFFICE		
0026	Smoke Detector	SMOKE: ADMIN 1D026REGISTRAR		09163674
0026	Smoke Detector	SMOKE: ADMIN Vice Principle		09163633
0027	Smoke Detector	ADMIN 1D027COUNSELING WEST		09163677
0028	Smoke Detector	ADMIN STORAGE A2		09163676
0028	Smoke Detector	SMOKE: ADMIN 1D028COUNSELING CONFERENCE		09163673
0029	Smoke Detector	SMOKE: ADMIN 1D029COUNSEL 8		09163670
0029	Smoke Detector	Bldg. 0 Library center .row north/center		09163162
0030	Smoke Detector	SMOKE: ADMIN 1D030COUNSEL 9		09163669
0031	Smoke Detector	SMOKE: ADMIN 1D031COUNSELING EAST		09163678
0031	Pull Station	Administration Counseling East		3953797799
0032	Smoke Detector	SMOKE: ADMIN 1D032GENERAL OFFICE N/W		09163682
0032	Smoke Detector	Northwest SMOKE: ADMIN 1D032GENERAL OFFICE		09163681
0033	Smoke Detector	SMOKE: ADMIN 1D033 conferance rm A		09163665
0034	Smoke Detector	SMOKE: ADMIN 1D034COUNSEL 10		09163666
0035	Smoke Detector	SMOKE: ADMIN 1D035COUNSEL 11		09163658
0036	Smoke Detector	SMOKE: ADMIN 1D036COUNSEL HALL		09163663
0037	Smoke Detector	SMOKE: ADMIN 1D037COUNSEL 20		09163661
0038	Smoke Detector	SMOKE: ADMIN counselor A14		09163657
0039	Smoke Detector	SMOKE: ADMIN 1D039COUNSEL 12		09163654
0040	Smoke Detector	SMOKE: ADMIN 1D040LOUNGE 13		09163649
0041	Smoke Detector	SMOKE: ADMIN 1D041STORAGE A16		09163653
0042	Smoke Detector	SMOKE: ADMIN 1D042ELECTRICAL ROOM 45		3953799083
0043	Smoke Detector	SMOKE: ADMIN 1D043OUTSIDE ELEC. RM. 45		09163648
0044	Smoke Detector	SMOKE: ADMIN 1D044WOMENS ROOM 14		09163652
0045	Heat Detector	Attic heat attic: ADMIN 1D045MENS ROOM 15		09163760
0047	Smoke Detector	SMOKE: ADMIN 1D047HALLWAY 17 STORAGE		09163637
0047	Smoke Detector	SMOKE: ADMIN HALLWAY STORAGE A21		09163638
0048	Heat Detector	Attic heat attic: ADMIN 1D048HALLWAY 17 NORTH		09163756
0048	Smoke Detector	SMOKE: ADMIN 1D048HALLWAY 17 NORTH		09163628
0048	Smoke Detector	SMOKE: ADMIN WORKROOM A24		09163629
Zone/Circuit: 2				
51	Smoke Detector	SMOKE: ADMIN 1D051PRINCIPAL 28		09163644
Zone/Circuit: 02				
0052	Smoke Detector	SMOKE: ADMIN 1D052SECRETARY 27		09163643

Address	Device Type	Location	Type	ScanID
0053	Smoke Detector	ADMIN 1D053MAIN ADMIN OFFICE		09163639
0128	Pull Station	Lobby building L admin.main office near announcer		09163646
Zone/Circuit: control panel				

Control Panel	Admin_Electrical_A19	08474598
---------------	----------------------	----------

Building: Tokay HS Lodi USD	Control Panel: 2 - EST EST3
------------------------------------	------------------------------------

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	Bldg. J water heater room outside by classroom HE6		09163264
0002	Smoke Detector	Bldg. J Classroom HE6 storage S/W		09163244
0003	Smoke Detector	Bldg. J Classroom HE6 storage N/W		09163245
0004	Smoke Detector	Bldg. J Classroom HE6 N/W by exit		09163241
0005	Heat Detector	Bldg. J Classroom HE6 storage East		09163247
0006	Smoke Detector	Bldg. J Classroom HE6 N/E		09163240
0007	Smoke Detector	Bldg. J Classroom HE6 S/W		09163242
0008	Smoke Detector	Bldg. J Classroom HE6 S/E		09163239
0009	Smoke Detector	Bldg. J Lounge room west		09163224
0010	Smoke Detector	Bldg. J office HE16 inside Lounge area		09163233
0011	Smoke Detector	Bldg. J custodian room HE15 inside Lounge area		09163234
0012	Smoke Detector	Bldg. J Lounge area between restrooms		09163228
0013	Smoke Detector	Bldg. J Lounge area mens restroom		09163230
0014	Smoke Detector	Bldg. J Lounge area womens restroom		09163229
0015	Smoke Detector	Bldg. J Classroom HE1 N/E		09163254
0016	Smoke Detector	Bldg. J Classroom HE1 S/E		09163255
0017	Smoke Detector	Bldg. J Classroom HE1 storage S/E		09163251
0018	Smoke Detector	Bldg. J Classroom HE1 storage S/W		09163250
0019	Smoke Detector	Bldg. J Classroom HE1 S/W by exit		09163252
0020	Smoke Detector	Bldg. J Classroom HE3 storage S/W by exit		09163221
0020	Heat Detector	Bldg. J Classroom HE1 storage north		09163248
0021	Smoke Detector	Bldg. J Classroom HE1 N/W		09163253
0022	Smoke Detector	Bldg. J west locker corridor south		09163260
0023	Smoke Detector	Bldg. J west locker corridor north		09163261
0024	Smoke Detector	Bldg. J Lounge room east		09163225
0025	Smoke Detector	Bldg. J Classroom HE3 S/W by ironing board area		09163215
0026	Smoke Detector	Bldg. J Classroom HE3 N/W by clock		09163214
0027	Smoke Detector	Bldg. J Classroom HE3 storage S/E by exit		09163222
0029	Smoke Detector	Bldg. J Classroom HE3 S/E by exit door		09163212
0031	Smoke Detector	Bldg. J Classroom HE3 N/E by washer		09163213

Address	Device Type	Location	Type	ScanID
		and dryer area		
0032	Smoke Detector	Bldg. J East locker corridor north		09163202
0034	Smoke Detector	Bldg. J East locker corridor south		09163203
0035	Smoke Detector	Bldg. J Classroom HE4 west		09163211
0036	Smoke Detector	Bldg. J Classroom HE4 east		09163210
0037	Smoke Detector	Bldg. J Classroom HE5 east		09163207
0038	Smoke Detector	Bldg. J Classroom HE5 west		09163206
0126	Heat Detector	Attic Bldg. J Classroom HE1 Center/E attic		09163273
0126	Heat Detector	Attic Bldg. J Classroom HE1 S/E attic		09163274
0126	Heat Detector	Attic Bldg. J Classroom HE1 S/W attic		09163271
0126	Heat Detector	Attic Bldg. J classroom HE6 attic N/Center		09163279
0126	Heat Detector	Attic Bldg. J classroom HE6 attic S/W		09163277
0127	Heat Detector	Attic Bldg. J classroom HE3 attic S/Center		09163283
0127	Heat Detector	Attic Bldg. J classroom HE3 attic S/E		09163286
0127	Heat Detector	Attic Bldg. J classroom HE3 attic S/W		09163282
0127	Heat Detector	Attic Bldg. J classroom HE5 east attic		09163290
0127	Heat Detector	Attic Bldg. J classroom HE5 west attic		09163289
0128	Heat Detector	Bldg. J Classroom HE3 N/E		09163219
0128	Heat Detector	Bldg. J Classroom HE3 N/W		09163218
0128	Heat Detector	Bldg. J Classroom HE1 N/E		09163258
0128	Heat Detector	Bldg. J Classroom HE6 N/E eastside		09163237
0128	Heat Detector	Bldg. J Classroom HE6 S/E eastside		09163236

Building: Tokay HS Lodi USD

Control Panel: 3 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	Bldg. F east locker corridor custodian room SS19		09163322
0002	Smoke Detector	Bldg. F classroom SS4 N/E		09163315
0003	Smoke Detector	Bldg. F classroom SS4 S/E		09163312
0004	Smoke Detector	Bldg. F east locker corridor south		09163318
0005	Smoke Detector	Bldg. F classroom SS5 N/W		09163326
0006	Smoke Detector	Bldg. F classroom SS5 S/W		09163323
0007	Smoke Detector	Bldg. F classroom SS5 S/E		09163324
0008	Smoke Detector	Bldg. F classroom SS5 N/E		09163325
0009	Smoke Detector	Bldg. F classroom SS6 N/E		09163330
0010	Smoke Detector	Bldg. F classroom SS6 S/E		09163331
0011	Smoke Detector	Bldg. F classroom SS6 S/W		09163332
0012	Smoke Detector	Bldg. F classroom SS6 N/W		09163329
0013	Smoke Detector	Bldg. F classroom SS7 S/E		09163336
0014	Smoke Detector	Bldg. F classroom SS7 N/E		09163337
0015	Smoke Detector	Bldg. F classroom SS7 N/W		09163334
0016	Smoke Detector	Bldg. F classroom SS7 S/W		09163335
0017	Smoke Detector	Bldg. F classroom SS8 S/W		09163370

Address	Device Type	Location	Type	ScanID
0018	Smoke Detector	Bldg. F classroom SS8 N/E		09163368
0019	Smoke Detector	Bldg. F classroom SS8 N/W		09163367
0020	Smoke Detector	Bldg. F bySS8 boys Restroom-north		09163351
0020	Smoke Detector	Bldg. F classroom SS8 S/E		09163369
0021	Smoke Detector	Bldg. F east locker corridor north		09163319
0023	Smoke Detector	Bldg. F bySS8 girls Restroom-north		09163340
0024	Smoke Detector	Bldg. F bySS8 girls Restroom-south		09163342
0025	Smoke Detector	Bldg. F bySS8 women Restroom-south		09163343
0026	Smoke Detector	Bldg. F bySS8 mens Restroom-south		09163346
0027	Smoke Detector	Bldg. F bySS8 boys Restroom-south		09163350
0029	Smoke Detector	Bldg. F classroom SS9 N/E		09163355
0030	Smoke Detector	Bldg. F classroom SS9 S/E		09163356
0031	Smoke Detector	Bldg. F classroom SS9 S/W		09163353
0032	Smoke Detector	Bldg. F classroom SS9 N/W		09163354
0033	Smoke Detector	Bldg. F west locker corridor north		09163304
0035	Smoke Detector	Bldg. F classroom SS10 S/E		09163357
0036	Smoke Detector	Bldg. F classroom SS10 N/E		09163360
0037	Smoke Detector	Bldg. F classroom SS10 N/W		09163359
0038	Smoke Detector	Bldg. F classroom SS10 S/W		09163358
0039	Smoke Detector	Bldg. F classroom SS11 S/E		09163364
0040	Smoke Detector	Bldg. F classroom SS11 N/E		09163363
0041	Horn/Strobe	Bldg. F classroom SS11 N/W		09163362
0042	Smoke Detector	Bldg. F classroom SS11 N/W		09163366
0042	Smoke Detector	Bldg. F classroom SS11 S/W		09163365
0043	Heat Detector	Bldg. F Classroom SS1 N/W		09163293
0044	Smoke Detector	Bldg. F Classroom SS1 S/W		09163296
0045	Smoke Detector	Bldg. F Classroom SS1 S/E		09163295
0046	Smoke Detector	Bldg. F Classroom SS1 N/E		09163294
0047	Smoke Detector	Bldg. F Classroom SS2 N/W		09163302
0048	Smoke Detector	Bldg. F Classroom SS2 S/W		09163301
0049	Smoke Detector	Bldg. F Classroom SS2 S/E		09163300
0050	Smoke Detector	Bldg. F Classroom SS2 N/E		09163299
0051	Smoke Detector	Bldg. F west locker corridor south		09163303
0052	Smoke Detector	Bldg. F classroom SS3 S/W		09163311
0053	Smoke Detector	Bldg. F classroom SS3 N/W		09163308
0054	Smoke Detector	Bldg. F classroom SS3 N/E		09163309
0055	Smoke Detector	Bldg. F classroom SS3 S/E		09163310
0056	Smoke Detector	Bldg. F classroom SS4 S/W		09163313
0057	Smoke Detector	Bldg. F classroom SS4 N/W		09163314
0126	Heat Detector	Attic Bldg. F classroom SS5 attic S/E		09163393
0126	Heat Detector	Attic Bldg. F classroom SS5 attic S/W		09163392
0126	Heat Detector	Attic Bldg. F classroom SS6 attic S/E		09163396
0126	Heat Detector	Attic Bldg. F classroom SS6 attic S/W		09163399
0127	Heat Detector	Attic Bldg. F classroom SS2 attic S/W		09163376
0127	Heat Detector	Attic Bldg. F classroom SS3 attic S/E		09163385

Address	Device Type	Location	Type	ScanID
0127	Heat Detector	Attic Bldg. F classroom SS3 attic S/W		09163382
0127	Heat Detector	Attic Bldg. F classroom SS4 attic S/E		09163386
0127	Heat Detector	Attic Bldg. F classroom SS4 attic S/W		09163387
0128	Heat Detector	Attic Bldg. F classroom SS1 attic S/E		09163373
0128	Heat Detector	Attic Bldg. F classroom SS1 attic S/W		09163372
0128	Heat Detector	Attic Bldg. F classroom SS2 attic S/E		09163379

Building: Tokay HS Lodi USD

Control Panel: 4 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	SMOKE: 4D001 SHOPFIRE PANEL ROOM		3953700478
0002	Smoke Detector	SHOPSTORAGE ROOM 48		3953704469
0003	Smoke Detector	SMOKE: 4D003 SHOPCLASSROOM 1 NORTH		3953700515
0004	Smoke Detector	SMOKE: 4D004 SHOPCLASSROOM 1 TOOLS		3953701871
0005	Smoke Detector	SMOKE: 4D005 SHOPCLASSROOM 1 OFFICE		3953704360
0006	Heat Detector	HEAT: shop IA #1 north west		3808417612
0007	Heat Detector	HEAT: shop IA #1 South west		3808417681
0008	Heat Detector	HEAT: shop IA #1 South center		3808418190
0009	Heat Detector	HEAT: 4D010 SHOP IA1 CNTR/EAST		3808417438
0010	Heat Detector	HEAT: shop IA #1 NE		75938209
0011	Heat Detector	HEAT: shop IA #1 SE		3808418404
0012	Smoke Detector	Smoke: 4D012 SHOPCLASSROOM 2 WEST		3964741569
0013	Smoke Detector	Smoke: 4D013 SHOPCLASSROOM 2 WEST		3964741378
0014	Smoke Detector	SHOPCLASSROOM 2		3964743600
0014	Smoke Detector	Smoke: 4D014 SHOPCLASSROOM 2 EAST		3964742221
0016	Heat Detector	SMOKE: 4D016 SHOPCLASSROOM 3 WEST		3809861346
0017	Heat Detector	SMOKE: 4D017 SHOPCLASSROOM 3 WEST		3809862039
0018	Heat Detector	SMOKE: 4D018 SHOPCLASSROOM 3 EAST		3809861377
0019	Heat Detector	SMOKE: 4D019 SHOPCLASSROOM 3 EAST		3809875268
0020	Smoke Detector	SMOKE: 4D020 SHOPCLASSROOM 3 N /E		3953711832
0021	Smoke Detector	SMOKE: 4D021 SHOPCLASSROOM 3 OFFICE		3953700546
0022	Smoke Detector	SMOKE: 4D022 SHOPCLASSROOM 3		3953711856

Address	Device Type	Location	Type	ScanID
		PARTS		
0023	Smoke Detector	SMOKE: 4D023 SHOPCLASSROOM 3 STORAGE		3953703868
0024	Smoke Detector	SMOKE: 4D024 SHOPCLASSROOM 2 STORAGE		3953711771
0025	Smoke Detector	SMOKE: 4D025 SHOPCLASSROOM 2 NORTH		3953703875
0026	Smoke Detector	SMOKE: 4D026 SHOPCLASSROOM 2 OFFICE		3953701925
0027	Smoke Detector	SMOKE: 4D027 SHOPCLASSROOM 2 STORAGE		3953701024
0027	Smoke Detector	Bldg.D classroom M7 N/E		09163433
0028	Smoke Detector	SMOKE: 4D001 SHOPFIRE PANEL ROOM		20414658
0029	Smoke Detector	Shop Main Hall Near room IA21		3953703073
0030	Smoke Detector	Shop Main Hall West exit		3953703905
0034	Smoke Detector	SMOKE: 4D034 SHOPCLASSROOM 13 SUPPLY		3953711801
0035	Smoke Detector	SMOKE: 4D035 SHOPCLASSROOM 13 SUPPLY		3953711665
0036	Smoke Detector	SMOKE: 4D036 SHOPCLASSRM 13 W STORAGE		3953702762
0040	Smoke Detector	SMOKE: 4D040 SHOPNORTH/WEST CORRIDOR		3953703219
0043	Smoke Detector	SMOKE: 4D043 SHOPCLASSROOM 12 CENTER/E		3953700553
0044	Smoke Detector	SMOKE: 4D044 SHOPCLASSROOM 12 CENTER/W		3953785178
0045	Smoke Detector	SMOKE: 4D045 SHOPNORTH/WEST CORRIDOR		3953784997
0046	Smoke Detector	SMOKE: 4D046 SHOPCLASSROOM 12 S /W		3953530259
0047	Smoke Detector	SMOKE: 4D047 SHOPCLASSROOM 11 NORTH		3953784720
0049	Smoke Detector	SMOKE: 4D049 SHOPCLASSROOM 10 SOUTH		3953704315
0050	Smoke Detector	SMOKE: 4D050 SHOPCLASSROOM 11 SOUTH		3953704971
0051	Smoke Detector	SMOKE: 4D051 SHOPCLASSROOM 12 STUDY RM		3953702809
0052	Smoke Detector	SMOKE: 4D052 IA SHOPNORTH/WEST CORRIDOR		3953701055
0053	Smoke Detector	SMOKE: 4D053 SHOPMAIN HALL (CENTER)		3953703035
0053	Smoke Detector	BLDG.K performing arts platform E /CENTER .		09164279
0053	Smoke Detector	BLDG.K performing arts platform N/E .		09164280
0053	Smoke Detector	BLDG.K performing arts platform N/W .		09164277

Address	Device Type	Location	Type	ScanID
0053	Smoke Detector	BLDG.K performing arts platform S/E .		09164278
0053	Smoke Detector	BLDG.K performing arts platform S/W .		09164281
0053	Smoke Detector	BLDG.K performing arts platform W /CENTER .		09164282
0054	Smoke Detector	SMOKE: SHOPMAIN HALL (CENTER)		3953704858
0055	Smoke Detector	SMOKE: SHOPMAIN HALL (CENTER)		3953704179
0056	Smoke Detector	SMOKE: SHOPMAIN HALL (East)		3953703936
0057	Heat Detector	Attic Bldg. 0 Library attic work experience office L14		09163141
0057	Heat Detector	Attic Bldg. 0 Library attic workroom L9 east		09163139
0057	Heat Detector	Attic Bldg. 0 Library attic workroom L9 west		09163138
0057	Heat Detector	Attic Bldg. 0 Library in main entrance attic		09163137
0057	Heat Detector	Attic Bldg. 0 attic Library storage L11		09163140
0057	Heat Detector	Attic Bldg. F classroom SS1 attic N/E		09163374
0057	Heat Detector	Attic Bldg. F classroom SS1 attic N/W		09163375
0057	Heat Detector	Attic Bldg. F classroom SS10 attic N/E		09163404
0057	Heat Detector	Attic Bldg. F classroom SS10 attic N/W		09163407
0057	Heat Detector	Attic Bldg. F classroom SS10 attic S/E		09163405
0057	Heat Detector	Attic Bldg. F classroom SS10 attic S/W		09163406
0057	Heat Detector	Attic Bldg. F classroom SS11 attic N/E		09163411
0057	Heat Detector	Attic Bldg. F classroom SS11 attic N/W		09163409
0057	Heat Detector	Attic Bldg. F classroom SS11 attic S/E		09163410
0057	Heat Detector	Attic Bldg. F classroom SS11 attic S/W		09163408
0057	Heat Detector	Attic Bldg. F classroom SS2 attic N/E		09163378
0057	Heat Detector	Attic Bldg. F classroom SS2 attic N/W		09163377
0057	Heat Detector	Attic Bldg. F classroom SS3 attic N/E		09163384
0057	Heat Detector	Attic Bldg. F classroom SS3 attic N/W		09163383
0057	Heat Detector	Attic Bldg. F classroom SS4 attic N/E		09163389
0057	Heat Detector	Attic Bldg. F classroom SS4 attic N/W		09163388
0057	Heat Detector	Attic Bldg. F classroom SS5 attic N/E		09163395
0057	Heat Detector	Attic Bldg. F classroom SS5 attic N/W		09163394
0057	Heat Detector	Attic Bldg. F classroom SS6 attic N/E		09163397
0057	Heat Detector	Attic Bldg. F classroom SS6 attic N/W		09163398
0057	Heat Detector	Attic Bldg. F classroom SS7 attic N/E		09163092
0057	Heat Detector	Attic Bldg. F classroom SS7 attic N/W		09163095
0057	Heat Detector	Attic Bldg. F classroom SS7 attic S/E		09163093
0057	Heat Detector	Attic Bldg. F classroom SS7 attic S/W		09163094
0057	Heat Detector	Attic Bldg. F classroom SS8 attic N/E		09163099
0057	Heat Detector	Attic Bldg. F classroom SS8 attic N/W		09163096
0057	Heat Detector	Attic Bldg. F classroom SS8 attic S/E		09163098
0057	Heat Detector	Attic Bldg. F classroom SS8 attic S/W		09163097
0057	Heat Detector	Attic Bldg. F classroom SS9 attic N/E		09163403
0057	Heat Detector	Attic Bldg. F classroom SS9 attic N/W		09163400
0057	Heat Detector	Attic Bldg. F classroom SS9 attic S/E		09163402

Address	Device Type	Location	Type	ScanID
0057	Heat Detector	Attic Bldg. F classroom SS9 attic S/W		09163401
0057	Heat Detector	Attic Bldg. F east locker corridor attic south		09163390
0057	Heat Detector	Attic Bldg. J Lounge room east attic		09163276
0057	Heat Detector	Attic Bldg. J Lounge room west attic		09163275
0057	Heat Detector	Attic Bldg. J Classroom HE1 N/E attic		09163272
0057	Heat Detector	Attic Bldg. J Classroom HE1 N/W attic		09163270
0057	Heat Detector	Attic Bldg. J classroom HE11 attic S/E.		09163281
0057	Heat Detector	Attic Bldg. J classroom HE3 attic N/Center		09163284
0057	Heat Detector	Attic Bldg. J classroom HE3 attic N/E		09163285
0057	Heat Detector	Attic Bldg. J classroom HE4 east attic		09163292
0057	Heat Detector	Attic Bldg. J classroom HE4 west attic		09163291
0057	Heat Detector	Attic Bldg. J classroom HE6 attic N/W		09163280
0057	Heat Detector	Attic Bldg. J classroom HE6 attic S/Center		09163278
0057	Heat Detector	Attic Bldg. J west locker corridor north attic		09163269
0057	Heat Detector	Attic Bldg. J west locker corridor south attic		09163266
0057	Heat Detector	Attic home economics East locker corridor north attic		09163288
0057	Heat Detector	Attic home economics East locker corridor south attic		09163287
0057	Heat Detector	Attic social science east locker corridor attic north		09163391
0057	Smoke Detector	Bldg. 0 Classroom MC2 N/W		09163198
0057	Smoke Detector	Bldg. 0 Classroom MC2 S/W		09163199
0057	Horn/Strobe	Bldg. 0 Inside library main entrance		09163151
0057	Horn/Strobe	Bldg. 0 Inside library main entrance by storage room L11		09163153
0057	Smoke Detector	Bldg. 0 Library Eastside Center/W		09163194
0057	Smoke Detector	Bldg. 0 Library Eastside N/E		09163196
0057	Smoke Detector	Bldg. 0 Library Eastside N/W		09163193
0057	Smoke Detector	Bldg. 0 Library Eastside S/E		09163197
0057	Smoke Detector	Bldg. 0 Library Eastside S/W		09163195
0057	Smoke Detector	Bldg. 0 Library Westside N/E		09163190
0057	Smoke Detector	Bldg. 0 Library Westside N/W		09163189
0057	Smoke Detector	Bldg. 0 Library Westside S/E		09163192
0057	Smoke Detector	Bldg. 0 Library Westside S/W		09163191
0057	Heat Detector	Bldg. 0 Library center .row north		09163086
0057	Heat Detector	Bldg. 0 Library center .row south		09163083
0057	Heat Detector	Bldg. 0 Library center .row south/center		09163084
0057	Smoke Detector	Bldg. 0 Library north office L4		09163165
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 IN north storage rm		09163091
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 IN south storage rm		09163136
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 N		09163090

Address	Device Type	Location	Type	ScanID
		/E		
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 N		09163089
		/W		
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 S		09163087
		/E		
0057	Heat Detector	Bldg. 0 Library textbook storage room L6 S		09163088
		/W		
0057	Horn	Bldg. 0 Outside Classroom MC2		09163186
0057	Horn	Bldg. 0 Outside Library north entrance		09163187
0057	Horn	Bldg. 0 Outside library main entrance		09163150
0057	Horn/Strobe	Bldg. 0 Classroom MC2 south wall		09163175
0057	Horn/Strobe	Bldg. 0 Library Library biography area		45709339
0057	Horn/Strobe	Bldg. 0 Library center on pole by check out stand		09163174
0057	Horn/Strobe	Bldg. 0 Library east wall		09163173
0057	Horn/Strobe	Bldg. 0 Library east wall by north exit		09163164
0057	Horn/Strobe	Bldg. 0 Library eastside south wall by clock		09163158
0057	Horn/Strobe	Bldg. 0 Library westside north wall		09163157
0057	Horn/Strobe	Bldg. 0 Library workroom L9 west wall		09163188
0057	Horn/Strobe	Bldg. 0 custodian room L16		09163184
0057	Horn/Strobe	Bldg. 0 girls restroom by custodian room L16		09163183
0057	Horn/Strobe	Bldg. D. . M13in M5		09163463
0057	Horn/Strobe	Bldg. D. classroom . M5		09163458
0057	Horn/Strobe	Bldg. D. classroom . M5 storage		09163462
0057	Horn/Strobe	Bldg. D. classroom . M8		09163471
0057	Horn/Strobe	Bldg. D. center office		09163428
0057	Horn/Strobe	Bldg. D. east cordor- north		09163446
0057	Horn/Strobe	Bldg. D. east cordor- south		09163447
0057	Horn/Strobe	Bldg. D. storage M17		09163454
0057	Horn/Strobe	Bldg. D. teachers work area. M15		09163457
0057	Horn/Strobe	Bldg. D. west cordor- north		09163420
0057	Horn/Strobe	Bldg. D.Classroom M1		09163413
0057	Horn/Strobe	Bldg. D.Classroom M2		09163422
0057	Horn/Strobe	Bldg. D.Classroom M3		09163439
0057	Horn/Strobe	Bldg. D.Classroom M4		09163448
0057	Horn/Strobe	Bldg. D.Classroom M4 break area		09163449
0057	Horn/Strobe	Bldg. D.Classroom M6		09163438
0057	Horn/Strobe	Bldg. D.Classroom M7		09163429
0057	Horn/Strobe	Bldg. D.west cordor- south		09163421
0057	Horn/Strobe	Bldg. F Classroom SS1		09163297
0057	Horn/Strobe	Bldg. F Classroom SS2		09163298
0057	Horn/Strobe	Bldg. F classroom SS10		09163361
0057	Horn/Strobe	Bldg. F classroom SS3		09163307
0057	Horn/Strobe	Bldg. F classroom SS4		09163316

Address	Device Type	Location	Type	ScanID
0057	Horn/Strobe	Bldg. F classroom SS5		09163327
0057	Horn/Strobe	Bldg. F classroom SS6		09163328
0057	Horn/Strobe	Bldg. F classroom SS7		09163333
0057	Horn/Strobe	Bldg. F classroom SS8		09163371
0057	Horn/Strobe	Bldg. F classroom SS9		09163352
0057	Horn/Strobe	Bldg. F east locker corridor north		09163320
0057	Horn/Strobe	Bldg. F east locker corridor south		09163321
0057	Horn/Strobe	Bldg. F girls restroom by SS8 and entrance		09163339
0057	Horn/Strobe	Bldg. F girls restroom by SS8 and toilet		09163341
0057	Horn/Strobe	Bldg. F girls restroom by SS8 and toilet-north		09163347
0057	Horn/Strobe	Bldg. F girls restroom by SS8 and toilet-south		09163349
0057	Horn/Strobe	Bldg. F mens restroom by SS8 and toilet		09163345
0057	Horn	Bldg. F outside classroom SS4		09163317
0057	Horn	Bldg. F outside classroom SS7		09163338
0057	Heat Detector	Bldg. F west locker corridor north		09163381
0057	Heat Detector	Bldg. F west locker corridor south		09163380
0057	Horn/Strobe	Bldg. F west locker corridor west wall north		09163305
0057	Horn/Strobe	Bldg. F west locker corridor west wall south		09163306
0057	Horn/Strobe	Bldg. F womens restroom by SS8 and toilet		09163344
0057	Horn/Strobe	Bldg. J Classroom HE3 N/W wall		09163217
0057	Horn/Strobe	Bldg. J Classroom HE3 S/W wall		09163216
0057	Heat Detector	Bldg. J Classroom HE3 storage S/W by exit		09163220
0057	Heat Detector	Bldg. J Classroom HE3 storage north by exit		09163223
0057	Horn/Strobe	Bldg. J Classroom HE4		09163209
0057	Horn/Strobe	Bldg. J Classroom HE5		09163208
0057	Horn/Strobe	Bldg. J East locker corridor east wall		09163204
0057	Horn/Strobe	Bldg. J East locker corridor west wall		09163205
0057	Horn/Strobe	Bldg. J Lounge area mens restroom		09163231
0057	Horn/Strobe	Bldg. J Lounge area north wall between restrooms		09163227
0057	Horn/Strobe	Bldg. J Lounge area north wall by clock		09163226
0057	Horn/Strobe	Bldg. J Lounge area womens restroom		09163232
0057	Horn	Bldg. J Outside East by locker side		09163201
0057	Horn	Bldg. J Outside West by locker side		09163200
0057	Heat Detector	Bldg. J Classroom HE1 N/W		09163259
0057	Horn/Strobe	Bldg. J Classroom HE1 eastwall north		09163257
0057	Horn/Strobe	Bldg. J Classroom HE1 eastwall south		09163256
0057	Horn/Strobe	Bldg. J Classroom HE1 storage S/E		09163267

Address	Device Type	Location	Type	ScanID
0057	Heat Detector	Bldg. J Classroom HE1 storage S/W		09163249
0057	Horn/Strobe	Bldg. J Classroom HE3 storage S/W		09163268
0057	Heat Detector	Bldg. J Classroom HE6 fire control panel rm N/W		09163246
0057	Horn/Strobe	Bldg. J Classroom HE6 south wall by clock		09163243
0057	Horn/Strobe	Bldg. J Classroom HE6 south wall eastside		09163238
0057	Horn/Strobe	Bldg. J Classroom HE6 storage S/W		09163265
0057	Heat Detector	Bldg. J custodian room HE15 inside Lounge area		09163235
0057	Horn/Strobe	Bldg. J west locker corridor west wall north		09163262
0057	Horn/Strobe	Bldg. J west locker corridor west wall south		09163263
0057	Horn	Bldg.D outside east		09163466
0057	Horn	Bldg.D outside west		09163412
0057	Strobe	Bldg.N main gym center of gym CENTER /EAST		09164285
0057	Strobe	Bldg.N main gym center of gym CENTER /WEST		09164288
0057	Strobe	Bldg.N main gym center of gym N/E		09164286
0057	Strobe	Bldg.N main gym center of gym N/W		09164289
0057	Strobe	Bldg.N main gym center of gym S/E		09164284
0057	Strobe	Bldg.N main gym center of gym S/W		09164287
0063	Smoke Detector	SMOKE: 4D063 SHOPCLASSROOM 5 LIBRARY		3953575854
0064	Smoke Detector	SMOKE: 4D064 SHOPEAST VESTIBULE		3953711719
0064	Horn/Strobe	building h class ia1		09164470
0064	Horn/Strobe	building h class ia1 north wall		09164472
0064	Horn/Strobe	building h class in hallway		09164471
0064	Horn/Strobe	BLDG.H classroom IA2 .by exit		09163757
0064	Horn/Strobe	BLDG.H classroom IA2 .east wall		09163758
0064	Horn/Strobe	BLDG.H classroom IA3 .by exit		09163759
0064	Communication Line	BLDG.H classroom IA3 east wall		09163761
0064	Horn/Strobe	BLDG.H classroom IA4 by exit		09163762
0064	Horn/Strobe	BLDG.H classroom IA4 north wall		09163763
0064	Horn/Strobe	East industrial arts		09164469
0064	Horn/Strobe	West industrial arts		09164467
0064	Horn/Strobe	middle industrial arts		09164468
0065	Smoke Detector	SMOKE: 4D065 SHOPCLASSROOM 6 OFFICE		3953702014
0066	Heat Detector	HEAT: 4D066 SHOPCLASSROOM 6 ISSUE IA35 rm		3808418367
0067	Smoke Detector	SMOKE: 4D067 SHOPCLASSROOM 6 STORAGE		3953785314
0068	Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6 S/E		3808418145
0069	Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6 N/E		3808419340

Address	Device Type	Location	Type	ScanID
0070	Heat Detector	HEAT: 4D070 SHOPCLASSROOM 6 S/W		3808418152
0071	Heat Detector	HEAT: 4D069 SHOPCLASSROOM 6 S/W		3808417728
0072	Smoke Detector	SMOKE: 4D072 SHOPCLASSROOM 5 NORTH		3953783976
0073	Smoke Detector	SMOKE: 4D073 SHOPCLASSROOM 5 SOUTH		3953783990
0074	Smoke Detector	HEAT: 4D074 SHOPCLASSROOM 4 S/E		3964742405
0075	Heat Detector	HEAT: 4D075 SHOPCLASSROOM 4 N/E		3964742382
0076	Smoke Detector	HEAT: 4D076 SHOPCLASSROOM 4 N/W		3964742528
0077	Heat Detector	HEAT: 4D077 SHOPCLASSROOM 4 S/W		3964716802
0078	Smoke Detector	SMOKE: 4D078 SHOPMAIN HALL (EAST)		3953785406
0079	Smoke Detector	SMOKE: 4D079 SHOPMAIN HALL (EAST)		3953784812
0086	Smoke Detector	SMOKE: 4D086 SHOPN/E CORRIDOR		3953782054
0089	Smoke Detector	SMOKE: 4D089 SHOPWOMENS RESTROOM		3953718398
0090	Smoke Detector	SMOKE: 4D102 SHOPCLASSROOM 9 storage room		3953797522
0091	Smoke Detector	SMOKE: 4D091 SHOP GIRLS' RESTROOM		3953735630
0092	Smoke Detector	SMOKE: 4D092 SHOPCLASSRM. 10 PRINT DRY		3953799038
0093	Smoke Detector	SMOKE: 4D093 SHOPROOM 10 DARKRM ENTRY		3953798826
0096	Smoke Detector	SMOKE: 4D096 SHOPCLASSROOM 9 S /W		3953785000
0099	Smoke Detector	SMOKE: 4D099 SHOPCLASSROOM 9 S /E		3953797607
0100	Smoke Detector	SMOKE: 4D100 SHOPN/E CORRIDOR		3953797461
0101	Smoke Detector	SMOKE: 4D101 SHOPN/E CORRIDOR		3953798444
0103	Smoke Detector	SMOKE: 4D103 SHOPCLASSROOM 8 S /W		3953745141
0104	Smoke Detector	SMOKE: 4D104 SHOPCLASSROOM 8 S /E		3953721176
0130	Pull Station	Bldg. 0 library north exit		09163172

Building: Tokay HS Lodi USD

Control Panel: 5 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	SMOKE: BUSINESS 5D001CUSTODIAN B12		09163492
0003	Smoke Detector	SMOKE: BUSINESS 5D003GIRLS Bathroom EAST		09163495
0003	Smoke Detector	SMOKE: BUSINESS 5D003GIRLS bathroom		08851418

Address	Device Type	Location	Type	ScanID
0004	Smoke Detector	SMOKE: ADMIN LOUNGE A28		09163696
0004	Horn/Strobe	SMOKE: BUSINESS 5D004WEST WOMENS ROOM		09163790
0004	Smoke Detector	SMOKE: BUSINESS 5D004WEST WOMENS ROOM		08851417
0005	Smoke Detector	SMOKE: BUSINESS 5D005ROOM 1 NORTH/WEST		08851414
0006	Horn	: .outside -multipurpose-north		09164039
0006	Horn	: .outside -multipurpose-south		09164038
0006	Horn	: .outside -p11		09164040
0006	Horn	: .outside -p19		09164065
0006	Horn	: OUTSIDE maint. storage-C35		09164042
0006	Horn/Strobe	: BUSINESS 5D006 CLASS B2		09163504
0006	Horn/Strobe	: BUSINESS 5D006 CLASS B20		09163499
0006	Horn	: BUSINESS 5D006 CLASS B20 OUTSIDE		09163505
0006	Horn	: BUSINESS 5D006 CLASS B6 OUTSIDE		09163532
0006	Horn	: BUSINESS 5D006 CLASS s1 OUTSIDE		09163558
0006	Horn	: BUSINESS 5D006 CLASS s6 OUTSIDE		09163577
0006	Horn/Strobe	: BUSINESS 5D006 NORTH LOCKER CORIdor east .		09163509
0006	Horn/Strobe	: BUSINESS 5D006 NORTH LOCKER CORIdor west .		09163508
0006	Horn/Strobe	: BUSINESS 5D006 b5 class .		09163524
0006	Horn/Strobe	: BUSINESS 5D006 bookstore .		09163516
0006	Horn/Strobe	: BUSINESS 5D006 class b3 .		09163514
0006	Horn/Strobe	: BUSINESS 5D006 mens room .		09163538
0006	Horn/Strobe	: BUSINESS 5D006 room .b4 n/w .		09163523
0006	Horn/Strobe	: BUSINESS 5D006 room .b4 s/w .		09163522
0006	Horn/Strobe	: BUSINESS 5D006 room b5 .		09163531
0006	Horn/Strobe	: BUSINESS 5D006GIRLG SROOM		08851420
0006	Horn/Strobe	: BUSINESS 5D006ROOM B 1 WEST		08851419
0006	Horn/Strobe	: BUSINESS 5D006ROOM B 17NORTHWEST		09163493
0006	Horn/Strobe	: BUSINESS 5D006ROOM B 17SOUTHWEST		09163491
0006	Horn/Strobe	: BUSINESS 5D006ROOM B 8 WEST		09163478
0006	Horn/Strobe	: BUSINESS 5D006ROOM GIRLS REST ROOM BY TOILET		09163484
0006	Smoke Detector	SMOKE: BUSINESS 5D006ROOM 1 SOUTH/WEST		09163472
0006	Horn	gym-bldg-N-.outside-lobby		09164073
0006	Horn	gym-bldg-N-.outside-west		09164074
0006	Horn	gym-bldg-N-east		14226390
0006	Smoke Detector	gym-bldg-N-east		09164071
0006	Horn	gym-bldg-N-south		09164072

Address	Device Type	Location	Type	ScanID
0006	Horn	.outside multipurpose-eastside		09163948
0006	Horn	Northeast outside gym		09164070
0007	Smoke Detector	SMOKE: BUSINESS 5D007ROOM 1 SOUTH/EAST		08851416
0008	Smoke Detector	SMOKE: BUSINESS 5D008ROOM 1 NORTH/EAST		08851415
0009	Smoke Detector	SMOKE: BUSINESS 5D009STORAGE FOR DB 13 ROOM 1&8		09163473
0010	Heat Detector	BUSINESS 5D010ROOM 8 NORTH /WEST		09163586
0010	Smoke Detector	SMOKE: BUSINESS 5D010ROOM B8 NORTH/WEST		09163475
0011	Heat Detector	: BUSINESS 5D011ROOM 8 SOUTH /WEST		09163587
0011	Smoke Detector	SMOKE: BUSINESS 5D011ROOMB 8 SOUTH/WEST		09163476
0012	Smoke Detector	SMOKE: BUSINESS 5D012ROOMB8 SOUTH/EAST		09163477
0013	Heat Detector	: BUSINESS 5D013ROOM 8 NORTH /EAST		09163585
0013	Smoke Detector	SMOKE: BUSINESS 5D013ROOMB8 NORTH/EAST		09163474
0016	Smoke Detector	SMOKE: BUSINESS 5D016EAST MENS ROOM		09163539
0017	Smoke Detector	SMOKE: BUSINESS 5D017SOUTH LOCKER SOUTHWEST B17CORRIDOR		09163490
0018	Pull Station	Lobby multipurpose		09163949
0018	Horn/Strobe	-boys-locker-outside-G24		09164128
0018	Horn/Strobe	-boys-locker-outside-G24-north shower		09164126
0018	Horn/Strobe	-boys-locker-outside-G24-north shower		09164127
0018	Horn/Strobe	-boys-locker-outside-G28		09164113
0018	Horn/Strobe	-boys-locker-team room-G27-east		09164129
0018	Horn/Strobe	-boys-locker-team room-G27-west		09164134
0018	Horn/Strobe	-wrestling room-G28-		09164136
0018	Heat Detector	.boys-shower-G8		09164085
0018	Horn/Strobe	.boys-shower-G8		09164084
0018	Horn/Strobe	Gym Wrestling Room		14226374
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s s 11 storageroom		09163549
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s s s2		09163555
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s s s4		09163570
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s s s5		09163576
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s s s6		09163584
0018	Horn/Strobe	SMOKE: BUSINESS 5D0 s3		09163565
0018	Smoke Detector	SMOKE: BUSINESS 5D018ROOM 7 SOUTH/WEST		09163533
0018	Horn/Strobe	between restroom-lobby -		09164157

Address	Device Type	Location	Type	ScanID
0018	Horn/Strobe	boys-locker first aide		14227184
0018	Horn/Strobe	boys-locker-outside-custodial-G11		09164086
0018	Horn/Strobe	boys-locker-outside-office		09164094
0018	Horn/Strobe	boys-locker-outside-office N		14227183
0018	Horn/Strobe	boys-locker-restroom		09164089
0018	Horn/Strobe	building -multipurpose-inside G4- .snack bar . l -girls locker room		09164252
0018	Horn/Strobe	building gym.-inside dancer room-g29 - inside G4- .snack bar . l -girls locker room		09164256
0018	Heat Detector	building -N-mens-staff-shower		09164080
0018	Horn/Strobe	building -N-mens-staff-shower		09164077
0018	Horn/Strobe	building -N-mens-staff-shower-restroom		09164078
0018	Horn/Strobe	building -N-outside-office-G17		09164075
0018	Horn/Strobe	building -multipurpse-C18 mens restroom		09164033
0018	Horn/Strobe	building -multipurpse-C18 staff dining-north		09164029
0018	Horn/Strobe	building -multipurpse-C18 staff dining-north		09164030
0018	Horn/Strobe	building -multipurpse-C18 womens restroom		09164034
0018	Horn/Strobe	building -multipurpse-C21 kitchen		09164015
0018	Horn/Strobe	building -multipurpse-C26 kitchen-east		09164002
0018	Horn/Strobe	building -multipurpse-C26 kitchen-restroom		09164006
0018	Horn/Strobe	building -multipurpse-C26 kitchen-restroom inside		09164007
0018	Horn/Strobe	building -multipurpse-C26 kitchen-roll up door		09164004
0018	Horn/Strobe	building -multipurpse-C35 maint.		09164014
0018	Horn/Strobe	building -multipurpse-C35 maint. -restroom		09164013
0018	Horn/Strobe	building -p11		09164041
0018	Horn/Strobe	building -p12		09164046
0018	Horn/Strobe	building -p13		09164049
0018	Horn/Strobe	building -p14		09164052
0018	Horn/Strobe	building -p15		09164055
0018	Horn/Strobe	building -p16		09164058
0018	Horn/Strobe	building -p17		09164061
0018	Horn/Strobe	building -p18		09164066
0018	Horn/Strobe	building -p19		09164067
0018	Horn/Strobe	building L admin assistant principal a38		09163712
0018	Horn/Strobe	building L admin assistant principal a39		09163715
0018	Horn/Strobe	building L admin assistant principal a40		09163716
0018	Horn/Strobe	building L admin conference room a		09163664
0018	Horn/Strobe	building L admin conference room a33		09163721
0018	Horn/Strobe	building L admin conference room b		09163672
0018	Horn/Strobe	building L admin counseling room west		09163679

Address	Device Type	Location	Type	ScanID
0018	Horn/Strobe	building L admin counselor a10		09163667
0018	Horn/Strobe	building L admin counselor a11		09163660
0018	Horn/Strobe	building L admin counselor a12		09163659
0018	Horn/Strobe	building L admin counselor a14		09163656
0018	Horn/Strobe	building L admin counselor a15		09163655
0018	Horn/Strobe	building L admin counselor a6		09163671
0018	Horn/Strobe	building L admin counselor a7		09163668
0018	Horn/Strobe	building L admin duplicating room a8		09163680
0018	Horn/Strobe	building L admin hall west boys restroom		09163694
0018	Horn/Strobe	building L admin hall west girls restroom		09163698
0018	Horn/Strobe	building L admin hall west lounge room a28		09163699
0018	Horn/Strobe	building L admin hall west north		09163685
0018	Horn/Strobe	building L admin hall west north outside registrar		14227181
0018	Horn/Strobe	building L admin hall west south		09163693
0018	Horn/Strobe	building L admin hallway near counselor a10		09163662
0018	Horn/Strobe	building L admin intake office a31		09163700
0018	Horn/Strobe	building L admin nurse a32		09163706
0018	Horn	building L admin outside north		09163723
0018	Horn	building L admin outside south		09163722
Zone/Circuit: 2				
18	Horn	building L admin outside south		45709322
Zone/Circuit: 02				
0018	Horn/Strobe	building L admin registan a3		09163675
0018	Horn/Strobe	building L admin storage a37		09163719
0018	Horn/Strobe	building L admin student services		09163709
0018	Horn/Strobe	building L admin teacher prep room a13		09163683
0018	Horn/Strobe	building L admin welfare office		09163711
0018	Horn/Strobe	building L admin. main office east wall		09163640
0018	Horn/Strobe	building L admin. main office southwest wall		09163642
0018	Horn/Strobe	building L admin. in work room a24		09163630
0018	Horn/Strobe	building L admin. mens restroom		09163631
0018	Horn/Strobe	building L admin. nearwork room a24		09163627
0018	Horn/Strobe	building L admin. principal a26		09163645
0018	Horn/Strobe	building L admin. vice prin a25		09163635
0018	Horn/Strobe	building L admin.girls restroom		09163651
0018	Horn/Strobe	building L admin.lounge 17		09163650
0018	Horn/Strobe	building N -gym outside - .girls locker I . I - girls locker room		09164244
0018	Horn/Strobe	building N -gym-by G31 -girls locker room		09164217
0018	Heat Detector	building N -gym-by G45- .girls locker shower I . I -girls locker room		09164235
0018	Horn/Strobe	building N -gym-by G45- .girls locker		09164236

Address	Device Type	Location	Type	ScanID
		shower I . I -girls locker room		
0018	Horn/Strobe	building N -gym-by exit and .girls locker restroom I . I -girls locker room		09164221
0018	Horn/Strobe	building N -gym-by exit and .girls locker shower I . I -girls locker room		09164223
0018	Horn/Strobe	building N -gym-by exit inside g46 I . I - girls locker room		09164233
0018	Horn/Strobe	building N -gym-by exit outside g45 I . I - girls locker room		09164234
0018	Horn/Strobe	building N -gym-inside G45- .girls locker I . I -girls locker room		09164238
0018	Horn/Strobe	building N -gym-inside G45- .womens staff locker I . I -girls locker room		09164241
0018	Horn/Strobe	building N -gym-inside G45- .womens staff toilet I . I -girls locker room		09164242
0018	Horn/Strobe	building N -gym-restroom -girls		09164214
0018	Horn/Strobe	building N -gym-west		09164201
0018	Horn/Strobe	east-dancer room-G28-		09164138
0018	Horn/Strobe	kitchen servin.g area S kitchen		09164037
0018	Horn/Strobe	kitchen servin.g area by freezer kitchen		14227188
0018	Horn/Strobe	kitchen serving area W		09163995
0018	Horn/Strobe	kitchen serving area middle wall		09164000
0018	Horn/Strobe	mens restroom-lobby -		09164156
0018	Horn/Strobe	mens restroom-lobby -		09164158
0018	Horn/Strobe	outside-boys-locker-.-G11		09164112
0018	Horn/Strobe	outside-boys-locker-boiler room-G25-		09164135
0018	Horn/Strobe	west-dancer room-G28-		09164137
0018	Pull Station	C12 multipurpose		09163969
0018	Horn/Strobe	double door-by .lobby-athletic director bldg. N-gym		09164161
0018	Pull Station	double door-by .lobby-athletic director bldg. N-gym		09164160
0018	Pull Station	double door-lobby bldg. N-gym		09164153
0018	Pull Station	double door-north multipurpose		09163991
0018	Horn/Strobe	english boys small restroom		09163833
0018	Horn/Strobe	english e1		09163813
0018	Horn/Strobe	english e10		09163877
0018	Horn/Strobe	english e11		09163882
0018	Horn/Strobe	english e2		09163818
0018	Horn/Strobe	english e3		09163838
0018	Horn/Strobe	english e4.		09163847
0018	Horn/Strobe	english e5		09163852
0018	Horn/Strobe	english e6		09163857
0018	Horn/Strobe	english e7		09163862
0018	Horn/Strobe	english e8		09163868
0018	Horn/Strobe	english e9		09163872

Address	Device Type	Location	Type	ScanID
0018	Horn/Strobe	english east hallway north		09163824
0018	Horn/Strobe	english east hallway south		09163823
0018	Horn/Strobe	english girls large restroom by .sink		09163829
0018	Horn/Strobe	english girls large restroom by door		09163828
0018	Horn/Strobe	english girls small restroom		09163831
0018	Horn/Strobe	english large large restroom by door		09163835
0018	Horn/Strobe	english large large restroom by toilet		09163836
0018	Horn/Strobe	english meeting room north		09163844
0018	Horn/Strobe	english meeting room south		09163843
0018	Horn	english north		09163887
0018	Horn	english south		09163888
0018	Horn/Strobe	gym. west near boys lockerroom G1		09164194
0018	Horn/Strobe	gym. west center G1		09164193
0018	Heat Detector	mens locker office staff shower hallway		3808255481
0018	Horn/Strobe	multipurpose- -by .double doors-northside		09163989
0018	Horn/Strobe	multipurpose- -by .window-westside		09163982
0018	Horn/Strobe	multipurpose- -by servery and trophy case		09163980
0018	Horn/Strobe	multipurpose- C21-by servery.		09163977
0018	Horn/Strobe	multipurpose- C8-conflict mgmt.		09163971
0018	Horn/Strobe	multipurpose- Lobby		09163967
0018	Horn/Strobe	multipurpose-C12-storage		09163964
0018	Horn/Strobe	multipurpose-boys Lobby-restroom		09163954
0018	Horn/Strobe	multipurpose-girls Lobby-restroom		09163951
0018	Horn/Strobe	multipurpose-student lounge-C12-student govern.		09163961
0018	Horn/Strobe	multipurpose-student lounge-C9-north		09163956
0018	Horn/Strobe	multipurpose-student lounge-C9-south		09163957
0018	Horn	new science bldg.-between SC2 and SC1		09164298
0018	Horn	new science bldg.-outside back sc8		09164347
0018	Horn	new science bldg.-outside front sc8		09164345
0018	Horn	East outside building k		09164349
0018	Horn	North outside building k		09164348
0018	Horn	West outside building k		09164346
0018	Horn/Strobe	gym. east- above water fountain G1		09164195
0018	Horn/Strobe	gym. center east G1		09164197
0018	Pull Station	gym. center-east G1		09164196
0018	Pull Station	gym. east G1		09164199
0018	Pull Station	gym. southeast G1		09164198
0018	Pull Station	gym. southeast G1		09164200
0018	Pull Station	gym. southwest G1		09164202
0018	Pull Station	gym. west G1		09164254
0019	Smoke Detector	SMOKE: BUSINESS 5D019ROOM 7 SOUTH/EAST		09163536
0020	Smoke Detector	SMOKE: BUSINESS 5D020ROOM 7 NORTH/EAST		09163534

Address	Device Type	Location	Type	ScanID
0021	Smoke Detector	SMOKE: BUSINESS 5D021ROOM 7 NORTH/WEST		09163535
0022	Smoke Detector	SMOKE: BUSINESS 5D022ROOM 6 WEST		09163530
0022	Heat Detector	Business 6 West		09163597
0023	Smoke Detector	SMOKE: BUSINESS 5D023ROOM 6 EAST		09163529
0024	Smoke Detector	SMOKE: BUSINESS 5D024NORTH LOCKER CORRIDOR		09163507
0025	Smoke Detector	SMOKE: BUSINESS 5D025ROOM 5 SOUTH/WEST		09163528
0026	Smoke Detector	SMOKE: BUSINESS 5D026ROOM 5 SOUTH/EAST		09163525
0027	Smoke Detector	SMOKE: BUSINESS 5D027ROOM 5 NORTH/EAST		09163526
0027	Heat Detector	heat BUSINESS 5D027ROOM 5 NORTH /EAST		09163607
0028	Smoke Detector	SMOKE: BUSINESS 5D028ROOM 5 NORTH/WEST		09163527
0029	Smoke Detector	SMOKE: BUSINESS 5D029ROOM 4 SOUTH/WEST		09163519
0030	Smoke Detector	SMOKE: BUSINESS 5D030ROOM 4 SOUTH/EAST		09163520
0031	Smoke Detector	SMOKE: BUSINESS 5D031ROOM 4 NORTH/EAST		09163521
0032	Smoke Detector	SMOKE: BUSINESS 5D032ROOM 4 NORTH/WEST		09163518
0033	Smoke Detector	SMOKE: BUSINESS 5D033ROOM 4 STORAGE		09163517
0034	Smoke Detector	SMOKE: BUSINESS 5D034BOOKSTORE		09163515
0035	Smoke Detector	SMOKE: BUSINESS 5D035ROOM 3 NORTH/WEST		09163513
0036	Smoke Detector	SMOKE: BUSINESS 5D036ROOM 3 NORTH/EAST		09163512
0037	Smoke Detector	SMOKE: BUSINESS 5D037ROOM 3 SOUTH/EAST		09163511
0038	Smoke Detector	SMOKE: BUSINESS 5D038ROOM 3 SOUTH/WEST		09163510
0039	Smoke Detector	SMOKE: BUSINESS 5D039NORTH LOCKER CORRIDOR		09163506
0041	Heat Detector	: BUSINESS 5D041ROOM 2 NORTH /EAST over duct		61237518
0041	Heat Detector	: BUSINESS 5D041ROOM 2 NORTH /WEST		09163593
0041	Smoke Detector	SMOKE: BUSINESS 5D041ROOM 2 NORTH/WEST		09163500
0042	Heat Detector	BUSINESS 5D042ROOM 2 NORTH/EAST		09163594
0042	Smoke Detector	SMOKE: BUSINESS 5D042ROOM 2		09163502

Address	Device Type	Location	Type	ScanID
		NORTH/EAST		
0043	Heat Detector	: BUSINESS 5D043ROOM 2 SOUTH /EAST		09163595
0043	Smoke Detector	SMOKE: BUSINESS 5D043ROOM 2 SOUTH/EAST		09163503
0044	Smoke Detector	SMOKE: BUSINESS 5D044ROOM 2 SOUTH/WEST		09163501
0045	Heat Detector	: BUSINESS 5D045BUSINESS MACHINE WEST		09163591
0045	Smoke Detector	SMOKE: BUSINESS 5D045BUSINESS MACHINE WEST		09163496
0046	Smoke Detector	SMOKE: BUSINESS 5D046BUSINESS MACHINE EAST		09163497
0048	Smoke Detector	SMOKE: BUSINESS 5D048WEST STORAGE ROOM		09163494
0049	Smoke Detector	SMOKE: BUSINESS 5D049SOUTH LOCKER B17westCORRIDOR		09163489
0050	Heat Detector	Attic Hatch Business South hall	Combination	61237504
00126	Heat Detector	: BUSINESS 5D012ROOM 8 SOUTH /EAST		09163588
0126	Heat Detector	Attic Hatch Business South Hall East	Combination	09163589
0126	Heat Detector	Attic Hatch Business South Hall West		09163590
0127	Heat Detector	: BUSINESS 5D019ROOM 7 SOUTH /EAST		09163601
0127	Heat Detector	: BUSINESS 5D046BUSINESS MACHINE EAST	Combination	09163592
0127	Heat Detector	SMOKE: BUSINESS 5D018ROOM 7 SOUTH/WEST		09163600
0127	Heat Detector	heat BUSINESS 5D020ROOM 7 NORTH /EAST		09163602
0127	Heat Detector	heat: BUSINESS 5D021ROOM 7 NORTH /WEST	Combination	09163603
0127	Heat Detector	Business 6 East	Combination	09163598
0127	Heat Detector	Attic Hatch B18 Storage (in B19) East	Combination	61237508
0127	Heat Detector	Attic Hatch B18 Storage (in B19) West	Combination	61237507
0128	Heat Detector	Attic B3 NE		09163612
0128	Heat Detector	heat BUSINESS 5D025ROOM 5 SOUTH /WEST		09163605
0128	Heat Detector	heat BUSINESS 5D026ROOM 5 SOUTH /EAST	Combination	09163604
0128	Heat Detector	heat BUSINESS 5D029ROOM 4 SOUTH /WEST		09163610
0128	Heat Detector	heat BUSINESS 5D031ROOM 4 NORTH /EAST		09163608
0128	Heat Detector	heat BUSINESS 5D032ROOM 4 NORTH /WEST		09163609
0128	Heat Detector	heat: BUSINESS 5D028ROOM 5 NORTH /WEST		09163606

Address	Device Type	Location	Type	ScanID
0128	Heat Detector	heat: BUSINESS 5D030ROOM 4 SOUTH /EAST		09163611
0128	Heat Detector	B North hall		20411027
0128	Heat Detector	B3 SE		09163614
0128	Heat Detector	B3 SW		09163615
0128	Heat Detector	B3 NE		09163613
0128	Heat Detector	Attic Hatch SMOKE: BUSINESS 5D024NORTH LOCKER CORRIDOR		09163599
0131	Heat Detector	Attic P1 north		09163889
(unknown)	Heat Detector	B Bookroom (Access west of B21 Storage (in 4))		09163617
(unknown)	Heat Detector	B19		61237509
(unknown)	Heat Detector	B21 Storage (in 4)		61237506

Building: Tokay HS Lodi USD

Control Panel: 6 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0003	Smoke Detector	Bldg. 0 Library center .row south/center		09163161
0006	Smoke Detector	Bldg. 0 Library workroom L9 west		09163155
0007	Smoke Detector	Bldg. 0 Library workroom L9 east		09163154
0008	Smoke Detector	Bldg. 0 Library office L10 inside workroom L9		09163156
0010	Smoke Detector	Bldg. 0 Library in main entrance		09163181
0011	Smoke Detector	Bldg. 0 Library storage L11		09163142
0013	Smoke Detector	Bldg. 0 Library work experience office L14		09163159
0014	Smoke Detector	Bldg. 0 girls restroom by custodian room L16		09163182
0015	Smoke Detector	Bldg. 0 custodian room L16		09163185
0020	Smoke Detector	Bldg. 0 Classroom MC2 S/E		09163176
0023	Smoke Detector	Bldg. 0 Classroom MC2 N/E		69506034
0024	Smoke Detector	Bldg. 0 insideClassroom MC2 workroom east		69506035
0025	Smoke Detector	Bldg. 0 insideClassroom MC2 workroom center		69506036
0026	Smoke Detector	Bldg. 0 insideClassroom MC2 workroom west		69506037
0030	Smoke Detector	Bldg. 0 Library center .row north		09163163
0031	Smoke Detector	Bldg. 0 Library textbook storage room L6 N /E		09163168
0032	Smoke Detector	Bldg. 0 Library textbook storage room L6 N /W		09163169
0034	Smoke Detector	Bldg. 0 Library textbook storage room L6 south storage		09163171
0035	Smoke Detector	Bldg. 0 Library textbook storage room L6 S /W		09163166

Address	Device Type	Location	Type	ScanID
0036	Smoke Detector	Bldg. 0 Library textbook storage room L6 S /E		09163167
0129	Pull Station	Bldg. 0 Inside library main entrance		09163152

Building: Tokay HS Lodi USD

Control Panel: 7 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	SMOKE: CAFETERIA D001JANITOR M2		09163983
0005	Smoke Detector	SMOKE: CAFETERIA D005STUDENT DINING NORTH		09163986
0006	Smoke Detector	SMOKE: CAFETERIA D006STUDENT DINING NORTH		09163987
0007	Smoke Detector	SMOKE: CAFETERIA D007STUDENT DINING NORTH		09163988
0008	Smoke Detector	SMOKE: CAFETERIA D008STUDENT DINING NORTH		09163974
0009	Smoke Detector	SMOKE: CAFETERIA D009NORTH TRIANGLE ROOM		09163973
0010	Smoke Detector	SMOKE: CAFETERIA D010STUDENT CENTER N/W		09163985
0011	Smoke Detector	SMOKE: CAFETERIA D011STUDENT CENTER N/E		09163970
0012	Smoke Detector	SMOKE: CAFETERIA D012STUDENT CENTER MID/E		09163965
0017	Smoke Detector	SMOKE: CAFETERIA D017STUDENT CENTER S/E		09163958
0019	Smoke Detector	SMOKE: CAFETERIA D019STUDENT CENTER MID/W		09163968
0020	Smoke Detector	SMOKE: CAFETERIA D020STUDENT DINING MIDDLE		09163975
0021	Smoke Detector	CAFETERIA D021STUDENT DINING MIDDLEEAST		09163993
0022	Smoke Detector	CAFETERIA D022STUDENT DINING MIDDLEWEST		09163992
0023	Smoke Detector	SMOKE: CAFETERIA D023STUDENT DINING MIDDLE		09163981
0025	Smoke Detector	CAFETERIAD025MAINT.. SHOP S		09164010
0026	Smoke Detector	SMOKE: CAFETERIA D026STUDENT DINING SOUTH		09163999
0027	Smoke Detector	SMOKE: CAFETERIA D027STUDENT DINING SOUTH		09163979
0028	Smoke Detector	SMOKE: CAFETERIA D028STUDENT DINING SOUTH		09163978
0029	Smoke Detector	SMOKE: CAFETERIA D029STUDENT DINING SOUTH		09163976
0030	Smoke Detector	SMOKE: CAFETERIA D030EAST ENTRY		09163950

Address	Device Type	Location	Type	ScanID
		WAY		
0031	Smoke Detector	SMOKE: CAFETERIA D031GIRLS M12		09163952
0032	Heat Detector	HEAT: CAFETERIA D032 GIRLS M12		69506106
0033	Smoke Detector	SMOKE: CAFETERIA D033RESTROOM ENTRY		09164063
0034	Smoke Detector	SMOKE: CAFETERIA D034MENS ROOM M15		09164031
0035	Smoke Detector	SMOKE: CAFETERIA D035WOMENS ROOM M16		09164032
0036	Smoke Detector	SMOKE: CAFETERIA D036FACULTY LOUNGE M18		09164027
0037	Smoke Detector	SMOKE: CAFETERIA D037FACULTY DINING SOUTH		09164026
0038	Smoke Detector	CAFETERIA D038FACULTY DINING NORTH		09164028
0039	Smoke Detector	SMOKE: CAFETERIA D039BOYS M11		09163955
0040	Heat Detector	HEAT: CAFETERIA D040 BOYS M11		69506105
0041	Smoke Detector	SMOKE: CAFETERIA D041SERVERY N /E		09163996
0042	Smoke Detector	SMOKE: CAFETERIA D042STORAGE M22		09163994
0043	Smoke Detector	SMOKE: CAFETERIA D043SERVERY N /W		09163997
0044	Smoke Detector	SMOKE: CAFETERIA D044SERVERY M25		09163998
0045	Smoke Detector	SMOKE: CAFETERIA D045CORRIDOR N /E M19		09164036
0046	Smoke Detector	SMOKE: CAFETERIA D046CORRIDOR S /E M19		09164025
0047	Smoke Detector	SMOKE: CAFETERIA D047CORRIDOR S /W M19		09164017
0047	Heat Detector	c26 kitchen by dry storage		09164023
0047	Heat Detector	c26 kitchen by office		09164022
0047	Heat Detector	c27 custodian		09164024
0047	Heat Detector	servery C4 snack bar inside dry storage i		09164192
0047	Heat Detector	servery C4 snack bar inside dry storage i		09164250
0047	Heat Detector	servery c24 between ovens		09164019
0047	Heat Detector	servery c25rollup door		09164020
0047	Heat Detector	servery c26 kitchen by freezer		09164021
0047	Heat Detector	servery c28 kitchen inside dry storage i		09164247
0048	Smoke Detector	SMOKE: CAFETERIA D048CORRIDOR N /W M19		09164035
0049	Smoke Detector	SMOKE: CAFETERIA D049JANITOR M26		09164018
0051	Smoke Detector	SMOKE: CAFETERIA D051TRASH ROOM M28		09164016
0053	Smoke Detector	SMOKE: CAFETERIA D053LOCKER M30		09164005
0054	Smoke Detector	SMOKE: CAFETERIA D054TOILET M28		09164008

Address	Device Type	Location	Type	ScanID
0055	Smoke Detector	CAFETERIA D055BOILER ROOM M35		09164009
0058	Smoke Detector	SMOKE: CAFETERIA D058STUDENT CNTR SUPPLY		09163984
Building: Tokay HS Lodi USD			Control Panel: 8 - EST EST3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	Bldg.D classroom M16 electrical rm. inside M4		09163455
0002	Smoke Detector	Bldg.D classroom M17 storage		09163453
0003	Smoke Detector	Bldg.D classroom M4 break area		09163450
0004	Heat Detector	Attic attic heat : MATH 8D004 ROOM 4 WEST		09163125
0004	Smoke Detector	Bldg.D classroom M4 north		09163451
0005	Heat Detector	Attic heat attic: MATH 8D005 NORTH LOCKER CORRIDOR		09163124
0005	Smoke Detector	Bldg.D Locker east cordor-north		09163444
0007	Heat Detector	Attic heat attic: MATH 8D007 ROOM 3 NORTH/WEST		09163127
0007	Smoke Detector	Bldg.D classroom M6 S/W		09163440
0009	Heat Detector	Attic heat attic: MATH 8D009 ROOM 2 NORTH/WEST		69506049
0009	Smoke Detector	Bldg.D classroom M2 N/E		09163426
0010	Heat Detector	Attic attic heat: MATH 8D010 ROOM 2 SOUTH/WEST		09163128
0010	Smoke Detector	Bldg.D classroom M2 N/W		09163423
0011	Heat Detector	Attic heat attic: MATH 8D011 ROOM 1 NORTH/WEST		09163130
0011	Smoke Detector	Bldg.D classroom M1 N/E		09163414
0012	Heat Detector	Attic heat attic: MATH 8D012 ROOM 1 SOUTH/EAST		09163116
0012	Heat Detector	Attic heat attic: MATH 8D012 ROOM 1 SOUTH/WEST		09163120
0012	Smoke Detector	Bldg.D classroom M1 N/W		09163415
0013	Smoke Detector	Bldg.D classroom M1 S./W		09163416
0014	Heat Detector	Attic heat attic: MATH 8D014 ROOM 8 SOUTH/WEST		09163799
0014	Smoke Detector	Bldg.D classroom M8 N/W		09163469
Zone/Circuit: 2				
14	Smoke Detector	Bldg.D classroom M8 S/W		3955350732
Zone/Circuit: 02				
0015	Heat Detector	Attic heat attic.: MATH 8D015 ROOM 8 SOUTH/EAST		09163787
0016	Heat Detector	Attic attic heat: MATH 8D016 ROOM 8 NORTH/EAST		69506050

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 2				
16	Smoke Detector	Bldg.D classroom M8 S/E		3996415810
Zone/Circuit: 02				
0017	Heat Detector	Attic heat attic: english e3 north east		09163923
0017	Heat Detector	Attic heat attic: english e3 north west		09163922
0017	Heat Detector	Attic heat attic: english e3 south east		09163920
0017	Heat Detector	Attic heat attic: english e3 south west		09163921
0017	Heat Detector	Attic heat attic: english meeting room north		09163925
0017	Heat Detector	Attic heat attic: english meeting room south		09163924
0017	Smoke Detector	Bldg.D classroom M8 N/E		09163468
0018	Heat Detector	Attic heat attic: MATH 8D018 ROOM 1 NORTH/EAST		09163129
0018	Smoke Detector	Bldg.D classroom M1 S/E		09163417
0019	Heat Detector	Attic heat attic: MATH 8D019 SOUTH LOCKER CORRIDOR		09163121
0019	Smoke Detector	Bldg.D Locker west cordor-north		09163418
0021	Heat Detector	Attic attic heat : MATH 8D021 SOUTH LOCKER CORRIDOR		09163755
0021	Smoke Detector	Bldg.D Locker west cordor-south		09163419
0022	Heat Detector	Attic heat attic: MATH 8D022 ROOM 7 SOUTH/EAST		09163751
0022	Smoke Detector	Bldg.D classroom M7 S/W		09163431
0023	Heat Detector	Attic heat attic: MATH 8D023 ROOM 7 SOUTH/WEST		09163754
0023	Smoke Detector	Bldg.D classroom M7. N/W		09163430
0024	Heat Detector	Attic heat attic: MATH 8D024 ROOM 2 SOUTH/EAST		09163122
0024	Smoke Detector	Bldg.D classroom M2 S/W		09163424
0025	Heat Detector	Attic attic heat: MATH 8D025 ROOM 2 NORTH/EAST		09163117
0025	Smoke Detector	Bldg.D classroom M2 S/E		09163425
0026	Smoke Detector	Bldg.D classroom center office		09163427
0027	Heat Detector	Attic heat attic : MATH 8D027 ROOM 7 NORTH/WEST		09163753
0028	Heat Detector	Attic heat attic: MATH 8D028 ROOM 7 NORTH/EAST		09163752
0028	Smoke Detector	Bldg.D classroom M7 S/E		09163432
0029	Heat Detector	Attic attic heat: MATH 8D029 ROOM 6 SOUTH/EAST		09163749
0029	Smoke Detector	Bldg.D classroom M6 S/W		09163437
0030	Heat Detector	Attic heat attic: MATH 8D030 ROOM 6 SOUTH/WEST		09163750
0030	Smoke Detector	Bldg.D classroom M6 S/W		09163434
0031	Smoke Detector	Bldg.D classroom M6 N/E		09163443
0032	Heat Detector	Attic attic heat: MATH 8D032 ROOM 3 NORTH/EAST		09163118

Address	Device Type	Location	Type	ScanID
0032	Smoke Detector	Bldg.D classroom M3 N/W		09163442
0033	Heat Detector	Attic heat attic: MATH 8D033 ROOM 6 NORTH/WEST		09163748
0033	Smoke Detector	Bldg.D classroom M6 N/E		09163435
0034	Heat Detector	Attic heat attic: MATH 8D034 ROOM 6 NORTH/EAST		09163747
0034	Smoke Detector	Bldg.D classroom M6 S/E		09163436
0035	Heat Detector	Attic attic heat: MATH 8D035 NORTH LOCKER CORRIDOR		09163745
0035	Smoke Detector	Bldg.D Locker east cordor-sout.h		09163445
0036	Heat Detector	Attic heat attic: MATH 8D036 ROOM 5 EAST		09163746
0036	Smoke Detector	Bldg.D classroom M5 north		09163460
0037	Smoke Detector	Bldg.D classroom M5 computer lab		09163461
0038	Smoke Detector	Bldg.D classroom M13 in M5		09163464
0039	Smoke Detector	Bldg.D storage M14 in M5		09163465
0040	Heat Detector	Attic heat attic room 5 west. : MATH 8D040 ROOM 5 WEST		09163744
0040	Smoke Detector	Bldg.D classroom M5 south		09163459
0041	Heat Detector	Attic heat attic: MATH 8D041 ROOM 4 EAST		09163743
0041	Smoke Detector	Bldg.D classroom M4 south		09163452

Building: Tokay HS Lodi USD

Control Panel: 9 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Heat Detector	HEAT: BLDG. S 9D001STORAGE ROOM S13		09163103
0001	Smoke Detector	SMOKE: BLDG. S 9D001STORAGE ROOM S13		09163560
0002	Heat Detector	BLDG. S 9D002CLASSROOM 2 N/W		09163551
0002	Heat Detector	heat BLDG. S 9D002CLASSROOM 2 N/W		09163625
0003	Heat Detector	BLDG. S 9D003CLASSROOM 2 S/W		09163552
0003	Heat Detector	heat BLDG. S 9D003CLASSROOM 2 S/W		09163626
0003	Heat Detector	heat-shower-G31		09164224
0003	Heat Detector	heat-shower-by G40-bldg N		09164229
0004	Heat Detector	BLDG. S 9D012 CLASSROOM s2		09163554
0005	Smoke Detector	SMOKE: BLDG. S 9D005WORKROOM C2 SOUTH		09163548
0005	Heat Detector	heat: BLDG. S 9D005WORKROOM S11 SOUTH		09163621
0006	Heat Detector	BLDG. S 9D006CLASSROOM 1 S/W		09163544
0006	Heat Detector	heat: BLDG. S 9D006CLASSROOM 1 S /W		09163618
0007	Heat Detector	SMOKE: BLDG. S 9D007CLASSROOM 1		09163545

Address	Device Type	Location	Type	ScanID
		S/E		
0007	Heat Detector	heat: BLDG. S 9D007CLASSROOM 1 S/E		09163620
0008	Heat Detector	SMOKE: BLDG. S 9D008CLASSROOM 1 N/E		09163546
0008	Heat Detector	heat: BLDG. S 9D008CLASSROOM 1 N/E		09163619
0008	Heat Detector	heat: BLDG. S 9D008CLASSROOM s2 N /w		09163623
0009	Heat Detector	SMOKE: BLDG. S 9D009CLASSROOM 1 N/W		3808873739
0009	Heat Detector	heat: BLDG. S 9D009CLASSROOM 1 N /W		09163616
0010	Heat Detector	HEAT: BLDG. S 9D010DARKROOM s10 between S1 & S2		09163557
0010	Heat Detector	HEAT: BLDG. S 9D010DARKROOM C3 S10 inside S11		09163622
0011	Heat Detector	HEAT: BLDG. S 9D011WORKROOM CLOSET next to Darkroom between S1 & S2		09163556
0012	Heat Detector	BLDG. S 9D012 CLASSROOM 2 N/E		09163550
0012	Heat Detector	SMOKE: BLDG. S 9D012 CLASSROOM s1		09163553
0012	Heat Detector	heat BLDG. S 9D012 CLASSROOM 2 N/E		09163624
0013	Smoke Detector	SMOKE: BLDG. S 9D013 OFFICE C5		09163559
0014	Heat Detector	BLDG. S 9D014 CLASSROOM 3 S/E		09163561
0014	Heat Detector	HEAT: BLDG. S 9D014 CLASSROOM 3 S /E		09163134
0015	Heat Detector	BLDG. S 9D015 CLASSROOM 3 S/W		09163564
0015	Heat Detector	HEAT: BLDG. S 9D015 CLASSROOM 3 S /W		09163100
0016	Heat Detector	Attic english e1 attic heat northeast		09163911
0016	Heat Detector	Attic english e1 attic heat northwest		09163912
0016	Heat Detector	Attic english e1 attic heat southeast		09163910
0016	Heat Detector	Attic english e1 attic heat southwest		09163909
0016	Heat Detector	Attic english e12 hallway attic heat north		09163918
0016	Heat Detector	Attic english e12 hallway attic heat south		09163917
0016	Heat Detector	Attic english e2 attic heat northeast		09163916
0016	Heat Detector	Attic english e2 attic heat northwest		09163915
0016	Heat Detector	Attic english e2 attic heat southeast		09163913
0016	Heat Detector	Attic english e2 attic heat southwest		09163914
0016	Heat Detector	.heat BLDG. S 9D016 CLASSROOM 3 N /W		09163563
0016	Heat Detector	HEAT...: BLDG. S 9D016 CLASSROOM 3 N/W		09163101
0017	Heat Detector	Attic english attic heat north weast e5		09163943
0017	Heat Detector	Attic english attic heat north east e10		09164107
0017	Heat Detector	Attic english attic heat north east e4		09163947
0017	Heat Detector	Attic english attic heat north east e5		09163944

Address	Device Type	Location	Type	ScanID
0017	Heat Detector	Attic english attic heat north east e6		09164090
0017	Heat Detector	Attic english attic heat north east e7		09164097
0017	Heat Detector	Attic english attic heat north east e8		09164098
0017	Heat Detector	Attic english attic heat north east e9		09164106
0017	Heat Detector	Attic english attic heat north weast e6		09164091
0017	Heat Detector	Attic english attic heat north west e10		09164108
0017	Heat Detector	Attic english attic heat north west e4		09163946
0017	Heat Detector	Attic english attic heat north west e7		09164099
0017	Heat Detector	Attic english attic heat north west e8		09164100
0017	Heat Detector	Attic english attic heat north west e9		09164103
0017	Heat Detector	Attic english attic heat northeast e11		09164210
0017	Heat Detector	Attic english attic heat sout east e7		09164096
0017	Heat Detector	Attic english attic heat south weast e5		09163942
0017	Heat Detector	Attic english attic heat south east e10		09163940
0017	Heat Detector	Attic english attic heat south east e4		09163927
0017	Heat Detector	Attic english attic heat south east e5		09163945
0017	Heat Detector	Attic english attic heat south east e6		09164093
0017	Heat Detector	Attic english attic heat south east e8		09164102
0017	Heat Detector	Attic english attic heat south east e9		09164105
0017	Heat Detector	Attic english attic heat south weast e6		09164092
0017	Heat Detector	Attic english attic heat south west e10		09164283
0017	Heat Detector	Attic english attic heat south west e4		09163926
0017	Heat Detector	Attic english attic heat south west e7		09164095
0017	Heat Detector	Attic english attic heat south west e8		09164101
0017	Heat Detector	Attic english attic heat south west e9		09164104
0017	Heat Detector	Attic english attic heat southeast e11		09164211
0017	Heat Detector	Attic english attic heat southwest e11		09164212
0017	Heat Detector	BLDG. S 9D017 CLASSROOM 3 N/E		09163562
0017	Heat Detector	Heat: BLDG. S 9D017 CLASSROOM 3 N /E		09163133
0017	Heat Detector	english attic heat north west e11		09164213
0017	Horn	g37-laundry/ storage		09164191
0018	Heat Detector	HEAT: BLDG. S 9D018 CLASSROOM 4 S /E	Rate-of-Rise	09163132
0018	Heat Detector	SMOKE: BLDG. S 9D018 CLASSROOM 4 S/E		09163568
0019	Heat Detector	Heat: BLDG. S 9D019 CLASSROOM 4 S /W		09163105
0019	Heat Detector	SMOKE: BLDG. S 9D019 CLASSROOM 4 S/W		09163567
0020	Heat Detector	HEat BLDG. S 9D020 CLASSROOM 4 N /W		09163102
0020	Heat Detector	SMOKE: BLDG. S 9D020 CLASSROOM 4 N/W		09163566
0021	Heat Detector	Attic heat-snackbar c4-attic		09164179
0021	Heat Detector	Attic loft-maint-storage-c35-attic		09164175

Address	Device Type	Location	Type	ScanID
0021	Heat Detector	Attic loft-maint-storage-c35-attic-north		09164177
0021	Heat Detector	Attic loft-maint-storage-c35-attic-south		09164176
0021	Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N/E		09163486
0021	Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N/E		09163487
0021	Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N/E		09163488
0021	Heat Detector	: BLDG. S 9D021 CLASSROOM 4 N/E		09163569
0021	Heat Detector	: Heat: BLDG. S 9D021 CLASSROOM 4 N /E		09163104
0021	Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM 4 N/E		09163123
0021	Heat Detector	SMOKE: BLDG. S 9D021 CLASSROOM s /w /E		09163126
0022	Heat Detector	HEAT: BLDG. S 9D022 STORAGE S9		09163131
0022	Smoke Detector	SMOKE: BLDG. S 9D022 STORAGE C9		09163571
0023	Heat Detector	HEat: BLDG. S 9D023 CLASSROOM 5 S /W		09163110
0023	Smoke Detector	SMOKE: BLDG. S 9D023 CLASSROOM 5 S/W		09163575
0024	Smoke Detector	SMOKE: BLDG. S 9D024 CLASSROOM 5 N/W		09163574
0024	Heat Detector	heat: BLDG. S 9D024 CLASSROOM 5 N /W		09163108
0025	Heat Detector	HEAT: BLDG. S 9D025 CLASSROOM 5 N /E		09163107
0025	Smoke Detector	SMOKE: BLDG. S 9D025 CLASSROOM 5 N/E		09163573
0026	Heat Detector	HEAt....: BLDG. S 9D026 CLASSROOM 5 S/E		09163106
0026	Smoke Detector	SMOKE: BLDG. S 9D026 CLASSROOM 5 S/E		09163572
0027	Heat Detector	Attic HEAT ATTIC: BLDG. S 9D027 STORAGE S8 inside S7		09163109
0027	Smoke Detector	SMOKE: BLDG. S 9D027 STORAGE S8		09163579
0028	Smoke Detector	SMOKE: BLDG. S 9D028 STORAGE C12		09163578
0029	Heat Detector	Attic heat attic: BLDG. S 9D029 CLASSROOM 6 N/W		09163111
0029	Smoke Detector	SMOKE: BLDG. S 9D029 CLASSROOM 6 N/W		09163580
0030	Heat Detector	Attic heat attic: BLDG. S 9D030 CLASSROOM 6 N/E		09163113
0030	Smoke Detector	SMOKE: BLDG. S 9D030 CLASSROOM 6 N/E		09163583
0031	Heat Detector	Attic heat attic: BLDG. S 9D031 CLASSROOM 6 S/E		09163112
0031	Smoke Detector	SMOKE: BLDG. S 9D031 CLASSROOM 6 S/E		09163582
0032	Heat Detector	Attic heat attic: BLDG. S 9D032 CLASSROOM 6 S/W		09163114

Address	Device Type	Location	Type	ScanID
0032	Smoke Detector	SMOKE: BLDG. S 9D032 CLASSROOM 6 S/W		09163581
0128	Heat Detector	Attic heat attic: BLDG. S 9D028 STORAGE S7		09163115
0136	Heat Detector	heat: BLDG. S 9D013 OFFICE C5		09163135

Building: Tokay HS Lodi USD

Control Panel: 10 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Horn/Strobe	PERFORMING ARTS10D001 HALL (GREEN RM)		09164403
0001	Smoke Detector	SMOKE:PERFORMING ARTS10D001 HALL(GREEN RM)		09164402
0001	Horn/Strobe	prop room PERFORMING ARTS10D001 HALL(GREEN RM)		09164400
0002	Horn/Strobe	PERFORMING ARTS10D002 N/W CORRIDOR		09164387
0002	Smoke Detector	SMOKE:PERFORMING ARTS10D002 N /W CORRIDOR		09164386
0003	Smoke Detector	SMOKE:PERFORMING ARTS10D003 N /W OFFICE		09164416
0004	Smoke Detector	SMOKE:PERFORMING ARTS10D004 ELECTRICAL RM.		09164390
0005	Smoke Detector	PERFORMING ARTS10D005 COSTUME ROOM		09164415
0006	Horn/Strobe	SMOKE:PERFORMING ARTS10D006 GIRLS DRESSING		09164412
0006	Smoke Detector	SMOKE:PERFORMING ARTS10D006 GIRLS DRESSING		09164411
0007	Horn/Strobe	:PERFORMING ARTS10D007 N/W WOMENS RM		09164410
0007	Smoke Detector	SMOKE:PERFORMING ARTS10D007 N /W WOMENS RM		09164409
0008	Horn/Strobe	:PERFORMING ARTS10D008 N/W MENS ROOM		09164408
0008	Smoke Detector	SMOKE:PERFORMING ARTS10D008 N /W MENS ROOM		09164407
0009	Horn/Strobe	:PERFORMING ARTS10D009 BOYS DRESSING		09164406
0009	Smoke Detector	SMOKE:PERFORMING ARTS10D009 BOYS DRESSING		09164405
0010	Smoke Detector	SMOKE:PERFORMING ARTS10D010 MAKE-UP ROOM		09164404
0011	Horn/Strobe	PERFORMING ARTS10D011 GREEN ROOM		09164389
0011	Smoke Detector	SMOKE:PERFORMING ARTS10D011		09164388

Address	Device Type	Location	Type	ScanID
		GREEN ROOM		
0013	Smoke Detector	PERFORMING ARTS10D013 MAIN SPEECH RM N/W		09164384
0014	Smoke Detector	SMOKE:PERFORMING ARTS10D014 MAIN SPEECH RM		09164383
0015	Smoke Detector	SMOKE:PERFORMING ARTS10D015 SPEECH ROOM		09164379
0016	Smoke Detector	PERFORMING ARTS PA4 OFFICE		09164378
0017	Smoke Detector	PERFORMING ARTS10D017 PA4 ROOM center storage		09164376
0018	Smoke Detector	SMOKE:PERFORMING ARTS10D018 SPEECH ROOM		09164373
0019	Smoke Detector	SMOKE:PERFORMING ARTS10D019 MAIN SPEECH RM		09164382
0020	Smoke Detector	PERFORMING ARTS10D020 MAIN SPEECH RM S/W		09164381
0021	Smoke Detector	SMOKE:PERFORMING ARTS10D021 N /E CORRIDOR		09164372
0021	Smoke Detector	SMOKE:PERFORMING ARTS10D021 N /E CORRIDOR		3980643304
0022	Horn/Strobe	PERFORMING ARTS10D022 N/E VESTIBULE		09164370
0022	Smoke Detector	SMOKE:PERFORMING ARTS10D022 N /E VESTIBULE		09164369
0022	Horn/Strobe	pa4 :PERFORMING		09164380
0022	Horn/Strobe	East pa4 :PERFORMING center		09164375
0022	Horn/Strobe	East pa4 :PERFORMING		09164374
0022	Horn/Strobe	West pa4 :PERFORMING .		09164377
0024	Smoke Detector	SMOKE:PERFORMING ARTS10D024 N /E WOMENS RM		09164365
0025	Horn/Strobe	:PERFORMING ARTS10D025 N/E MENS ROOM		09164364
0025	Horn/Strobe	:PERFORMING ARTS10D025 N/E womens ROOM		09164366
0025	Horn/Strobe	:PERFORMING ARTS10D025 N/E womens outsi.de ROOM		09164367
0025	Smoke Detector	SMOKE:PERFORMING ARTS10D025 N /E MENS ROOM		09164363
0026	Smoke Detector	SMOKE:PERFORMING ARTS10D026 N /E CORRIDOR		09164368
0027	Smoke Detector	SMOKE:PERFORMING ARTS10D027 FRONT LOBBY		09164356
0028	Smoke Detector	SMOKE:PERFORMING ARTS10D028 TICKET BOOTH		09164357
0029	Smoke Detector	SMOKE:PERFORMING ARTS10D029 CONTROL ENTRY		09164358
0030	Smoke Detector	SMOKE:PERFORMING ARTS10D030 CONTROL ROOM		09164360

Address	Device Type	Location	Type	ScanID
0031	Smoke Detector	SMOKE:PERFORMING ARTS10D031 AUDITORIUM N/E		69506040
0031	Smoke Detector	BLDG.K performing arts auditorium S/E .		14227196
0032	Smoke Detector	BLDG.K performing arts auditorium N/E .		14227194
0036	Smoke Detector	PERFORMING ARTS10D036 SCENE SHOP N/E		09164396
0037	Smoke Detector	PERFORMING ARTS10D037 SCENE SHOP N/W		09164395
0038	Smoke Detector	PERFORMING ARTS10D038 SCENE SHOP S/W		09164394
0040	Horn/Strobe	PERFORMING ARTS10D040 SCENE STORAGE		09164397
0040	Smoke Detector	SMOKE:PERFORMING ARTS10D040 SCENE STORAGE		69506046
0041	Heat Detector	HEAT: PERFORMING ARTSROOF ACCESS		69506108
0042	Smoke Detector	SMOKE:PERFORMING ARTS10D042 SCENE RM STAIR		69506045
0044	Heat Detector	:PERFORMING ARTS10D044 UNIFORM ROOM		09164466
0044	Smoke Detector	SMOKE:PERFORMING ARTS10D044 UNIFORM ROOM		09164422
0045	Smoke Detector	SMOKE:PERFORMING ARTS10D045 PLATFORM RM.		09164417
0046	Smoke Detector	SMOKE:PERFORMING ARTS10D046 PLATFORM RM.		09164418
0050	Smoke Detector	BLDG.K performing arts auditorium N/W .		14227193
0051	Smoke Detector	BLDG.K performing arts auditorium S/W .		14227195
0052	Smoke Detector	West :PERFORMING audience coatroom		09164351
0053	Smoke Detector	SMOKE:PERFORMING ARTS10D053 FRONT LOBBY		09164350
0054	Pull Station	:PERFORMING ARTS10D054 S/E CORRIDOR		09164456
0054	Smoke Detector	SMOKE:PERFORMING ARTS10D054 S /E CORRIDOR		09164455
0054	Pull Station	East :PERFORMING audience exit CORRIDOR		09164459
0054	Pull Station	West :PERFORMING audience exit CORRIDOR		09164458
0055	Smoke Detector	SMOKE:PERFORMING ARTS10D055 CHORAL STORAGE		09164452
0056	Smoke Detector	SMOKE:PERFORMING ARTS10D056 CHORAL OFFICE		09164451
0057	Smoke Detector	SMOKE:PERFORMING ARTS10D057 MUSIC PREP		09164450
0058	Smoke Detector	SMOKE:PERFORMING ARTS10D058 CHORAL RM S/E		09164461
0059	Smoke Detector	PERFORMING ARTS10D059 CHORAL		09164460

Address	Device Type	Location	Type	ScanID
		RM N/E		
0060	Smoke Detector	PERFORMING ARTS10D060 CHORAL NORTH		09164462
0061	Horn/Strobe	PERFORMING ARTS10D061 SOUTH CORRIDOR		09164454
0061	Smoke Detector	SMOKE:PERFORMING ARTS10D061 SOUTH CORRIDOR		09164453
0062	Smoke Detector	PERFORMING ARTS10D062 CHORAL RM N/W		09164463
0063	Smoke Detector	PERFORMING ARTS10D063 CHORAL RM S/W		09164464
0064	Horn/Strobe	..PERFORMING ARTS10D064 PRACTICE RM 6		09164457
0064	Smoke Detector	SMOKE:PERFORMING ARTS10D064 PRACTICE RM 6		09164436
0064	Horn/Strobe	East pa1 ..PERFORMING ARTS10D064 PRACTICE RM 6		09164447
0064	Horn/Strobe	South pa1 ..PERFORMING ARTS10D064 PRACTICE RM 6		09164449
0064	Horn/Strobe	north pa1 ..PERFORMING ARTS10D064 PRACTICE RM 6		09164448
0065	Horn/Strobe	:PERFORMING ARTS10D065 PRACTICE RM 7		09164438
0065	Smoke Detector	SMOKE:PERFORMING ARTS10D065 PRACTICE RM 7		09164437
0066	Horn/Strobe	:PERFORMING ARTS10D066 PRACTICE RM 8		09164440
0066	Smoke Detector	SMOKE:PERFORMING ARTS10D066 PRACTICE RM 8		09164439
0067	Horn/Strobe	SMOKE:PERFORMING ARTS10D067 PRACTICE RM 9		09164441
0067	Smoke Detector	SMOKE:PERFORMING ARTS10D067 PRACTICE RM 9		09164442
0068	Horn/Strobe	:PERFORMING ARTS10D068 PRACTICE RM 10		09164444
0068	Smoke Detector	:PERFORMING ARTS10D068 PRACTICE RM 10		09164443
0069	Smoke Detector	SMOKE:PERFORMING ARTS10D069 ENSEMBLE		09164445
0069	Smoke Detector	SMOKE:PERFORMING ARTS10D069 ENSEMBLE		69506048
0070	Smoke Detector	SMOKE:PERFORMING ARTS10D070 SOUTH CORRIDOR		09164425
0071	Smoke Detector	SMOKE:PERFORMING ARTS10D071 BAND RM. N/E		09164429
0072	Smoke Detector	SMOKE:PERFORMING ARTS10D072 BAND RM. S/E		09164428
0073	Smoke Detector	SMOKE:PERFORMING ARTS10D073		09164427

Address	Device Type	Location	Type	ScanID
		BAND RM. S/W		
0074	Smoke Detector	SMOKE:PERFORMING ARTS10D074		09164426
		BAND RM. N/W		
0075	Heat Detector	Attic BLDG.H attic girls restroom		09157876
0075	Heat Detector	Attic BLDG.H room IA7 attic north		09157875
0075	Heat Detector	Attic BLDG.H room IA7 attic south		09157874
0075	Heat Detector	Attic BLDG.H west classroom IA10 attic north		09157869
0075	Heat Detector	Attic BLDG.H west classroom IA10 attic south		09157870
0075	Heat Detector	Attic BLDG.H west classroom IA11 attic north		09157868
0075	Heat Detector	Attic BLDG.H west classroom IA11 attic south		09157867
0075	Heat Detector	Attic BLDG.H west hallway attic by north exit		09157866
0075	Heat Detector	Attic BLDG.H west hallway attic by room IA12		09157865
0075	Heat Detector	Attic BLDG.H west hallway attic by room IA14		09157864
0075	Horn/Strobe	:PERFORMING ARTS10D075 SOUTH CORRIDOR		09164424
0075	Smoke Detector	SMOKE:PERFORMING ARTS10D075 SOUTH CORRIDOR		09164423
0075	Horn/Strobe	BLDG.H .boys restroom		09163775
0075	Horn/Strobe	BLDG.H classroom IA10		09163777
0075	Horn/Strobe	BLDG.H classroom IA10 darkroom		09163778
0075	Horn/Strobe	BLDG.H classroom IA11		09163779
0075	Horn/Strobe	BLDG.H classroom IA8		09163771
0075	Horn/Strobe	BLDG.H classroom IA9		09163772
0075	Horn/Strobe	BLDG.H girls restroom		09163776
0075	Horn/Strobe	BLDG.H mens restroom		09163774
0075	Horn/Strobe	BLDG.H office IA12 north wall		09163783
0075	Horn/Strobe	BLDG.H office IA12 west wall		09163782
0075	Horn/Strobe	BLDG.H office IA49		09163781
0075	Horn/Strobe	BLDG.H womens restroom		09163773
0075	Horn/Strobe	BLDG.H classroom IA13 east		09163791
0075	Horn/Strobe	BLDG.H classroom IA13 west		09163792
0075	Horn/Strobe	BLDG.H classroom IA14east		09163794
0075	Horn/Strobe	BLDG.H classroom IA14west		09163793
0075	Heat Detector	BLDG.H east hallway by ladies room		09157872
0075	Heat Detector	BLDG.H east hallway by mens room		09157871
0075	Heat Detector	BLDG.H east hallway by rm. IA8		09157873
0075	Horn	BLDG.H outside classroom IA12		09163797
0075	Horn	BLDG.H outside classroom IA14		09163795
0075	Horn	BLDG.H outside classroom IA3		09163796

Address	Device Type	Location	Type	ScanID
0075	Horn/Strobe	BLDG.H west hallway across office IA49		09163780
0075	Horn/Strobe	BLDG.H west hallway by IA13		09163784
0075	Horn	BLDG.H East outside IA8		09163798
0075	Horn/Strobe	BLDG.H classroom IA5 east wall		09163764
0075	Horn/Strobe	BLDG.H classroom IA5 storage room IA32		09163765
0075	Horn/Strobe	BLDG.H classroom IA6 west wall		09163766
0075	Horn/Strobe	BLDG.H classroom IA7 back room		09163768
0075	Horn/Strobe	BLDG.H classroom IA7 west wall		09163767
0075	Horn/Strobe	BLDG.H classroom east hallway across classroom IA8		09163770
0075	Horn/Strobe	BLDG.H classroom east hallway across mens restroom		09163769
0075	Horn/Strobe	East pa2		09164430
0075	Horn/Strobe	West pa2		09164431
0076	Smoke Detector	SMOKE:PERFORMING ARTS10D076 INSTRUMENT RM.		09164432
0077	Smoke Detector	SMOKE:PERFORMING ARTS10D077 BAND RM OFFICE		09164433
0078	Smoke Detector	SMOKE:PERFORMING ARTS10D078 MUSIC STORAGE		09164434
0079	Smoke Detector	SMOKE:PERFORMING ARTS10D079 BAND STORAGE		09164435
0080	Smoke Detector	SMOKE:PERFORMING ARTS10D080 SCENE SHOP		69506041
0080	Smoke Detector	second 2 of 2 SMOKE:PERFORMING ARTS10D080 SCENE SHOP		69506042
0082	Horn/Strobe	:PERFORMING ARTS10D082 COSTUME STORAG		09164414
0082	Smoke Detector	SMOKE:PERFORMING ARTS10D082 COSTUME STORAG		09164413
0082	Horn/Strobe	stage east		14227185
0082	Horn/Strobe	stage west		09164419
0082	Horn/Strobe	East audience		09164420
0082	Horn/Strobe	West audience		09164421

Building: Tokay HS Lodi USD

Control Panel: 11 - EST EST3

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	SMOKE: ENGLISH 11D001FIRE PANEL ROOM		09163827
0002	Smoke Detector	SMOKE: ENGLISH 11D002ROOM 9 SOUTH/WEST		09163874
0003	Smoke Detector	SMOKE: ENGLISH 11D003ROOM 9 NORTH/WEST		09163873
0004	Smoke Detector	SMOKE: ENGLISH 11D004WEST		09163826

Address	Device Type	Location	Type	ScanID
		LOCKER CORRIDOR		
0005	Smoke Detector	SMOKE: ENGLISH 11D005ROOM 10 SOUTH/EAST		09163881
0006	Smoke Detector	SMOKE: ENGLISH 11D006ROOM 10 NORTH/EAST		09163878
0007	Smoke Detector	SMOKE: ENGLISH 11D007ROOM 10 NORTH/WEST		09163879
0008	Smoke Detector	SMOKE: ENGLISH 11D008ROOM 10 SOUTH/WEST		09163880
0009	Smoke Detector	SMOKE: ENGLISH 11D009ROOM 11 SOUTH/EAST		09163885
0010	Smoke Detector	SMOKE: ENGLISH 11D010ROOM 11 NORTH/EAST		09163886
0011	Smoke Detector	SMOKE: ENGLISH 11D011ROOM 11 NORTH/WEST		09163883
0012	Smoke Detector	SMOKE: ENGLISH 11D012ROOM 11 SOUTH/WEST		09163884
0013	Smoke Detector	SMOKE: ENGLISH 11D013ROOM 1 NORTH/WEST		09163817
0014	Smoke Detector	SMOKE: ENGLISH 11D014ROOM 1 SOUTH/WEST		09163814
0015	Smoke Detector	SMOKE: ENGLISH 11D015ROOM 1 SOUTH/EAST		09163815
0016	Smoke Detector	SMOKE: ENGLISH 11D016ROOM 1 NORTH/EAST		09163816
0017	Smoke Detector	SMOKE: ENGLISH 11D017ROOM 2 NORTH/WEST		09163821
0018	Smoke Detector	SMOKE: ENGLISH 11D018ROOM 2 SOUTH/WEST		09163822
0019	Smoke Detector	SMOKE: ENGLISH 11D019ROOM 2 SOUTH/EAST		09163819
0020	Smoke Detector	SMOKE: ENGLISH 11D020ROOM 2 NORTH/EAST		09163820
0021	Smoke Detector	SMOKE: ENGLISH 11D021WEST LOCKER CORRIDOR		09163825
0022	Heat Detector	HEAT: ENGLISH 11D022 WEST ROOF ACCESS Locker Area closet between E2 and Girls Restroom		09163919
0023	Smoke Detector	SMOKE: ENGLISH 11D023SOUTH /WEST VESTIBULE		09163830
0024	Smoke Detector	South ENGLISH girls restroom		20411020
0025	Smoke Detector	SMOKE: ENGLISH 11D025SOUTH WOMENS ROOM		09163832
0027	Smoke Detector	ENGLISH boys room D028SOUTH/EAST		20411021
0028	Smoke Detector	SMOKE: ENGLISH 11D028SOUTH/EAST VESTIBULE		09163837
0029	Smoke Detector	SMOKE: ENGLISH 11D029ROOM 3 SOUTH/WEST		09163842

Address	Device Type	Location	Type	ScanID
0030	Smoke Detector	SMOKE: ENGLISH 11D030ROOM 3 NORTH/WEST		09163841
0031	Smoke Detector	SMOKE: ENGLISH 11D031ROOM 3 NORTH/EAST		09163840
0032	Smoke Detector	SMOKE: ENGLISH 11D032ROOM 3 SOUTH/EAST		09163839
0033	Smoke Detector	SMOKE: ENGLISH 11D033EAST LOCKER CORRIDOR Workability room.		09163846
0035	Smoke Detector	SMOKE: ENGLISH 11D035ROOM 4 NORTH/WEST		09163851
0036	Smoke Detector	SMOKE: ENGLISH 11D036ROOM 4 SOUTH/WEST		09163848
0037	Smoke Detector	SMOKE: ENGLISH 11D037ROOM 4 SOUTH/EAST		09163849
0038	Smoke Detector	SMOKE: ENGLISH 11D038ROOM 4 NORTH/EAST		09163850
0039	Smoke Detector	SMOKE: ENGLISH 11D039ROOM 5 NORTH/WEST		09163855
0040	Smoke Detector	SMOKE: ENGLISH 11D040ROOM 5 SOUTH/WEST		09163856
0041	Smoke Detector	SMOKE: ENGLISH 11D041ROOM 5 SOUTH/EAST		09163853
0042	Smoke Detector	SMOKE: ENGLISH 11D042ROOM 5 NORTH/EAST		09163854
0043	Smoke Detector	SMOKE: ENGLISH 11D043ROOM 6 SOUTH/EAST		09163861
0044	Smoke Detector	SMOKE: ENGLISH 11D044ROOM 6 NORTH/EAST		09163858
0045	Smoke Detector	SMOKE: ENGLISH 11D045ROOM 6 NORTH/WEST		09163859
0046	Smoke Detector	SMOKE: ENGLISH 11D046ROOM 6 SOUTH/WEST		09163860
0047	Smoke Detector	SMOKE: ENGLISH 11D047ROOM 7 SOUTH/EAST		09163865
0048	Smoke Detector	SMOKE: ENGLISH 11D048ROOM 7 NORTH/EAST		09163866
0049	Smoke Detector	SMOKE: ENGLISH 11D049ROOM 7 NORTH/WEST		09163863
0050	Smoke Detector	SMOKE: ENGLISH 11D050ROOM 7 SOUTH/WEST		09163864
0051	Smoke Detector	SMOKE: ENGLISH 11D051EAST LOCKER .CORRIDOR Workability room.		09163845
0052	Smoke Detector	SMOKE: ENGLISH 11D052ROOM 8 NORTH/EAST		09163867
0053	Smoke Detector	SMOKE: ENGLISH 11D053ROOM 8 SOUTH/EAST		09163871
0054	Smoke Detector	SMOKE: ENGLISH 11D054ROOM 8 SOUTH/WEST		09163870

Address	Device Type	Location	Type	ScanID
0055	Smoke Detector	SMOKE: ENGLISH 11D055ROOM 8 NORTH/WEST		09163869
0056	Smoke Detector	SMOKE: ENGLISH 11D056ROOM 9 NORTH/EAST		09163876
0057	Smoke Detector	SMOKE: ENGLISH 11D057ROOM 9 SOUTH/EAST		09163875
0060	Heat Detector	sc8 8 n/w		3815898466
0061	Heat Detector	sc8 8 S/W		3815622429
0062	Heat Detector	sc8 8 s/e		3815888351
0068	Heat Detector	HEAT: SCIENCE 11D068 ROOM 4 SOUTH/EAST		09164291
0069	Heat Detector	HEAT: SCIENCE 11D069 ROOM 4 SOUTH/WEST		09164292
0070	Heat Detector	HEAT: SCIENCE 11D070 ROOM 5 SOUTH/EAST		09164261
0071	Heat Detector	HEAT: SCIENCE 11D071 ROOM 5 SOUTH/WEST		09164263
0072	Heat Detector	HEAT: SCIENCE 11D072 ROOM 6 SOUTH/EAST		09164270
0073	Heat Detector	HEAT: SCIENCE 11D073 ROOM 6 SOUTH/WEST		09164272
0074	Heat Detector	HEAT: SCIENCE 11D074 ROOM 6 NORTH/WEST		09164271
0075	Heat Detector	HEAT: SCIENCE 11D075 ROOM 6 NORTH/EAST		09164264
0076	Heat Detector	HEAT: SCIENCE 11D076 ROOM 5 NORTH/WEST		14226342
0077	Heat Detector	HEAT: SCIENCE 11D077 ROOM 5 NORTH/EAST		09164290
0078	Heat Detector	HEAT: SCIENCE 11D078 ROOM 4 NORTH/WEST		09164293
0079	Heat Detector	HEAT: SCIENCE 11D079 ROOM 4 NORTH/EAST		09164294
0080	Smoke Detector	SMOKE: SCIENCE 11D080UTILITY /ELEC. ROOM east of sc4		09164260
0081	Smoke Detector	SMOKE: SCIENCE 11D081RESOURCE ROOM		09164267
0082	Horn/Strobe	SCIENCE RESOURCE ROOM		14227180
0082	Smoke Detector	SMOKE: SCIENCE 11D082RESOURCE ROOM		09164257
0083	Smoke Detector	SMOKE: SCIENCE 11D083RESOURCE ROOM		09164266
0100	Smoke Detector	North building -p18		3953760274
0101	Smoke Detector	South building -p18		3953757373
0104	Smoke Detector	SMOKE: SCIENCE 11D104RESOURCE ROOM		09164269
0106	Heat Detector	HEAT: SCIENCE 11D106 ROOM 3 NORTH/EAST		09164297

Address	Device Type	Location	Type	ScanID
0107	Heat Detector	HEAT: SCIENCE 11D107 ROOM 3 NORTH/WEST		09164296
0108	Heat Detector	HEAT: SCIENCE 11D108 ROOM 2 NORTH/EAST		09164167
0109	Heat Detector	HEAT: SCIENCE 11D109 ROOM 2 NORTH/WEST		09164166
0110	Heat Detector	HEAT: SCIENCE 11D110 ROOM 1 NORTH/EAST		09164171
0111	Heat Detector	HEAT: SCIENCE 11D111 ROOM 1 NORTH/WEST		09164170
0112	Heat Detector	HEAT: SCIENCE 11D112 ROOM 1 SOUTH/WEST		09164173
0113	Heat Detector	HEAT: SCIENCE 11D113 ROOM 1 SOUTH/EAST		09164172
0114	Heat Detector	HEAT: SCIENCE 11D114 ROOM 2 SOUTH/WEST		09164169
0115	Heat Detector	HEAT: SCIENCE 11D115 ROOM 2 SOUTH/EAST		09164168
0116	Heat Detector	HEAT: SCIENCE 11D116 ROOM 3 SOUTH/WEST		09164165
0117	Horn/Strobe	2nd West lighting control room bldg. k . performing art		09164359
0117	Horn/Strobe	.sc1		09164163
0117	Horn/Strobe	.sc3		09164295
0117	Heat Detector	HEAT: SCIENCE 11D117 ROOM 3 SOUTH/EAST		09164164
0117	Horn/Strobe	sc2		09164273
0117	Horn/Strobe	sc4		09164274
0117	Horn/Strobe	sc5		09164275
0117	Horn/Strobe	sc6		09164276
0117	Horn/Strobe	East Lobby bldg. k .performing art		09164354
0117	Pull Station	East Lobby bldg. k .performing art		09164355
0117	Horn/Strobe	West Lobby bldg. k .performing art		09164352
0117	Pull Station	West Lobby bldg. k .performing art		09164353
Zone/Circuit: .				
	Horn/Strobe	SCIENCE RESOURCE ROOM		09164259
	Horn/Strobe	SMOKE: SCIENCE-west 11D104RESOURCE ROOM		09164268
Building: Tokay HS Lodi USD			Control Panel: 12 - EST EST3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0002	Smoke Detector	SMOKE: GYM 12D002 BOYS LOCKER MID/NORTH		69506028
0007	Smoke Detector	SMOKE: GYM 12D007 BOYS LOCKER N /W		69506030

Address	Device Type	Location	Type	ScanID
0008	Smoke Detector	SMOKE: GYM BOYS LOCKER MID /NORTH		69506031
0009	Smoke Detector	SMOKE: GYM 12D009 BOYS LOCKER S /E		69506029
0011	Smoke Detector	SMOKE: GYM 12D011 VESTIBULE N18		09164110
0013	Smoke Detector	GYM boys locker restroom		20411025
0015	Smoke Detector	SMOKE: GYM 12D015 INSTRUCTOR OFFICE N53		09164076
0017	Smoke Detector	SMOKE: GYM 12D017 FIRST AID N26		09164121
0018	Smoke Detector	SMOKE: GYM 12D018 TOILET N24		09164079
0020	Smoke Detector	SMOKE: GYM 12D020 BOYS LOCKER N /W		69506026
0021	Smoke Detector	SMOKE: GYM 12D021 BOYS LOCKER S /W		69506027
0022	Smoke Detector	SMOKE: GYM 12D022 BOYS LOCKER S /E		69506033
0023	Smoke Detector	SMOKE: GYM 12D023 BOYS LOCKER N /E		69506032
0024	Smoke Detector	SMOKE: GYM 12D024 CUSTODIAN N14		09164088
0025	Smoke Detector	SMOKE: GYM 12D025 VESTIBULE N13		09164111
0026	Smoke Detector	SMOKE: GYM 12D026 VESTIBULE N15		09164087
0031	Smoke Detector	SMOKE: GYM 12D031 LOBBY NORTH		09164150
0032	Smoke Detector	SMOKE: GYM 12D032 LOBBY SOUTH		09164151
0034	Smoke Detector	GYM 12D034 WRESTLING NORTH /WEST		09164114
0036	Smoke Detector	GYM 12D036 WRESTLING SOUTH /CENTER/WEST		09164115
0037	Smoke Detector	SMOKE: GYM 12D037 WRESTLING NORTH		09164118
0038	Smoke Detector	SMOKE: GYM 12D038 WRESTLING NORTH/EAST		09164117
0039	Smoke Detector	SMOKE: GYM 12D039 WRESTLING SOUTH/EAST		09164116
0040	Smoke Detector	GYM 12D040 DANCE SOUTH/WEST		09164149
0041	Smoke Detector	SMOKE: GYM 12D041 DANCE NORTH /WEST		09164141
0042	Smoke Detector	SMOKE: GYM 12D042 DANCE NORTH /CENTER		09164142
0043	Smoke Detector	SMOKE: GYM 12D043 DANCE SOUTH /CENTER		09164147
0044	Smoke Detector	SMOKE: GYM 12D044 DANCE SOUTH /EAST		09164146
0045	Smoke Detector	SMOKE: GYM 12D045 DANCE NORTH /EAST		09164145
0047	Heat Detector	HEAT: SC7 center east		09164343
0047	Heat Detector	HEAT: SC7 east		09164344
0047	Heat Detector	HEAT: SC7 west		09164341

Address	Device Type	Location	Type	ScanID
0047	Heat Detector	HEAT: SC7 west south		09164342
0047	Heat Detector	HEAT: GYM 12D047 TOWEL ROOM N43		69506109
0047	Heat Detector	Southeast HEAT: SC1		09164302
0047	Heat Detector	Southwest HEAT: SC2		09164306
0047	Heat Detector	northeast center HEAT: SC5		09164321
0047	Heat Detector	northeast center HEAT: SC4		09164324
0047	Heat Detector	northeast. HEAT: SC5		09164313
0047	Heat Detector	northheast center HEAT: SC6		09164315
0047	Heat Detector	northheast. HEAT: SC4		09164312
0047	Heat Detector	northheast. HEAT: SC6		09164316
0047	Heat Detector	northwest HEAT: SC4		09164322
0047	Heat Detector	northwest HEAT: SC5		09164319
0047	Heat Detector	northwest HEAT: SC6		09164318
0047	Heat Detector	northwest center HEAT: SC4		09164323
0047	Heat Detector	northwest center HEAT: SC5		09164320
0047	Heat Detector	northwest center HEAT: SC6		09164317
0047	Heat Detector	sguthwest HEAT: SC1		09164299
0047	Heat Detector	south West center HEAT: SC3		09164308
0047	Heat Detector	southWest HEAT: SC2		09164303
0047	Heat Detector	southWest HEAT: SC3		09164307
0047	Heat Detector	southeast center HEAT: SC1		09164301
0047	Heat Detector	southeast center HEAT: SC2		09164305
0047	Heat Detector	southeast center HEAT: SC3		09164309
0047	Heat Detector	southeast. HEAT: SC3		09164310
0047	Heat Detector	southwest center HEAT: SC1		09164300
0047	Heat Detector	sovthWest center HEAT: SC2		09164304
0048	Heat Detector	HEAT: GYM 12D048 LAUNDRY (SOUTH ROOM)		69506107
0050	Smoke Detector	SMOKE: GYM 12D050 GIRLS LOCKER WEST		09164228
0051	Smoke Detector	SMOKE: GYM 12D051 GIRLS LOCKER EAST		09164227
0052	Smoke Detector	SMOKE: GYM 12D052 GIRLS LOCKER EAST		09164226
0053	Smoke Detector	SMOKE: GYM 12D053 GIRLS LOCKER WEST		09164225
0054	Smoke Detector	SMOKE: GYM 12D054 TEACHING SPACE WEST		09164220
0055	Smoke Detector	SMOKE: GYM 12D055 TEACHING SPACE EAST		09164219
0059	Smoke Detector	girls locker restroom		20411024
0060	Smoke Detector	SMOKE: GYM 12D060 CUSTODIAN		09164215
0061	Smoke Detector	SMOKE: GYM 12D061 GIRLS LOCKER W ENTRY		09164222
0062	Smoke Detector	SMOKE: GYM 12D062 GIRLS LOCKER WEST		09164230

Address	Device Type	Location	Type	ScanID
0063	Smoke Detector	SMOKE: GYM 12D063 GIRLS LOCKER EAST		09164231
0065	Smoke Detector	SMOKE: GYM 12D065 INSTRUCTOR OFFICE N53		09164237
0067	Smoke Detector	SMOKE: GYM 12D067 DRESSING AREA N50		09164240
0068	Smoke Detector	SMOKE: GYM 12D068 TOILET N49		09164243
0069	Smoke Detector	SMOKE: GYM Girls Locker Room Entrance		09164245
0071	Smoke Detector	GYM 12D071WRESTLING CENTER /WEST		09164119
0072	Smoke Detector	GYM 12D036 WRESTLING SOUTH /CENTER/EAST		14227182
0072	Smoke Detector	GYM 12D072WRESTLING CENTER /EAST		09164140
0073	Smoke Detector	SMOKE: GYM 12D073DANCE CENTER /EAST		09164148
0074	Smoke Detector	SMOKE: GYM 12D074DANCE CENTER /WEST		09164143
0132	Beam Detector	Gym west end beam detector		14226391
0133	Beam Detector	gym west/center beam detector		14226392
0134	Beam Detector	gym east/center beam detector		14226394
0135	Beam Detector	gym east beam detector		14226393

Building: Tokay HS Lodi USD

Control Panel: 14

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	Press Box North		3933163033
0002	Smoke Detector	Press Box Center		3933165273
0003	Smoke Detector	Press Box South		3933389495
0131	Pull Station	Press Box		75938189
0132	Heat Detector	Press Box North		75938191
0133	Heat Detector	Press Box center		75938190
0134	Heat Detector	Press Box south		75938192

Building: Tokay HS Lodi USD

Control Panel: 15

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	Practice Gym electrical room	Photoelectric	3931681942
0002	Smoke Detector	P.E Classroom storage	Photoelectric	3931671974
0003	Smoke Detector	Main Practice Gym Storage		3931672988
0004	Smoke Detector	Practice Gym Lobby West		3931673770
0005	Smoke Detector	Practice Gym lobby for team room 1		3931672971

Address	Device Type	Location	Type	ScanID
0006	Smoke Detector	Practice Gym Lobby women restroom		3931673534
0007	Smoke Detector	Practice Gym Lobby Mens Restroom		3931672735
0008	Smoke Detector	Practice Gym Outside Mens restroom South		3931673589
0009	Smoke Detector	Practice Gym Outside Womens Restroom south		3931673565
0010	Smoke Detector	Practice Gym Outside Womens Restroom North		3931681843
0011	Smoke Detector	Practice Gym Outside Staff Restroom south		3931673411
0012	Smoke Detector	Practice Gym Outside Mens restroom North		3931672278
0013	Smoke Detector	Practice Gym IDF	Photoelectric	3931672513
0014	Smoke Detector	P.E Classroom southwest	Photoelectric	3931672018
0015	Smoke Detector	P.E Classroom northwest	Photoelectric	3931672063
0016	Smoke Detector	P.E Classroom southeast	Photoelectric	3931672162
0017	Smoke Detector	P.E Classroom south center	Photoelectric	3931672001
0018	Smoke Detector	P.E Classroom north center	Photoelectric	3931673503
0019	Smoke Detector	P.E Classroom northeast	Photoelectric	3931672810
0020	Smoke Detector	Practice Gym Lobby East		3931672483
0021	Smoke Detector	Practice Gym Lobby janitor		3931681621
0022	Smoke Detector	Practice Gym Lobby staff restroom		3931673848
0023	Smoke Detector	Practice Gym lobby for team room 2		3931673480
0024	Smoke Detector	Practice Gym Fire Riser	Photoelectric	3931672780
00025	Smoke Detector	Practice Gym Team Room 2 South		3931672797
0025	Smoke Detector	Practice Gym team room 2 North		3931681904
00027	Smoke Detector	Practice Gym Team room 2 storage		3931673527
0028	Smoke Detector	Practice Gym Tickets		3931682543
0029	Smoke Detector	Practice Gym Concessions		3930791819
00030	Smoke Detector	Practice Gym Team Room 1 Storage		3930781582
00031	Smoke Detector	Practice Gym Team Room 1 North		3930793264
00032	Smoke Detector	Practice Gym Team Room 1 South		3930792533
0126	Beam Detector	Main Practice Gym West		75938195
0127	Beam Detector	Main Practice Gym East		75938194
0128	Pull Station	Main Practice Gym		75938193
0133	Waterflow Switch	Practice Gym Fire Riser		75938187
0134	Tamper Switch	Practice Gym Fire Riser		75938186

Building: Tokay HS Lodi USD

Control Panel: 16

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 02				
0001	Smoke Detector	1st floor fire riser by T115	Photoelectric	3931671882
0002	Smoke Detector	1st floor electrical by T115	Photoelectric	3931672827
0003	Smoke Detector	1st floor IDF by T115	Photoelectric	3931672070

Address	Device Type	Location	Type	ScanID
0004	Smoke Detector	1st floor janitor by T115	Photoelectric	3931681492
0005	Multi-Sensor Detector	1st floor T107 north	SMOKE/CO	3110854945
0006	Multi-Sensor Detector	1st floor T107 south	SMOKE/CO	3110846957
0007	Multi-Sensor Detector	1st floor T106 north	SMOKE/CO	3110848685
0008	Multi-Sensor Detector	1st floor T106 south	SMOKE/CO	3110853023
0009	Heat Detector	1st floor elevator machine room	Fixed/ROR	3828163964
0010	Smoke Detector	1st floor elevator machine room	Photoelectric	3931682178
0011	Multi-Sensor Detector	1st floor T105 north	SMOKE/CO	3110849057
0012	Multi-Sensor Detector	1st floor T105 south	SMOKE/CO	3110849132
0013	Multi-Sensor Detector	1st floor T104 north	SMOKE/CO	3110846865
0014	Multi-Sensor Detector	1st floor T104 south	SMOKE/CO	3110851883
0015	Multi-Sensor Detector	1st floor T103 northeast	SMOKE/CO	3110851159
0015	Multi-Sensor Detector	1st floor T103 northwest	SMOKE/CO	3110856574
0017	Multi-Sensor Detector	1st floor T103 Southeast	SMOKE/CO	3110854563
0018	Multi-Sensor Detector	1st floor T103 Southwest	SMOKE/CO	3110854358
0019	Multi-Sensor Detector	1st floor T102 North	SMOKE/CO	3110849095
0020	Multi-Sensor Detector	1st floor T102 south	SMOKE/CO	3110853672
0021	Multi-Sensor Detector	1st floor T101 Northeast	SMOKE/CO	3110850411
0022	Multi-Sensor Detector	1st floor T101 Northwest	SMOKE/CO	3110937709
0023	Multi-Sensor Detector	1st floor T101 Southeast	SMOKE/CO	3111079170
0024	Multi-Sensor Detector	1st floor T101 Southwest	SMOKE/CO	3110848616
0025	Smoke Detector	1st floor staff restroom by T115	Photoelectric	3931673862
0026	Smoke Detector	1st floor girls restroom by T115	Photoelectric	3931653666
0026	Smoke Detector	1st floor girls restroom by T115	Photoelectric	75938127
0027	Smoke Detector	1st floor boys restroom next to T115	Photoelectric	3931672100
0028	Multi-Sensor Detector	1st floor T115 east	SMOKE/CO	3110857755
0029	Multi-Sensor Detector	1st floor T115 west	SMOKE/CO	3110849484
0030	Multi-Sensor Detector	1st floor T116 east	SMOKE/CO	3110846315
0031	Multi-Sensor Detector	1st floor T116 west	SMOKE/CO	3110846780
0032	Multi-Sensor Detector	1st floor T117 east	SMOKE/CO	3110854679
0033	Multi-Sensor Detector	1st floor T117 west	SMOKE/CO	3110854617
0034	Multi-Sensor Detector	1st floor T118 east	SMOKE/CO	3110854877
0035	Multi-Sensor Detector	1st floor T118 West	SMOKE/CO	3110850220
0131	Heat Detector	1st BLDG T Attic outside of Fire riser	Line / fixed temperature	75938199
0132	Heat Detector	1st BLDG T Attic outside of T107	Line / fixed temperature	75938200
0133	Supervisory Valve	South of BLDG T		75938208
0135	Waterflow Switch	1st floor fire riser		75938125
0136	Tamper Switch	1st floor fire riser		75938126
0137	Heat Detector	1st Floor T07 Attic southeast	Fixed Temperature /rate of rise	75938148
0138	Heat Detector	1st Floor T07 Attic northwest	Fixed Temperature /rate of rise	75938149
0139	Heat Detector	1st Floor T06 Attic southeast	Fixed Temperature /rate of rise	75938150

Address	Device Type	Location	Type	ScanID
0140	Heat Detector	1st Floor T06 Attic northwest	Fixed Temperature /rate of rise	75938151
0142	Heat Detector	1st Floor T05 Attic southwest	Fixed Temperature /rate of rise	75938152
0143	Heat Detector	1st Floor T105 Attic northwest	Fixed Temperature /rate of rise	75938153
0144	Heat Detector	1st Floor T104 Attic southwest	Fixed Temperature /rate of rise	75938154
0145	Heat Detector	1st Floor T104 Attic northwest	Fixed Temperature /rate of rise	75938155
0147	Heat Detector	1st Floor T103 Attic center	Fixed Temperature /rate of rise	75938156
0147	Heat Detector	1st Floor T103 Attic east	Fixed Temperature /rate of rise	75938158
0147	Heat Detector	1st Floor T103 Attic west	Fixed Temperature /rate of rise	75938157
0149	Heat Detector	1st Floor T103 & 102 workroom Attic center	Fixed Temperature /rate of rise	75938159
0150	Heat Detector	1st Floor T102 Attic east	Fixed Temperature /rate of rise	75938160
0151	Heat Detector	1st Floor T102 Attic center	Fixed Temperature /rate of rise	75938161
0152	Heat Detector	1st Floor T102 Attic west	Fixed Temperature /rate of rise	75938162
0153	Heat Detector	1st attic girls restroom by T115	Fixed Temperature /rate of rise	75938202
0154	Heat Detector	1st attic boys restroom by T115	Fixed Temperature /rate of rise	75938201
0155	Heat Detector	1st Floor T115 Attic southeast	Fixed Temperature /rate of rise	75938146
0156	Heat Detector	1st Floor T115 Attic northwest	Fixed Temperature /rate of rise	75938147
0157	Heat Detector	1st Floor T116 Attic southeast	Fixed Temperature /rate of rise	75938144
0158	Heat Detector	1st Floor T116 Attic northwest	Fixed Temperature /rate of rise	75938145
0159	Heat Detector	1st Floor T117 Attic Southeast	Fixed Temperature /rate of rise	75938142
0160	Heat Detector	1st Floor T117 Attic northwest	Fixed Temperature /rate of rise	75938143
0161	Heat Detector	1st Floor T118 Attic Southeast	Fixed Temperature /rate of rise	75938140
0162	Heat Detector	1st Floor T118 Attic Northwest	Fixed Temperature /rate of rise	75938141
0251	Multi-Sensor Detector	2nd floor electrical by T215	SMOKE/CO	3931672261
0252	Multi-Sensor Detector	2nd floor IDF by T215	SMOKE/CO	3931672841
0253	Multi-Sensor Detector	2nd floor janitor by T215	SMOKE/CO	3931672124
0254	Multi-Sensor Detector	2nd floor T207 north	SMOKE/CO	3110851081

Address	Device Type	Location	Type	ScanID
0255	Multi-Sensor Detector	2nd floor T207 south	SMOKE/CO	3110850299
0256	Multi-Sensor Detector	2nd floor T206 north	SMOKE/CO	3110854396
0257	Multi-Sensor Detector	2nd floor T206 south	SMOKE/CO	3110844328
0258	Smoke Detector	2nd floor storage by elevator	Photoelectric	3931673275
0259	Multi-Sensor Detector	2nd floor T205 north	SMOKE/CO	3110848425
0260	Multi-Sensor Detector	2nd floor T205 south	SMOKE/CO	3110854198
0261	Multi-Sensor Detector	2nd floor T204 north	SMOKE/CO	3110852286
0262	Multi-Sensor Detector	2nd floor T204 south	SMOKE/CO	3110854907
0263	Multi-Sensor Detector	2nd floor T203 Northeast	SMOKE/CO	3110850305
0264	Multi-Sensor Detector	2nd floor T203 Northwest	SMOKE/CO	3110853795
0265	Multi-Sensor Detector	2nd floor T203 Southeast	SMOKE/CO	3110855126
0266	Multi-Sensor Detector	2nd floor T203 Southwest	SMOKE/CO	3110855171
0267	Multi-Sensor Detector	2nd floor T202 north	SMOKE/CO	3111285465
0268	Multi-Sensor Detector	2nd floor T202 south	SMOKE/CO	3106246150
0269	Multi-Sensor Detector	2nd floor T201 Northeast	SMOKE/CO	3110854693
0270	Multi-Sensor Detector	2nd floor T201 Northwest	SMOKE/CO	3110849415
0271	Multi-Sensor Detector	2nd floor T201 Southeast	SMOKE/CO	3110851517
0272	Multi-Sensor Detector	2nd floor T201 Southwest	SMOKE/CO	3110850329
0273	Multi-Sensor Detector	2nd floor staff restroom by T215	SMOKE/CO	3931673053
0274	Multi-Sensor Detector	2nd floor girls restroom by T215	SMOKE/CO	3931672834
0275	Multi-Sensor Detector	2nd floor boys restroom by T215	SMOKE/CO	3931672568
0276	Multi-Sensor Detector	2nd floor T215 east	SMOKE/CO	3110854730
0277	Multi-Sensor Detector	2nd floor T215 west	SMOKE/CO	3110851227
0278	Multi-Sensor Detector	2nd floor T216 east	SMOKE/CO	3110850114
0279	Multi-Sensor Detector	2nd floor T216 west	SMOKE/CO	3110846896
0280	Multi-Sensor Detector	2nd floor T217 east	SMOKE/CO	3110855133
0281	Multi-Sensor Detector	2nd floor T217 west	SMOKE/CO	3110850206
0282	Multi-Sensor Detector	2nd floor T218 east	SMOKE/CO	3110850169
0283	Multi-Sensor Detector	2nd floor T218 west	SMOKE/CO	3110849729
0377	Heat Detector	2nd T207 Attic southeast	Fixed Temperature /rate of rise	75938176
0378	Heat Detector	2nd T207 Attic northwest	Fixed Temperature /rate of rise	75938177
0379	Heat Detector	2nd T206 Attic southeast	Fixed Temperature /rate of rise	75938174
0380	Heat Detector	2nd T206 Attic northwest	Fixed Temperature /rate of rise	75938175
0382	Heat Detector	2nd T205 Attic southeast	Fixed Temperature /rate of rise	75938172
0383	Heat Detector	2nd T205 Attic northwest	Fixed Temperature /rate of rise	75938173
0385	Heat Detector	2nd T204 Attic northwest	Fixed Temperature /rate of rise	75938171
0386	Heat Detector	2nd T203 Attic east	Fixed Temperature /rate of rise	75938169
0386	Heat Detector	2nd T204 Attic southeast	Fixed Temperature	75938170

Address	Device Type	Location	Type	ScanID
			/rate of rise	
0387	Heat Detector	2nd T203 Attic center	Fixed Temperature	75938168
			/rate of rise	
0388	Heat Detector	2nd T203 Attic west	Fixed Temperature	75938167
			/rate of rise	
0389	Heat Detector	2nd T201&203 workroomAttic center	Fixed Temperature	75938166
			/rate of rise	
0390	Heat Detector	2nd T201Attic east	Fixed Temperature	75938165
			/rate of rise	
0391	Heat Detector	2nd T201Attic center	Fixed Temperature	75938164
			/rate of rise	
0392	Heat Detector	2nd T201Attic west	Fixed Temperature	75938163
			/rate of rise	
0393	Heat Detector	2nd floor attic girls restroom by T215	Fixed Temperature	75938206
			/rate of rise	
0394	Heat Detector	2nd floor attic boys restroom by T215	Fixed Temperature	75938207
			/rate of rise	
0395	Heat Detector	2nd T215 Attic southeast	Fixed Temperature	75938178
			/rate of rise	
0396	Heat Detector	2nd T215 Attic northwest	Fixed Temperature	75938179
			/rate of rise	
0397	Heat Detector	2nd T216 Attic southeast	Fixed Temperature	75938180
			/rate of rise	
0398	Heat Detector	2nd T216 Attic northwest	Fixed Temperature	75938181
			/rate of rise	
0399	Heat Detector	2nd T217 Attic Southeast	Fixed Temperature	75938182
			/rate of rise	
0400	Heat Detector	2nd T217 Attic northwest	Fixed Temperature	75938183
			/rate of rise	
0401	Heat Detector	2nd T218 Attic southeast	Fixed Temperature	75938184
			/rate of rise	
0402	Heat Detector	2nd T218 Attic northwest	Fixed Temperature	75938185
			/rate of rise	
0423	Heat Detector	2nd floor BLDG T Attic outside of T207	Line / fixed temperature	75938203
0424	Heat Detector	2nd floor BLDG T Attic outside electrical rm	Line / fixed temperature	75938204

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Turner ES (Point Quest)-Lodi
USD
18051 N ray Rd
Lodi, CA 95242

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Sep 8, 2022

Building: Turner ES (Point Quest)-Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: *BuildingReports.com*

Building Information

Address: 18051 N ray Rd

Address:

City/State/ZIP Code: Lodi, CA 95242

Country: United States of America

System Control Unit

Model Number: EST 3

Software Version: 1.8

Location: Admin Office

Install Date: 03/02/2007

Version Date: 03/02/2007

Current Protection: Breaker

IDC Style: B

SLC Style:

NAC Style: Y

Central Station Signal Verification

Test Time/Date: 9/8/22 7:11:34 PM

Restore Time:

Note: Dialer did not report trouble to panel.

Inspection Completion Date: Sep 8, 2022					
Building: Turner ES (Point Quest)-Lodi USD					
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Pull Station	1	1	0	1	1
Smoke Detector	32	32	0	32	32
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Horn/Strobe	7	6	1	7	7
Strobe	3	3	0	3	3
EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Power Supply	1	1	0	1	1
Total Device Count: 66					

Inspection & Testing

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left.
Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Heat Detector	9	9	0	9	9

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Attic 4	14226329	1-02 0128	09/08-P
Heat Detector	Attic 4	14226330	1-02 0128	09/08-P
Heat Detector	Attic 5	14226328	1-02 0128	09/08-P
Heat Detector	Attic 5	14226327	1-02 0128	09/08-P
Heat Detector	Attic 6 East	14226325	1-02 0128	09/08-P
Heat Detector	Attic 6 West	14226326	1-02 0128	09/08-P
Heat Detector	Attic Admin Restroom	04099233	1-02 0126	09/08-P
Heat Detector	Attic Admin South Center Office Near smoke	04099209	1-02 0126	09/08-P
Heat Detector	Custodian Rm near boys rm	07257862	1-02 014	09/08-P

Device Total: 9 [Return to Executive Summary](#)

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Pull Station	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Pull Station	Main Office Admin.		04099231	1-02 0129	09/08-P
Device Total: 1		Return to Executive Summary			

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Smoke Detector	32	32	0	32	32
Device Type	Location		ScanID	Address	Q3/22
Smoke Detector	5th At 1 West		04099188	1-02 029	09/08-P
Smoke Detector	Admin Bathrm		07257892	1-01020009	09/08-P
Smoke Detector	Admin Entrance		07257890	1-01020007	09/08-P
Smoke Detector	Admin Office Rm		07257893	1-010200010	09/08-P
Smoke Detector	Admin Office Work Rm		07257894	1-02 0011	09/08-P
Smoke Detector	Admin Storage		07257891	1-01020008	09/08-P
Smoke Detector	Class Rm 1 1		07257895	1-2 0033	09/08-P
Smoke Detector	Class Rm 1 2		07257896	1-2 0032	09/08-P
Smoke Detector	Class Rm 1 3		07257897	1-2 0031	09/08-P
Smoke Detector	Class Rm 1 4		07257898	1-2 0030	09/08-P
Smoke Detector	Class Rm 2 1		07257901	1-02 0028	09/08-P
Smoke Detector	Class Rm 2 2		07257900	1-02 0027	09/08-P
Smoke Detector	Class Rm 2 3		07257899	1-02 0026	09/08-P
Smoke Detector	Class Rm 2 4		07257855	1-02 0025	09/08-P
Smoke Detector	Class Rm 2 5		07257854	1-02 0024	09/08-P
Smoke Detector	Class Rm 3 1		04099186	1-02 0023	09/08-P
Smoke Detector	Class Rm 3 2		07257856	1-02 0022	09/08-P
Smoke Detector	Class Rm 3 3		07257857	1-02 0021	09/08-P
Smoke Detector	Class Rm 3 4		07257858	1-02 0020	09/08-P
Smoke Detector	Class Rm 3 5		07257859	1-02 0019	09/08-P
Smoke Detector	Lounge by 3 1		07257860	1-01020018	09/08-P
Smoke Detector	Lounge by 3 2		07257861	1-01020017	09/08-P
Smoke Detector	East . Bathroom boys		04099180	1-01020013	09/08-P
Smoke Detector	East . Bathroom girls		04099196	1-01020016	09/08-P
Smoke Detector	North Classroom 4		3967073100	1-02 0001	09/08-P
Smoke Detector	North Classroom 5		3967095713	1-02 0003	09/08-P
Smoke Detector	North . Classroom 6		3967095256	1-02 0005	09/08-P
Smoke Detector	South Classroom 4		3967096345	1-02 0002	09/08-P
Smoke Detector	South Classroom 6		3967097069	1-02 0006	09/08-P
Smoke Detector	South . Classroom 5		3967093160	1-02 0004	09/08-P
Smoke Detector	West . Bathroom boys		04099187	1-01020012	09/08-P
Smoke Detector	West . Bathroom girls		04099195	1-01020015	09/08-P

Device Type	Location	ScanID	Address	Q3/22

EC 02.03.05 EP 04

Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5

Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn	6	6	0	6	6
Device Type	Location	ScanID	Address	Q3/22	
Horn	Inside Classroom #1	04099431	1	09/08-P	
Horn	Inside Classroom #2	04099432	1	09/08-P	
Horn	Inside Classroom #3	04099433	1	09/08-P	
Horn	Outside Admin Office	04099227	1-0 6	09/08-P	
Horn	Outside Classroom #6	20414664	1	09/08-P	
Horn	Outside Classroom-2	04099294	1-0 6	09/08-P	
Device Total: 6 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18.					
Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	7	6	1	7	7
Device Type	Location		ScanID	Address	Q3/22
Horn/Strobe	Bathroom Boys		04099436	1	09/08-P
Horn/Strobe	Bathroom Girls		04099435	1-0 6	09/08-P
Horn/Strobe	Classroom 4		14226324	1	09/08-F
Horn/Strobe	Classroom 5		14226320	1	09/08-P
Horn/Strobe	Classroom 6		14226319	1	09/08-P
Horn/Strobe	Conference rm		04099434	1-0 6	09/08-P
Horn/Strobe	Office Admin Hall		04099230	1	09/08-P
Device Total: 7 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Strobe	3	3	0	3	3
Device Type	Location		ScanID	Address	Q3/22
Strobe	Office Admin		04099232	1	09/08-P
Strobe	Office Admin Restroom		04099229	1	09/08-P
Strobe	Office Admin Workroom		04099228	1	09/08-P
Device Total: 3		Return to Executive Summary			

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Communicator	Admin Office		04099210	1	09/08-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q3/22	
Control Panel			Admin Office				04099206		1		09/08-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Battery	5	3	2	5	5
Device Type	Location		ScanID	Address	Q3/22
Battery	Admin Office Dialer		49363603	1	09/08-P
Battery	Admin Office FACP		49363601	1	09/08-F
Battery	Admin Office FACP		49363602	1	09/08-F
Battery	Classroom 4		44807744	1	09/08-P
Battery	Classroom 4		44807745	1	09/08-P
Device Total: 5 Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Power Supply	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Power Supply	Classroom 4		14226321	1-02 0001	09/08-P
Device Total: 1 Return to Executive Summary					

Service Summary

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		2
Horn/Strobe	Annual	1
		3
<i>Passed</i>		
Battery	Tested	3
Communicator	Annual	1
Control Panel	Annual	1
Heat Detector	Annual	9
Horn/Strobe	Annual	6
Horn	Annual	6
Power Supply	Annual	1
Pull Station	Annual	1
Smoke Detector	Annual	32
Strobe	Annual	3
Total		63
Grand Total		66

Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD		Control Panel: 1 - EST EST 3		
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
Passed				
Smoke Detector				
Air Duct	South Classroom 6	Passed	3967097069	

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD				Control Panel: 1 - EST EST 3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	Classroom 4	7	12	13.7	13.2	80%	100%
Sealed Lead Acid	Classroom 4	7	12	13.7	13.2	80%	100%
Failed/Other							
Sealed Lead Acid	Admin Office FACP	12	12	13.2	13.1	80%	80%
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
	Classroom 4	10	120				

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD	Control Panel: 1 - EST EST 3
---	------------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Communicator	Control	1.52%	1
Control Panel	Control	1.52%	1
Heat Detector	Initiating	13.64%	9
Horn	Indicating	9.09%	6
Horn/Strobe	Indicating	10.61%	7
Power Supply	Control	1.52%	1
Pull Station	Initiating	1.52%	1
Smoke Detector	Initiating	48.48%	32
Strobe	Indicating	4.55%	3

Type	Qty	Model #	Description	Install Date
<i>In Service - 3 Years to 5 Years</i>				
Power-Sonic				

<i>In Service - 5 Years to 10 Years</i>				
Power-Sonic				

Battery	2	PS-1270	Sealed Lead Acid	05/17/2016
---------	---	---------	------------------	------------

<i>In Service - 15 Years to 25 Years</i>				
---	--	--	--	--

EST				
Control Panel	1	EST 3		03/02/2007
Heat Detector	4	284B-PL	Fixed Temperature	03/02/2007
Heat Detector	3	985-a	Fixed Temperature	03/02/2007
Heat Detector	1	G1RF VM	Fixed Temperature	03/02/2007
Heat Detector	1	Siga-HRS		03/02/2007
Horn	2	7571AT		03/02/2007
Horn/Strobe	1	G1RF .HDVM		03/02/2007
Horn/Strobe	3	G1RFHDVM		03/02/2007
Pull Station	1	Siga-270	Single Action	03/02/2007
Smoke Detector	23	Siga-PS	Photoelectric	03/02/2007
Smoke Detector	9	Siga-ps		03/02/2007
Strobe	3	G1RF VM		03/02/2007

Wheelock				
-----------------	--	--	--	--

Horn/Strobe	3	NS-24MCW	03/02/2007
Power Supply	1	PS-24-8MC	03/02/2007
EST			
Horn	3	G1RFHD	07/06/2006
Silent Knight			
Communicator	1	5104B	07/06/2006
Wheelock			
Horn	1	G1RFHD	07/06/2006

Zone Address Report

Generated by: BuildingReports.com

Building: Turner ES (Point Quest)-Lodi USD			Control Panel: 1 - EST EST 3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 0				
6	Horn/Strobe	Bathroom Girls		04099435
6	Horn/Strobe	Conference rm		04099434
6	Horn	Outside Admin Office		04099227
6	Horn	Outside Classroom-2		04099294
Zone/Circuit: 02				
0001	Power Supply	Classroom 4		14226321
0001	Smoke Detector	North Classroom 4	Photoelectric	3967073100
0002	Smoke Detector	South Classroom 4	Photoelectric	3967096345
0003	Smoke Detector	North Classroom 5	Photoelectric	3967095713
0004	Smoke Detector	South . Classroom 5	Photoelectric	3967093160
0005	Smoke Detector	North . Classroom 6	Photoelectric	3967095256
0006	Smoke Detector	South Classroom 6	Photoelectric	3967097069
0011	Smoke Detector	Admin Office Work Rm		07257894
014	Heat Detector	Custodian Rm near boys rm		07257862
0019	Smoke Detector	Class Rm 3 5	Photoelectric	07257859
0020	Smoke Detector	Class Rm 3 4	Photoelectric	07257858
0021	Smoke Detector	Class Rm 3 3	Photoelectric	07257857
0022	Smoke Detector	Class Rm 3 2	Photoelectric	07257856
0023	Smoke Detector	Class Rm 3 1	Photoelectric	04099186
0024	Smoke Detector	Class Rm 2 5	Photoelectric	07257854
0025	Smoke Detector	Class Rm 2 4	Photoelectric	07257855
0026	Smoke Detector	Class Rm 2 3	Photoelectric	07257899
0027	Smoke Detector	Class Rm 2 2	Photoelectric	07257900
0028	Smoke Detector	Class Rm 2 1	Photoelectric	07257901
029	Smoke Detector	5th At 1 West	Photoelectric	04099188
Zone/Circuit: 2				
0030	Smoke Detector	Class Rm 1 4		07257898
0031	Smoke Detector	Class Rm 1 3		07257897
0032	Smoke Detector	Class Rm 1 2		07257896
0033	Smoke Detector	Class Rm 1 1		07257895
Zone/Circuit: 02				
0126	Heat Detector	Attic Admin Restroom	Fixed Temperature	04099233
0126	Heat Detector	Attic Admin South Center Office Near smoke	Fixed Temperature	04099209
0128	Heat Detector	Attic 4	Fixed Temperature	14226329

Address	Device Type	Location	Type	ScanID
0128	Heat Detector	Attic 4	Fixed Temperature	14226330
0128	Heat Detector	Attic 5	Fixed Temperature	14226327
0128	Heat Detector	Attic 5	Fixed Temperature	14226328
0128	Heat Detector	Attic 6 East	Fixed Temperature	14226325
0128	Heat Detector	Attic 6 West	Fixed Temperature	14226326
0129	Pull Station	Main Office Admin.	Single Action	04099231
01020007	Smoke Detector	Admin Entrance		07257890
01020008	Smoke Detector	Admin Storage		07257891
01020009	Smoke Detector	Admin Bathrm		07257892
01020012	Smoke Detector	West . Bathroom boys	Photoelectric	04099187
01020013	Smoke Detector	East . Bathroom boys	Photoelectric	04099180
01020015	Smoke Detector	West . Bathroom girls	Photoelectric	04099195
01020016	Smoke Detector	East . Bathroom girls	Photoelectric	04099196
01020017	Smoke Detector	Lounge by 3 2	Photoelectric	07257861
01020018	Smoke Detector	Lounge by 3 1	Photoelectric	07257860
010200010	Smoke Detector	Admin Office Rm		07257893

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Victor ES-Lodi USD
17670 North Bruella Rd
Victor, CA 95253

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Sep 7, 2022

Building: Victor ES-Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: *BuildingReports.com*

Building Information

Address: 17670 North Bruella Rd

Address:

City/State/ZIP Code: Victor, CA 95253

Country: United States of America

System Control Unit

Model Number: E3 Series

Software Version:

Location: Library Work room

Install Date: 05/03/2007

Version Date: 06/09/2021

Current Protection:

IDC Style:

SLC Style:

NAC Style:

Inspection Completion Date: Sep 7, 2022					
Building: Victor ES-Lodi USD					
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Heat Detector	35	35	0	35	66
Pull Station	1	1	0	1	1
Smoke Detector	54	54	0	54	54
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Horn/Strobe	31	31	0	31	31
Strobe	2	2	0	2	2
Voice Evacuation	1	1	0	1	1
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Battery	4	2	2	4	4
Power Supply	1	1	0	1	1
Total Device Count: 175					

Inspection & Testing

Generated by: BuildingReports.com

Building: Victor ES-Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left. Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

In addition to testing in place to ensure smoke entry into the sensing chamber and an alarm response, duct smoke detectors utilizing sampling tubes shall be tested by verifying the correct pressure differential (within the manufacturer's published ranges) between the inlet and exhaust tubes using a method acceptable to the manufacturer to ensure that the device will properly sample the airstream. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g. 6))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Duct Detector	4	4	0	4	4
Device Type	Location	ScanID	Address	Q3/22	
Duct Detector	Northwest BLDG B Roof	67443090	1-L	09/07-P	
Duct Detector	Southeast BLDG A Roof	67443089	1-L	09/07-P	
Duct Detector	Southeast BLDG B Roof	67443088	1-L	09/07-P	
Duct Detector	Southwest BLDG B Attic	67443091	1-L	09/07-P	
Device Total: 4 Return to Executive Summary					

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
---------	--------------	------------	------------	-------------------	----------------

Heat Detector	35	35	0	35	66
---------------	----	----	---	----	----

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Admin Janitors Room	66013425	1-1-73	09/07-P
Heat Detector	K1 Classroom Closet	66013379	1-L D67	09/07-P
Heat Detector	Library Custodial Room	66013413	1-L D34	09/07-P
Heat Detector	Main Building Breakroom	66013423	1-1-95	09/07-P
Heat Detector	Main Building Breakroom Attic	67442999	1-L D78	09/07-P
Heat Detector	Main Building Breakroom Attic	67443000	1-L D92	09/07-P
Heat Detector	Main Building Breakroom Attic	67443006	1-L1 D128	09/07-P
Heat Detector	Main Building Breakroom Attic	67443008	1-L1 D127	09/07-P
Heat Detector	Main Building Breakroom Attic	67443007	1-L1 D129	
Heat Detector	Main Building Breakroom Attic	67443009	1-L1 D75	
Heat Detector	Main Building Breakroom Closet	66013422	1-1-95	09/07-P
Heat Detector	Principal's Office	67443001	1-L1 D84	09/07-P
Heat Detector	Center West Exterior Front Entrance Attic	67443011	1-L1 D79	
Heat Detector	East Exterior Classroom K1 Attic	67443017	1-L1 D65	
Heat Detector	East Exterior Classroom 4 & 3 Attic	67443098	1-L1 D24	
Heat Detector	East Exterior Classroom 5 Attic	67443096	1-L1 D42	
Heat Detector	East K1 Classroom	66014645	1-L D131	09/07-P
Heat Detector	East Library Classroom 3	66014654	1-L D22	09/07-P
Heat Detector	East Library Classroom 4	66014653	1-L D28	09/07-P
Heat Detector	East Library Classroom 7	66014642	1-L D51	
Heat Detector	East Library Classroom 8	66014644	1-L D155	
Heat Detector	East Portable 11	66014665	1-L D103	09/07-P
Heat Detector	East Portable 10	66014663	1-L1D107	09/07-P
Heat Detector	North Cafeteria	67442998	1-L 88	09/07-P
Heat Detector	North Exterior Cafeteria Attic	67443015	1-L1 D99	
Heat Detector	North Exterior Classroom 2 & 1 Attic	67443100	1-L1 D19	
Heat Detector	North Exterior Classroom 2 & 3 Attic	67443099	1-L1 D23	
Heat Detector	North Exterior Front Entrance Attic	67443010	1-L1 D90	
Heat Detector	North Exterior of Classroom 8 Attic	67443024	1-L1 D52	
Heat Detector	North Library Classroom 1	66014656	1-L D123	09/07-P
Heat Detector	North Library Classroom 2	66014646	1-L D18	09/07-P
Heat Detector	North Library Classroom 2	66014655	1-L D124	09/07-P
Heat Detector	North Library Classroom 4	66014649	1-L D126	09/07-P
Heat Detector	North Library Classroom 5	66014652	1-L D41	
Heat Detector	North Library Classroom 6	66014651	1-L D46	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	North Library Conference Room	66013398	1-L D07	09/07-P
Heat Detector	North Library Conference Room Attic	66014658	1-L D05	09/07-P
Heat Detector	North Library Conference Room Attic	66014668	1-L D08	09/07-P
Heat Detector	North Library Conference Room Attic	66014667	1-L D02	
Heat Detector	North Portable 11	66014664	1-L D115	09/07-P
Heat Detector	Northwest Exterior of Breakroom Attic	67443014	1-L1 D83	
Heat Detector	Northwest Exterior of Principles Office Attic	67443012	1-L1 D89	
Heat Detector	Northwest Exterior of Principles Office Attic	67443013	1-L1 D82	
Heat Detector	South Cafeteria	67443004	1-L D97	09/07-P
Heat Detector	South Exterior Cafeteria Attic	67443020	1-L1 D72	
Heat Detector	South Exterior Classroom K1 Attic	67443018	1-L1 D69	
Heat Detector	South Exterior Classroom 4 Attic	67443097	1-L1 D29	
Heat Detector	South Exterior Front Entrance Attic	67443003	7-L1 D63	
Heat Detector	South Exterior of Classroom 6 Attic	67443023	1-L1 D43	
Heat Detector	South Library Boys Bathroom Attic	67443095	1-L1 D31	09/07-P
Heat Detector	South Library Boys Bathroom Attic	67443022	1-L1 D33	
Heat Detector	South Library Classroom 1	66014657	1-L D14	09/07-P
Heat Detector	South Library Classroom 5	66014648	1-L D119	09/07-P
Heat Detector	South Library Classroom 6	66014647	1-L D120	09/07-P
Heat Detector	South Portable 11	66014666	1-L D112	09/07-P
Heat Detector	Southeast Exterior Cafeteria Attic	67443021	1-L1 D101	
Heat Detector	Southwest Exterior of Classroom 7 & 6 Attic	67443016	1-L1 D47	
Heat Detector	West Exterior Classroom 1 Attic	67443094	1-L1 D15	
Heat Detector	West Exterior Front Entrance Attic	67443002	7-L1 D80	
Heat Detector	West Exterior of Classroom 8 Attic	67443025	1-L1 D03	
Heat Detector	West K1 Classroom	66014640	1-L D61	09/07-P
Heat Detector	West Library Classroom 3	66014650	1-L D125	
Heat Detector	West Library Classroom 7	66014641	1-L D121	09/07-P
Heat Detector	West Library Classroom 8	66014643	1-L D122	09/07-P
Heat Detector	West Portable 10	66014670	1-L1D108	09/07-P
Heat Detector	West Portable 11	66014669	1-L1D104	09/07-P
Device Total: 66 Return to Executive Summary				

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Pull Station	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Pull Station	Main office on the side of call station.		66013438	1-L1 M02	09/07-P
Device Total: 1		Return to Executive Summary			

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5					
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Smoke Detector	54	54	0	54	54
Device Type	Location	ScanID	Address	Q3/22	
Smoke Detector	Counselor's Office	66013389	1-1-85	09/07-P	
Smoke Detector	K1 Classroom	66013418	1-L D59	09/07-P	
Smoke Detector	K1 Classroom	66013419	1-L D60	09/07-P	
Smoke Detector	K1 Classroom	66013380	1-L D62	09/07-P	
Smoke Detector	K1 Classroom bathroom	66013382	1-L D62	09/07-P	
Smoke Detector	Main Building Multipurpose Room	66013383	1-L D100	09/07-P	
Smoke Detector	Main Building Multipurpose Room	66013421	1-L D98	09/07-P	
Smoke Detector	Main office above reception	66013436	1-1-83	09/07-P	
Smoke Detector	Nurse's Office	66013431	1-1-91	09/07-P	
Smoke Detector	Portable Classroom 09	66013440	1-I D113	09/07-P	
Smoke Detector	Portable Classroom 09	66013447	1-I D114	09/07-P	
Smoke Detector	Portable Classroom 09 Bathroom	66013441	1-I D111	09/07-P	
Smoke Detector	Portable Classroom 09 storage	66013358	1-I D110	09/07-P	
Smoke Detector	Portable Classroom 10	66013396	1-L D109	09/07-P	
Smoke Detector	Portable Classroom 10	66013439	1-L D106	09/07-P	
Smoke Detector	Portable Classroom 11	66013448	1-L D102	09/07-P	
Smoke Detector	Principal's Office	66013390	1-1-87	09/07-P	
Smoke Detector	library boys bathroom	66013446	1-I D32	09/07-P	
Smoke Detector	library classroom 1	66013403	1-L D12	09/07-P	
Smoke Detector	library classroom 1	66013401	1-L D13	09/07-P	
Smoke Detector	library classroom 2	66013406	1-L D16	09/07-P	
Smoke Detector	library classroom 2	66013404	1-L D17	09/07-P	
Smoke Detector	library classroom 3	66013409	1-L D20	09/07-P	
Smoke Detector	library classroom 3	66013407	1-L D21	09/07-P	
Smoke Detector	library classroom 4	66013412	1-L D25	09/07-P	
Smoke Detector	library classroom 4	66013411	1-L D27	09/07-P	
Smoke Detector	library classroom 5	66013392	1-I D39	09/07-P	
Smoke Detector	library classroom 5	66013394	1-I D40	09/07-P	
Smoke Detector	library classroom 6	66013366	1-I D44	09/07-P	
Smoke Detector	library classroom 6	66013365	1-I D45	09/07-P	
Smoke Detector	library classroom 7	66013400	1-I 1d48	09/07-P	
Smoke Detector	library classroom 7	66013399	1-I 1d50	09/07-P	

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	library classroom 8	66013416	1-I D53	09/07-P
Smoke Detector	library classroom 8	66013378	1-I d54	09/07-P
Smoke Detector	library entrance hallway north	66013376	1-L1 006	09/07-P
Smoke Detector	library entrance hallway north	66013363	1-L1 004	09/07-P
Smoke Detector	library girls bathroom	66013353	1-L D30	09/07-P
Smoke Detector	library room	66013372	1-L D09	09/07-P
Smoke Detector	library room	66013371	1-L D11	09/07-P
Smoke Detector	library room	66013369	1-L D10	09/07-P
Smoke Detector	library room	66013370	1-L D130	09/07-P
Smoke Detector	library room	66013373	1-L D49	09/07-P
Smoke Detector	library room	66013367	1-L D26	09/07-P
Smoke Detector	library room	66013375	1-L D35	09/07-P
Smoke Detector	library room	66013374	1-L D36	09/07-P
Smoke Detector	library south entrance	66013415	1-L D37	09/07-P
Smoke Detector	library workoorm	66013362	1-L1 001	09/07-P
Smoke Detector	North Office Admin Hallway	66013435	1-1-81	09/07-P
Smoke Detector	South Office Admin Entrance Lobby	66013433	1-1-77	09/07-P
Smoke Detector	South Office Admin Mens Bathroom	66013385	1-1-70	09/07-P
Smoke Detector	South Office Admin Womans Bathroom	66013386	1-1-56	09/07-P
Smoke Detector	South Office Admin hallway	66013429	1-1-76	09/07-P
Smoke Detector	South Office Admin hallway	66013427	1-1-74	09/07-P
Smoke Detector	South Portable Classroom 11	66013355	1-L D105	09/07-P
Device Total: 54 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn	7	7	0	7	9
Device Type	Location		ScanID	Address	Q3/22
Horn	Portable Classroom 09 exterior		66013356	1	09/07-P
Horn	Portable Classroom 10 exterior		66013360	1	09/07-P
Horn	Portable Classroom 11 exterior		66013354	1	09/07-P
Horn	library exterior east		66013443	1	09/07-P
Horn	library exterior south		66013449	1	09/07-P
Horn	main building K Room exterior South		66013450	1	
Horn	main building K Room exterior east		66013352	1	09/07-P
Horn	main building K Room exterior west		66013349	1	09/07-P
Horn	main building exterior east		66013350	1	
Device Total: 9 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18.					
Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	31	31	0	31	31
Device Type	Location	ScanID	Address	Q3/22	
Horn/Strobe	Counselor's Office	66013388	1	09/07-P	
Horn/Strobe	K1 Classroom	66013417	1-L	09/07-P	
Horn/Strobe	K1 Classroom bathroom	66013381	1-L	09/07-P	
Horn/Strobe	Main Building Breakroom	66013424	1	09/07-P	
Horn/Strobe	Main Building Multipurpose Room	66013420	1	09/07-P	
Horn/Strobe	Main office above reception	66013437	1	09/07-P	
Horn/Strobe	Nurse's Office	66013430	1	09/07-P	
Horn/Strobe	Office Admin Entrannce lobby	66013434	1	09/07-P	
Horn/Strobe	Portable Classroom 09	66013359	1	09/07-P	
Horn/Strobe	Portable Classroom 10	66013397	1	09/07-P	
Horn/Strobe	Portable Classroom 11	66013305	1	09/07-P	
Horn/Strobe	Principal's Office	66013391	1	09/07-P	
Horn/Strobe	library boys bathroom	66013445	1	09/07-P	
Horn/Strobe	library classroom 1	66013402	1	09/07-P	
Horn/Strobe	library classroom 2	66013405	1	09/07-P	
Horn/Strobe	library classroom 3	66013408	1	09/07-P	
Horn/Strobe	library classroom 4	66013410	1	09/07-P	
Horn/Strobe	library classroom 5	66013393	1	09/07-P	
Horn/Strobe	library classroom 6	66013364	1	09/07-P	
Horn/Strobe	library classroom 7	66013395	1	09/07-P	
Horn/Strobe	library classroom 8	66013377	1	09/07-P	
Horn/Strobe	library entrance hallway North	66013351	1	09/07-P	
Horn/Strobe	library girls bathroom	66013444	1	09/07-P	
Horn/Strobe	library room	66013368	1	09/07-P	
Horn/Strobe	library south entrance	66013414	1	09/07-P	
Horn/Strobe	library workroom	66013361	1	09/07-P	
Horn/Strobe	South Office Admin Entrance Lobby	66013432	1	09/07-P	
Horn/Strobe	South Office Admin Hallway	66013426	1-1-74	09/07-P	
Horn/Strobe	South Office Admin Mens Bathroom	66013384	1-1-76	09/07-P	
Horn/Strobe	South Office Admin Womans Bathroom	66013387	1	09/07-P	
Horn/Strobe	South Office Admin hallway	66013428	1-1-76	09/07-P	
Device Total: 31 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Strobe	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Strobe	Portable Classroom 09 Bathroom		66013442	1-I D111	09/07-P
Strobe	Portable Classroom 09 storage		66013357	1	09/07-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 04	Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). Audible information shall be verified to be distinguishable and understandable. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15b))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Voice Evacuation	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Voice Evacuation	Main office on the side of call station.		66014662	1	09/07-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q3/22	
Control Panel			Libray Work room				66013451		1		09/07-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
The correct operation and identification of annunciators shall be verified. If provided, the correct operation of annunciator under a fault condition shall be verified. (2010 ed.) (NFPA 72 Table 14.4.2.2 (11))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Annunciator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Annunciator	Office Admin		07257866	1	09/07-P
Device Total: 1		Return to Executive Summary			

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Battery	4	2	2	4	4
Device Type	Location		ScanID	Address	Q3/22
Battery	Library Workroom FACP		67443093	1	09/07-P
Battery	Library Workroom FACP		67443092	1	09/07-P
Battery	Library Workroom Power Supply		66013454	1	09/07-F
Battery	Library Workroom Power Supply		66013453	1	09/07-F
Device Total: 4		Return to Executive Summary			

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Power Supply	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Power Supply	Library Workroom Power Supply		66013452	1	09/07-P
Device Total: 1 Return to Executive Summary					

Service Summary

Generated by: BuildingReports.com

Building: Victor ES-Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		2
<i>Passed</i>		
		1
Battery	Tested	2
Control Panel	Tested	1
Duct Detector	Tested	4
Heat Detector	Tested	35
Horn/Strobe	Tested	31
Horn	Tested	7
Power Supply	Tested	1
Pull Station	Tested	1
Smoke Detector	Tested/Cleaned	54
Strobe	Tested	2
Voice Evacuation	Tested	1
		140
<i>Untested</i>		
Heat Detector		31
Horn		2
Total		33
Grand Total		175

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Victor ES-Lodi USD				Control Panel: 1 - Honeywell E3 Series			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	Library Workroom FACP	18ah	12V	13.7	13.4	80%	80%
Failed/Other							
Sealed Lead Acid	Library Workroom Power Supply	7ah	12V				
Sealed Lead Acid	Library Workroom Power Supply	7ah	12V	12.5		80%	20%
Passed							
Sealed Lead Acid	Library Workroom FACP	18ah	12V	13.7	13.2	80%	80%

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Victor ES-Lodi USD	Control Panel: 1 - Honeywell E3 Series
------------------------------	--

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Battery	Control	2.29%	4
Control Panel	Control	0.57%	1
Duct Detector	Initiating	2.29%	4
Heat Detector	Initiating	37.71%	66
Horn	Indicating	5.14%	9
Horn/Strobe	Indicating	17.71%	31
Power Supply	Control	0.57%	1
Pull Station	Initiating	0.57%	1
Smoke Detector	Initiating	30.86%	54
Strobe	Indicating	1.14%	2
Voice Evacuation	Control	0.57%	1

Type	Qty	Model #	Description	Install Date
<i>In Service - 5 Years to 10 Years</i>				
Honeywell				

Power-Sonic

Yuasa

<i>In Service - 15 Years to 25 Years</i>

Honeywell				
Control Panel	1	E3 Series		05/03/2007
Duct Detector	4			05/03/2007
Heat Detector	3			05/03/2007
Heat Detector	1	66014645		05/03/2007
Heat Detector	60	ATD-L3H-1V		05/03/2007
Horn/Strobe	2			05/03/2007
Horn/Strobe	2	4098-9601		05/03/2007
Horn/Strobe	2	Notifier		05/03/2007
Pull Station	1		Single Action	05/03/2007
Smoke Detector	4			05/03/2007
Smoke Detector	1		Photoelectric	05/03/2007
Smoke Detector	2	4098-9601	Photoelectric	05/03/2007

Smoke Detector	1	ASD-PL3		05/03/2007
Smoke Detector	9	Notifier		05/03/2007
Voice Evacuation	1			05/03/2007
Silent Knight				
Horn	9			05/03/2007
Horn/Strobe	17			05/03/2007
Smoke Detector	37			05/03/2007
Strobe	1			05/03/2007
Simplex				
Annunciator	1	Notifier		05/03/2007
Wheelock				
Horn/Strobe	1			05/03/2007
Horn/Strobe	7	Notifier		05/03/2007
Strobe	1			05/03/2007
Building: Victor ES-Lodi USD				Control Panel: 7
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<i>In Service - 15 Years to 25 Years</i>				
Honeywell				
Heat Detector	2	ATD-L3H-1V		05/03/2007

Zone Address Report

Generated by: BuildingReports.com

Building: Victor ES-Lodi USD			Control Panel: 1 - Honeywell E3 Series	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: L				
88	Heat Detector	North Cafeteria		67442998
D02	Heat Detector	North Library Conference Room Attic		66014667
D05	Heat Detector	North Library Conference Room Attic		66014658
D07	Heat Detector	North Library Conference Room		66013398
D08	Heat Detector	North Library Conference Room Attic		66014668
D09	Smoke Detector	library room		66013372
D10	Smoke Detector	library room		66013369
D11	Smoke Detector	library room		66013371
D12	Smoke Detector	library classroom 1		66013403
D13	Smoke Detector	library classroom 1		66013401
D14	Heat Detector	South Library Clasroom 1		66014657
D16	Smoke Detector	library classroom 2		66013406
D17	Smoke Detector	library classroom 2		66013404
D18	Heat Detector	North Library Clasroom 2		66014646
D20	Smoke Detector	library classroom 3		66013409
D21	Smoke Detector	library classroom 3		66013407
D22	Heat Detector	East Library Clasroom 3		66014654
D25	Smoke Detector	library classroom 4		66013412
D26	Smoke Detector	library room		66013367
D27	Smoke Detector	library classroom 4		66013411
D28	Heat Detector	East Library Clasroom 4		66014653
D30	Smoke Detector	library girls bathroom		66013353
D34	Heat Detector	Library Custodial Room		66013413
D35	Smoke Detector	library room		66013375
D36	Smoke Detector	library room		66013374
D37	Smoke Detector	library south entrance		66013415
D41	Heat Detector	North Library Clasroom 5		66014652
D46	Heat Detector	North Library Clasroom 6		66014651
D49	Smoke Detector	library room		66013373
D51	Heat Detector	East Library Classroom 7		66014642
D59	Smoke Detector	K1 Classroom		66013418
D60	Smoke Detector	K1 Classroom		66013419
D61	Heat Detector	West K1 Classroom		66014640
D62	Smoke Detector	K1 Classroom		66013380
D62	Smoke Detector	K1 Classroom bathroom		66013382
D67	Heat Detector	K1 Classroom Closet		66013379

Address	Device Type	Location	Type	ScanID
D78	Heat Detector	Main Building Breakroom Attic		67442999
D92	Heat Detector	Main Building Breakroom Attic		67443000
D97	Heat Detector	South Cafeteria		67443004
D98	Smoke Detector	Main Building Multipurpose Room		66013421
D100	Smoke Detector	Main Building Multipurpose Room		66013383
D102	Smoke Detector	Portable Classroom 11		66013448
D103	Heat Detector	East Portable 11		66014665
D105	Smoke Detector	South Portable Classroom 11		66013355
D106	Smoke Detector	Portable Classroom 10		66013439
D109	Smoke Detector	Portable Classroom 10		66013396
D112	Heat Detector	South Portable 11		66014666
D115	Heat Detector	North Portable 11		66014664
D119	Heat Detector	South Library Classroom 5		66014648
D120	Heat Detector	South Library Classroom 6		66014647
D121	Heat Detector	West Library Classroom 7		66014641
D122	Heat Detector	West Library Classroom 8		66014643
D123	Heat Detector	North Library Classroom 1		66014656
D124	Heat Detector	North Library Classroom 2		66014655
D125	Heat Detector	West Library Classroom 3		66014650
D126	Heat Detector	North Library Classroom 4		66014649
D130	Smoke Detector	library room		66013370
D131	Heat Detector	East K1 Classroom		66014645
D155	Heat Detector	East Library Classroom 8		66014644
	Horn/Strobe	K1 Classroom		66013417
	Horn/Strobe	K1 Classroom bathroom		66013381
	Duct Detector	Northwest BLDG B Roof		67443090
	Duct Detector	Southeast BLDG A Roof		67443089
	Duct Detector	Southeast BLDG B Roof		67443088
	Duct Detector	Southwest BLDG B Attic		67443091
Zone/Circuit: L1				
001	Smoke Detector	library workroom	Photoelectric	66013362
004	Smoke Detector	library entrance hallway north	Photoelectric	66013363
006	Smoke Detector	library entrance hallway north	Photoelectric	66013376
D03	Heat Detector	West Exterior of Classroom 8 Attic		67443025
D15	Heat Detector	West Exterior Classroom 1 Attic		67443094
D19	Heat Detector	North Exterior Classroom 2 & 1 Attic		67443100
D23	Heat Detector	North Exterior Classroom 2 & 3 Attic		67443099
D24	Heat Detector	East Exterior Classroom 4 & 3 Attic		67443098
D29	Heat Detector	South Exterior Classroom 4 Attic		67443097
D31	Heat Detector	South Library Boys Bathroom Attic		67443095
D33	Heat Detector	South Library Boys Bathroom Attic		67443022
D42	Heat Detector	East Exterior Classroom 5 Attic		67443096
D43	Heat Detector	South Exterior of Classroom 6 Attic		67443023
D47	Heat Detector	Southwest Exterior of Classroom 7 & 6 Attic		67443016
D52	Heat Detector	North Exterior of Classroom 8 Attic		67443024

Address	Device Type	Location	Type	ScanID
D65	Heat Detector	East Exterior Clasroom K1 Attic		67443017
D69	Heat Detector	South Exterior Clasroom K1 Attic		67443018
D72	Heat Detector	South Exterior Cafeteria Attic		67443020
D75	Heat Detector	Main Building Breakroom Attic		67443009
D79	Heat Detector	Center West Exterior Front Entrance Attic		67443011
D82	Heat Detector	Northwest Exterior of Principles Office Attic		67443013
D83	Heat Detector	Northwest Exterior of Breakroom Attic		67443014
D84	Heat Detector	Principal's Office		67443001
D89	Heat Detector	Northwest Exterior of Principles Office Attic		67443012
D90	Heat Detector	North Exterior Front Entrance Attic		67443010
D99	Heat Detector	North Exterior Cafeteria Attic		67443015
D101	Heat Detector	Southeast Exterior Cafeteria Attic		67443021
D127	Heat Detector	Main Building Breakroom Attic		67443008
D128	Heat Detector	Main Building Breakroom Attic		67443006
D129	Heat Detector	Main Building Breakroom Attic		67443007
M02	Pull Station	Main office on the side of call station.	Single Action	66013438
Zone/Circuit: I				
1d48	Smoke Detector	library classroom 7		66013400
1d50	Smoke Detector	library classroom 7		66013399
D32	Smoke Detector	library boys bathroom		66013446
D39	Smoke Detector	library classroom 5		66013392
D40	Smoke Detector	library classroom 5		66013394
D44	Smoke Detector	library classroom 6		66013366
D45	Smoke Detector	library classroom 6		66013365
D53	Smoke Detector	library classroom 8		66013416
D110	Smoke Detector	Portable Classroom 09 storage		66013358
D111	Smoke Detector	Portable Classroom 09 Bathroom		66013441
D111	Strobe	Portable Classroom 09 Bathroom		66013442
D113	Smoke Detector	Portable Classroom 09		66013440
D114	Smoke Detector	Portable Classroom 09		66013447
d54	Smoke Detector	library classroom 8		66013378
1-56	Smoke Detector	South Office Admin Womans Bathroom		66013386
1-70	Smoke Detector	South Office Admin Mens Bathroom		66013385
1-73	Heat Detector	Admin Janitors Room		66013425
1-74	Horn/Strobe	South Office Admin Hallway		66013426
1-74	Smoke Detector	South Office Admin hallway		66013427
1-76	Horn/Strobe	South Office Admin Mens Bathroom		66013384
1-76	Horn/Strobe	South Office Admin hallway		66013428
1-76	Smoke Detector	South Office Admin hallway		66013429
1-77	Smoke Detector	South Office Admin Entrance Lobby		66013433
1-81	Smoke Detector	North Office Admin Hallway		66013435
1-83	Smoke Detector	Main office above reception		66013436
1-85	Smoke Detector	Counselor's Office		66013389

Address	Device Type	Location	Type	ScanID
1-87	Smoke Detector	Principal's Office		66013390
1-91	Smoke Detector	Nurse's Office		66013431
1-95	Heat Detector	Main Building Breakroom		66013423
1-95	Heat Detector	Main Building Breakroom Closet		66013422
L1D104	Heat Detector	West Portablle 11		66014669
L1D107	Heat Detector	East Portablle 10		66014663
L1D108	Heat Detector	West Portablle 10		66014670
Building: Victor ES-Lodi USD			Control Panel: 7	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: L1				
D63	Heat Detector	South Exterior Front Entrance Attic		67443003
D80	Heat Detector	West Exterior Front Entrance Attic		67443002

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Vinewood ES-Lodi USD
1600 W Tokay Street
Lodi, CA 95242

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Dec 9, 2022

Building: Vinewood ES-Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: *BuildingReports.com*

Building Information

Address: 1600 W Tokay Street

Address:

City/State/ZIP Code: Lodi, CA 95242

Country: United States of America

System Control Unit

Model Number: Honeywell

Software Version:

Location: Front Main Office

Install Date: 04/09/2007

Version Date: 04/09/2007

Current Protection: Breaker

IDC Style:

SLC Style:

NAC Style:

Central Station Signal Verification

Test Time/Date: 12/9/22 8:26:20 PM

Restore Time:

Note:

Inspection Completion Date: Dec 9, 2022					
Building: Vinewood ES-Lodi USD					
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Heat Detector	4	4	0	4	4
Pull Station	1	1	0	1	2
Smoke Detector	76	76	0	76	76
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Horn/Strobe	1	1	0	1	1
Voice Evacuation	7	7	0	7	7
EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
CO Detector	8	8	0	8	8
Power Supply	7	7	0	7	7
Total Device Count: 142					

Inspection & Testing

Generated by: BuildingReports.com

Building: Vinewood ES-Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left. Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 03 Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5

In addition to testing in place to ensure smoke entry into the sensing chamber and an alarm response, duct smoke detectors utilizing sampling tubes shall be tested by verifying the correct pressure differential (within the manufacturer's published ranges) between the inlet and exhaust tubes using a method acceptable to the manufacturer to ensure that the device will properly sample the airstream. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g. 6))

Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Duct Detector	0	0	0	0	2
Device Type	Location	ScanID	Address	Q4/22	
Duct Detector	Roof BLDG A, ON ROOF, ACCESS THROUGH ELECTRICAL ROOM	45705214	1		
Duct Detector	Roof BLDG B, ON ROOF, ACCESS THROUGH ELECTRICAL ROOM	45705215	1		
Device Total: 2 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Heat Detector	4	4	0	4	4
Device Type	Location		ScanID	Address	Q4/22
Heat Detector	MP Kitchen		66016877	1-053	12/09-P
Heat Detector	MP Kitchen Storage		66016878	1-058	12/09-P
Heat Detector	Above Ceiling portable #1 east Attic		09162693	1-01 0001	12/09-P
Heat Detector	Above Ceiling portable #1 west Attic		09162694	1-01 013	12/09-P
Device Total: 4 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Pull Station	1	1	0	1	2
Device Type	Location		ScanID	Address	Q4/22
Pull Station	portable #2		04104358	1	
Pull Station	Entry Main Office		69507645	1-01 001	12/09-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 03	Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Smoke Detector	76	76	0	76	76
Device Type	Location		ScanID	Address	Q4/22
Smoke Detector	A boys bathroom		66016847	1-01 037	12/09-P
Smoke Detector	A girls bathroom		66016846	1-01 037	12/09-P
Smoke Detector	A Classroom 2 Bathroom		66016865	1-01 013	12/09-P
Smoke Detector	A Classroom 2 NE		66016866	1-01 013	12/09-P
Smoke Detector	A Classroom 2 NW		66016867	1-01 013	12/09-P
Smoke Detector	A Classroom 2 SE		66016869	1-01 013	12/09-P
Smoke Detector	A Classroom 2 SW		66016868	1-01 013	12/09-P
Smoke Detector	A Classroom 3		66016859	1-01 013	12/09-P
Smoke Detector	A Classroom 3		66016858	1-01 014	12/09-P
Smoke Detector	A Classroom 4		66016853	1-01 021	12/09-P
Smoke Detector	A Classroom 4		66016854	1-01 022	12/09-P
Smoke Detector	A Classroom 6		66016850	1-01 031	12/09-P
Smoke Detector	A Classroom 6		66016851	1-01 029	12/09-P
Smoke Detector	A Janitors closet		66016748	1-01 017	12/09-P
Smoke Detector	A RM 5		66016849	1-01 039	12/09-P
Smoke Detector	A RM 5		66016848	1-01 053	12/09-P
Smoke Detector	A SCC		66016856	1-01 028	12/09-P
Smoke Detector	A SCC		66016855	1-01 025	12/09-P
Smoke Detector	A SCC		66016852	1-01 033	12/09-P
Smoke Detector	A Workroom		66016857	1-01 013	12/09-P
Smoke Detector	B boys bathroom		66016844	1-01 066	12/09-P
Smoke Detector	B girls bathroom		66016831	1-01 068	12/09-P
Smoke Detector	B hallway		66016841	1-01 073	12/09-P
Smoke Detector	B hallway		66016843	1-01 065	12/09-P
Smoke Detector	B Electrical rm		66016759	1-01 082	12/09-P
Smoke Detector	B Room 10		66016834	1-01 057	12/09-P
Smoke Detector	B Room 7		66016836	1-01 075	12/09-P
Smoke Detector	B Room 8		66016832	1-01 061	12/09-P
Smoke Detector	B Room 9		66016837	1-01 081	12/09-P
Smoke Detector	B Room 9		66016838	1-01 079	12/09-P
Smoke Detector	B workroom		66016840	1-01 055	12/09-P
Smoke Detector	C Hallway		66016816	1-01 147	12/09-P

Device Type	Location	ScanID	Address	Q4/22
Smoke Detector	C boys bathroom	66016819	1-01 144	12/09-P
Smoke Detector	C girls bathroom	66016815	1-01 142	12/09-P
Smoke Detector	C workroom	66016829	1-01 056	12/09-P
Smoke Detector	C Classroom 11	66016821	1-01 155	12/09-P
Smoke Detector	C Classroom 12	66016825	1-01 137	12/09-P
Smoke Detector	C Classroom 12	66016824	1-01 134	12/09-P
Smoke Detector	C Classroom 13	66016818	1-01 148	12/09-P
Smoke Detector	C Classroom 14	66016823	1-01 138	12/09-P
Smoke Detector	C Electrical rm	66016827	1-01 132	12/09-P
Smoke Detector	C LIB	66016828	1-01 156	12/09-P
Smoke Detector	Counselor Office by Nurse	69507646	1-01 002	12/09-P
Smoke Detector	D 17	66016807	1-102	12/09-P
Smoke Detector	D 17	66016806	1-099	12/09-P
Smoke Detector	D Center	66016809	1-105	12/09-P
Smoke Detector	D Workroom	66016808	1-109	12/09-P
Smoke Detector	D boys bathroom	66016781	1-092	12/09-P
Smoke Detector	D girls bathroom	66016782	1-094	12/09-P
Smoke Detector	D15	66016804	1-098	12/09-P
Smoke Detector	D15	66016805	1-095	12/09-P
Smoke Detector	D16	66016801	1-089	12/09-P
Smoke Detector	D16	66016800	1-090	12/09-P
Smoke Detector	Kinder Classroom 1 Bathroom	66016860	1-01 012	12/09-P
Smoke Detector	Kinder Classroom 1 NW	66016861	1-01 010	12/09-P
Smoke Detector	Kinder Classroom 1 SE	66016863	1-01 008	12/09-P
Smoke Detector	Kinder Classroom 1 SW	66016864	1-01 011	12/09-P
Smoke Detector	MP Storage	66016876	1-042	12/09-P
Smoke Detector	Main Office Above Reception	69507651	1-01 001	12/09-P
Smoke Detector	Main Office Nurse	69507652	1-01 040	12/09-P
Smoke Detector	Main Office Nurse Restroom	69507653	1-01 003	12/09-P
Smoke Detector	Main Office Principal	69507648	1-01 004	12/09-P
Smoke Detector	Main Office Principal Closet	66016870	1-01 025	12/09-P
Smoke Detector	Main Office Storage Outside Principal Office	66016871	1-01 001	12/09-P
Smoke Detector	Main Office Workroom by FACP	69507647	1-01 006	12/09-P
Smoke Detector	portable MP Teachers rm	66016880	1-01 052	12/09-P
Smoke Detector	portable p1	66016768	1-01 087	12/09-P
Smoke Detector	portable p1	66016769	1-01 088	12/09-P
Smoke Detector	portable p2	66016771	1-01 083	12/09-P
Smoke Detector	portable p2	66016770	1-01 084	12/09-P
Smoke Detector	portable p3	66016814	1-01 092	12/09-P
Smoke Detector	portable p3	66016813	1-01 091	12/09-P
Smoke Detector	portable p4	66016811	1-01 096	12/09-P

Device Type	Location	ScanID	Address	Q4/22
Smoke Detector	portable p4	66016812	1-01 095	12/09-P
Smoke Detector	portable #1north	09162695	1-01 013	12/09-P
Smoke Detector	portable #1south	09162696	1-01 013	12/09-P
Device Total: 76 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Horn	2	2	0	2	2
Device Type	Location		ScanID	Address	Q4/22
Horn	portable #2		04104359	1	12/09-P
Horn	Outside portable #1		09162700	1	12/09-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18. Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	1	1	0	1	1
Device Type	Location		ScanID	Address	Q4/22
Horn/Strobe	portable #1		09162699	1	12/09-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). Audible information shall be verified to be distinguishable and understandable. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15b))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Voice Evacuation	7	7	0	7	7
Device Type	Location		ScanID	Address	Q4/22
Voice Evacuation	BLDG B Electrical rm		66016756	4	12/09-P
Voice Evacuation	Bldg D Electrical Rm		66016764	1	12/09-P
Voice Evacuation	MP Electrical Rm		69507660	1	12/09-P
Voice Evacuation	Main Office		66016753	3	12/09-P
Voice Evacuation	Main Office Workroom		69507656	1	12/09-P
Voice Evacuation	P2		66016773	3	12/09-P
Voice Evacuation	Pod A Electrical		69507671	1	12/09-P
Device Total: 7 Return to Executive Summary					

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q4/22
Communicator	Main INSIDE QUICKSTART FACP		45705216	1	12/09-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q4/22		Pass Q4/22		Fail Q4/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q4/22	
Control Panel			Front Main Office				66016745		1		12/09-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Battery	31	31	0	31	31
Device Type	Location		ScanID	Address	Q4/22
Battery	B Electrical Rm		66016758	1	12/09-P
Battery	B Electrical rm		66016757	1	12/09-P
Battery	B Electrical rm		66016761	1	12/09-P
Battery	B Electrical rm		66016762	1	12/09-P
Battery	C Electrical rm		66016749	1	12/09-P
Battery	C Electrical rm		66016750	1	12/09-P
Battery	C Electrical rm		66016752	1	12/09-P
Battery	C Electrical rm		66016754	1	12/09-P
Battery	C Electrical rm		66016755	1	12/09-P
Battery	D Electrical Rm		66016872	1	12/09-P
Battery	D Electrical Rm		66016873	1	12/09-P
Battery	D Electrical rm		66016765	1	12/09-P
Battery	D Electrical rm		66016766	1	12/09-P
Battery	MP Electrical Rm		69507662	1	12/09-P
Battery	MP Electrical Rm		69507661	1	12/09-P
Battery	MP Electrical Rm		69507663	1	12/09-P
Battery	MP Electrical Rm		69507664	1	12/09-P
Battery	Main Office FACP		66016747	1	12/09-P
Battery	Main Office FACP		66016746	1	12/09-P
Battery	Main Office Workroom		69507655	1	12/09-P
Battery	Main Office Workroom		69507654	1	12/09-P
Battery	Main Office Workroom		69507658	1	12/09-P
Battery	Main Office Workroom		69507657	1	12/09-P
Battery	P2		66016779	1	12/09-P
Battery	P2		66016780	1	12/09-P
Battery	P2		66016774	1	12/09-P
Battery	P2		66016778	1	12/09-P
Battery	Pod A Electrical Rm		69507667	1	12/09-P
Battery	Pod A Electrical Rm		69507668	1	12/09-P
Battery	Pod A Electrical Rm		69507670	1	12/09-P
Battery	Pod A Electrical Rm		69507669	1	12/09-P
Device Total: 31 Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
The devices shall be tested in place to ensure CO entry to the sensing chamber by introduction of CO gas from the protected area, through the vents, to the sensing chamber. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14h))					
Devices	Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
CO Detector	8	8	0	8	8
Device Type	Location		ScanID	Address	Q4/22
CO Detector	B Room 10		66016833	1-01 059	12/09-P
CO Detector	B Room 7		66016835	1-01 077	12/09-P
CO Detector	B Room 8		66016830	1-01 063	12/09-P
CO Detector	C Classroom 11		66016820	1-01 152	12/09-P
CO Detector	C Classroom 13		66016817	1-01 151	12/09-P
CO Detector	C Classroom 14		66016822	1-01 141	12/09-P
CO Detector	D center		66016842	1-01 061	12/09-P
CO Detector	Kinder Classroom 1 NE		66016862	1-01 009	12/09-P
Device Total: 8 Return to Executive Summary					

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))						
Devices		Tested Q4/22	Pass Q4/22	Fail Q4/22	Tested YTD (2022)	Total Quantity
Device Type		Location		ScanID	Address	Q4/22
Power Supply		BLDG D Electrical Rm		66016874	1	12/09-P
Power Supply		MP electival rm		69507659	1	12/09-P
Power Supply		Main Office		69507644	2	12/09-P
Power Supply		Main Office Workroom		69507650	1	12/09-P
Power Supply		P2		66016777	1	12/09-P
Power Supply		Pod A Electrical Rm		69507665	1	12/09-P
Device Total: 7		Return to Executive Summary				

Service Summary

Generated by: BuildingReports.com

Building: Vinewood ES-Lodi USD

Device Type	Service	Quantity
<i>Passed</i>		
		31
CO Detector	Tested	8
Communicator	Tested	1
Control Panel	Tested	1
Heat Detector	Tested	4
Horn/Strobe	Tested	1
Horn	Tested	2
Power Supply	Tested	7
Pull Station	Tested	1
Smoke Detector	Tested/Cleaned	76
Voice Evacuation	Tested	7
		139
<i>Untested</i>		
Duct Detector		2
Pull Station		1
Total		3
Grand Total		142

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Vinewood ES-Lodi USD				Control Panel: 1 - EST Honeywell			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	B Electrical rm	12AH	12V	13.60	13.49	80	80
Sealed Lead Acid	B Electrical rm	7AH	12V	13.86	13.53	80	100
Sealed Lead Acid	B Electrical rm	7AH	12V	13.88	13.51	80	100
Sealed Lead Acid	C Electrical rm	7AH	12V	13.88	13.51	80	100
Sealed Lead Acid	C Electrical rm	7AH	12V	13.70	13.40	80	100
Sealed Lead Acid	C Electrical rm	7AH	12V	13.79	13.5	80	100
Sealed Lead Acid	C Electrical rm	12AH	12V	13.6	13.4	80	100
Sealed Lead Acid	C Electrical rm	12AH	12V	13.70	13.55	80	100
Sealed Lead Acid	D Electrical Rm	7AH	12V	13.76		80	100
Sealed Lead Acid	D Electrical Rm	7AH	12V	13.92	13.60	80	100
Sealed Lead Acid	D Electrical rm	12AH	12V	13.72	13.4	80	100
Sealed Lead Acid	D Electrical rm	12AH	12V	13.57	13.4	80	100
Sealed Lead Acid	MP Electrical Rm	12AH	12V	13.70	13.40	80	100
Sealed Lead Acid	MP Electrical Rm	12AH	12V	13.66	13.30	80	100
Sealed Lead Acid	MP Electrical Rm	7AH	12V	13.73	13.3	80	100
Sealed Lead Acid	MP Electrical Rm	7AH	12V	13.7	13.4	80	100
Sealed Lead Acid	Main Office FACP	18AH	12V	13.64	13.19	80	100
Sealed Lead Acid	Main Office FACP	18AH	12V	13.63	13.26	80	100
Sealed Lead Acid	Main Office Workroom			13.52	13.22	80	100
Sealed Lead Acid	Main Office Workroom			13.50	13.22	80	80
Sealed Lead Acid	Main Office Workroom	12AH	12V	13.52	13.32	80	100
Sealed Lead Acid	Main Office Workroom	12AH	12V	13.63	13.32	80	100
Sealed Lead Acid	P2	7AH	12V	13.78	13.66	80	100
Sealed Lead Acid	P2	12AH	12V	13.66	13.44	80	80
Sealed Lead Acid	P2	12AH	12V	13.63	13.44	80	100
Sealed Lead Acid	P2	7AH	12V	13.79	13.41	80	100
Sealed Lead Acid	Pod A Electrical Rm	7AH	12V	13.86	13.31	80	100
Sealed Lead Acid	Pod A Electrical Rm	7AH	12V	13.73	13.41	80	100
Sealed Lead Acid	Pod A Electrical Rm	12AH	12V	13.64	13.57	80	100
Sealed Lead Acid	Pod A Electrical Rm	12AH	12V	13.86	13.62	80	100
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
<i>Passed</i>				
Breaker	MP electival rm		12	7

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Vinewood ES-Lodi USD	Control Panel: 1 - EST Honeywell
--------------------------------	----------------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
CO Detector	Initiating	5.63%	8
Communicator	Control	0.70%	1
Control Panel	Control	0.70%	1
Duct Detector	Initiating	1.41%	2
Heat Detector	Initiating	2.82%	4
Horn	Indicating	1.41%	2
Horn/Strobe	Indicating	0.70%	1
Power Supply	Control	4.93%	7
Pull Station	Initiating	1.41%	2
Smoke Detector	Initiating	53.52%	76
Voice Evacuation	Control	4.93%	7

Type	Qty	Model #	Description	Install Date
<i>In Service - 5 Years to 10 Years</i>				

Battery	1		Sealed Lead Acid	03/13/2018
Heat Detector	2			03/13/2018
Smoke Detector	11			03/13/2018

Power-Sonic

In Service - 10 Years to 15 Years

Ultra Tech

Battery	5	UT 1270	Sealed Lead Acid	08/11/2008
---------	---	---------	------------------	------------

Power-Sonic

In Service - 15 Years to 25 Years

Bosch

Communicator	1		Digital Communicator	04/09/2007
--------------	---	--	----------------------	------------

EST

CO Detector	8	EC3OU-3		04/09/2007
Control Panel	1	Honeywell	Addressable	04/09/2007
Heat Detector	2	282B	Rate-of-Rise	04/09/2007
Smoke Detector	27	EC3OU-3		04/09/2007

Smoke Detector	30	EC3OU-3	Photoelectric	04/09/2007
Fire-Lite				
Pull Station	1	BG10	Single Action	04/09/2007
Honeywell				
Power Supply	6	HPF-24S8		04/09/2007
Pull Station	1	MS-7AF	Dual Action	04/09/2007
Smoke Detector	8	ASD-PL3	Photoelectric	04/09/2007
Voice Evacuation	4	INI-VG		04/09/2007
Ultra Tech				
Battery	1	UT 1270	Sealed Lead Acid	04/09/2007
Wheelock				
Horn	2	AH-24		04/09/2007
Horn/Strobe	1	4904-9215		04/09/2007
Building: Vinewood ES-Lodi USD				Control Panel: 2
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<i>In Service - 15 Years to 25 Years</i>				
Honeywell				
Power Supply	1	E3BB-BC/INCC		04/09/2007
Building: Vinewood ES-Lodi USD				Control Panel: 3
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<i>In Service - 15 Years to 25 Years</i>				
Honeywell				
Voice Evacuation	2	IN-VG Series		04/09/2007
Building: Vinewood ES-Lodi USD				Control Panel: 4
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<i>In Service - 15 Years to 25 Years</i>				
Honeywell				
Voice Evacuation	1	IN-VG Series		04/09/2007

Zone Address Report

Generated by: BuildingReports.com

Building: Vinewood ES-Lodi USD			Control Panel: 1 - EST Honeywell	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 01				
001	Smoke Detector	Main Office Above Reception	Photoelectric	69507651
001	Smoke Detector	Main Office Storage Outside Principal Office	Photoelectric	66016871
0001	Heat Detector	Above Ceiling portable #1 east Attic	Rate-of-Rise	09162693
001	Pull Station	Entry Main Office	Dual Action	69507645
002	Smoke Detector	Counselor Office by Nurse	Photoelectric	69507646
003	Smoke Detector	Main Office Nurse Restroom	Photoelectric	69507653
004	Smoke Detector	Main Office Principal	Photoelectric	69507648
006	Smoke Detector	Main Office Workroom by FACP	Photoelectric	69507647
008	Smoke Detector	Kinder Classroom 1 SE		66016863
009	CO Detector	Kinder Classroom 1 NE		66016862
010	Smoke Detector	Kinder Classroom 1 NW		66016861
011	Smoke Detector	Kinder Classroom 1 SW		66016864
012	Smoke Detector	Kinder Classroom 1 Bathroom	Photoelectric	66016860
013	Smoke Detector	A Classroom 2 Bathroom	Photoelectric	66016865
013	Smoke Detector	A Classroom 2 NE	Photoelectric	66016866
013	Smoke Detector	A Classroom 2 NW	Photoelectric	66016867
013	Smoke Detector	A Classroom 2 SE	Photoelectric	66016869
013	Smoke Detector	A Classroom 2 SW	Photoelectric	66016868
013	Smoke Detector	A Classroom 3		66016859
013	Smoke Detector	A Workroom	Photoelectric	66016857
013	Smoke Detector	portable #1north	Photoelectric	09162695
013	Smoke Detector	portable #1south	Photoelectric	09162696
013	Heat Detector	Above Ceiling portable #1 west Attic	Rate-of-Rise	09162694
014	Smoke Detector	A Classroom 3		66016858
017	Smoke Detector	A Janitors closet	Photoelectric	66016748
021	Smoke Detector	A Classroom 4	Photoelectric	66016853
022	Smoke Detector	A Classroom 4	Photoelectric	66016854
025	Smoke Detector	A SCC	Photoelectric	66016855
025	Smoke Detector	Main Office Principal Closet	Photoelectric	66016870
028	Smoke Detector	A SCC	Photoelectric	66016856
029	Smoke Detector	A Classroom 6	Photoelectric	66016851
031	Smoke Detector	A Classroom 6	Photoelectric	66016850
033	Smoke Detector	A SCC	Photoelectric	66016852
037	Smoke Detector	A boys bathroom	Photoelectric	66016847
037	Smoke Detector	A girls bathroom	Photoelectric	66016846

Address	Device Type	Location	Type	ScanID
039	Smoke Detector	A RM 5	Photoelectric	66016849
040	Smoke Detector	Main Office Nurse	Photoelectric	69507652
052	Smoke Detector	portable MP Teachers rm		66016880
053	Smoke Detector	A RM 5	Photoelectric	66016848
055	Smoke Detector	B workroom	Photoelectric	66016840
056	Smoke Detector	C workroom		66016829
057	Smoke Detector	B Room 10		66016834
059	CO Detector	B Room 10		66016833
061	Smoke Detector	B Room 8		66016832
061	CO Detector	D center		66016842
063	CO Detector	B Room 8		66016830
065	Smoke Detector	B hallway	Photoelectric	66016843
066	Smoke Detector	B boys bathroom	Photoelectric	66016844
068	Smoke Detector	B girls bathroom	Photoelectric	66016831
073	Smoke Detector	B hallway	Photoelectric	66016841
075	Smoke Detector	B Room 7	Photoelectric	66016836
077	CO Detector	B Room 7		66016835
079	Smoke Detector	B Room 9	Photoelectric	66016838
081	Smoke Detector	B Room 9	Photoelectric	66016837
082	Smoke Detector	B Electrical rm	Photoelectric	66016759
083	Smoke Detector	portable p2		66016771
084	Smoke Detector	portable p2		66016770
087	Smoke Detector	portable p1		66016768
088	Smoke Detector	portable p1		66016769
091	Smoke Detector	portable p3		66016813
092	Smoke Detector	portable p3		66016814
095	Smoke Detector	portable p4		66016812
096	Smoke Detector	portable p4		66016811
132	Smoke Detector	C Electrical rm		66016827
134	Smoke Detector	C Classroom 12		66016824
137	Smoke Detector	C Classroom 12		66016825
138	Smoke Detector	C Classroom 14		66016823
141	CO Detector	C Classroom 14		66016822
142	Smoke Detector	C girls bathroom		66016815
144	Smoke Detector	C boys bathroom		66016819
147	Smoke Detector	C Hallway		66016816
148	Smoke Detector	C Classroom 13		66016818
151	CO Detector	C Classroom 13		66016817
152	CO Detector	C Classroom 11		66016820
155	Smoke Detector	C Classroom 11		66016821
156	Smoke Detector	C LIB		66016828
042	Smoke Detector	MP Storage		66016876
053	Heat Detector	MP Kitchen		66016877
058	Heat Detector	MP Kitchen Storage		66016878
089	Smoke Detector	D16		66016801

Address	Device Type	Location	Type	ScanID
090	Smoke Detector	D16		66016800
092	Smoke Detector	D boys bathroom		66016781
094	Smoke Detector	D girls bathroom		66016782
095	Smoke Detector	D15		66016805
098	Smoke Detector	D15		66016804
099	Smoke Detector	D 17		66016806
102	Smoke Detector	D 17		66016807
105	Smoke Detector	D Center		66016809
109	Smoke Detector	D Workroom		66016808

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Wagner-Holt-Lodi USD
8778 Brattle Place
Stockton, CA 95209

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
May 17, 2021

Building: Wagner-Holt-Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information

Address: 8778 Brattle Place

Address:

City/State/ZIP Code: Stockton, CA 95209

Country: United States of America

System Control Unit

Model Number: E3BB-BD/INCC

Install Date: 07/15/1989

IDC Style:

Software Version:

Version Date: 10/29/2020

SLC Style:

Location: Main Office Building D

Current Protection:

NAC Style:

Central Station Signal Verification

Test Time/Date: 5/17/21 6:46:33 PM

Restore Time:

Note:

Inspection Completion Date: May 17, 2021					
Building: Wagner-Holt-Lodi USD					
EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
Tamper Switch	1	1	0	1	1
Waterflow Switch	1	1		1	1
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
Heat Detector	101	100	1	101	173
Pull Station	1	1	0	1	1
Smoke Detector	134	132	2	134	137
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
Horn	26	26	0	26	26
Horn/Strobe	1	1	0	1	1
Strobe	0	0	0	0	0
EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2021)	Total Quantity
Expander Panel	2	2	0	2	2
Power Supply	2	2	0	2	2
Total Device Count: 361					

Inspection & Testing

Generated by: BuildingReports.com

Building: Wagner-Holt-Lodi USD

*The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left.
Passed=P, Failed=F, Replaced=R*

EC 02.03.05 EP 02 Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.

Valve shall be operated and signal receipt shall be verified to be within the first two revolutions of the hand wheel or within one-fifth of the travel distance, or per the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14i.1))

Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Tamper Switch	1	1	0	1	1
Device Type	Location	ScanID	Address	Q4/20	Q2/21
Tamper Switch	Multi-Use- Storage Room	05652183	1	10/29-F	05/17-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.				
Vane-type and pressure switch-type waterflow alarm devices shall be tested semiannually. Per NFPA 25, Section 5.3.3.1, mechanical waterflow alarm devices shall be tested quarterly. Water shall be flowed through an inspector's test connection indicating the flow of water equal to that from a single sprinkler of the smallest orifice size installed in the system for wet-pipe systems, or an alarm test bypass connection for dry-pipe, pre-action, or deluge systems. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14j))						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Waterflow Switch	1	1	0	1	1	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Waterflow Switch	Multipurpose Riser Room		05652182	1-L1 M004	10/21-P	05/17-P
Device Total: 1 Return to Executive Summary						

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5					
In addition to testing in place to ensure smoke entry into the sensing chamber and an alarm response, duct smoke detectors utilizing sampling tubes shall be tested by verifying the correct pressure differential (within the manufacturer's published ranges) between the inlet and exhaust tubes using a method acceptable to the manufacturer to ensure that the device will properly sample the airstream. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g. 6))							
Devices		Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Duct Detector		2	2	0	2	4	
Device Type	Location		ScanID		Address	Q4/20	Q2/21
Duct Detector	Above RR Attic Multipurpose		69501159		1-L1 S070		05/17-P
Duct Detector	Above RR Attic Multipurpose		66012821		1-L1 S070	10/29-P	
Duct Detector	Admin Workroom		69501158		1-L1 S109		05/17-P
Duct Detector	Admin Workroom		66012822		1-L1 S109	10/29-P	
Device Total: 4		Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Heat Detector	101	100	1	101	173	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Heat Detector	Attic Admin Conference room		66012729	1-L1 S016	10/28-P	05/17-P
Heat Detector	Bathroom Womens Building A		04099140	1	10/29 Removed	
Heat Detector	Bathroom.MensBuilding A		04099139	1	10/29 Removed	
Heat Detector	Building B-1		04099101	1	10/29 Removed	
Heat Detector	Building B-2		04099169	1	10/29 Removed	
Heat Detector	Building B-3		04099170	1	10/29 Removed	
Heat Detector	Building B-4		04099171	1	10/29 Removed	
Heat Detector	Building B-5		04099172	1	10/29 Removed	
Heat Detector	Building B-6		04099173	1	10/29 Removed	
Heat Detector	Building F boys bath rm		04099179	1	10/29 Removed	
Heat Detector	Building F-1		04099518	1	10/29 Removed	
Heat Detector	Building F-2		04099519	1	10/29 Removed	
Heat Detector	Building F-3		04099520	1	10/29 Removed	
Heat Detector	Building F-4		04099521	1	10/29 Removed	
Heat Detector	Building G-1		04099174	1	10/29 Removed	
Heat Detector	Building G-1 in class rm		04099176	1	10/29 Removed	
Heat Detector	Building G-2		04099175	1	10/29 Removed	
Heat Detector	Pre school		04099202	1	10/29 Removed	
Heat Detector	A-3 Attic		66012836	1-L2 S080	10/30-P	05/17-P
Heat Detector	Admin Reception		66012733	1-L1 S003	10/28-P	05/17-P
Heat Detector	Admin Restroom Attic		66012732	1-L1 S010	10/28-P	05/17-P

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	Admin Workroom Attic	66012731	1-L1 S013	10/28-P	05/17-P
Heat Detector	Attic Janitor Room Multipurpose	66012827	1-L1 S126	10/29-P	
Heat Detector	B Workroom Attic Library	66012698	1-L2 S002	10/28-P	05/17-P
Heat Detector	B-1 Attic Library	66012701	1-L2 S101	10/28-P	05/17-P
Heat Detector	B-1 Attic Library	66012702	1-L2 S009	10/28-P	
Heat Detector	B-1 Soffit	66012805	1-L2 S049	10/29-P	
Heat Detector	B-2 Attic Library	66012700	1-L2 S011	10/28-P	05/17-P
Heat Detector	B-2 Attic Library	66012699	1-L2 S102	10/28-P	
Heat Detector	B-2 Soffit	66012807	1-L2 S016	10/29-P	
Heat Detector	B-3 Attic	66012687	1-L2 S018	10/28-P	
Heat Detector	B-3 Soffit	66012663	1-L2 S014	10/29-P	05/17-P
Heat Detector	B-4 Attic	66012690	1-L2 S121	10/28-P	05/17-P
Heat Detector	B-4 Attic	66012688	1-L2 S104	10/28-P	
Heat Detector	B-5 Attic	66012692	1-L2 S105	10/28-P	05/17-P
Heat Detector	B-5 Attic	66012691	1-L2 S025	10/28-P	05/17-P
Heat Detector	B-6 Attic	66012694	1-L2 S029	10/28-P	05/17-P
Heat Detector	B-6 Attic	66012693	1-L2 S106	10/28-P	05/17-P
Heat Detector	B-6 Soffit	66012809	1-L2 S038	10/29-P	
Heat Detector	B-7 Attic Library	66012706	1-L2 S107	10/28-P	05/17-P
Heat Detector	B-7 Attic Library	66012705	1-L2 S042	10/28-P	
Heat Detector	B-7 Soffit	66012808	1-L2 S044	10/29-P	
Heat Detector	B-8 Attic Library	66012704	1-L2 S108	10/28-P	05/17-P
Heat Detector	B-8 Attic Library	66012703	1-L2 S047	10/28-P	
Heat Detector	Bathroom Building D 3	07257516	1	10/29 Removed	
Heat Detector	Bathroom H-Boys	04099275	1	10/29 Removed	
Heat Detector	Bathroom Staff H bldg by custodian	04099150	1	10/29 Removed	
Heat Detector	Bldg D Attic Class RR	66012823	1-L1 S119	10/29-P	
Heat Detector	Bldg H Bathroom Girls	04099523	1	10/29 Removed	
Heat Detector	Boiler Room Attic	66012684	1-L1 S042	10/28-P	05/17-P
Heat Detector	Building A Custodian Attic	66012835	1-L2 S064	10/30-P	
Heat Detector	Building A Upper Attic	66012757	1-L2 S078	10/29-P	
Heat Detector	Building A Custodian Room	66012766	1-L2 S050	10/29-P	05/17-P
Heat Detector	Building A Restroom Attic	66012740	1-L2 S061	10/29-P	
Heat Detector	Building A Restroom Attic	66012742	1-L2 S051	10/29-P	
Heat Detector	Building A Restroom Boys" Upper Attic	66012745	1-L2 S119	10/29-P	
Heat Detector	Building A Restroom Boys" Upper Attic	66012746	1-L2 S111	10/29-P	
Heat Detector	Building A Restroom Girls' Attic	66012743	1-L2 S056	10/29-P	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	Building A Restroom Girls' Upper Attic	66012744	1-L2 S110	10/29-P	
Heat Detector	Building A Restroom Soffit Attic	66012739	1-L2 S058	10/29-P	
Heat Detector	Building A Soffit Near Room A1	66012840	1-L2 S082	10/30-P	
Heat Detector	Building A Soffit Near Room A3	66012838	1-L2 S082	10/30-P	
Heat Detector	Building A West Soffit Attic	66012842	1-L2 S058	10/30-P	
Heat Detector	Building H Teacher's Workroom	04099182	1	10/29 Removed	
Heat Detector	Cafeteria Kitchen Supervisor Office	04099099	1	10/29 Removed	
Heat Detector	Cafeteria Kitchen in sink area	04099095	1	10/29 Removed	
Heat Detector	Cafeteria Storeroom	04099100	1	10/29 Removed	
Heat Detector	Classroom A-1	04099143	1	10/29 Removed	
Heat Detector	Classroom A-4	04099145	1	10/29 Removed	
Heat Detector	Classroom A-5	04099146	1	10/29 Removed	
Heat Detector	Classroom A-6	04099147	1	10/29 Removed	
Heat Detector	Classroom A-7	04099144	1	10/29 Removed	
Heat Detector	Classroom B.7	04099141	1	10/29 Removed	
Heat Detector	Classroom B.8	04099168	1	10/29 Removed	
Heat Detector	Classroom D-3	04099142	1	10/29 Removed	
Heat Detector	Classroom D-4	04099163	1	10/29 Removed	
Heat Detector	Counselor Attic Library	66012707	1-L2 S040	10/28-P	05/17-P
Heat Detector	Custodial Attic H building	66012664	1-L1 S072	10/26-P	05/17-P
Heat Detector	Custodial Office Attic Multipurpose	66012728	1-L1 S049	10/29-P	05/17-P
Heat Detector	East Hallway Attic Library	66012712	1-L2 S035	10/28-P	05/17-P
Heat Detector	Jainitor H	04099151	1	10/29 Removed	
Heat Detector	Kitchen Attic	66012830	1-L1 S043	10/29-P	
Heat Detector	Kitchen Food Storage Attic	66012795	1-L1 S047	10/29-P	
Heat Detector	Kitchen Office Attic	66012796	1-L1 S045	10/29-P	05/17-F
Heat Detector	Main Office vice principal	04099158	1	10/29 Removed	
Heat Detector	Main Office.Huggs	04099161	1	10/29 Removed	
Heat Detector	Main Office.restroom	04099160	1	10/29	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
				Removed	
Heat Detector	Main supply/ storage	04099159	1	10/29	
				Removed	
Heat Detector	Main Office Supply rm	04099162	1	10/29	
				Removed	
Heat Detector	Men's Restroom by cafeteria	08851747	1	10/29	
				Removed	
Heat Detector	Multipurpose Attic Service Yard	66012845	1-L1 S003	10/30-P	
Heat Detector	Multipurpose Soffit by Telecom	66012828	1-L1 S142	10/29-P	
Heat Detector	Multipurpose Soffit near Restroom	66012804	1-L1 S030	10/29-P	
Heat Detector	Multipurpose Soffit near Telecom	66012803	1-L1 S031	10/29-P	
Heat Detector	Multipurpose Womens Restroom Attic	66012829	1-L1 S033	10/29-P	
Heat Detector	Music room Attic Adjacent to cafeteria	66012685	1-L1 S055	10/28-P	05/17-P
Heat Detector	North Conference Room Attic Library	66012695	1-L2 S013	10/28-P	
Heat Detector	Principal Attic	66012789	1-L1 S004	10/29-P	05/17-P
Heat Detector	Restroom Boys' Attic H building	66012662	1-L1 S070	10/26-P	05/17-P
Heat Detector	Restroom Boys' Attic H building	66012806	1-L1 S070	10/29-P	
Heat Detector	Restroom Building Boys' Attic	66012713	1-L2 S120	10/28-P	05/17-P
Heat Detector	Restroom Building Girls' Attic	66012714	1-L2 S116	10/28-P	05/17-P
Heat Detector	Restroom Girls' Attic H building	66012667	1-L1 S075	10/29-P	
Heat Detector	Restroom Staff H building	66012817	1-L1 S074	10/29-P	
Heat Detector	Restroom Staff Attic H building	66012665	1-L1 S073	10/26-P	05/17-P
Heat Detector	Soffit By Janitor Room Multipurpose	66012826	1-L1 S125	10/29-P	
Heat Detector	South Conference Attic Library	66012711	1-L2 S037	10/28-P	05/17-P
Heat Detector	Sprinkler Riser Room Attic North Cafeteria	66012566	1-L1 S052	10/21-P	05/17-P
Heat Detector	Staff Lounge South of Cafeteria	66012505	1-L1 S035	10/21-P	05/17-P
Heat Detector	Storage Attic Admin	66012730	1-L1 S015	10/28-P	
Heat Detector	Storage by Stage Attic Multipurpose	66012819	1-L1 S066	10/29-P	
Heat Detector	Vice Principal Attic	66012790	1-L1 S006	10/29-P	05/17-P
Heat Detector	West Hallway Attic Library	66012696	1-L2 S004	10/28-P	05/17-P
Heat Detector	Women's Restroom by cafeteria	08851749	1	10/29	
				Removed	
Heat Detector	behind Kitchen hot watertank	08851748	1-01 003	10/29	
				Removed	
Heat Detector	Center A-4 Attic	66012777	1-L2 S125	10/29-P	05/17-P
Heat Detector	Center A-4 Attic	66012776	1-L2 S071	10/29-P	05/17-P
Heat Detector	Center H-1 Attic	66012642	1-L1 S077	10/26-P	05/17-P
Heat Detector	Center H-2 Attic	66012660	1-L1 S078	10/26-P	05/17-P
Heat Detector	Center H-3 Attic	66012644	1-L1 S083	10/26-P	05/17-P
Heat Detector	Center H-4 Attic	66012658	1-L1 S084	10/26-P	05/17-P
Heat Detector	Center H-5 Attic	66012645	1-L1 S089	10/26-P	05/17-P
Heat Detector	Center H-6 Attic	66012656	1-L1 S090	10/26-P	05/17-P

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	Center H-7 Attic	66012647	1-L1 S095	10/26-P	05/17-P
Heat Detector	Center H-8 Attic	66012655	1-L1 S096	10/29-P	05/17-P
Heat Detector	Center H-9 Attic	66012650	1-L1 S101	10/26-P	05/17-P
Heat Detector	Center Kitchen	66012524	1-L1 S044	10/21-P	05/17-P
Heat Detector	Center Kitchen Attic	66012683	1-L1 S063	10/29-P	05/17-P
Heat Detector	Center Teachers' Workroom Attic H Building East	66012651	1-L1 S108	10/26-P	05/17-P
Heat Detector	Center North Music room Attic Adjacent to cafeteria	66012686	1-L1 S130	10/28-P	05/17-P
Heat Detector	East Building F girls bath rm	04099178	1	10/29 Removed	
Heat Detector	East Building G-1 in class rm	04099177	1	10/29 Removed	
Heat Detector	East Admin Soffit	66012734	1-L1 S011	10/28-P	
Heat Detector	East Admin Upper Soffit	66012737	1-L1 S116	10/28-P	
Heat Detector	East Cafeteria Break rm	04099092	1	10/29 Removed	
Heat Detector	East D-3 Attic	66012786	1-L1 S118	10/29-P	
Heat Detector	East D-4 Attic	66012783	1-L2 S028	10/29-P	
Heat Detector	East E-1 Attic	66012726	1-L2 S129	10/28-P	05/17-P
Heat Detector	East E-2 Attic	66012719	1-L2 S130	10/28-P	05/17-P
Heat Detector	East E-3 Attic	66012677	1-L2 S131	10/26-P	05/17-P
Heat Detector	East E-4 Attic	66012675	1-L2 S132	10/26-P	05/17-P
Heat Detector	East E-5 Attic	66012673	1-L2 S133	10/26-P	05/17-P
Heat Detector	East F-1 Attic	66012724	1-L2 S134	10/28-P	05/17-P
Heat Detector	East F-2 Attic	66012721	1-L2 S135	10/28-P	
Heat Detector	East F-3 Attic	66012717	1-L2 S136	10/28-P	05/17-P
Heat Detector	East F-4 Attic	66012715	1-L2 S113	10/28-P	05/17-P
Heat Detector	East G-2 Attic	66012668	1-L2 S142	10/26-P	05/17-P
Heat Detector	East H-8 Attic	66012654	1-L1 S142	10/26-P	05/17-P
Heat Detector	East Headstart Attic	66012788	1-L2 S126	10/29-P	05/17-P
Heat Detector	East Outside Kitchen Hot Watertank	66012523	1-L1 S041	10/28-P	05/17-P
Heat Detector	North Bathroom Boys-Building A	04099164	1	10/29 Removed	
Heat Detector	North Bathroom Girls Building A	04099167	1	10/29 Removed	
Heat Detector	North A-2 Attic	66012772	1-L2 S086	10/29-P	05/17-P
Heat Detector	North A-3 Attic	66012775	1-L2 S124	10/29-P	05/17-P
Heat Detector	North A-5 Attic	66012778	1-L2 S126	10/29-P	05/17-P
Heat Detector	North A-6 Attic	66012769	1-L2 S077	10/29-P	05/17-P
Heat Detector	North A-6 Attic	66012767	1-L2 S120	10/29-P	05/17-P
Heat Detector	North A-7 Attic	66012771	1-L2 S121	10/29-P	05/17-P
Heat Detector	North Admin Soffit	66012735	1-L1 S002	10/28-P	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	North Admin Upper Soffit	66012736	1-L1 S114	10/28-P	
Heat Detector	North Bathroom Pre school	04099200	1	10/29 Removed	
Heat Detector	North Building A Upper Attic	66012763	1-L2 S068	10/29-P	
Heat Detector	North Building A Upper Attic by Staff Restroom	66012764	1-L2 S053	10/29-P	
Heat Detector	North Building A Janitor Room	04099149	1	10/29 Removed	
Heat Detector	North Building A Restroom	66012832	1-L2 S054	10/29-P	
Heat Detector	North Building A Soffit Upper Attic by Staff Restroom	66012765	1-L2 S055	10/29-P	
Heat Detector	North Cafeteria Stage Attic	66012517	1-L1 S128	10/21-P	05/17-P
Heat Detector	North Classroom H-1	04099273	1-01 012	10/29 Removed	
Heat Detector	North Classroom H-10	04099223	1	10/29 Removed	
Heat Detector	North Classroom H-2	04099157	1	10/29 Removed	
Heat Detector	North Classroom H-3	04099214	1	10/29 Removed	
Heat Detector	North Classroom H-4	04099156	1	10/29 Removed	
Heat Detector	North Classroom H-5	04099225	1	10/29 Removed	
Heat Detector	North Classroom H-6	04099153	1	10/29 Removed	
Heat Detector	North Classroom H-7	04099184	1	10/29 Removed	
Heat Detector	North Classroom H-8	04099152	1	10/29 Removed	
Heat Detector	North Classroom H-9	04099221	1	10/29 Removed	
Heat Detector	North H-1 Attic	66012641	1-L1 S136	10/26-P	05/17-P
Heat Detector	North H-10 Attic	66012652	1-L1 S102	10/28-P	05/17-P
Heat Detector	North H-3 Attic	66012643	1-L1 S137	10/29-P	05/17-P
Heat Detector	North H-5 Attic	66012646	1-L1 S138	10/26-P	05/17-P
Heat Detector	North H-7 Attic	66012648	1-L1 S095	10/26-P	05/17-P
Heat Detector	North Multipurpose Soffit	66012831	1-L1 S051	10/29-P	
Heat Detector	Northeast Cafeteria Kitchen.	04099098	1	10/29 Removed	
Heat Detector	Northeast G-1 Attic	66012670	1-L2 S143	10/26-P	05/17-P
Heat Detector	South Bathroom Boys-Building A	04099165	1	10/29 Removed	
Heat Detector	South Bathroom Girls Building A	04099166	1	10/29 Removed	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	South Jainitor rm bldg A	04099148	1	10/29 Removed	
Heat Detector	South A-1 Attic	66012839	1-L2 S085	10/30-P	
Heat Detector	South A-2 Attic	66012773	1-L2 S123	10/29-P	05/17-P
Heat Detector	South A-3 Attic	66012774	1-L2 S122	10/29-P	05/17-P
Heat Detector	South A-5 Attic	66012782	1-L2 S067	10/29-P	05/17-P
Heat Detector	South A-7 Attic	66012770	1-L2 S074	10/29-P	05/17-P
Heat Detector	South Admin Soffit	66012797	1-L1 S024	10/29-P	
Heat Detector	South Bathroom Pre school	04099201	1	10/29 Removed	
Heat Detector	South Building A Upper Attic by room A-2	66012760	1-L2 S115	10/29-P	
Heat Detector	South Building A Upper Attic by room A-3	66012761	1-L2 S116	10/29-P	
Heat Detector	South Building A Upper Attic by room A-3	66012843	1-L2 S114	10/30-P	
Heat Detector	South Building A Upper Attic by room A-4	66012844	1-L2 S114	10/30-P	
Heat Detector	South Building A Upper Attic by room A-5	66012762	1-L2 S118	10/29-P	
Heat Detector	South Building A Upper Attic by room A-6	66012758	1-L2 S112	10/29-P	
Heat Detector	South Building A Upper Attic by room A-7	66012759	1-L2 S113	10/29-P	
Heat Detector	South Building A Restroom	66012833	1-L2 S062	10/29-P	
Heat Detector	South Building A Restroom Soffit	66012834	1-L2 S063	10/29-P	
Heat Detector	South Cafeteria Break rm	04099094	1	10/29 Removed	
Heat Detector	South Cafeteria Stage Attic	66012518	1-L1 S129	10/21-P	05/17-P
Heat Detector	South Classroom H-1	04099274	1	10/29 Removed	
Heat Detector	South Classroom H-10	04099185	1	10/29 Removed	
Heat Detector	South Classroom H-2	04099226	1-01 012	10/29 Removed	
Heat Detector	South Classroom H-3	04099155	1	10/29 Removed	
Heat Detector	South Classroom H-4	04099199	1	10/29 Removed	
Heat Detector	South Classroom H-5	04099154	1	10/29 Removed	
Heat Detector	South Classroom H-6	04099198	1	10/29 Removed	
Heat Detector	South Classroom H-7	04099222	1	10/29 Removed	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	South Classroom H-8	04099224	1	10/29 Removed	
Heat Detector	South Classroom H-9	04099183	1	10/29 Removed	
Heat Detector	South D-3 Restroom Attic	66012799	1-L1 S022	10/29-P	
Heat Detector	South D-4 Restroom Attic	66012798	1-L1 S026	10/29-P	
Heat Detector	South Kitchen Attic Accessibility via staffbreakroom	66012679	1-L1 S121	10/29-P	05/17-P
Heat Detector	South Kitchen Attic Accessible via staff breakroom	66012680	1-L1 S122	10/28-P	05/17-P
Heat Detector	South Kitchen Dishwash Station	66012525	1-L1 S040	10/21-P	05/17-P
Heat Detector	South Kitchen Dishwash Station Attic	66012682	1-L1 S039	10/28-P	05/17-P
Heat Detector	Southeast Cafeteria Kitchen.	04099096	1	10/29 Removed	
Heat Detector	Southeast Staff Lounge Attic	66012681	1-L1 S037	10/29-P	05/17-P
Heat Detector	Southwest Cafeteria Kitchen.	04099097	1	10/29 Removed	
Heat Detector	Southwest Soffit Attic Multipurpose	66012820	1-L1 S068	10/29-P	
Heat Detector	Upper Soffit Above Service Yard Multipurpose	66012824	1-L1 S123	10/29-P	
Heat Detector	Upper Soffit Dry Storage Multipurpose	66012825	1-L1 S124	10/29-P	
Heat Detector	West Admin Soffit	66012802	1-L1 S18	10/29-P	
Heat Detector	West Admin Conference Upper Soffit	66012800	1-L1 S115	10/29-P	
Heat Detector	West Admin Lobby Upper Soffit	66012801	1-L1 S117	10/29-P	
Heat Detector	West Cafeteria Break rm	04099093	1	10/29 Removed	
Heat Detector	West D-3 Attic	66012785	1-L1 S020	10/29-P	
Heat Detector	West D-4 Attic	66012784	1-L1 S120	10/29-P	
Heat Detector	West E-1 Attic	66012727	1-L2 S090	10/28-P	05/17-P
Heat Detector	West E-2 Attic	66012720	1-L2 S093	10/29-P	05/17-P
Heat Detector	West E-3 Attic	66012678	1-L2 S096	10/26-P	05/17-P
Heat Detector	West E-4 Attic	66012676	1-L2 S099	10/26-P	05/17-P
Heat Detector	West E-5 Attic	66012674	1-L2 S102	10/26-P	05/17-P
Heat Detector	West Electrical Room In Cafeteria	66012522	1-L1 S050	10/21-P	05/17-P
Heat Detector	West F-1 Attic	66012725	1-L2 S105	10/28-P	05/17-P
Heat Detector	West F-2 Attic	66012723	1-L2 S107	10/28-P	
Heat Detector	West F-3 Attic	66012718	1-L2 S111	10/28-P	05/17-P
Heat Detector	West F-4 Attic	66012716	1-L2 S137	10/28-P	05/17-P
Heat Detector	West G-1 Attic	66012672	1-L2 S140	10/29-P	05/17-P
Heat Detector	West G-2 Attic	66012669	1-L2 S141	10/26-P	05/17-P
Heat Detector	West H-10 Attic	66012653	1-L1 S141	10/28-P	05/17-P
Heat Detector	West H-2 Attic	66012661	1-L1 S145	10/26-P	05/17-P
Heat Detector	West H-4 Attic	66012659	1-L1 S144	10/26-P	05/17-P
Heat Detector	West H-6 Attic	66012657	1-L1 S143	10/26-P	05/17-P

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Heat Detector	West H-9 Attic	66012649	1-L1 S140	10/26-P	05/17-P
Heat Detector	West Headstart Attic	66012787	1-L2 S128	10/29-P	05/17-P
Device Total: 173 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Pull Station	1	1	0	1	1
Device Type	Location	ScanID	Address	Q4/20	Q2/21
Pull Station	Classroom G-2	04099287	1-01 009	10/29 Removed	
Pull Station	Classroom G1	04099285	1-01 009	10/29 Removed	
Pull Station	Classroom H 1	04099261	1-.01 011	10/29 Removed	
Pull Station	Classroom H 10	04099268	1-01 011	10/29 Removed	
Pull Station	Classroom H 2	04099262	1-01 011	10/29 Removed	
Pull Station	Classroom H 3	04099264	1-01 011	10/29 Removed	
Pull Station	Classroom H 4	04099246~	1-01 011	10/29 Removed	
Pull Station	Classroom H 4	04099263	1-01 011	10/29 Removed	
Pull Station	Classroom H 5	04099265	1-01 011	10/29 Removed	
Pull Station	Classroom H 6	20411063	1-01 011	10/29 Removed	
The above device replaced ScanID 04099267:					
Pull Station	Classroom H 6	04099267	1-01 011	10/28-R	
Pull Station	Classroom H 7	04099270	1-01 011	10/29 Removed	
Pull Station	Classroom H 8	04099266	1-01 011	10/29 Removed	
Pull Station	Classroom H 9	04099269	1-01 0110	10/29 Removed	
Pull Station	Inside Administration Office	07257503	1-01 001	10/29 Removed	
Pull Station	Inside Administration Office	66012738	1-01 001	10/29-P	05/17-P
Pull Station	North Building H Classroom H Teachers	04099272	1-01 011	10/29 Removed	
Pull Station	South Building H Teachers Workroom	04099271	1-01 011	10/29 Removed	
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5				
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Smoke Detector	134	132	2	134	137	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Smoke Detector	Classroom A1		08469995	1-01 001	10/29 Removed	
Smoke Detector	Classroom A2		08469978	1-01 001	10/29 Removed	
Smoke Detector	Classroom A3		08469977	1-01 001	10/29 Removed	
Smoke Detector	Classroom A6		08469993	1-01 001	10/29 Removed	
Smoke Detector	Classroom A7		08469994	1-01 001	10/29 Removed	
Smoke Detector	Classroom B1		08469979	1-01 002	10/29 Removed	
Smoke Detector	Classroom B3		08469986	1-01 002	10/29 Removed	
Smoke Detector	Classroom B4		08469985	1-01 002	10/29 Removed	
Smoke Detector	Classroom B4		20411062	1-01 002	10/29 Removed	
Smoke Detector	Classroom B5		08469984	1-01 002	10/29 Removed	
Smoke Detector	Classroom B6		08469983	1-01 002	10/29 Removed	
Smoke Detector	Classroom B7		08469980	1-01 002	10/29 Removed	
Smoke Detector	Classroom E1		08469996	1-01 005	10/29 Removed	
Smoke Detector	Classroom E2		08469976	1-01 005	10/29 Removed	
Smoke Detector	Classroom E3		08469997	1-01 005	10/29 Removed	
Smoke Detector	Classroom E4		08469998	1-01 005	10/29 Removed	
Smoke Detector	Classroom E5		08469999	1-01 005	10/29 Removed	
Smoke Detector	classroom B2		08851771	1-01 002	10/29	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
				Removed	
Smoke Detector	A-1	66012590	1-L2 S084	10/29-P	05/17-P
Smoke Detector	Admin near Principal	66012635	1-L1 S008	10/22-P	05/17-P
Smoke Detector	Admin Reception Main Office	66012632	1-L1 S001	10/22-P	05/17-P
Smoke Detector	Admin Workroom near main office	66012634	1-L1 S012	10/22-P	05/17-P
Smoke Detector	Admin restroom	66012636	1-L1 S009	10/22-P	05/17-P
Smoke Detector	Building A Classroom A 2	04098911	1	10/29	Removed
Smoke Detector	Building A Classroom A 3	04098905	1	10/29	Removed
Smoke Detector	Building A Classroom A 4	04098909	1	10/29	Removed
Smoke Detector	Building A Classroom A 4	08469991	1-01 001	10/29	Removed
Smoke Detector	Building A Classroom A 5	04098908	1	10/29	Removed
Smoke Detector	Building A Classroom A 5	08469992	1-01 001	10/29	Removed
Smoke Detector	Building A Classroom A 6	04098907	1	10/29	Removed
Smoke Detector	Building A Classroom A 7	04098906	1	10/29	Removed
Smoke Detector	Building B Classroom B 1	04098912	1	10/29	Removed
Smoke Detector	Building B Classroom B 2	04098913	1	10/29	Removed
Smoke Detector	Building B Classroom B 8	08469990	1-01 002	10/29	Removed
Smoke Detector	Building B Library	07257505	1	10/29	Removed
Smoke Detector	Building D Classroom D 3	04098904	1	10/29	Removed
Smoke Detector	Building D Classroom D 4	04098903	1	10/29	Removed
Smoke Detector	Building E Room E -2	04098940	1	10/29	Removed
Smoke Detector	Building E Room E -3	04098941	1	10/29	Removed
Smoke Detector	Building E Room E -4	04098942	1	10/29	Removed
Smoke Detector	Building E Room E -5	04098943	1	10/29	Removed
Smoke Detector	Building E Room E-1	04098939	1	10/29	Removed
Smoke Detector	Building F Room F -3	04098945	1	10/29	Removed

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Smoke Detector	Building F Room F -4	04098944	1	10/29 Removed	
Smoke Detector	Building F Room F 1	04098947	1	10/29 Removed	
Smoke Detector	Building F Room F 2	04098946	1	10/29 Removed	
Smoke Detector	Building H Teachers workroom	04099260	1-01 010	10/29 Removed	
Smoke Detector	Cafeteria Housekeeping rm	04098936	1	10/29 Removed	
Smoke Detector	Cafeteria Resource Lab	04098927	1	10/29 Removed	
Smoke Detector	Cafeteria Storeroom	04098934	1	10/29 Removed	
Smoke Detector	Cafeteria Supply food rm	04098935	1	10/29 Removed	
Smoke Detector	Cafeteria storage/riser rm	08851754	1-01 003	10/29 Removed	
Smoke Detector	Counselor Library by East Exit	66012578	1-L2 S039	10/22-P	05/17-P
Smoke Detector	D-3 Restroom	66012627	1-L1 S023	10/22-P	05/17-P
Smoke Detector	D-4 Restroom	66012626	1-L1 S025	10/22-P	05/17-P
Smoke Detector	Electrical Room AV room by West Library Entrance	66012575	1-L2 S001	10/22-P	05/17-P
Smoke Detector	Electrical Room and Storage Main Office	66012633	1-L1 S014	10/29-P	05/17-P
Smoke Detector	G-1 Restroom	66012597	1-L2 S146	10/22-P	05/17-P
Smoke Detector	H Restroom Boys	66012549	1-L1 S071	10/21-P	05/17-P
Smoke Detector	H Restroom Girl's	66012527	1-L1 S076	10/21-P	05/17-P
Smoke Detector	Headstart North restroom	66012639	1-L2 S124	10/22-P	05/17-P
Smoke Detector	Headstart South restroom	66012638	1-L2 S125	10/22-P	05/17-P
Smoke Detector	Kitchen dry storage	08851739	1-01 003	10/29 Removed	
Smoke Detector	Kitchen Food Storage	66012793	1-L1 S048	10/29-P	05/17-F
Smoke Detector	Kitchen Office	66012794	1-L1 S046	10/29-P	05/17-F
Smoke Detector	Library Conference by East Exit	66012577	1-L2 S036	10/22-P	05/17-P
Smoke Detector	Main Office Building D	04098899	1	10/29 Removed	
Smoke Detector	Main Office building D Huggs Office	04098901	1	10/29 Removed	
Smoke Detector	Main Office building D Supply.room	04098900	1	10/29 Removed	
Smoke Detector	Main Office building D Work.Office	04098902	1	10/29 Removed	
Smoke Detector	Music Room East of Cafeteria	66012526	1-L1 S054	10/21-P	05/17-P
Smoke Detector	North Conference by West Library	66012574	1-L2 S015	10/22-P	05/17-P

Device Type	Location	ScanID	Address	Q4/20	Q2/21
	Entrance				
Smoke Detector	Nurse's Office near admin	66012631	1-L1 S016	10/22-P	05/17-P
Smoke Detector	Principal	66012791	1-L1 S005	10/29-P	05/17-P
Smoke Detector	Restroom Building Southwest room	66012606	1-L2 S118	10/22-P	05/17-P
Smoke Detector	Restroom Building Boys'	66012608	1-L2 S121	10/22-P	05/17-P
Smoke Detector	Restroom Building Girls'	66012609	1-L2 S117	10/22-P	05/17-P
Smoke Detector	Restroom building Southeast room	66012607	1-L2 S122	10/22-P	05/17-P
Smoke Detector	Staff Breakroom by Cafeteria	66012506	1-L1 S038	10/21-P	05/17-P
Smoke Detector	Staff Restroom Mens' near Office	66012503	1-L1 S019	10/22-P	05/17-P
Smoke Detector	Staff Restroom Women's Near Office	66012504	1-L1 S034	10/21-P	05/17-P
Smoke Detector	Teachers' Workroom East H building	66012538	1-L1 S107	10/21-P	05/17-P
Smoke Detector	Telecom Room Near Office	66012502	1-L1 S073	10/21-P	05/17-P
Smoke Detector	Vice Principal	66012792	1-L1 S005	10/29-P	05/17-P
Smoke Detector	admin principal	08469967	1-01 04	10/29	Removed
Smoke Detector	admin. Office teachers work room	08469969	1-01 004	10/29	Removed
Smoke Detector	admin. Office reception area	08469966	1-01 004	10/29	Removed
Smoke Detector	admin. Office stock room	08469968	1-01 004	10/29	Removed
Smoke Detector	building A Classroom A.3	04098910	1	10/29	Removed
Smoke Detector	building B Av hall	04098924	1	10/29	Removed
Smoke Detector	building B Av rm.	04098923	1	10/29	Removed
Smoke Detector	building B Classroom B.3	04098914	1	10/29	Removed
Smoke Detector	building B Classroom B.4	04098915	1	10/29	Removed
Smoke Detector	building B Classroom B.5	04098916	1	10/29	Removed
Smoke Detector	building B Classroom B.6	04098917	1	10/29	Removed
Smoke Detector	building B Classroom B.7	04098918	1	10/29	Removed
Smoke Detector	building B Classroom B.8	04098919	1	10/29	Removed
Smoke Detector	building B room .counselor	04098921	1	10/29	Removed
Smoke Detector	building B room next to Av rm.	04098922	1	10/29	Removed
Smoke Detector	building B room next to counselor	04098920	1	10/29	Removed

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Smoke Detector	classroom D3	08851755	1-01 004	10/29 Removed	
Smoke Detector	classroom D4	08851734	1-01 004	10/29 Removed	
Smoke Detector	classroom F1	08469972	1-01 006	10/29 Removed	
Smoke Detector	classroom F2	08469973	1-01 006	10/29 Removed	
Smoke Detector	classroom F3	08469974	1-01 006	10/29 Removed	
Smoke Detector	classroom F4	08469975	1-1 6	10/29 Removed	
Smoke Detector	custodial room storage-multi-use	08851750	1-01 003	10/29 Removed	
Smoke Detector	library north	20411067	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098925:</i>					
Smoke Detector	library north	04098925	1-01 010	10/28-R	
Smoke Detector	library south	20411068	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098926:</i>					
Smoke Detector	library south	04098926	1-01 010	10/28-R	
Smoke Detector	music room .	08851738	1-01 003	10/29 Removed	
Smoke Detector	stage north	20411069	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098932:</i>					
Smoke Detector	stage north	04098932	1-01 010	10/28-R	
Smoke Detector	stage south	20411070	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098933:</i>					
Smoke Detector	stage south	04098933	1-01 010	10/28-R	
Smoke Detector	Center Northeast Cafeteria	66012512	1-L1 S057	10/21-P	05/17-P
Smoke Detector	Center Northwest Cafeteria	66012511	1-L1 S061	10/21-P	05/17-P
Smoke Detector	Center Southeast Cafeteria	66012510	1-L1 058	10/29-P	05/17-P
Smoke Detector	Center Southwest Cafeteria	66012509	1-L1 S062	10/22-P	05/17-P
Smoke Detector	East Classroom H-1	04099240	1-01 010	10/29 Removed	
Smoke Detector	East Classroom H-10	04099255	1-01 010	10/29 Removed	
Smoke Detector	East Classroom H-2	04099242	1-01 010	10/29 Removed	
Smoke Detector	East Classroom H-3	04099247	1-01 010	10/29 Removed	
Smoke Detector	East Classroom H-4	04099245	1-01 010	10/29	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
				Removed	
Smoke Detector	East Classroom H-5	04099249	1-01 010	10/29	
				Removed	
Smoke Detector	East Classroom H-6	04099251	1-01 010	10/29	
				Removed	
Smoke Detector	East Classroom H-7	04099256	1-01 010	10/29	
				Removed	
Smoke Detector	East Classroom H-8	04099253	1-01 010	10/29	
				Removed	
Smoke Detector	East Classroom H-9	04099259	1-01 010	10/29	
				Removed	
Smoke Detector	East Library	08469989	1-01 002	10/29	
				Removed	
Smoke Detector	East B-1	66012561	1-L2 S008	10/21-P	05/17-P
Smoke Detector	East B-2	66012562	1-L2 S007	10/21-P	05/17-P
Smoke Detector	East B-5	66012552	1-L2 S026	10/21-P	05/17-P
Smoke Detector	East B-6	66012555	1-L2 S030	10/21-P	05/17-P
Smoke Detector	East D-3	66012629	1-L1 S112	10/22-P	05/17-P
Smoke Detector	East E-1	66012618	1-L2 S091	10/22-P	05/17-P
Smoke Detector	East E-2	66012616	1-L2 S094	10/22-P	05/17-P
Smoke Detector	East E-3	66012614	1-L2 S095	10/22-P	05/17-P
Smoke Detector	East E-4	66012604	1-L2 S100	10/22-P	05/17-P
Smoke Detector	East E-5	66012603	1-L2 S103	10/22-P	05/17-P
Smoke Detector	East F-1	66012622	1-L2 S106	10/22-P	05/17-P
Smoke Detector	East F-2	66012620	1-L2 S109	10/22-P	05/17-P
Smoke Detector	East F-3	66012612	1-L2 S110	10/22-P	05/17-P
Smoke Detector	East F-4	66012610	1-L2 S115	10/22-P	05/17-P
Smoke Detector	East H-1	66012528	1-L1 S081	10/21-P	05/17-P
Smoke Detector	East H-10	66012539	1-L1 S103	10/21-P	05/17-P
Smoke Detector	East H-2	66012547	1-L1 S079	10/21-P	05/17-P
Smoke Detector	East H-3	66012531	1-L1 S088	10/21-P	05/17-P
Smoke Detector	East H-4	66012545	1-L1 S085	10/21-P	05/17-P
Smoke Detector	East H-5	66012533	1-L1 S094	10/21-P	05/17-P
Smoke Detector	East H-6	66012543	1-L1 S091	10/21-P	05/17-P
Smoke Detector	East H-7	66012818	1-L1 S100	10/29-P	05/17-P
Smoke Detector	East H-8	66012541	1-L1 S097	10/21-P	05/17-P
Smoke Detector	East H-9	66012537	1-L1 S106	10/21-P	05/17-P
Smoke Detector	East Library Counselor	08469982	1-01 002	10/29	
				Removed	
Smoke Detector	East Library Psychologist	08469981	1-01 002	10/29	
				Removed	
Smoke Detector	East Library by Entrance	66012576	1-L2 S031	10/22-P	05/17-P
Smoke Detector	North Classroom G-1	08851744	1-01 009	10/29	
				Removed	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Smoke Detector	North Classroom G-2	08851731	1-01 009	10/29 Removed	
Smoke Detector	North A-2	66012589	1-L2 S087	10/22-P	05/17-P
Smoke Detector	North A-3	66012588	1-L2 S081	10/22-P	05/17-P
Smoke Detector	North A-4	66012585	1-L2 S070	10/29-P	05/17-P
Smoke Detector	North A-5	66012584	1-L2 S066	10/22-P	05/17-P
Smoke Detector	North A-6	66012593	1-L2 S075	10/22-P	05/17-P
Smoke Detector	North A-7	66012591	1-L2 S072	10/29-P	05/17-P
Smoke Detector	North B-3	66012564	1-L2 S019	10/21-P	05/17-P
Smoke Detector	North B-4	66012550	1-L2 S022	10/21-P	05/17-P
Smoke Detector	North B-7	66012556	1-L2 S041	10/21-P	05/17-P
Smoke Detector	North B-8	66012559	1-L2 S046	10/21-P	05/17-P
Smoke Detector	North Building G Room G -1	04098948	1	10/29 Removed	
Smoke Detector	North Building G Room G-2	04098950	1	10/29 Removed	
Smoke Detector	North Classroom Preschool	04098937	1	10/29 Removed	
Smoke Detector	North D-3	66012630	1-L1 S019	10/22-P	05/17-P
Smoke Detector	North G-2	66012596	1-L2 S147	10/22-P	05/17-P
Smoke Detector	North Headstart	66012640	1-L2 S127	10/22-P	05/17-P
Smoke Detector	North Restroom Boys' A Building	66012581	1-L2 S060	10/22-P	05/17-P
Smoke Detector	North Restroom Girls' A Building	66012579	1-L2 S057	10/22-P	05/17-P
Smoke Detector	North Sprinkler Room In Cafeteria	66012521	1-L1 S053	10/21-P	05/17-P
Smoke Detector	North Stage	69501156	1-L1 S064		05/17-P
Smoke Detector	North Stage	66012515	1-L1 S064	10/21-P	
Smoke Detector	North- Headstart	08469970	1-01 006	10/29 Removed	
Smoke Detector	Northeast Cafeteria	66012514	1-L1 S056	10/21-P	05/17-P
Smoke Detector	Northeast D-4	66012623	1-L1 S029	10/22-P	05/17-P
Smoke Detector	Northeast G-1	66012600	1-L2 S139	10/22-P	05/17-P
Smoke Detector	Northeast Library High Ceiling	66012570	1-L2 S033	10/22-P	05/17-P
Smoke Detector	Northeast cafeteria	20411060	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098928:</i>					
Smoke Detector	Northeast cafeteria	04098928	1-01 010	10/28-R	
Smoke Detector	Northwest Cafeteria	66012513	1-L1 S060	10/21-P	05/17-P
Smoke Detector	Northwest G-1	66012601	1-L2 S144	10/22-P	05/17-P
Smoke Detector	Northwest Library High Ceiling	66012569	1-L2 S005	10/22-P	05/17-P
Smoke Detector	Northwest cafeteria	20411064	1-01 010	10/29 Removed	
<i>The above device replaced ScanID 04098929:</i>					
Smoke Detector	Northwest cafeteria	04098929	1-01 010	10/28-R	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Smoke Detector	South Classroom G-1	08851732	1-01 009	10/29 Removed	
Smoke Detector	South Classroom G-2	08851730	1-01 009	10/29 Removed	
Smoke Detector	South A-3	66012587	1-L2 S079	10/29-P	05/17-P
Smoke Detector	South A-4	66012586	1-L2 S069	10/22-P	05/17-P
Smoke Detector	South A-5	66012583	1-L2 S066	10/29-P	05/17-P
Smoke Detector	South A-6	66012594	1-L2 S076	10/22-P	05/17-P
Smoke Detector	South A-7	66012592	1-L2 S073	10/22-P	05/17-P
Smoke Detector	South B-3	66012565	1-L2 S017	10/21-P	05/17-P
Smoke Detector	South B-4	66012551	1-L2 S020	10/21-P	05/17-P
Smoke Detector	South B-7	66012557	1-L2 S043	10/21-P	05/17-P
Smoke Detector	South B-8	66012558	1-L2 S048	10/21-P	05/17-P
Smoke Detector	South Building G Room G -1	04098949	1	10/29 Removed	
Smoke Detector	South Building G Room G-2	04098951	1	10/29 Removed	
Smoke Detector	South Cafeteria Stage by Chairlift	69501155	1-L1 S071		05/17-P
Smoke Detector	South Cafeteria Stage by Chairlift	66012519	1-L1 S071	10/21-P	
Smoke Detector	South Classroom Preschool	04098938	1	10/29 Removed	
Smoke Detector	South Electrical Room by South Cafeteria Stage	66012520	1-L1 S067	10/21-P	05/17-P
Smoke Detector	South G-2	66012595	1-L2 S148	10/22-P	05/17-P
Smoke Detector	South Headstart	66012637	1-L2 S123	10/22-P	05/17-P
Smoke Detector	South Headstart	08469971	1-01 006	10/29 Removed	
Smoke Detector	South Restroom Boys' A Building	66012582	1-L2 S052	10/22-P	05/17-P
Smoke Detector	South Restroom Girls' A Building	66012580	1-L2 S059	10/22-P	05/17-P
Smoke Detector	South Stage	69501157	1-L1 S065		05/17-P
Smoke Detector	South Stage	66012516	1-L1 S065	10/21-P	
Smoke Detector	Southeast Cafeteria	66012508	1-L1 S059	10/22-P	05/17-P
Smoke Detector	Southeast D-4	66012625	1-L1 S027	10/22-P	05/17-P
Smoke Detector	Southeast G-1	66012598	1-L2 S138	10/22-P	05/17-P
Smoke Detector	Southeast Library High Ceiling	66012571	1-L2 S032	10/22-P	05/17-P
Smoke Detector	Southeast cafeteria	20411065	1-01 010	10/29 Removed	
The above device replaced ScanID 04098930:					
Smoke Detector	Southeast cafeteria	04098930	1-01 010	10/28-R	
Smoke Detector	Southwest Cafeteria	66012507	1-L1 S111	10/22-P	05/17-P
Smoke Detector	Southwest D-3	66012628	1-L1 S021	10/22-P	05/17-P
Smoke Detector	Southwest G-1	66012599	1-L2 S145	10/22-P	05/17-P
Smoke Detector	Southwest Library High Ceiling	66012572	1-L2 S006	10/22-P	05/17-P
Smoke Detector	Southwest cafeteria	20411066	1-01 010	10/29	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
				Removed	
<i>The above device replaced ScanID 04098931:</i>					
Smoke Detector	Southwest Cafeteria	04098931	1-L1 S111	10/28-R	
Smoke Detector	West Classroom H-1	04099241	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-10	04099254	1	10/29	
				Removed	
Smoke Detector	West Classroom H-2	04099243	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-3	04099246	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-4	04099244	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-5	04099248	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-6	04099250	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-7	04099257	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-8	04099252	1-01 010	10/29	
				Removed	
Smoke Detector	West Classroom H-9	04099258	1-01 010	10/29	
				Removed	
Smoke Detector	West B-1	66012560	1-L2 S010	10/21-P	05/17-P
Smoke Detector	West B-2	66012563	1-L2 S012	10/21-P	05/17-P
Smoke Detector	West B-5	66012553	1-L2 S024	10/21-P	05/17-P
Smoke Detector	West B-6	66012554	1-L2 S028	10/21-P	05/17-P
Smoke Detector	West D-4	66012624	1-L1 S113	10/22-P	05/17-P
Smoke Detector	West E-1	66012619	1-L2 S089	10/22-P	05/17-P
Smoke Detector	West E-2	66012617	1-L2 S092	10/22-P	05/17-P
Smoke Detector	West E-3	66012615	1-L2 S097	10/22-P	05/17-P
Smoke Detector	West E-4	66012605	1-L2 S098	10/22-P	05/17-P
Smoke Detector	West E-5	66012602	1-L2 S101	10/22-P	05/17-P
Smoke Detector	West F-1	66012501	1-05 0104	10/22-P	05/17-P
Smoke Detector	West F-2	66012621	1-L2 S108	10/22-P	05/17-P
Smoke Detector	West F-3	66012613	1-L2 S112	10/22-P	05/17-P
Smoke Detector	West F-4	66012611	1-L2 S114	10/22-P	05/17-P
Smoke Detector	West H-1	66012530	1-L1 S082	10/21-P	05/17-P
Smoke Detector	West H-10	66012540	1-L1 S104	10/21-P	05/17-P
Smoke Detector	West H-2	66012548	1-L1 S080	10/21-P	05/17-P
Smoke Detector	West H-3	66012529	1-L1 S087	10/21-P	05/17-P
Smoke Detector	West H-4	66012546	1-L1 S086	10/21-P	05/17-P
Smoke Detector	West H-5	66012532	1-L1 S093	10/21-P	05/17-P
Smoke Detector	West H-6	66012544	1-L1 S092	10/21-P	05/17-P

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Smoke Detector	West H-7	66012534	1-L1 S099	10/21-P	05/17-P
Smoke Detector	West H-8	66012542	1-L1 S098	10/21-P	05/17-P
Smoke Detector	West H-9	66012536	1-L1 S105	10/21-P	05/17-P
Smoke Detector	West Library Electrical	08469988	1-01 002	10/29 Removed	
Smoke Detector	West Library by Entrance	66012573	1-L2 S003	10/22-P	05/17-P
Smoke Detector	West- Library bldg B	08469987	1-01 002	10/29 Removed	
Smoke Detector	West- library bldg B nurse office	08851770	1-01 002	10/29 Removed	
Device Total: 137 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Bell	1	1	0	1	1	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Bell	North Multipurpose Outside		61239636	1	10/19-P	05/17-P
Device Total: 1 Return to Executive Summary						

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Horn	26	26	0	26	26
Device Type	Location	ScanID	Address	Q4/20	Q2/21
Horn	A-3 Outside	61239621	1	10/19-P	05/17-P
Horn	B-1 Outside	61239629	1	10/19-P	05/17-P
Horn	B-2 Outside	61239613	1	10/19-P	05/17-P
Horn	B-3 Outside	61239612	1	10/19-P	05/17-P
Horn	B-4 Outside	61239615	1	10/19-P	05/17-P
Horn	B-6 Outside	61239614	1	10/19-P	05/17-P
Horn	D-3 Outside	61239632	1	10/19-P	05/17-P
Horn	Data Room Outside by south cafeteria	61239610	1	10/19-P	05/17-P
Horn	E-5 Outside	61239627	1	10/19-P	05/17-P
Horn	G-1 Outside	61239618	1	10/19-P	05/17-P
Horn	Main Office Outside	61239609	1	10/19-P	05/17-P
Horn	North A-5 Outside	61239620	1	10/19-P	05/17-P
Horn	North Building H Outside	61239616	1	10/19-P	05/17-P
Horn	North Multipurpose Outside	61239634	1	10/19-P	05/17-P
Horn	North Multipurpose Outside	61239635	1	10/19-P	05/17-P
Horn	North Restroom Outside	61239624	1	10/19-P	05/17-P
Horn	Northeast Building A Outside by restroom	61239619	1	10/19-P	05/17-P
Horn	Northwest A-4 Outside	61239622	1	10/19-P	05/17-P
Horn	South A-6 Outside	61239625	1	10/19-P	05/17-P
Horn	South Building D Outside	61239630	1	10/19-P	05/17-P
Horn	South Building H Outside	61239617	1	10/19-P	05/17-P
Horn	South Headstart Outside	61239631	1	10/19-P	05/17-P
Horn	Southeast Building A Restroom Outside	61239626	1	10/19-P	05/17-P
Horn	Southeast Cafeteria Outside	61239611	1	10/19-P	05/17-P
Horn	Southwest A-1 Outside	61239623	1	10/19-P	05/17-P
Horn	West Multipurpose Outside gate	61239633	1	10/19-P	05/17-P
Device Total: 26		Return to Executive Summary			

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18. Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Horn/Strobe	1	1	0	1	1	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Horn/Strobe	Tested all Horn/Strobes for proper operation		66012816	1	10/29-P	05/17-P
Horn/Strobe	Bldg H Bathroom Boys		04099524	1	10/29 Removed	
Horn/Strobe	Bldg H Bathroom Girls		04099522	1	10/29 Removed	
Horn/Strobe	Building B Library		07257521	1	10/29 Removed	
Horn/Strobe	H building Bathroom Staff		04099219	1	10/29 Removed	
Horn/Strobe	H building Teachers workroom		04099282	1	10/29 Removed	
Horn/Strobe	Music Room		08851751	1	10/29 Removed	
Horn/Strobe	Staff Breakroom		61239639	1	10/30 Removed	
Horn/Strobe	Center F-1 Classroom		66012500	1	10/30 Removed	
Horn/Strobe	East Classroom H-1		07257515	1	10/29 Removed	
Horn/Strobe	Northwest Multipurpose		61239637	1	10/30 Removed	
Horn/Strobe	Southwest Multipurpose		61239638	1	10/30 Removed	
Device Total: 1 Return to Executive Summary						

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))					
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Strobe	0	0	0	0	0
Device Type	Location	ScanID	Address	Q4/20	Q2/21
Strobe	A building Bathroom Mens	04099297	1	10/29 Removed	
Strobe	A building Bathroom Women	04099299	1	10/29 Removed	
Strobe	Cafeteria Kitchen	04099288	1	10/29 Removed	
Strobe	F building Bathroom Boys	04099300	1	10/29 Removed	
Strobe	F building Bathroom girls	04099281	1	10/29 Removed	
Strobe	F building staff restroom east	08851736	1	10/29 Removed	
Strobe	F building staff restroom west	08851737	1	10/29 Removed	
Strobe	G-1 Bathroom.	04099286	1	10/29 Removed	
Strobe	Mens Restroom Cafeteria	04099304	1	10/29 Removed	
Strobe	Resource lab	07257504	1	10/29 Removed	
Strobe	Restroom admin. Main Building	04099276	1	10/29 Removed	
Strobe	Womens Restroom Cafeteria	04099303	1	10/29 Removed	
Strobe	classroom D4 restroom	08851735	1	10/29 Removed	
Strobe	East Classroom H-5	07257512	1	10/29 Removed	
Strobe	Inside North Headstart Bathroom	04099301	1	10/29 Removed	
Strobe	Inside South Headstart Bathroom	04099280	1	10/29 Removed	
Strobe	North A building Bathroom Boys	04099217	1	10/29 Removed	
The above device replaced ScanID 04099216:					
Horn/Strobe	Headstart	04099216	1	10/28-R	
Strobe	North A building Bathroom Girls	04099220	1	10/29 Removed	
Strobe	North Cafeteria	04099290	1	10/29 Removed	

Device Type	Location	ScanID	Address	Q4/20	Q2/21
Strobe	South A building Bathroom Boys	04099218	1	10/29 Removed	
Strobe	South A building Bathroom Girls	04099298	1	10/29 Removed	
Strobe	South Cafeteria	04099289	1-01 003	10/29 Removed	
Strobe	West Classroom H-1	07257514	1	10/29 Removed	
Strobe	West Classroom H-3	07257511	1	10/29 Removed	
Strobe	West Classroom H-4	07257513	1	10/29 Removed	
Device Total: 0 Return to Executive Summary					

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5				
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))						
Devices		Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Communicator		1	1	0	1	1
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Communicator	FACP Main Office		61240911	1	10/19-P	05/17-P
Device Total: 1 Return to Executive Summary						

LS 02.01.34 EP 02							Protected master fire alarm control panel								
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))															
Devices				Tested Q2/21		Pass Q2/21		Fail Q2/21		Tested YTD (2021)		Total Quantity			
Control Panel				1		1		0		1		1			
Device Type				Location				ScanID		Address		Q4/20		Q2/21	
Control Panel				Main Office Building D				61239536		2		10/19-P		05/17-P	
Device Total: 1				Return to Executive Summary											

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))						
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity	
Battery	10	10	0	10	10	
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Battery	Admin beside FACP		61239534	1	10/19-P	05/17-P
Battery	Admin beside FACP		61239533	1	10/19-P	05/17-P
Battery	Head Start Pre School next to parking lot		51995076	1	10/30 Removed	
Battery	Head Start Pre School next to parking lot		51995077	1	10/30 Removed	
Battery	Pre school portable G1		08851746	1	10/30 Removed	
Battery	Pre school portable G1		08851745	1	10/30 Removed	
Battery	E-1 Left		66012810	1	10/29-P	05/17-P
Battery	E-1 Right		66012811	1	10/29-P	05/17-P
Battery	FACP Admin		61239538	1	10/19-P	05/17-P
Battery	FACP Admin		61239537	1	10/19-P	05/17-P
Battery	FACP E-1 Booster Left		66012813	1	10/29-P	05/17-P
Battery	FACP E-1 Booster Right		66012814	1	10/29-P	05/17-P
Battery	West Custodial Bldg H		61239540	1	10/19-P	05/17-P
Battery	West Custodial Bldg H		61239539	1	10/19-P	05/17-P
Device Total: 10 Return to Executive Summary						

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))						
Devices		Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Expander Panel		2	2	0	2	2
Device Type	Location		ScanID	Address	Q4/20	Q2/21
Expander Panel	Pre school		04099203	1	10/30 Removed	
Expander Panel	E-1		69501141	1		05/17-P
The above device replaced ScanID 66012815:						
Expander Panel	E-1		66012815	1	10/29-P	05/17-R
Expander Panel	West Custodial Bldg H		61239532	1	10/19-P	05/17-P
Device Total: 2		Return to Executive Summary				

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))					
Devices	Tested Q2/21	Pass Q2/21	Fail Q2/21	Tested YTD (2021)	Total Quantity
Device Type	Location		ScanID	Address	Q4/20 Q2/21
Power Supply	E-1		66012812	1	10/29-P 05/17-P
Power Supply	Portable G1		08474592	1	10/30 Removed
Device Total: 2		Return to Executive Summary			

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Wagner-Holt-Lodi USD						Control Panel: 1	
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Lead Acid	Admin beside FACP	7	12	13.8	13.5	80	100
Lead Acid	E-1 Left	18	12	13.7	13.3	80	100
Lead Acid	E-1 Right	18	12	13.6	13.3	80	10
Sealed Lead Acid	FACP Admin	7	12	13.7	13.3	80	100
Sealed Lead Acid	FACP Admin	7	12	13.6	13.3	90	100
Sealed Lead Acid	FACP E-1 Booster Left	7	12	13.7	13.3	80	100
Sealed Lead Acid	FACP E-1 Booster Right	7	12	13.7	13.3	80	100
	West Custodial Bldg H	18.0	12	13.6	13.3	80	100
Sealed Lead Acid	West Custodial Bldg H	7	12	13.7	13.3	80	100
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	E-1	3a	120				

Zone Address Report

Generated by: BuildingReports.com

Building: Wagner-Holt-Lodi USD				Control Panel: 1
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 01				
001	Pull Station	Inside Administration Office	Single Action	66012738
Zone/Circuit: 05				
0104	Smoke Detector	West F-1	Photoelectric	66012501
Zone/Circuit: L1				
058	Smoke Detector	Center Southeast Cafeteria		66012510
M004	Waterflow Switch	Multipurpose Riser Room		05652182
S001	Smoke Detector	Admin Reception Main Office	Photoelectric	66012632
S002	Heat Detector	North Admin Soffit	Rate-of-Rise	66012735
S003	Heat Detector	Admin Reception	Rate-of-Rise	66012733
S003	Heat Detector	Multipurpose Attic Service Yard		66012845
S004	Heat Detector	Principal Attic		66012789
S005	Smoke Detector	Principal	Photoelectric	66012791
S005	Smoke Detector	Vice Principal	Photoelectric	66012792
S006	Heat Detector	Vice Principal Attic		66012790
S008	Smoke Detector	Admin near Principal	Photoelectric	66012635
S009	Smoke Detector	Admin restroom	Photoelectric	66012636
S010	Heat Detector	Admin Restroom Attic	Rate-of-Rise	66012732
S011	Heat Detector	East Admin Soffit	Rate-of-Rise	66012734
S012	Smoke Detector	Admin Workroom near main office	Photoelectric	66012634
S013	Heat Detector	Admin Workroom Attic	Rate-of-Rise	66012731
S014	Smoke Detector	Electrical Room and Storage Main Office	Photoelectric	66012633
S015	Heat Detector	Storage Attic Admin	Rate-of-Rise	66012730
S016	Heat Detector	Attic Admin Conference room	Rate-of-Rise	66012729
S016	Smoke Detector	Nurse's Office near admin	Photoelectric	66012631
S18	Heat Detector	West Admin Soffit		66012802
S019	Smoke Detector	Staff Restroom Mens' near Office	Photoelectric	66012503
S019	Smoke Detector	North D-3	Photoelectric	66012630
S020	Heat Detector	West D-3 Attic		66012785
S021	Smoke Detector	Southwest D-3	Photoelectric	66012628
S022	Heat Detector	South D-3 Restroom Attic		66012799
S023	Smoke Detector	D-3 Restroom	Photoelectric	66012627
S024	Heat Detector	South Admin Soffit		66012797
S025	Smoke Detector	D-4 Restroom	Photoelectric	66012626
S026	Heat Detector	South D-4 Restroom Attic		66012798
S027	Smoke Detector	Southeast D-4	Photoelectric	66012625
S029	Smoke Detector	Northeast D-4	Photoelectric	66012623

Address	Device Type	Location	Type	ScanID
S030	Heat Detector	Multipurpose Soffit near Restroom		66012804
S031	Heat Detector	Multipurpose Soffit near Telecom		66012803
S033	Heat Detector	Multipurpose Womens Restroom Attic		66012829
S034	Smoke Detector	Staff Restroom Women's Near Office	Photoelectric	66012504
S035	Heat Detector	Staff Lounge South of Cafeteria		66012505
S037	Heat Detector	Southeast Staff Lounge Attic		66012681
S038	Smoke Detector	Staff Breakroom by Cafeteria		66012506
S039	Heat Detector	South Kitchen Dishwash Station Attic		66012682
S040	Heat Detector	South Kitchen Dishwash Station		66012525
S041	Heat Detector	East Outside Kitchen Hot Watertank		66012523
S042	Heat Detector	Boiler Room Attic		66012684
S043	Heat Detector	Kitchen Attic		66012830
S044	Heat Detector	Center Kitchen		66012524
S045	Heat Detector	Kitchen Office Attic		66012796
S046	Smoke Detector	Kitchen Office	Photoelectric	66012794
S047	Heat Detector	Kitchen Food Storage Attic		66012795
S048	Smoke Detector	Kitchen Food Storage	Photoelectric	66012793
S049	Heat Detector	Custodial Office Attic Multipurpose	Rate-of-Rise	66012728
S050	Heat Detector	West Electrical Room In Cafeteria		66012522
S051	Heat Detector	North Multipurpose Soffit		66012831
S052	Heat Detector	Sprinkler Riser Room Attic North Cafeteria		66012566
S053	Smoke Detector	North Sprinkler Room In Cafeteria		66012521
S054	Smoke Detector	Music Room East of Cafeteria	Photoelectric	66012526
S055	Heat Detector	Music room Attic Adjacent to cafeteria		66012685
S056	Smoke Detector	Northeast Cafeteria		66012514
S057	Smoke Detector	Center Northeast Cafeteria		66012512
S059	Smoke Detector	Southeast Cafeteria		66012508
S060	Smoke Detector	Northwest Cafeteria		66012513
S061	Smoke Detector	Center Northwest Cafeteria		66012511
S062	Smoke Detector	Center Southwest Cafeteria		66012509
S063	Heat Detector	Center Kitchen Attic		66012683
S064	Smoke Detector	North Stage		66012515
S064	Smoke Detector	North Stage		69501156
S065	Smoke Detector	South Stage		66012516
S065	Smoke Detector	South Stage		69501157
S066	Heat Detector	Storage by Stage Attic Multipurpose	Rate-of-Rise	66012819
S067	Smoke Detector	South Electrical Room by South Cafeteria Stage		66012520
S068	Heat Detector	Southwest Soffit Attic Multipurpose	Rate-of-Rise	66012820
S070	Duct Detector	Above RR Attic Multipurpose		66012821
S070	Duct Detector	Above RR Attic Multipurpose		69501159
S070	Heat Detector	Restroom Boys' Attic H building		66012662
S070	Heat Detector	Restroom Boys' Attic H building		66012806
S071	Smoke Detector	H Restroom Boys	Photoelectric	66012549
S071	Smoke Detector	South Cafeteria Stage by Chairlift		66012519

Address	Device Type	Location	Type	ScanID
S071	Smoke Detector	South Cafeteria Stage by Chairlift		69501155
S072	Heat Detector	Custodial Attic H building		66012664
S073	Heat Detector	Restroom Staff Attic H building		66012665
S073	Smoke Detector	Telecom Room Near Office	Photoelectric	66012502
S074	Heat Detector	Restroom Staff H building		66012817
S075	Heat Detector	Restroom Girls' Attic H building		66012667
S076	Smoke Detector	H Restroom Girl's	Photoelectric	66012527
S077	Heat Detector	Center H-1 Attic		66012642
S078	Heat Detector	Center H-2 Attic		66012660
S079	Smoke Detector	East H-2	Photoelectric	66012547
S080	Smoke Detector	West H-2	Photoelectric	66012548
S081	Smoke Detector	East H-1	Photoelectric	66012528
S082	Smoke Detector	West H-1	Photoelectric	66012530
S083	Heat Detector	Center H-3 Attic		66012644
S084	Heat Detector	Center H-4 Attic		66012658
S085	Smoke Detector	East H-4	Photoelectric	66012545
S086	Smoke Detector	West H-4	Photoelectric	66012546
S087	Smoke Detector	West H-3	Photoelectric	66012529
S088	Smoke Detector	East H-3	Photoelectric	66012531
S089	Heat Detector	Center H-5 Attic		66012645
S090	Heat Detector	Center H-6 Attic		66012656
S091	Smoke Detector	East H-6	Photoelectric	66012543
S092	Smoke Detector	West H-6	Photoelectric	66012544
S093	Smoke Detector	West H-5	Photoelectric	66012532
S094	Smoke Detector	East H-5	Photoelectric	66012533
S095	Heat Detector	Center H-7 Attic		66012647
S095	Heat Detector	North H-7 Attic		66012648
S096	Heat Detector	Center H-8 Attic		66012655
S097	Smoke Detector	East H-8	Photoelectric	66012541
S098	Smoke Detector	West H-8	Photoelectric	66012542
S099	Smoke Detector	West H-7	Photoelectric	66012534
S100	Smoke Detector	East H-7	Photoelectric	66012818
S101	Heat Detector	Center H-9 Attic		66012650
S102	Heat Detector	North H-10 Attic		66012652
S103	Smoke Detector	East H-10	Photoelectric	66012539
S104	Smoke Detector	West H-10	Photoelectric	66012540
S105	Smoke Detector	West H-9	Photoelectric	66012536
S106	Smoke Detector	East H-9	Photoelectric	66012537
S107	Smoke Detector	Teachers' Workroom East H building	Photoelectric	66012538
S108	Heat Detector	Center Teachers' Workroom Attic H Building East		66012651
S109	Duct Detector	Admin Workroom		66012822
S109	Duct Detector	Admin Workroom		69501158
S111	Smoke Detector	Southwest Cafeteria		66012507
S112	Smoke Detector	East D-3	Photoelectric	66012629

Address	Device Type	Location	Type	ScanID
S113	Smoke Detector	West D-4	Photoelectric	66012624
S114	Heat Detector	North Admin Upper Soffit	Rate-of-Rise	66012736
S115	Heat Detector	West Admin Conference Upper Soffit		66012800
S116	Heat Detector	East Admin Upper Soffit	Rate-of-Rise	66012737
S117	Heat Detector	West Admin Lobby Upper Soffit		66012801
S118	Heat Detector	East D-3 Attic		66012786
S119	Heat Detector	Bldg D Attic Class RR		66012823
S120	Heat Detector	West D-4 Attic		66012784
S121	Heat Detector	South Kitchen Attic Accessibility via staffbreakroom		66012679
S122	Heat Detector	South Kitchen Attic Accessible via staff breakroom		66012680
S123	Heat Detector	Upper Soffit Above Service Yard Multipurpose	Rate-of-Rise	66012824
S124	Heat Detector	Upper Soffit Dry Storage Multipurpose	Rate-of-Rise	66012825
S125	Heat Detector	Soffit By Janitor Room Multipurpose	Rate-of-Rise	66012826
S126	Heat Detector	Attic Janitor Room Multipurpose	Rate-of-Rise	66012827
S128	Heat Detector	North Cafeteria Stage Attic		66012517
S129	Heat Detector	South Cafeteria Stage Attic		66012518
S130	Heat Detector	Center North Music room Attic Adjacent to cafeteria		66012686
S136	Heat Detector	North H-1 Attic		66012641
S137	Heat Detector	North H-3 Attic		66012643
S138	Heat Detector	North H-5 Attic		66012646
S140	Heat Detector	West H-9 Attic		66012649
S141	Heat Detector	West H-10 Attic		66012653
S142	Heat Detector	Multipurpose Soffit by Telecom		66012828
S142	Heat Detector	East H-8 Attic		66012654
S143	Heat Detector	West H-6 Attic		66012657
S144	Heat Detector	West H-4 Attic		66012659
S145	Heat Detector	West H-2 Attic		66012661
Zone/Circuit: L2				
S001	Smoke Detector	Electrical Room AV room by West Library Entrance	Photoelectric	66012575
S002	Heat Detector	B Workroom Attic Library	Rate-of-Rise	66012698
S003	Smoke Detector	West Library by Entrance	Photoelectric	66012573
S004	Heat Detector	West Hallway Attic Library	Rate-of-Rise	66012696
S005	Smoke Detector	Northwest Library High Ceiling		66012569
S006	Smoke Detector	Southwest Library High Ceiling		66012572
S007	Smoke Detector	East B-2	Photoelectric	66012562
S008	Smoke Detector	East B-1	Photoelectric	66012561
S009	Heat Detector	B-1 Attic Library	Rate-of-Rise	66012702
S010	Smoke Detector	West B-1	Photoelectric	66012560
S011	Heat Detector	B-2 Attic Library	Rate-of-Rise	66012700
S012	Smoke Detector	West B-2	Photoelectric	66012563
S013	Heat Detector	North Conference Room Attic Library	Rate-of-Rise	66012695

Address	Device Type	Location	Type	ScanID
S014	Heat Detector	B-3 Soffit		66012663
S015	Smoke Detector	North Conference by West Library Entrance	Photoelectric	66012574
S016	Heat Detector	B-2 Soffit		66012807
S017	Smoke Detector	South B-3	Photoelectric	66012565
S018	Heat Detector	B-3 Attic	Rate-of-Rise	66012687
S019	Smoke Detector	North B-3	Photoelectric	66012564
S020	Smoke Detector	South B-4	Photoelectric	66012551
S022	Smoke Detector	North B-4	Photoelectric	66012550
S024	Smoke Detector	West B-5	Photoelectric	66012553
S025	Heat Detector	B-5 Attic	Rate-of-Rise	66012691
S026	Smoke Detector	East B-5	Photoelectric	66012552
S028	Heat Detector	East D-4 Attic		66012783
S028	Smoke Detector	West B-6	Photoelectric	66012554
S029	Heat Detector	B-6 Attic	Rate-of-Rise	66012694
S030	Smoke Detector	East B-6	Photoelectric	66012555
S031	Smoke Detector	East Library by Entrance	Photoelectric	66012576
S032	Smoke Detector	Southeast Library High Ceiling		66012571
S033	Smoke Detector	Northeast Library High Ceiling		66012570
S035	Heat Detector	East Hallway Attic Library	Rate-of-Rise	66012712
S036	Smoke Detector	Library Conference by East Exit	Photoelectric	66012577
S037	Heat Detector	South Conference Attic Library	Rate-of-Rise	66012711
S038	Heat Detector	B-6 Soffit		66012809
S039	Smoke Detector	Counselor Library by East Exit	Photoelectric	66012578
S040	Heat Detector	Counselor Attic Library	Rate-of-Rise	66012707
S041	Smoke Detector	North B-7	Photoelectric	66012556
S042	Heat Detector	B-7 Attic Library	Rate-of-Rise	66012705
S043	Smoke Detector	South B-7	Photoelectric	66012557
S044	Heat Detector	B-7 Soffit		66012808
S046	Smoke Detector	North B-8	Photoelectric	66012559
S047	Heat Detector	B-8 Attic Library	Rate-of-Rise	66012703
S048	Smoke Detector	South B-8	Photoelectric	66012558
S049	Heat Detector	B-1 Soffit		66012805
S050	Heat Detector	Building A Custodian Room		66012766
S051	Heat Detector	Building A Restroom Attic		66012742
S052	Smoke Detector	South Restroom Boys' A Building	Photoelectric	66012582
S053	Heat Detector	North Building A Upper Attic by Staff Restroom		66012764
S054	Heat Detector	North Building A Restroom		66012832
S055	Heat Detector	North Building A Soffit Upper Attic by Staff Restroom		66012765
S056	Heat Detector	Building A Restroom Girls' Attic		66012743
S057	Smoke Detector	North Restroom Girls' A Building	Photoelectric	66012579
S058	Heat Detector	Building A Restroom Soffit Attic		66012739
S058	Heat Detector	Building A West Soffit Attic		66012842

Address	Device Type	Location	Type	ScanID
S059	Smoke Detector	South Restroom Girls' A Building	Photoelectric	66012580
S060	Smoke Detector	North Restroom Boys' A Building	Photoelectric	66012581
S061	Heat Detector	Building A Restroom Attic		66012740
S062	Heat Detector	South Building A Restroom		66012833
S063	Heat Detector	South Building A Restroom Soffit		66012834
S064	Heat Detector	Building A Custodian Attic		66012835
S066	Smoke Detector	North A-5	Photoelectric	66012584
S066	Smoke Detector	South A-5	Photoelectric	66012583
S067	Heat Detector	South A-5 Attic		66012782
S068	Heat Detector	North Building A Upper Attic		66012763
S069	Smoke Detector	South A-4	Photoelectric	66012586
S070	Smoke Detector	North A-4	Photoelectric	66012585
S071	Heat Detector	Center A-4 Attic		66012776
S072	Smoke Detector	North A-7	Photoelectric	66012591
S073	Smoke Detector	South A-7	Photoelectric	66012592
S074	Heat Detector	South A-7 Attic		66012770
S075	Smoke Detector	North A-6		66012593
S076	Smoke Detector	South A-6		66012594
S077	Heat Detector	North A-6 Attic		66012769
S078	Heat Detector	Building A Upper Attic		66012757
S079	Smoke Detector	South A-3	Photoelectric	66012587
S080	Heat Detector	A-3 Attic		66012836
S081	Smoke Detector	North A-3	Photoelectric	66012588
S082	Heat Detector	Building A Soffit Near Room A1		66012840
S082	Heat Detector	Building A Soffit Near Room A3		66012838
S084	Smoke Detector	A-1	Photoelectric	66012590
S085	Heat Detector	South A-1 Attic		66012839
S086	Heat Detector	North A-2 Attic		66012772
S087	Smoke Detector	North A-2	Photoelectric	66012589
S089	Smoke Detector	West E-1		66012619
S090	Heat Detector	West E-1 Attic	Rate-of-Rise	66012727
S091	Smoke Detector	East E-1		66012618
S092	Smoke Detector	West E-2		66012617
S093	Heat Detector	West E-2 Attic	Rate-of-Rise	66012720
S094	Smoke Detector	East E-2		66012616
S095	Smoke Detector	East E-3		66012614
S096	Heat Detector	West E-3 Attic		66012678
S097	Smoke Detector	West E-3		66012615
S098	Smoke Detector	West E-4		66012605
S099	Heat Detector	West E-4 Attic		66012676
S100	Smoke Detector	East E-4		66012604
S101	Heat Detector	B-1 Attic Library	Rate-of-Rise	66012701
S101	Smoke Detector	West E-5		66012602
S102	Heat Detector	B-2 Attic Library	Rate-of-Rise	66012699
S102	Heat Detector	West E-5 Attic		66012674

Address	Device Type	Location	Type	ScanID
S103	Smoke Detector	East E-5		66012603
S104	Heat Detector	B-4 Attic	Rate-of-Rise	66012688
S105	Heat Detector	B-5 Attic	Rate-of-Rise	66012692
S105	Heat Detector	West F-1 Attic	Rate-of-Rise	66012725
S106	Heat Detector	B-6 Attic	Rate-of-Rise	66012693
S106	Smoke Detector	East F-1		66012622
S107	Heat Detector	B-7 Attic Library	Rate-of-Rise	66012706
S107	Heat Detector	West F-2 Attic	Rate-of-Rise	66012723
S108	Heat Detector	B-8 Attic Library	Rate-of-Rise	66012704
S108	Smoke Detector	West F-2		66012621
S109	Smoke Detector	East F-2		66012620
S110	Heat Detector	Building A Restroom Girls' Upper Attic		66012744
S110	Smoke Detector	East F-3		66012612
S111	Heat Detector	Building A Restroom Boys" Upper Attic		66012746
S111	Heat Detector	West F-3 Attic	Rate-of-Rise	66012718
S112	Heat Detector	South Building A Upper Attic by room A-6		66012758
S112	Smoke Detector	West F-3		66012613
S113	Heat Detector	East F-4 Attic	Rate-of-Rise	66012715
S113	Heat Detector	South Building A Upper Attic by room A-7		66012759
S114	Heat Detector	South Building A Upper Attic by room A-3		66012843
S114	Heat Detector	South Building A Upper Attic by room A-4		66012844
S114	Smoke Detector	West F-4		66012611
S115	Smoke Detector	East F-4		66012610
S115	Heat Detector	South Building A Upper Attic by room A-2		66012760
S116	Heat Detector	Restroom Building Girls' Attic	Rate-of-Rise	66012714
S116	Heat Detector	South Building A Upper Attic by room A-3		66012761
S117	Smoke Detector	Restroom Building Girls'		66012609
S118	Smoke Detector	Restroom Building Southwest room		66012606
S118	Heat Detector	South Building A Upper Attic by room A-5		66012762
S119	Heat Detector	Building A Restroom Boys" Upper Attic		66012745
S120	Heat Detector	Restroom Building Boys' Attic	Rate-of-Rise	66012713
S120	Heat Detector	North A-6 Attic		66012767
S121	Heat Detector	B-4 Attic	Rate-of-Rise	66012690
S121	Smoke Detector	Restroom Building Boys'		66012608
S121	Heat Detector	North A-7 Attic		66012771
S122	Smoke Detector	Restroom building Southeast room		66012607
S122	Heat Detector	South A-3 Attic		66012774
S123	Heat Detector	South A-2 Attic		66012773
S123	Smoke Detector	South Headstart		66012637
S124	Smoke Detector	Headstart North restroom		66012639
S124	Heat Detector	North A-3 Attic		66012775
S125	Smoke Detector	Headstart South restroom		66012638
S125	Heat Detector	Center A-4 Attic		66012777
S126	Heat Detector	East Headstart Attic		66012788
S126	Heat Detector	North A-5 Attic		66012778

Address	Device Type	Location	Type	ScanID
S127	Smoke Detector	North Headstart		66012640
S128	Heat Detector	West Headstart Attic		66012787
S129	Heat Detector	East E-1 Attic	Rate-of-Rise	66012726
S130	Heat Detector	East E-2 Attic	Rate-of-Rise	66012719
S131	Heat Detector	East E-3 Attic		66012677
S132	Heat Detector	East E-4 Attic		66012675
S133	Heat Detector	East E-5 Attic		66012673
S134	Heat Detector	East F-1 Attic	Rate-of-Rise	66012724
S135	Heat Detector	East F-2 Attic	Rate-of-Rise	66012721
S136	Heat Detector	East F-3 Attic	Rate-of-Rise	66012717
S137	Heat Detector	West F-4 Attic	Rate-of-Rise	66012716
S138	Smoke Detector	Southeast G-1		66012598
S139	Smoke Detector	Northeast G-1		66012600
S140	Heat Detector	West G-1 Attic		66012672
S141	Heat Detector	West G-2 Attic		66012669
S142	Heat Detector	East G-2 Attic		66012668
S143	Heat Detector	Northeast G-1 Attic		66012670
S144	Smoke Detector	Northwest G-1		66012601
S145	Smoke Detector	Southwest G-1		66012599
S146	Smoke Detector	G-1 Restroom		66012597
S147	Smoke Detector	North G-2		66012596
S148	Smoke Detector	South G-2		66012595

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

Westwood-Lodi USD
9444 Caywood Dr
Stockton, CA 95210

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Aug 17, 2022

Building: Westwood-Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information

Address: 9444 Caywood Dr

Address: :

City/State/ZIP Code: Stockton, CA 95210

Country: United States of America

System Control Unit

Model Number: EST 3

Install Date: 09/01/1990

IDC Style:

Software Version:

Version Date: 04/16/2007

SLC Style:

Location: Main Office

Current Protection: Breaker

NAC Style:

Central Station Signal Verification

Test Time/Date: 8/16/22 8:13:03 PM

Restore Time:

Note:

Inspection Completion Date: Aug 17, 2022					
Building: Westwood-Lodi USD					
EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Tamper Switch	0	0	0	0	1
Waterflow Switch	1	1		1	1
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Heat Detector	46	43	3	46	184
Pull Station	10	8	2	10	10
Smoke Detector	135	134	1	135	135
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Horn	18	18	0	18	18
Horn/Strobe	47	47	0	47	47
Strobe	36	36	0	36	36
EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Power Supply	10	10	0	10	10
Total Device Count: 469					

Inspection & Testing

Generated by: BuildingReports.com

Building: Westwood-Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left. Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 02 Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.

Valve shall be operated and signal receipt shall be verified to be within the first two revolutions of the hand wheel or within one-fifth of the travel distance, or per the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14i.1))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Tamper Switch	0	0	0	0	1
Device Type	Location	ScanID	Address	Q3/22	
Tamper Switch	Cafeteria in storage room. Building C.	07257545	1-02 0388		
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Vane-type and pressure switch-type waterflow alarm devices shall be tested semiannually. Per NFPA 25, Section 5.3.3.1, mechanical waterflow alarm devices shall be tested quarterly. Water shall be flowed through an inspector's test connection indicating the flow of water equal to that from a single sprinkler of the smallest orifice size installed in the system for wet-pipe systems, or an alarm test bypass connection for dry-pipe, pre-action, or deluge systems. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14j))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Waterflow Switch	1	1	0	1	1
Device Type	Location	ScanID	Address	Q3/22	
Waterflow Switch	MP Steel Chair Storage ITV: Backstage	07257546	1-02 0387	08/16-P	
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
The detector shall be tested by introducing smoke, other aerosol, or an optical filter into the beam path. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.7))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Beam Detector	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Beam Detector	MU NORTH		20413656	1-02 0386	08/16-P
Beam Detector	MU SOUTH		20413657	1-02 0385	08/16-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 03	Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5
-------------------	---

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
---------	--------------	------------	------------	-------------------	----------------

Heat Detector	46	43	3	46	184
---------------	----	----	---	----	-----

Device Type	Location	ScanID	Address	Q3/22
-------------	----------	--------	---------	-------

Heat Detector	Attic 12 SW	04100108	1-02 0127	
Heat Detector	Attic 20 East.	16426859	1-02 0400	
Heat Detector	Attic 20 East.	16427167	1-02 0400	
Heat Detector	Attic 23 West.	16427137	1-02 0400	
Heat Detector	Attic 24 West..	16426965	1-02 0400	
Heat Detector	Attic 26 West.	16426974	1-02 0400	
Heat Detector	Attic 27 East.	16426964	1-02 0400	08/17-P
Heat Detector	Attic 27 West.	16426967	1-02 0400	
Heat Detector	Attic 28 East.	16426884	1-02 0401	
Heat Detector	Attic 28 West.	16426960	1-02 0401	08/17-P
Heat Detector	Attic 28 West.	04100244	1-02 0401	08/17-F
Heat Detector	Attic 29 East.	16426973	1-02 0401	
Heat Detector	Attic 29 West.	16426976	1-02 0401	
Heat Detector	Attic 30 East.	16426977	1-02 0401	
Heat Detector	Attic 30 West.	16426978	1-02 0401	
Heat Detector	Attic 31 East.	16426961	1-02 0401	
Heat Detector	Attic 31 West	16426962	1-02 0401	08/17-P
Heat Detector	Attic Admin Main	04099505	1	08/16-F
Heat Detector	Attic Custodial Closet by 12 & 13	16426833	1-02 0127	
Heat Detector	Attic Custodial Closet by 12&13 North (Hatch)	16426878	1-02 0127	
Heat Detector	Attic principal office	04100105	1	
Heat Detector	Attic East 24	16427136	1-02 0400	
Heat Detector	Attic East 26	16426972	1-02 0400	
Heat Detector	attic East 26	16427163	1-02 0400	08/17-P
Heat Detector	10	04100117	1	
Heat Detector	10 #12 (lower NE)	16426873	1-02 0128	
Heat Detector	11	69500031	1	
Heat Detector	13 SE	69500034	1	
Heat Detector	14	69500041	1	
Heat Detector	16	04100233	1	
Heat Detector	16 East	04100235	1-02 0281	
Heat Detector	16 NW	16426777	1-02 0281	
Heat Detector	16 SW	16426765	1-02 0281	
Heat Detector	16 SW	16426778	1-02 0281	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	19	04100229	1	08/17-P
Heat Detector	19	16426802	1-02 0377	
Heat Detector	19	16426827	1-02 0281	
Heat Detector	19	16426869	1-02 0281	
Heat Detector	19 Attic	16426764	1-02 0377	
Heat Detector	2 restroom	07257540	1	
Heat Detector	21 Attic	16426773	1-02 0378	
Heat Detector	21 Attic	16426798	1-02 0378	
Heat Detector	22 NE	16426808	1-02 0281	
Heat Detector	23 East building E	04100245	1	
Heat Detector	23 West building E	04100246	1	08/17-F
Heat Detector	24 East building E	04100247	1	
Heat Detector	24 West building E	04100248	1	
Heat Detector	5	04100304	1	
Heat Detector	6	04100305	1	
Heat Detector	7	04100306	1	
Heat Detector	8	04100307	1	
Heat Detector	A South jaintor rm	04100109	1	
Heat Detector	ADMIN secritary office	16426758	1-02 0146	
Heat Detector	Admin	04100316	1-02 0146	
Heat Detector	Admin	16426897	1-02 0146	08/17-P
Heat Detector	Admin	16426903	1-02 0146	
Heat Detector	Admin	16426914	1-02 0146	
Heat Detector	Admin	16426927	1-02 0146	
Heat Detector	Admin	16426930	1-02 0146	
Heat Detector	Admin	16426935	1-02 0146	
Heat Detector	Admin	16426937	1-02 0146	
Heat Detector	Admin	16426943	1-02 0146	
Heat Detector	Admin	16426952	1-02 0146	
Heat Detector	Admin	16426955	1-02 0146	
Heat Detector	Admin	16426958	1-02 0146	08/17-P
Heat Detector	Admin	16426968	1-02 0146	
Heat Detector	Admin Secretary	04104946	1	
Heat Detector	Attic heat room10 southeast	16426875	1-02 0128	
Heat Detector	Attic room10 west	16426824	1-02 0128	
Heat Detector	Boy's building E	04100237	1	
Heat Detector	Boy's near portable 9 North Bathroom boys North	04100309	1	
Heat Detector	Custodian room near 12&13, North	3820496794	1-02 0008	
Heat Detector	Girl's building E	04100049	1	
Heat Detector	Girl's near portable 9 North Bathroom girls North	04100312	1	08/16-P

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Girl's near portable 9 South Bathroom girls South	04100311	1	
Heat Detector	Janitor's room near Classrooms 12&13, South	3820505335	1-02 0001	08/16-P
Heat Detector	K-1	04100156	1	
Heat Detector	K-2	04100155	1	
Heat Detector	K1 restroom Building D	08851610	1-1	
Heat Detector	K2	16426928	1-02 0147	08/17-P
Heat Detector	K2 Southeast	16426890	1-02 0147	08/17-P
Heat Detector	K2 northwest	16426939	1-02 0147	08/17-P
Heat Detector	K2 restroom Building D	08851609	1-1	
Heat Detector	KINDERGARTEN	16426934	1-02 0147	
Heat Detector	KINDERGARTEN	16426942	1-02 0147	
Heat Detector	KINDERGARTEN	16426945	1-02 0147	
Heat Detector	KINDERGARTEN	16426954	1-02 0147	
Heat Detector	KINDERGARTEN	16426983	1-02 0147	
Heat Detector	MU Custodial Office	3815261260	1-02 0297	08/16-P
Heat Detector	MU KITCHEN CENTER	14227387	1-02 0392	08/17-P
Heat Detector	MU KITCHEN DISH WASHROOM	14227388	1-02 0390	08/17-P
Heat Detector	MU KITCHEN NORTH	14227428	1-02 0391	08/17-P
Heat Detector	MU Staff Lounge Above Sink	3820496862	1-02 0290	08/16-P
Heat Detector	MU Stage, North	3820505120	1-02 0301	08/16-P
Heat Detector	MU corridor by Kitchen Dry Storage	3820505984	1-02 0295	08/16-P
Heat Detector	Womens restroom southeast	3820501245	1-02 0059	08/16-P
Heat Detector	attic room13 west	16426760	1-02 0127	08/17-P
Heat Detector	classroom 5	16426910	1-02 0150	08/17-P
Heat Detector	classroom 6	16426911	1-02 0151	08/17-P
Heat Detector	custodian room 116	3820504840	1-02 332	08/16-P
Heat Detector	library room 18NE attic Attic	16426769	1-02 0377	08/17-P
Heat Detector	library room 18NW attic Attic	16426797	1-02 0377	08/17-P
Heat Detector	library speech	16426781	1-02 0377	
Heat Detector	library supply storage	16426860	1-02 0281	
Heat Detector	mens restroom southeast	3820494257	1-02 0058	08/16-P
Heat Detector	room 22NW attic	16426774	1-02 0378	08/17-P
Heat Detector	room 22sw attic	16426820	1-02 0378	08/17-P
Heat Detector	room 4 Attic	16426892	1-02 0155	08/17-P
Heat Detector	room 7 Attic	16426889	1-02 0151	08/17-P
Heat Detector	room 8 Attic	16426918	1-02 0152	08/17-P
Heat Detector	room 9	16426900	1-02 0152	08/17-P
Heat Detector	Above MU, Stage, South	3820504857	1-02 0302	08/16-P
Heat Detector	East 17 Attic	16426782	1-2 377	
Heat Detector	East 25 Attic	04100294	1	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	East 32 Attic	16426975	1-02 0401	08/17-P
Heat Detector	North 15 Attic	16426785	1-02 0378	
Heat Detector	North P 2 Attic	16426895	1-02 0158	
Heat Detector	Northeast classroom 2 Attic	16426909	1-02 0154	
Heat Detector	South 15 Attic	16426815	1-02 0378	
Heat Detector	South Bldg E unisex restroom. Attic	16426905	1-02 0399	08/17-P
Heat Detector	South P 1 Attic	16426901	1-02 0158	
Heat Detector	South P 2 Attic	16426919	1-02 0158	
Heat Detector	Southwest room 3 Attic	16426885	1-02 0155	
Heat Detector	West 17 Attic	16426854	1-02 0377	
Heat Detector	West 25 Attic	16426971	1-02 0400	08/17-P
Heat Detector	West 32 Attic	04100299	1-02 0400	
Heat Detector	south classroom 2 Attic	16426887	1-02 0154	
Heat Detector	southwest classroom 2 Attic	16426883	1-02 0154	
Heat Detector	Attic Lower 10 NE	16426831	1-02 0128	
Heat Detector	Attic Lower 10 NW	16426822	1-02 0128	08/17-P
Heat Detector	Attic Lower 11 East	16426608	1-02 0128	
Heat Detector	Attic Lower 11 West	16426843	1-02 0128	
Heat Detector	Attic Lower 12 NE	16426851	1-02 0127	
Heat Detector	Attic Lower 14	16426828	1-02 0128	
Heat Detector	Attic Lower attic room 13 SE	16426682	1-02 0127	08/17-P
Heat Detector	Attic Upper 13 #1	16426863	1-02 0127	
Heat Detector	Attic hatch 13 Outside east boy's	61242149	1-02 0127	
Heat Detector	Attic upper 10 #1 (NE)	16426582	1-02 0128	
Heat Detector	Attic upper 10 #10 (lower)	16426592	1-02 0128	
Heat Detector	Attic upper 10 #11 (lower)	16426842	1-02 0128	08/17-P
Heat Detector	Attic upper 10 #2	16426587	1-02 0128	
Heat Detector	Attic upper 10 #3	16426861	1-02 0128	
Heat Detector	Attic upper 10 #4	16426844	1-02 0128	
Heat Detector	Attic upper 10 #5	16426847	1-02 0128	
Heat Detector	Attic upper 10 #6	16426866	1-02 0128	08/17-P
Heat Detector	Attic upper 10 #7	16426867	1-02 0128	
Heat Detector	Attic upper 10 #8 (SE)	16426870	1-02 0128	
Heat Detector	Attic upper 10 #9 (lower SE)	16426868	1-02 0128	
Heat Detector	Attic upper 11 #1 (NE)	69500030	1-02 0128	
Heat Detector	Attic upper 11 #2 (SE)	16426880	1-02 0128	08/17-P
Heat Detector	Attic upper 11 #3	69500029	1-02 0128	
Heat Detector	Attic upper 11 #4 (SW)	16426877	1-02 0128	
Heat Detector	Attic upper 11 #5 (NW)	69500027	1-02 0128	
Heat Detector	Attic upper 11 #6	16426872	1-02 0128	
Heat Detector	Attic upper 12 #1 (NW)	16426841	1-02 0127	08/17-P
Heat Detector	Attic upper 12 #2 (SW)	69500026	1-02 0127	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	Attic upper 12 #3	16426595	1-02 0127	
Heat Detector	Attic upper 12 #4 (SE)	69500024	1-02 0127	
Heat Detector	Attic upper 12 #5 (NE)	69500025	1-02 0127	
Heat Detector	Attic upper 12 #6 (NE)	16426862	1-02 0127	
Heat Detector	Attic upper 13 #2 (NW)	16426855	1-02 0127	
Heat Detector	Attic upper 13 #3	69500033	1-02 0127	
Heat Detector	Attic upper 13 #4	16426848	1-02 0127	
Heat Detector	Attic upper 13 #5 (NW)	16426856	1-02 0127	
Heat Detector	Attic upper 13 #6	16426881	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #1 (high NW, clockwise)	69500042	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #10	69500038	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #2	69500036	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #3	69500040	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #4	69500043	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #5	69500037	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #6	69500044	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #7 (lower, SW countercloc	69500035	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #8	69500039	1-02 0127	
Heat Detector	Attic upper 13 Outside east Girl's #9	61242148	1-02 0127	
Heat Detector	Attic upper 14 #1	16426714	1-02 0128	
Heat Detector	Attic upper 14 #2 (NE)	16426602	1-02 0128	
Heat Detector	Attic upper 14 #3	16426871	1-02 0128	
Heat Detector	Attic upper 14 #4	16426876	1-02 0128	
Heat Detector	Attic upper 14 #5 (SW)	16426857	1-02 0128	
Heat Detector	Attic upper 14 #6	16426882	1-02 0128	
Heat Detector	library room 22sw	16426807	1-02 0378	08/17-P
Heat Detector	library room 18 SE Attic	16426684	1-02 0377	08/17-P
Heat Detector	library room 18 sw Attic	16426799	1-02 0377	08/17-P
Device Total: 184 Return to Executive Summary				

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Pull Station	10	8	2	10	10
Device Type	Location		ScanID	Address	Q3/22
Pull Station	Admin, by FACP		20413646	1-02 0148	08/15-P
Pull Station	Library building, Nort-West Exit		20413654	1-02 0381	08/16-P
Pull Station	Library building, South-East Exit		20413655	1-02 0380	08/16-P
Pull Station	MP North Exit		20413651	1-02 0393	08/16-P
Pull Station	MP SE		20413650	1-02 0396	08/16-P
Pull Station	MP Southwest Exit		20413647	1-02 0397	08/16-P
Pull Station	MP Stage, South		20413653	1-02 0395	08/16-P
Pull Station	MP Stage, north east		20413652	1-02 0394	08/16-P
Pull Station	P2		04100275	1	08/15-F
Pull Station	Southwest 2		04104288	1-02 0	08/16-F
Device Total: 10 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Smoke Detector	135	134	1	135	135
Device Type	Location		ScanID	Address	Q3/22
Smoke Detector	10 North		3912362389	1-02 0013	08/15-P
Smoke Detector	10 South		3912359099	1-02 0016	08/15-P
Smoke Detector	11 East		3912280423	1-02 0018	08/15-P
Smoke Detector	11 West		3912365007	1-02 0017	08/15-P
Smoke Detector	12 East		3912361665	1-02 0020	08/15-P
Smoke Detector	12 West		3912352182	1-02 0019	08/15-P
Smoke Detector	13 East		3912353592	1-02 0009	08/15-P
Smoke Detector	13 West		3910294149	1-02 0010	08/15-P
Smoke Detector	14 East		3912364932	1-02 0011	08/15-P
Smoke Detector	14 West		3912353561	1-02 0012	08/15-P
Smoke Detector	2 N.E.		3912360279	1-02 0050	08/15-P
Smoke Detector	2 N.W.		3912358948	1-02 0049	08/15-P
Smoke Detector	2 Restroom		3912279250	1-02 0051	08/15-P
Smoke Detector	2 S.W.		3912359020	1-02 0052	08/15-P
Smoke Detector	20 (Library Building) West		3969842186	1-02 0252	08/16-P
Smoke Detector	20 (Library) South		3912365106	1-02 0254	08/16-P
Smoke Detector	20 East		3912279823	1-02 0253	08/16-P
Smoke Detector	23 North		3912359068	1-02 0329	08/15-P
Smoke Detector	23 South		3912359723	1-02 0330	08/15-P
Smoke Detector	24 North		3912281802	1-02 0327	08/15-P
Smoke Detector	24South		3912280263	1-02 0328	08/15-P
Smoke Detector	25 North Building E.		3976386703	1-02 0325	08/15-P
Smoke Detector	25 South		3912365045	1-02 0326	08/15-P
Smoke Detector	26 North		3912359136	1-02 0323	08/15-P
Smoke Detector	26 South		3912280546	1-02 0324	08/15-P
Smoke Detector	27 North		3927465594	1-02 0321	08/15-P
Smoke Detector	27 South		3912280201	1-02 0322	08/15-P
Smoke Detector	28 North		3912279335	1-02 0311	08/15-P
Smoke Detector	28 South		3912358979	1-02 0310	08/15-P
Smoke Detector	29 North		3912280782	1-02 0313	08/15-P
Smoke Detector	29 South		3912359129	1-02 0312	08/15-P
Smoke Detector	3 North		3912364949	1-02 0054	08/15-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	3 South	3912359013	1-02 0053	08/15-P
Smoke Detector	30 North	3912280041	1-02 0315	08/15-P
Smoke Detector	30 South	3912279694	1-02 0314	08/15-P
Smoke Detector	31 North	3912279618	1-02 0317	08/15-P
Smoke Detector	31 South	3912281079	1-02 0316	08/15-P
Smoke Detector	32 North	3912280010	1-02 0319	08/15-P
Smoke Detector	32 South	3912279359	1-02 0318	08/15-P
Smoke Detector	4 North	3912356005	1-02 0055	08/15-P
Smoke Detector	4 South	3912279502	1-02 0056	08/15-P
Smoke Detector	5 North	3912035931	1-02 0039	08/15-P
Smoke Detector	5 South	3912282052	1-02 0040	08/15-P
Smoke Detector	6 North	3912364529	1-02 0041	08/15-P
Smoke Detector	6 South	3912361016	1-02 0042	08/15-P
Smoke Detector	7 North.	3910307726	1-02 0044	08/15-P
Smoke Detector	7 South	3912358931	1-02 0043	08/15-P
Smoke Detector	8 North	3912361962	1-02 0045	08/15-P
Smoke Detector	8 South	3912279410	1-02 0046	08/15-P
Smoke Detector	9 North	3912359105	1-02 0048	08/15-P
Smoke Detector	9 South	3912279922	1-02 0047	08/15-P
Smoke Detector	Admin Bldg Secretary's Area	3976858934	1-02 0028	08/16-P
Smoke Detector	Admin, Principal's Office	3912035481	1-02 0024	08/15-P
Smoke Detector	Admin, Staff Restroom	3912035825	1-02 0023	08/15-P
Smoke Detector	Admin, Workroom	3912035771	1-02 0021	08/15-P
Smoke Detector	Admin, Vice Principal's office.	3913550723	1-02 0025	08/15-P
Smoke Detector	Admin, hallway, east	3912036013	1-02 0022	08/15-P
Smoke Detector	Admin, hallway, west	3912035573	1-02 0026	08/15-P
Smoke Detector	Admin, office/storage room	3912036662	1-02 0030	08/15-P
Smoke Detector	Boy's near 10-14 South	3912365069	1-02 0002	08/16-P
Smoke Detector	Boy's near 10-14, North	3912361993	1-02 0007	08/16-P
Smoke Detector	Boy's near 23&28	3912279984	1-02 0331	08/15-P
Smoke Detector	Cafeteria music Storage South	3976839087	1-02 300	08/16-P
Smoke Detector	Cafeteria music storage room, north	3912035559	1-02 0299	08/16-P
Smoke Detector	Cafeteria telephone room	3912219164	1-02 0287	08/16-P
Smoke Detector	Conference room near 10	3912350881	1-02 0014	08/15-P
Smoke Detector	Girl's near 10-14 South	3912365076	1-02 0004	08/15-P
Smoke Detector	Girl's near 10-14, North	3912362167	1-02 0005	08/15-P
Smoke Detector	Girl's near 23&28	3912360194	1-02 0309	08/15-P
Smoke Detector	K-1 S.W.	3912035351	1-02 0033	08/15-P
Smoke Detector	K-1 E.	3950376201	1-02 0031	08/15-P
Smoke Detector	K-1 Toilet	3912036945	1-02 0034	08/15-P
Smoke Detector	K-1, N.W.	3937676317	1-02 0032	08/15-P
Smoke Detector	K-2 N.E.	3912036990	1-02 0038	08/15-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	K-2 Restroom	3912035795	1-02 0035	08/15-P
Smoke Detector	K-2 West	3912219553	1-02 0036	08/15-P
Smoke Detector	K-2, S.E.	3913550556	1-02 0037	08/16-P
Smoke Detector	Library Building Classroom 19 West	3912364857	1-02 0256	08/16-P
Smoke Detector	Library Building, Classroom 19 East	3912279571	1-02 0257	08/16-P
Smoke Detector	Library Building, Classroom 15 North.	3912035542	1-02 0270	08/16-P
Smoke Detector	Library Building, Classroom 15 S.E.	3928038285	1-02 0271	08/16-P
<i>The above device replaced ScanID 3912035788:</i>				
Smoke Detector	Library Building, Classroom 15 S.E.	3912035788	1-02 0271	08/15-R
Smoke Detector	Library Building, Classroom 15 S.W.	3912036921	1-02 0272	08/16-P
Smoke Detector	Library Building, Classroom 17 N.E.	3912358993	1-02 0262	08/16-P
Smoke Detector	Library Building, Classroom 17 S.E.	3912359501	1-02 0263	08/16-P
Smoke Detector	Library Building, Classroom 17 West	3912364901	1-02 0261	08/16-P
Smoke Detector	Library Building, Classroom 18 N.E.	3912279656	1-02 0258	08/16-P
Smoke Detector	Library Building, Classroom 18 S.E.	3912365137	1-02 0259	08/16-P
Smoke Detector	Library Building, Classroom 18 West	3912037010	1-02 0260	08/16-P
Smoke Detector	Library Building, Classroom 19, South.	3912287989	1-02 0255	08/16-P
Smoke Detector	Library Building, Classroom 21 N.W.	3912035498	1-02 0278	08/16-P
Smoke Detector	Library Building, Classroom 21 S.E.	3912219508	1-02 0276	08/16-P
Smoke Detector	Library Building, Classroom 22 N.E.	3912219119	1-02 0275	08/16-P
Smoke Detector	Library Building, Classroom 22 S.W.	3912035917	1-02 0273	08/16-P
Smoke Detector	Library Building, Counselors office	3912359396	1-02 0251	08/16-P
Smoke Detector	Library Building, East entry	3912359419	1-02 0264	08/16-P
Smoke Detector	Library Building, Electrical room	3912035924	1-02 0280	08/16-P
Smoke Detector	Library Building, Library CENTER-EAST	20413667	1-02 0283	08/16-P
Smoke Detector	Library Building, Library CENTER-WEST	20413670	1-02 0284	08/16-P
Smoke Detector	Library Building, Library NORTH-EAST	20413668	1-02 0282	08/16-P
Smoke Detector	Library Building, Library NORTH-WEST	20413671	1-02 0281	08/16-P
Smoke Detector	Library Building, Library SOUTH-EAST	20413666	1-02 0286	08/16-P
Smoke Detector	Library Building, Library SOUTH-WEST	20413669	1-02 0285	08/16-P
Smoke Detector	Library Building, PE room	3912364833	1-02 0265	08/16-P
Smoke Detector	Library Building, Speech room	3912365144	1-02 0266	08/16-P
Smoke Detector	Library Building, west entry	3912038680	1-02 0279	08/16-P
Smoke Detector	Library room 16, S.E.	3910235920	1-02 0267	08/16-P
Smoke Detector	MU KITCHEN office	3912035818	1-02 0298	08/16-P
Smoke Detector	MU Kitchen Dry Storage	3912219195	1-02 0296	08/16-P
Smoke Detector	MU Lift by Stage	3912035511	1-02 0304	08/16-P
Smoke Detector	MU Men's	3912035467	1-02 0288	08/16-P
Smoke Detector	MU Stage Electrical Room	3912037003	1-02 0303	08/16-P
Smoke Detector	MU Women's	3944428343	1-02 0289	08/16-P
<i>The above device replaced ScanID 61239541:</i>				
Smoke Detector	MU Women's	61239541	1-02 0289	08/16-R

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	Mens near 12 &13	3912364970	1-02	08/16 Removed
Smoke Detector	Nurses office near 10	3912365083	1-02 0015	08/15-P
Smoke Detector	P1 East	3912282076	1-02 0067	08/15-P
Smoke Detector	P1 East Restroom	3908959777	1-02 0065	08/15-P
Smoke Detector	P1 West	3912357996	1-02 0068	08/15-P
Smoke Detector	P1 West Restroom	3912280300	1-02 0066	08/15-P
Smoke Detector	P2 East	3912361573	1-02 0063	08/15-P
Smoke Detector	P2 East restroom.	3910318432	1-02 0061	08/15-P
Smoke Detector	P2 West	3912280942	1-02 0064	08/15-P
Smoke Detector	P2 West Restroom	3912280935	1-02 0062	08/15-P
Smoke Detector	Restroom bldng, Boy's SE	3912361658	1-02 0057	08/15-P
Smoke Detector	Restroom bldng, Girl's SE	3912279267	1-02 0060	08/15-P
Smoke Detector	Staff Restroom near 23&28	3912279830	1-02 0308	08/15-P
Smoke Detector	Teachers workroom near 27&32	3912280430	1-02 0320	08/15-P
Smoke Detector	Women's near 10-14	3912358917	1-02 0003	08/15-P
Smoke Detector	cafeteria storage Riser room	3912035399	1-02 0298	08/16-P
Smoke Detector	cafeteria teacher dining east	3912036761	1-02 0292	08/16-P
Smoke Detector	cafeteria teacher dining west	3937699385	1-02 0291	08/16-P
Smoke Detector	custodian closet by rooms 23 and28	04100238	1	08/15-F
Smoke Detector	principal office	3912036976	1-02 0029	08/15-P
Smoke Detector	Northeast Library Building, Classroom 16	3912279458	1-02 0268	08/16-P
Smoke Detector	Northwest Library Building, Classroom 16	3912364895	1-02 0269	08/16-P
Smoke Detector	Northwest Library Building, Classroom 22	3912035979	1-02 0274	08/16-P
Smoke Detector	southwest Library Building, Classroom 21	3912035894	1-02 0277	08/16-P
Device Total: 135 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Bell	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Bell	Outside/Front of school. outside of waterflow sw		08851606	1	08/16-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 04	Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5				
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn	18	18	0	18	18
Device Type	Location	ScanID	Address	Q3/22	
Horn	Outside horn, MU Building, West of Kitchen	16425896	1	08/17-P	
Horn	Outside horn, MU Buildng, East	20413672	1	08/17-P	
Horn	Outside horn, MU Building, North	16425892	1	08/17-P	
Horn	Outside horn, MU Buildng, South	16425897	1	08/17-P	
Horn	Outside horn, N-E, by room 19 Library building	16425894	1	08/17-P	
Horn	Outside horn, N-W, by room 20 Library building	16425899	1	08/17-P	
Horn	Outside horn, S-W, by room 15 Library building	16425900	1	08/17-P	
Horn	Outside horn, by 10, North	16425895	1	08/17-P	
Horn	Outside horn, by 10, South	16425901	1	08/17-P	
Horn	Outside horn, by 2, North	45705207	1	08/17-P	
Horn	Outside horn, by 25	16425884	1	08/17-P	
Horn	Outside horn, by 30	16425888	1	08/17-P	
Horn	Outside horn, by 9, South	16425889	1	08/17-P	
Horn	Outside horn, by P-1, North	16425885	1	08/17-P	
Horn	Outside horn, by S-E entry Library building	16425893	1	08/17-P	
Horn	Outside horn, by West Entry Library building	16425890	1	08/17-P	
Horn	Outside horn, by Workroom near 27	16425898	1	08/17-P	
Horn	Outside room K2.	61239529	1	08/17-P	
Device Total: 18 Return to Executive Summary					

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18.					
Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	47	47	0	47	47
Device Type	Location		ScanID	Address	Q3/22
Horn/Strobe	11		16425951	1	08/17-P
Horn/Strobe	12		16425953	1	08/17-P
Horn/Strobe	13		16425991	1	08/17-P
Horn/Strobe	14		16425954	1	08/15-P
Horn/Strobe	2		16425961	1	08/17-P
Horn/Strobe	23		16425970	1	08/17-P
Horn/Strobe	24		16425986	1	08/17-P
Horn/Strobe	25		16425969	1	08/17-P
Horn/Strobe	26		16425968	1	08/17-P
Horn/Strobe	27		16425976	1	08/17-P
Horn/Strobe	28		16425959	1	08/17-P
Horn/Strobe	29		16425988	1	08/17-P
Horn/Strobe	3		16425990	1	08/17-P
Horn/Strobe	30		16425987	1	08/17-P
Horn/Strobe	31		16425972	1	08/17-P
Horn/Strobe	32		16425975	1	08/17-P
Horn/Strobe	4		16425957	1	08/17-P
Horn/Strobe	5		16425963	1	08/17-P
Horn/Strobe	6		16425966	1	08/17-P
Horn/Strobe	7		16425967	1	08/17-P
Horn/Strobe	8		16425965	1	08/17-P
Horn/Strobe	9		16425973	1	08/17-P
Horn/Strobe	Admin, Main Office		16425982	1	08/17-P
Horn/Strobe	Admin, Workroom		16425981	1	08/17-P
Horn/Strobe	Classroom 10		16425955	1	08/17-P
Horn/Strobe	K-1		16425984	1	08/17-P
Horn/Strobe	K-2		16425983	1	08/17-P
Horn/Strobe	Library building, Classroom 15		16425948	1	08/17-P
Horn/Strobe	Library building, Classroom 16		16425947	1	08/17-P
Horn/Strobe	Library building, Classroom 17		16425946	1	08/17-P
Horn/Strobe	Library building, Classroom 18		16425944	1	08/17-P
Horn/Strobe	Library building, Classroom 19		16425945	1	08/17-P
Horn/Strobe	Library building, Classroom 20		16425985	1	08/17-P

Device Type	Location	ScanID	Address	Q3/22
Horn/Strobe	Library building, Classroom 21	16425949	1	08/17-P
Horn/Strobe	Library building, Classroom 22	16425977	1	08/17-P
Horn/Strobe	Library building, library, East	16425950	1	08/17-P
Horn/Strobe	Library building, library, West	16425989	1	08/17-P
Horn/Strobe	MP, Stage, South	16425980	1	08/17-P
Horn/Strobe	MU Kitchen	16425956	1	08/17-P
Horn/Strobe	MU North	16425978	1	08/17-P
Horn/Strobe	MU PE storage room	16425979	1	08/17-P
Horn/Strobe	MU South	16425942	1	08/17-P
Horn/Strobe	MU Staff lounge	16425943	1	08/17-P
Horn/Strobe	Office by 10	16425952	1	08/15-P
Horn/Strobe	P-1	16425964	1	08/17-P
Horn/Strobe	P2	16425958	1	08/17-P
Horn/Strobe	Workroom near 27&32	16425971	1	08/17-P
Device Total: 47 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15c))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Strobe	36	36	0	36	36
Device Type	Location		ScanID	Address	Q3/22
Strobe	2 Restroom		16425902	1	08/17-P
Strobe	Admin, Hallway, east		16425907	1	08/17-P
Strobe	Admin, Office/Conference room		16425909	1	08/17-P
Strobe	Admin, Principals Office		16425917	1	08/17-P
Strobe	Admin, Staff Restroom		16425906	1	08/17-P
Strobe	Admin, Vice Principals Office		16425914	1	08/17-P
Strobe	Boy's near 12&13		16425925	1	08/17-P
Strobe	Boy's near 23&28		16425929	1	08/17-P
Strobe	Girl's near 12&13		16425922	1	08/17-P
Strobe	Girl's near 23&28		16425920	1	08/17-P
Strobe	K-1 Restroom		16425916	1	08/17-P
Strobe	K-2-Restroom		16425915	1	08/17-P
Strobe	Library building, PE		16425926	1	08/17-P
Strobe	Library building, couselfors office		16425936	1	08/17-P
Strobe	Library building, electrical room		16425912	1	08/17-P
Strobe	Library building, near east exit		16425919	1	08/17-P
Strobe	Library building, near west exit		16425910	1	08/17-P
Strobe	Library building, speech room		16425911	1	08/17-P
Strobe	MU Kitchen, dishwashing area		16425933	1	08/17-P
Strobe	MU Kitchen, hallway		16425938	1	08/17-P
Strobe	MU Men's entry		16425937	1	08/17-P
Strobe	MU Staff lounge, kitchen		16425918	1	08/17-P
Strobe	MU Stage elevator		16425931	1	08/17-P
Strobe	MU Women's		16425941	1	08/17-P
Strobe	MU, Stage, North		16425934	1-2 0394	08/17-P
Strobe	MUMen's near toilet		16425932	1	08/17-P
Strobe	Nurses office by 10		16425903	1	08/17-P
Strobe	P-1, east restroom		16425913	1	08/17-P
Strobe	P-1, west restroom		16425904	1	08/17-P
Strobe	P-2, east restroom		16425935	1	08/17-P
Strobe	Restroom building, Men's		16425921	1	08/17-P
Strobe	Restroom building, Women's		16425928	1	08/17-P
Strobe	Restroom building, boy's		16425940	1	08/17-P
Strobe	Restroom building, girl's		16425923	1	08/17-P
Strobe	Staff Restroom near 23&28		16425939	1	08/17-P
Strobe	Women's near 12&13		16425927	1	08/17-P

Device Type	Location	ScanID	Address	Q3/22

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Communicator	Main office		61237579	1	08/16-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q3/22	
Control Panel			Main Office				14226395		1		08/15-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Battery	22	6	16	22	22
Device Type	Location		ScanID	Address	Q3/22
Battery	2 Lower BPS		37521670	1	08/16-F
Battery	2 Lower BPS		37521671	1	08/16-F
Battery	2 Upper		37521672	1	08/16-F
Battery	2 Upper		37521673	1	08/16-F
Battery	5		61239530	1	08/16-F
Battery	5		61239531	1	08/16-F
Battery	Admin Workroom		37521668	1	08/16-F
Battery	Admin Workroom		37521669	1	08/16-F
Battery	Admin at FACP		44809805	1	08/16-P
Battery	Admin at FACP		44809806	1	08/16-P
Battery	Custodial 116 (Outside 23 South)		20413545	1	08/16-P
Battery	Custodial 116 (Outside 23 South)		20413546	1	08/16-P
Battery	Custodial by 12&13		37521674	1	08/16-F
Battery	Custodial by 12&13		37521675	1	08/16-F
Battery	Library Electrical room		20413543	1	08/16-F
Battery	Library Electrical room		20413544	1	08/16-F
Battery	MU Data Closet by Restrooms		37521676	1	08/16-F
Battery	MU Data Closet by Restrooms		37521677	1	08/16-F
Battery	Main office BPS		20409228	1	08/16-P
Battery	Main office BPS		20409230	1	08/16-P
Battery	P2		20409231	1	08/16-F
Battery	P2		20409232	1	08/16-F
Device Total: 22		Return to Executive Summary			

LS 02.01.34 EP 10

All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5

At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
---------	--------------	------------	------------	-------------------	----------------

Device Type	Location	ScanID	Address	Q3/22
Power Supply	2 Upper	20413662	1	08/16-P
Power Supply	5	20413663	1	08/16-P
Power Supply	Admin Workroom	20413665	1	08/16-P
Power Supply	Custodial 116 (23 Outside South)	20413660	1	08/16-P
Power Supply	Custodial by 12&13	20413661	1	08/16-P
Power Supply	Library NW Electrical by RM20	20413659	1	08/16-P
Power Supply	MU Data Closet by Restrooms	20413658	1	08/16-P
Power Supply	Main office BPS	04100209	1	08/16-P
Power Supply	P2 By K1	20413664	1	08/16-P
Device Total: 10		Return to Executive Summary		

Service Summary

Generated by: BuildingReports.com

Building: Westwood-Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		16
Heat Detector	Annual	3
Pull Station	Annual	2
Smoke Detector	Annual	1
		22
<i>Passed</i>		
		6
Beam Detector	Annual	2
Bell	Annual	1
Communicator	Annual	1
Control Panel	Annual	1
Heat Detector	Annual	43
Horn/Strobe	Annual	47
Horn	Annual	18
Power Supply	Tested	10
Pull Station	Annual	8
Smoke Detector	Annual	134
Strobe	Annual	36
Waterflow Switch	Tested	1
		308
<i>Untested</i>		
Tamper Switch		1

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Westwood-Lodi USD				Control Panel: 1 - Edwards EST 3			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	Admin at FACP	26	12	13.4	13.2	80%	80%
Sealed Lead Acid	Custodial 116 (Outside 23 South)	10	12	13.2	13.1	80%	100%
Sealed Lead Acid	Custodial 116 (Outside 23 South)	10	12	13.2	13.0	80%	90%
Sealed Lead Acid	Main office BPS	7	12	13.5	13.1	80%	90%
Sealed Lead Acid	Main office BPS	7	12	13.5	13.1a	80%	90%
Failed/Other							
Sealed Lead Acid	2 Lower BPS	7	12				
Sealed Lead Acid	2 Upper	10	12	13.1		80%	60%
Sealed Lead Acid	2 Upper	10	12	13.1		80%	70%
Sealed Lead Acid	5	10	12	13.4	13.2	80%	100%
Sealed Lead Acid	5	10	12	13		80%	60%
Sealed Lead Acid	Admin Workroom	10	12				10%
Sealed Lead Acid	Admin Workroom	10	12				80%
Sealed Lead Acid	Custodial by 12&13	10	12				10%
Sealed Lead Acid	Custodial by 12&13	10	12				
Sealed Lead Acid	Library Electrical room	10	12	13.4	13.2	80%	100%
Sealed Lead Acid	Library Electrical room	10	12	12.8			70%
Sealed Lead Acid	MU Data Closet by Restrooms	10	12	13		80%	70%
Sealed Lead Acid	MU Data Closet by Restrooms	10	12	13.4			
Sealed Lead Acid	P2	10	12	13.2		80%	70%
Sealed Lead Acid	P2	10	12	13.2	13.0	80%	80%
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							
Breaker	2 Lower	10		120			
Breaker	2 Upper	10		120			
Breaker	5	10		120			
Breaker	Admin Workroom	10		120			
Breaker	Custodial 116 (23 Outside South)	10		120			

Protection Type	Location	Rated Ah	Rated Volts	Charging Voltage
Breaker	Custodial by 12&13	10	120	
Breaker	Library NW Electrical by RM20	10	120	
Breaker	MU Data Closet by Restrooms	10	120	
Breaker	Main office BPS	10	120	
Breaker	P2 By K1	10	120	

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Westwood-Lodi USD	Control Panel: 1 - Edwards EST 3
-----------------------------	----------------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Beam Detector	Initiating	0.43%	2
Bell	Indicating	0.21%	1
Communicator	Control	0.21%	1
Control Panel	Control	0.21%	1
Heat Detector	Initiating	39.23%	184
Horn	Indicating	3.84%	18
Horn/Strobe	Indicating	10.02%	47
Power Supply	Control	2.13%	10
Pull Station	Initiating	2.13%	10
Smoke Detector	Initiating	28.78%	135
Strobe	Indicating	7.68%	36
Tamper Switch	Supervisory	0.21%	1
Waterflow Switch	Initiating	0.21%	1

Type	Qty	Model #	Description	Install Date
<i>In Service - 90 Days - 1 Year</i>				
EST				

<i>In Service - 2 Years to 3 Years</i>				
---	--	--	--	--

<i>In Service - 3 Years to 5 Years</i>				
Thermotech				

Power-Sonic				
--------------------	--	--	--	--

Battery	2	PS-1210H	Sealed Lead Acid	04/22/2019
---------	---	----------	------------------	------------

<i>In Service - 5 Years to 10 Years</i>				
--	--	--	--	--

Duracell ultra				
-----------------------	--	--	--	--

Battery	2	Dura12-26NB	Sealed Lead Acid	06/01/2017
---------	---	-------------	------------------	------------

Duracell Ultra				
-----------------------	--	--	--	--

Battery	2	DURA12-10F2	Sealed Lead Acid	08/02/2016
---------	---	-------------	------------------	------------

Duracell				
-----------------	--	--	--	--

Battery	2	DURA12-10F2	Sealed Lead Acid	05/12/2016
---------	---	-------------	------------------	------------

Battery	2	DURA12-7F	Sealed Lead Acid	05/12/2016
---------	---	-----------	------------------	------------

Battery	2	DURA12-10F2	Sealed Lead Acid	04/26/2016
Battery	2	DURA12-10F2	Sealed Lead Acid	04/15/2016
Battery	2	DURA12-10F2	Sealed Lead Acid	02/22/2016
Duracell Ultra				
Battery	2	DURA12-10F2	Sealed Lead Acid	11/13/2014
Power-Sonic				
Battery	2	PS12120	Sealed Lead Acid	06/18/2014
Heat Detector	4	302		01/01/2014
EST				
Heat Detector	19			01/01/2014
Heat Detector	1	302		01/01/2014
Smoke Detector	4	SIGA-PS	Photoelectric	01/01/2014
Smoke Detector	7	SIGA2-PS	Photoelectric	01/01/2014
<i>In Service - 10 Years to 15 Years</i>				
302				
Heat Detector	1	302		01/01/2012
EST				
Heat Detector	1	.thermite		01/01/2012
Heat Detector	1	302		01/01/2012
Thermotech				
Heat Detector	21	302		01/01/2012
<i>In Service - 15 Years to 25 Years</i>				
Edwards				
Heat Detector	1	281B	Rate-of-Rise	04/16/2007
Heat Detector	3	282-1B	Rate-of-Rise	04/16/2007
Heat Detector	17	282-2B	Rate-of-Rise	04/16/2007
System Sensor				
Heat Detector	2	5451	Rate-of-Rise	04/16/2007
Thermotech				
Heat Detector	7	302	Rate-of-Rise	04/16/2007
<i>In Service - 25 Years or Older</i>				
Beam Detector	2			09/01/1990
Heat Detector	1			09/01/1990
Heat Detector	1		Rate-of-Rise	09/01/1990
Heat Detector	7	302		09/01/1990
Smoke Detector	1	DNE		09/01/1990
DNE				
Smoke Detector	1	DNE	Photoelectric	09/01/1990
EST				
Communicator	1	3MODCOM	Digital Communicator	09/01/1990
Heat Detector	1	302		09/01/1990

Heat Detector	1	302	Rate-of-Rise	09/01/1990
Heat Detector	3	985a		09/01/1990
Heat Detector	1	SIGA-HD	Rate-of-Rise	09/01/1990
Heat Detector	7	SIGA-HRS		09/01/1990
Horn	17	757-1A-T		09/01/1990
Horn/Strobe	47	G1RF-HDVM		09/01/1990
Power Supply	8	BPS10A		09/01/1990
Pull Station	3	BG-12L		09/01/1990
Pull Station	3	BG-12L	Dual Action	09/01/1990
Smoke Detector	1		Photoelectric	09/01/1990
Smoke Detector	1	757-1A-T		09/01/1990
Smoke Detector	1	G1RF-VM		09/01/1990
Smoke Detector	3	SIGA-PS		09/01/1990
Smoke Detector	115	SIGA-PS	Photoelectric	09/01/1990
Smoke Detector	1	siga-	Photoelectric	09/01/1990
Strobe	36	G1RF-VM		09/01/1990
Edwards				
Control Panel	1	EST 3		09/01/1990
Horn	1	882-2B		09/01/1990
Fire-Lite				
Power Supply	1	FCPS-24F		09/01/1990
Pull Station	1		Dual Action	09/01/1990
Pull Station	1	BG-10		09/01/1990
Pull Station	1	BG-12L	Dual Action	09/01/1990
Pull Station	1	bg-12l		09/01/1990
MILWAUKEE VALVE				
Tamper Switch	1	BB-SOSO		09/01/1990
Notifier				
Power Supply	1	FCPS-24		09/01/1990
Potter Electric				
Bell	1	PI-2010		09/01/1990
Waterflow Switch	1	VSR F		09/01/1990
Thermotech				
Heat Detector	55	302		09/01/1990
Heat Detector	25	302	Combination	09/01/1990

Zone Address Report

Generated by: BuildingReports.com

Building: Westwood-Lodi USD			Control Panel: 1 - Edwards EST 3	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 1				
	Heat Detector	K1 restroom Building D		08851610
	Heat Detector	K2 restroom Building D	Rate-of-Rise	08851609
Zone/Circuit: 02				
0	Pull Station	Southwest 2		04104288
0001	Heat Detector	Janitor's room near Classrooms 12&13, South		3820505335
0002	Smoke Detector	Boy's near 10-14 South	Photoelectric	3912365069
0003	Smoke Detector	Women's near 10-14	Photoelectric	3912358917
0004	Smoke Detector	Girl's near 10-14 South	Photoelectric	3912365076
0005	Smoke Detector	Girl's near 10-14, North	Photoelectric	3912362167
0007	Smoke Detector	Boy's near 10-14, North	Photoelectric	3912361993
0008	Heat Detector	Custodian room near 12&13, North		3820496794
0009	Smoke Detector	13 East	Photoelectric	3912353592
0010	Smoke Detector	13 West	Photoelectric	3910294149
0011	Smoke Detector	14 East	Photoelectric	3912364932
0012	Smoke Detector	14 West	Photoelectric	3912353561
0013	Smoke Detector	10 North	Photoelectric	3912362389
0014	Smoke Detector	Conference room near 10	Photoelectric	3912350881
0015	Smoke Detector	Nurses office near 10	Photoelectric	3912365083
0016	Smoke Detector	10 South	Photoelectric	3912359099
0017	Smoke Detector	11 West	Photoelectric	3912365007
0018	Smoke Detector	11 East	Photoelectric	3912280423
0019	Smoke Detector	12 West	Photoelectric	3912352182
0020	Smoke Detector	12 East	Photoelectric	3912361665
0021	Smoke Detector	Admin, Workroom	Photoelectric	3912035771
0022	Smoke Detector	Admin, hallway, east	Photoelectric	3912036013
0023	Smoke Detector	Admin, Staff Restroom	Photoelectric	3912035825
0024	Smoke Detector	Admin, Principal's Office	Photoelectric	3912035481
0025	Smoke Detector	Admin, Vice Principal's office.	Photoelectric	3913550723
0026	Smoke Detector	Admin, hallway, west	Photoelectric	3912035573
0028	Smoke Detector	Admin Bldg Secretary's Area	Photoelectric	3976858934
0029	Smoke Detector	principal office	Photoelectric	3912036976
0030	Smoke Detector	Admin, office/storage room	Photoelectric	3912036662
0031	Smoke Detector	K-1 E.	Photoelectric	3950376201
0032	Smoke Detector	K-1, N.W.	Photoelectric	3937676317
0033	Smoke Detector	K-1 S.W.	Photoelectric	3912035351

Address	Device Type	Location	Type	ScanID
0034	Smoke Detector	K-1 Toilet		3912036945
0035	Smoke Detector	K-2 Restroom	Photoelectric	3912035795
0036	Smoke Detector	K-2 West	Photoelectric	3912219553
0037	Smoke Detector	K-2, S.E.	Photoelectric	3913550556
0038	Smoke Detector	K-2 N.E.	Photoelectric	3912036990
0039	Smoke Detector	5 North	Photoelectric	3912035931
0040	Smoke Detector	5 South	Photoelectric	3912282052
0041	Smoke Detector	6 North	Photoelectric	3912364529
0042	Smoke Detector	6 South	Photoelectric	3912361016
0043	Smoke Detector	7 South	Photoelectric	3912358931
0044	Smoke Detector	7 North.	Photoelectric	3910307726
0045	Smoke Detector	8 North	Photoelectric	3912361962
0046	Smoke Detector	8 South	Photoelectric	3912279410
0047	Smoke Detector	9 South	Photoelectric	3912279922
0048	Smoke Detector	9 North	Photoelectric	3912359105
0049	Smoke Detector	2 N.W.	Photoelectric	3912358948
0050	Smoke Detector	2 N.E.	Photoelectric	3912360279
0051	Smoke Detector	2 Restroom	Photoelectric	3912279250
0052	Smoke Detector	2 S.W.	Photoelectric	3912359020
0053	Smoke Detector	3 South	Photoelectric	3912359013
0054	Smoke Detector	3 North	Photoelectric	3912364949
0055	Smoke Detector	4 North	Photoelectric	3912356005
0056	Smoke Detector	4 South	Photoelectric	3912279502
0057	Smoke Detector	Restroom bldng, Boy's SE	Photoelectric	3912361658
0058	Heat Detector	mens restroom southeast	Rate-of-Rise	3820494257
0059	Heat Detector	Womens restroom southeast	Rate-of-Rise	3820501245
0060	Smoke Detector	Restroom bldng, Girl's SE	Photoelectric	3912279267
0061	Smoke Detector	P2 East restroom.	Photoelectric	3910318432
0062	Smoke Detector	P2 West Restroom	Photoelectric	3912280935
0063	Smoke Detector	P2 East	Photoelectric	3912361573
0064	Smoke Detector	P2 West	Photoelectric	3912280942
0065	Smoke Detector	P1 East Restroom	Photoelectric	3908959777
0066	Smoke Detector	P1 West Restroom	Photoelectric	3912280300
0067	Smoke Detector	P1 East	Photoelectric	3912282076
0068	Smoke Detector	P1 West	Photoelectric	3912357996
0127	Heat Detector	Attic 12 SW	Rate-of-Rise	04100108
0127	Heat Detector	Attic Custodial Closet by 12 & 13		16426833
0127	Heat Detector	Attic Custodial Closet by 12&13 North (Hatch)		16426878
0127	Heat Detector	attic room13 west		16426760
0127	Heat Detector	Attic Lower 12 NE		16426851
0127	Heat Detector	Attic Lower attic room 13 SE		16426682
0127	Heat Detector	Attic Upper 13 #1	Combination	16426863
0127	Heat Detector	Attic hatch 13 Outside east boy's	Combination	61242149
0127	Heat Detector	Attic upper 12 #1 (NW)	Combination	16426841

Address	Device Type	Location	Type	ScanID
0127	Heat Detector	Attic upper 12 #2 (SW)	Combination	69500026
0127	Heat Detector	Attic upper 12 #3	Combination	16426595
0127	Heat Detector	Attic upper 12 #4 (SE)	Combination	69500024
0127	Heat Detector	Attic upper 12 #5 (NE)	Combination	69500025
0127	Heat Detector	Attic upper 12 #6 (NE)	Combination	16426862
0127	Heat Detector	Attic upper 13 #2 (NW)	Combination	16426855
0127	Heat Detector	Attic upper 13 #3	Combination	69500033
0127	Heat Detector	Attic upper 13 #4	Combination	16426848
0127	Heat Detector	Attic upper 13 #5 (NW)	Combination	16426856
0127	Heat Detector	Attic upper 13 #6	Combination	16426881
0127	Heat Detector	Attic upper 13 Outside east Girl's #1 (high NW, clockwise)		69500042
0127	Heat Detector	Attic upper 13 Outside east Girl's #10		69500038
0127	Heat Detector	Attic upper 13 Outside east Girl's #2		69500036
0127	Heat Detector	Attic upper 13 Outside east Girl's #3		69500040
0127	Heat Detector	Attic upper 13 Outside east Girl's #4		69500043
0127	Heat Detector	Attic upper 13 Outside east Girl's #5		69500037
0127	Heat Detector	Attic upper 13 Outside east Girl's #6		69500044
0127	Heat Detector	Attic upper 13 Outside east Girl's #7 (lower, SW counterclockwise)		69500035
0127	Heat Detector	Attic upper 13 Outside east Girl's #8		69500039
0127	Heat Detector	Attic upper 13 Outside east Girl's #9		61242148
0128	Heat Detector	10 #12 (lower NE)		16426873
0128	Heat Detector	Attic heat room10 southeast	Rate-of-Rise	16426875
0128	Heat Detector	Attic room10 west		16426824
0128	Heat Detector	Attic Lower 10 NE		16426831
0128	Heat Detector	Attic Lower 10 NW		16426822
0128	Heat Detector	Attic Lower 11 East		16426608
0128	Heat Detector	Attic Lower 11 West		16426843
0128	Heat Detector	Attic Lower 14		16426828
0128	Heat Detector	Attic upper 10 #1 (NE)		16426582
0128	Heat Detector	Attic upper 10 #10 (lower)		16426592
0128	Heat Detector	Attic upper 10 #11 (lower)		16426842
0128	Heat Detector	Attic upper 10 #2		16426587
0128	Heat Detector	Attic upper 10 #3		16426861
0128	Heat Detector	Attic upper 10 #4		16426844
0128	Heat Detector	Attic upper 10 #5		16426847
0128	Heat Detector	Attic upper 10 #6		16426866
0128	Heat Detector	Attic upper 10 #7		16426867
0128	Heat Detector	Attic upper 10 #8 (SE)		16426870
0128	Heat Detector	Attic upper 10 #9 (lower SE)		16426868
0128	Heat Detector	Attic upper 11 #1 (NE)	Combination	69500030
0128	Heat Detector	Attic upper 11 #2 (SE)	Combination	16426880
0128	Heat Detector	Attic upper 11 #3	Combination	69500029
0128	Heat Detector	Attic upper 11 #4 (SW)	Combination	16426877

Address	Device Type	Location	Type	ScanID
0128	Heat Detector	Attic upper 11 #5 (NW)	Combination	69500027
0128	Heat Detector	Attic upper 11 #6	Combination	16426872
0128	Heat Detector	Attic upper 14 #1	Combination	16426714
0128	Heat Detector	Attic upper 14 #2 (NE)	Combination	16426602
0128	Heat Detector	Attic upper 14 #3	Combination	16426871
0128	Heat Detector	Attic upper 14 #4	Combination	16426876
0128	Heat Detector	Attic upper 14 #5 (SW)	Combination	16426857
0128	Heat Detector	Attic upper 14 #6	Combination	16426882
0146	Heat Detector	ADMIN secritary office		16426758
0146	Heat Detector	Admin		04100316
0146	Heat Detector	Admin		16426897
0146	Heat Detector	Admin		16426903
0146	Heat Detector	Admin		16426914
0146	Heat Detector	Admin		16426927
0146	Heat Detector	Admin		16426930
0146	Heat Detector	Admin		16426935
0146	Heat Detector	Admin		16426937
0146	Heat Detector	Admin		16426943
0146	Heat Detector	Admin		16426952
0146	Heat Detector	Admin		16426955
0146	Heat Detector	Admin		16426958
0146	Heat Detector	Admin		16426968
0147	Heat Detector	K2		16426928
0147	Heat Detector	K2 Southeast		16426890
0147	Heat Detector	K2 northwest		16426939
0147	Heat Detector	KINDERGARTEN		16426934
0147	Heat Detector	KINDERGARTEN		16426942
0147	Heat Detector	KINDERGARTEN		16426945
0147	Heat Detector	KINDERGARTEN		16426954
0147	Heat Detector	KINDERGARTEN		16426983
0148	Pull Station	Admin, by FACP	Dual Action	20413646
0150	Heat Detector	classroom 5		16426910
0151	Heat Detector	classroom 6		16426911
0151	Heat Detector	room 7 Attic		16426889
0152	Heat Detector	room 8 Attic		16426918
0152	Heat Detector	room 9	Rate-of-Rise	16426900
0154	Heat Detector	Northeast classroom 2 Attic		16426909
0154	Heat Detector	south classroom 2 Attic		16426887
0154	Heat Detector	southwest classroom 2 Attic		16426883
0155	Heat Detector	room 4 Attic		16426892
0155	Heat Detector	Southwest room 3 Attic		16426885
0158	Heat Detector	North P 2 Attic		16426895
0158	Heat Detector	South P 1 Attic		16426901
0158	Heat Detector	South P 2 Attic		16426919
0251	Smoke Detector	Library Building, Counselors office	Photoelectric	3912359396

Address	Device Type	Location	Type	ScanID
0252	Smoke Detector	20 (Library Building) West	Photoelectric	3969842186
0253	Smoke Detector	20 East	Photoelectric	3912279823
0254	Smoke Detector	20 (Library) South	Photoelectric	3912365106
0255	Smoke Detector	Library Building, Classroom 19, South.	Photoelectric	3912287989
0256	Smoke Detector	Library Building Classroom 19 West	Photoelectric	3912364857
0257	Smoke Detector	Library Building, Classroom 19 East	Photoelectric	3912279571
0258	Smoke Detector	Library Building, Classroom 18 N.E.	Photoelectric	3912279656
0259	Smoke Detector	Library Building, Classroom 18 S.E.	Photoelectric	3912365137
0260	Smoke Detector	Library Building, Classroom 18 West	Photoelectric	3912037010
0261	Smoke Detector	Library Building, Classroom 17 West	Photoelectric	3912364901
0262	Smoke Detector	Library Building, Classroom 17 N.E.	Photoelectric	3912358993
0263	Smoke Detector	Library Building, Classroom 17 S.E.	Photoelectric	3912359501
0264	Smoke Detector	Library Building, East entry	Photoelectric	3912359419
0265	Smoke Detector	Library Building, PE room	Photoelectric	3912364833
0266	Smoke Detector	Library Building, Speech room	Photoelectric	3912365144
0267	Smoke Detector	Library room 16, S.E.	Photoelectric	3910235920
0268	Smoke Detector	Northeast Library Building, Classroom 16	Photoelectric	3912279458
0269	Smoke Detector	Northwest Library Building, Classroom 16	Photoelectric	3912364895
0270	Smoke Detector	Library Building, Classroom 15 North.	Photoelectric	3912035542
0271	Smoke Detector	Library Building, Classroom 15 S.E.	Photoelectric	3928038285
0272	Smoke Detector	Library Building, Classroom 15 S.W.	Photoelectric	3912036921
0273	Smoke Detector	Library Building, Classroom 22 S.W.	Photoelectric	3912035917
0274	Smoke Detector	Northwest Library Building, Classroom 22	Photoelectric	3912035979
0275	Smoke Detector	Library Building, Classroom 22 N.E.	Photoelectric	3912219119
0276	Smoke Detector	Library Building, Classroom 21 S.E.	Photoelectric	3912219508
0277	Smoke Detector	southwest Library Building, Classroom 21	Photoelectric	3912035894
0278	Smoke Detector	Library Building, Classroom 21 N.W.	Photoelectric	3912035498
0279	Smoke Detector	Library Building, west entry	Photoelectric	3912038680
0280	Smoke Detector	Library Building, Electrical room	Photoelectric	3912035924
0281	Heat Detector	16 East		04100235
0281	Heat Detector	16 NW		16426777
0281	Heat Detector	16 SW		16426765
0281	Heat Detector	16 SW		16426778
0281	Heat Detector	19		16426827
0281	Heat Detector	19		16426869
0281	Heat Detector	22 NE		16426808
0281	Smoke Detector	Library Building, Library NORTH-WEST	Photoelectric	20413671
0281	Heat Detector	library supply storage		16426860
0282	Smoke Detector	Library Building, Library NORTH-EAST	Photoelectric	20413668
0283	Smoke Detector	Library Building, Library CENTER-EAST	Photoelectric	20413667
0284	Smoke Detector	Library Building, Library CENTER-WEST	Photoelectric	20413670
0285	Smoke Detector	Library Building, Library SOUTH-WEST	Photoelectric	20413669
0286	Smoke Detector	Library Building, Library SOUTH-EAST	Photoelectric	20413666
0287	Smoke Detector	Cafeteria telephone room	Photoelectric	3912219164
0288	Smoke Detector	MU Men's	Photoelectric	3912035467

Address	Device Type	Location	Type	ScanID
0289	Smoke Detector	MU Women's		3944428343
0290	Heat Detector	MU Staff Lounge Above Sink		3820496862
0291	Smoke Detector	cafeteria teacher dining west	Photoelectric	3937699385
0292	Smoke Detector	cafeteria teacher dining east	Photoelectric	3912036761
0295	Heat Detector	MU corridor by Kitchen Dry Storage		3820505984
0296	Smoke Detector	MU Kitchen Dry Storage	Photoelectric	3912219195
0297	Heat Detector	MU Custodial Office	Rate-of-Rise	3815261260
0298	Smoke Detector	MU KITCHEN office	Photoelectric	3912035818
0298	Smoke Detector	cafeteria storage Riser room		3912035399
0299	Smoke Detector	Cafeteria music storage room, north	Photoelectric	3912035559
300	Smoke Detector	Cafeteria music Storage South		3976839087
0301	Heat Detector	MU Stage, North		3820505120
0302	Heat Detector	Above MU, Stage, South		3820504857
0303	Smoke Detector	MU Stage Electrical Room	Photoelectric	3912037003
0304	Smoke Detector	MU Lift by Stage	Photoelectric	3912035511
0308	Smoke Detector	Staff Restroom near 23&28	Photoelectric	3912279830
0309	Smoke Detector	Girl's near 23&28	Photoelectric	3912360194
0310	Smoke Detector	28 South	Photoelectric	3912358979
0311	Smoke Detector	28 North	Photoelectric	3912279335
0312	Smoke Detector	29 South	Photoelectric	3912359129
0313	Smoke Detector	29 North	Photoelectric	3912280782
0314	Smoke Detector	30 South	Photoelectric	3912279694
0315	Smoke Detector	30 North	Photoelectric	3912280041
0316	Smoke Detector	31 South	Photoelectric	3912281079
0317	Smoke Detector	31 North	Photoelectric	3912279618
0318	Smoke Detector	32 South	Photoelectric	3912279359
0319	Smoke Detector	32 North	Photoelectric	3912280010
0320	Smoke Detector	Teachers workroom near 27&32	Photoelectric	3912280430
0321	Smoke Detector	27 North		3927465594
0322	Smoke Detector	27 South	Photoelectric	3912280201
0323	Smoke Detector	26 North	Photoelectric	3912359136
0324	Smoke Detector	26 South	Photoelectric	3912280546
0325	Smoke Detector	25 North Building E.		3976386703
0326	Smoke Detector	25 South	Photoelectric	3912365045
0327	Smoke Detector	24 North	Photoelectric	3912281802
0328	Smoke Detector	24South	Photoelectric	3912280263
0329	Smoke Detector	23 North	Photoelectric	3912359068
0330	Smoke Detector	23 South	Photoelectric	3912359723
0331	Smoke Detector	Boy's near 23&28	Photoelectric	3912279984
332	Heat Detector	custodian room 116		3820504840
0377	Heat Detector	19		16426802
0377	Heat Detector	19 Attic		16426764
0377	Heat Detector	library room 18NE attic Attic		16426769
0377	Heat Detector	library room 18NW attic Attic		16426797
0377	Heat Detector	library speech		16426781

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 2				
377	Heat Detector	East 17 Attic		16426782
Zone/Circuit: 02				
0377	Heat Detector	West 17 Attic		16426854
0377	Heat Detector	library room 18 SE Attic		16426684
0377	Heat Detector	library room 18 sw Attic		16426799
0378	Heat Detector	21 Attic		16426773
0378	Heat Detector	21 Attic		16426798
0378	Heat Detector	room 22NW attic		16426774
0378	Heat Detector	room 22sw attic		16426820
0378	Heat Detector	North 15 Attic		16426785
0378	Heat Detector	South 15 Attic		16426815
0378	Heat Detector	library room 22sw		16426807
0380	Pull Station	Library building, South-East Exit		20413655
0381	Pull Station	Library building, Nort-West Exit	Dual Action	20413654
0385	Beam Detector	MU SOUTH		20413657
0386	Beam Detector	MU NORTH		20413656
0387	Waterflow Switch	MP Steel Chair Storage ITV: Backstage		07257546
0388	Tamper Switch	Cafeteria in storage room. Building C.		07257545
0390	Heat Detector	MU KITCHEN DISH WASHROOM		14227388
0391	Heat Detector	MU KITCHEN NORTH		14227428
0392	Heat Detector	MU KITCHEN CENTER		14227387
0393	Pull Station	MP North Exit		20413651
0394	Pull Station	MP Stage, north east	Dual Action	20413652
Zone/Circuit: 2				
0394	Strobe	MU, Stage, North		16425934
Zone/Circuit: 02				
0395	Pull Station	MP Stage, South		20413653
0396	Pull Station	MP SE		20413650
0397	Pull Station	MP Southwest Exit	Dual Action	20413647
0399	Heat Detector	South Bldg E unisex restroom. Attic		16426905
0400	Heat Detector	Attic 20 East.		16426859
0400	Heat Detector	Attic 20 East.		16427167
0400	Heat Detector	Attic 23 West.		16427137
0400	Heat Detector	Attic 24 West..		16426965
0400	Heat Detector	Attic 26 West.		16426974
0400	Heat Detector	Attic 27 East.		16426964
0400	Heat Detector	Attic 27 West.		16426967
0400	Heat Detector	Attic East 24		16427136
0400	Heat Detector	Attic East 26		16426972
0400	Heat Detector	attic East 26		16427163
0400	Heat Detector	West 25 Attic		16426971
0400	Heat Detector	West 32 Attic	Rate-of-Rise	04100299
0401	Heat Detector	Attic 28 East.		16426884
0401	Heat Detector	Attic 28 West.		04100244

Address	Device Type	Location	Type	ScanID
0401	Heat Detector	Attic 28 West.		16426960
0401	Heat Detector	Attic 29 East.		16426973
0401	Heat Detector	Attic 29 West.		16426976
0401	Heat Detector	Attic 30 East.		16426977
0401	Heat Detector	Attic 30 West.		16426978
0401	Heat Detector	Attic 31 East.		16426961
0401	Heat Detector	Attic 31 West		16426962
0401	Heat Detector	East 32 Attic		16426975

Fire/Life Safety System Inspection, Testing and/or Maintenance Certificate

For

WoodBridge Lodi USD
1290 Lilac St
Lodi, CA 95240

This inspection was performed in accordance with NFPA 101, EDITION 2012, LIFE SAFETY CODE, NFPA 72, EDITION 2010, FIRE ALARM SYSTEMS and/or other regulatory standards applicable to this inspection.

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Completion Date
Sep 8, 2022

Building: WoodBridge Lodi USD

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information

Address: 1290 Lilac St

Address:

City/State/ZIP Code: Lodi, CA 95240

Country: United States of America

System Control Unit

Model Number: Quickstart

Install Date: 12/20/2007

IDC Style:

Software Version:

Version Date: 12/20/2007

SLC Style:

Location: Electrical/Custodial Room

Current Protection:

NAC Style:

Central Station Signal Verification

Test Time/Date: 9/8/22 6:35:35 PM

Restore Time:

Note: Line 1: 29 Second
Trouble / 13 Second Restore
Line 2: 32 Second Trouble /
14 Second Restore

Inspection Completion Date: Sep 8, 2022					
Building: WoodBridge Lodi USD					
EC 02.03.05 EP 02		Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Waterflow Switch	2	2	0	2	2
EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Duct Detector	1	1	0	1	1
Heat Detector	19	19	0	19	52
Pull Station	5	5	0	5	5
Smoke Detector	127	127	0	127	127
EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Horn	19	19	0	19	19
Horn/Strobe	63	63	0	63	63
Releasing Device	7	7	0	7	7
EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
EC 02.03.05 EP 20		Annual operation and full closure of sliding and rolling fire and smoke barrier doors for proper operation and full closure. NFPA 80-2010 5.2.14.3; NFPA 105-2010 5.2.1; 5.2.2			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
LS 02.01.34 EP 02		Protected master fire alarm control panel			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Control Panel	1	1	0	1	1
LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
Devices	Tested This Quarter	Pass	Fail	Tested YTD (2022)	Total Quantity
Battery	17	13	4	17	17
Power Supply	7	7	0	7	7
Total Device Count: 308					

Inspection & Testing

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD

The Inspection & Testing section lists all of the items inspected in your building, which are then categorized by the applicable code reference. The most recent inspection is listed in the far right column and is based on the Finish Date of that inspection. The latest inspection uploaded in each previous quarter appears in the four columns to the left.
Passed=P, Failed=F, Replaced=R

EC 02.03.05 EP 02 Six-month testing of tamper switches and vane-type and pressure-type water-flow devices. Quarterly testing of mechanical water-flow devices. NFPA 72-2010 Table 14.4.5; NFPA 25-2011 Table 5.1.1.2.

Vane-type and pressure switch-type waterflow alarm devices shall be tested semiannually. Per NFPA 25, Section 5.3.3.1, mechanical waterflow alarm devices shall be tested quarterly. Water shall be flowed through an inspector's test connection indicating the flow of water equal to that from a single sprinkler of the smallest orifice size installed in the system for wet-pipe systems, or an alarm test bypass connection for dry-pipe, pre-action, or deluge systems. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14j))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Waterflow Switch	2	2	0	2	2
Device Type	Location	ScanID	Address	Q3/22	
Waterflow Switch	West Outside multi purpose room	56280581	1	09/08-P	
Waterflow Switch	West Outside multi purpose room	61242168	1	09/08-P	
Device Total: 2 Return to Executive Summary					

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
The detector shall be tested by introducing smoke, other aerosol, or an optical filter into the beam path. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.7))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Beam Detector	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Beam Detector	multi purpose room east		08467811	1-02 145	09/07-P
Beam Detector	multi purpose room west		08467810	1-02 150	09/07-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
In addition to testing in place to ensure smoke entry into the sensing chamber and an alarm response, duct smoke detectors utilizing sampling tubes shall be tested by verifying the correct pressure differential (within the manufacturer's published ranges) between the inlet and exhaust tubes using a method acceptable to the manufacturer to ensure that the device will properly sample the airstream. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g. 6))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Duct Detector	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Duct Detector	Above Boiler room(Roof), East of main building		20413802	1-02 054	09/08-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 03	Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5
-------------------	---

Restorable: Heat test shall be performed with a heat source per the manufacturer's published instructions. Non-Restorable: Heat tests shall not be performed. Functionality shall be tested mechanically and electrically. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14d))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
---------	--------------	------------	------------	-------------------	----------------

Heat Detector	19	19	0	19	52
---------------	----	----	---	----	----

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	admin storage room	09162710	1-02 085	09/08-P
Heat Detector	attic heat classroom 12 east	08467839	1	
Heat Detector	attic heat classroom 12 west	08467838	1	
Heat Detector	attic heat classroom 13 east	08467841	1	
Heat Detector	attic heat classroom 13 west	08467840	1	
Heat Detector	attic heat classroom 7	08467735	1	09/07-P
Heat Detector	attic heat classroom 8	08467734	1	09/07-P
Heat Detector	attic heat classroom 8	08467736	1	09/07-P
Heat Detector	attic heat computer lab	08467732	1	09/07-P
Heat Detector	attic heat computer lab	08467733	1	
Heat Detector	attic heat counselor room	08467724	1	
Heat Detector	attic heat food service room	08467718	1	09/07-P
Heat Detector	attic heat library	08467731	1	09/07-P
Heat Detector	attic heat library	08467730	1	09/07-P
Heat Detector	attic heat next to fax machine in office	08467728	1	09/07-P
Heat Detector	attic heat office copy machine room	08467719	1	09/07-P
Heat Detector	attic heat office entrance	08467727	1	09/07-P
Heat Detector	attic heat office file room	08467726	1	09/07-P
Heat Detector	attic heat office hallway copy machine	08467723	1	
Heat Detector	attic heat office hallway mail room	08467722	1	
Heat Detector	attic heat office mens restroom	08467720	1	
Heat Detector	attic heat office storage	08467725	1	09/07-P
Heat Detector	attic heat office womens restroom	08467721	1	
Heat Detector	attic heat principal office	08467729	1	09/07-P
Heat Detector	back of class 09 storage room west	08467791	1-02 0027	
Heat Detector	class 09 above ceiling tiles .	08467789	1	
Heat Detector	class 15 above ceiling tiles top of projector	08467843	1	
Heat Detector	class 16 above ceiling tiles top of projector	08467842	1	
Heat Detector	class 19 above ceiling tiles near screen	08467758	1-02 132	
Heat Detector	class 19 above ceiling tiles top of projector	08467759	1-02 132	
Heat Detector	class 20 above ceiling tiles near projector	08467756	1-02 133	
Heat Detector	class 20 above ceiling tiles near screen	08467757	1-02 133	
Heat Detector	class 21 above ceiling tiles near projector	08467755	1-02 134	

Device Type	Location	ScanID	Address	Q3/22
Heat Detector	class 21 above ceiling tiles near screen	08467754	1-02 134	
Heat Detector	class 22 above ceiling tiles near projector	08467752	1	
Heat Detector	class 22 above ceiling tiles near screen	08467753	1	
Heat Detector	class 23 above ceiling tiles near projector	08467751	1	
Heat Detector	class 23 above ceiling tiles near screen	08467750	1	
Heat Detector	class 24 above ceiling tiles near projector	08467748	1	
Heat Detector	class 24 above ceiling tiles near screen	08467749	1	
Heat Detector	food service room north	08467717	1-02 040	09/08-P
Heat Detector	food service room south	44812909	1-2 41	09/08-P
Heat Detector	hallway above ceiling conference room	08467738	1	
Heat Detector	inside of class 16 storage room	09162715	1-01 129	
Heat Detector	mechanical RM	09162717	1-02 093	09/08-P
Heat Detector	multi purpose room storage north end	08467807	1-02 037	09/08-P
Heat Detector	near main fire control panel	09162713	1-01 126	09/08-P
Heat Detector	East class 10 above ceiling tiles .	08467787	1	
Heat Detector	N/W class 10 above ceiling tiles .	08467785	1	
Heat Detector	back of class 09 storage room east	08467790	1	
Heat Detector	centerroom class 10 above ceiling tiles .	08467786	1	
Heat Detector	restroom class 10 above ceiling tiles .	08467788	1	
Device Total: 52 Return to Executive Summary				

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Manual fire alarm boxes shall be operated per the manufacturer's published instructions. Key-operated presignal and general alarm manual fire alarm boxes shall both be tested. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14e))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Pull Station	5	5	0	5	5
Device Type	Location		ScanID	Address	Q3/22
Pull Station	front door		08467663	1-02 142	09/07-P
Pull Station	inside reception area of main admin.		08467662	1-02 140	09/07-P
Pull Station	inside room 24		08467704	1-02 164	09/08-P
Pull Station	multi purpose room		20413801	1-02 137	09/07-P
Pull Station	near stage storage room		08467664	1-02 141	09/07-P
Device Total: 5		Return to Executive Summary			

EC 02.03.05 EP 03		Annual testing of duct detectors, heat detectors, manual fire alarm boxes, and smoke detectors. NFPA 72-2010 Table 14.4.5			
Smoke detectors/smoke alarms shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response. Sensitivity shall be checked every alternate year. Any of the following tests shall be performed to ensure that each smoke detector is within its listed and marked sensitivity range: 1) Calibrated test method, 2) Manufacturer's calibrated sensitivity test instrument, 3) Listed control equipment arranged for the purpose, 4) Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range, 5) Other calibrated sensitivity test method approved by the authority having jurisdiction. (2010 ed.) (NFPA 72 Table 14.4.2.2 (14g.1); 14.4.5.3.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Smoke Detector	127	127	0	127	127
Device Type	Location		ScanID	Address	Q3/22
Smoke Detector	1st hallway 3 kitchen		3603725837	1-2 77	09/08-P
Smoke Detector	Reception area		08467615	1-02 084	09/07-P
Smoke Detector	boys restroom north		08467673	1-02 047	09/08-P
Smoke Detector	boys restroom south		08467502	1-01 017	09/08-P
Smoke Detector	bridge program rm		08467585	1-02 035	09/07-P
Smoke Detector	bridge program rm		08467584	1-02 034	09/07-P
Smoke Detector	bridge program rm		08467583	1-02 072	09/07-P
Smoke Detector	classroom 3 southeast		08467506	1-01 034	09/08-P
Smoke Detector	classroom 3 northeast		08467505	1-01 016	09/08-P
Smoke Detector	classroom 3 northwest		08467504	1-01 015	09/08-P
Smoke Detector	classroom 3 southwest		08467507	1-01 033	09/08-P
Smoke Detector	classroom 1 southeast		08467512	1-01 025	09/08-P
Smoke Detector	classroom 1 southwest		08467513	1-01 027	09/08-P
Smoke Detector	classroom 1 northeast		08467515	1-01 026	09/08-P
Smoke Detector	classroom 1 northwest		08467514	1-01 028	09/08-P
Smoke Detector	classroom 10 north		08467676	1-02 012	09/08-P
Smoke Detector	classroom 10 restroom		08467677	1-02 014	09/08-P
Smoke Detector	classroom 10 south		08467674	1-02 013	09/08-P
Smoke Detector	classroom 10 south		08467675	1-02 022	09/08-P
Smoke Detector	classroom 11 restroom		08467671	1-02 003	09/08-P
Smoke Detector	classroom 11east		08467628	1-02 002	09/08-P
Smoke Detector	classroom 11west		08467627	1-02 001	09/08-P
Smoke Detector	classroom 12 east		08467629	1-02 005	09/08-P
Smoke Detector	classroom 12 west		08467630	1-02 004	09/08-P
Smoke Detector	classroom 13 east		08467632	1-02 007	09/08-P
Smoke Detector	classroom 13 west		08467631	1-02 006	09/08-P
Smoke Detector	classroom 14 east		08467633	1-02 009	09/08-P
Smoke Detector	classroom 14 south		08467708	1	09/08-P
Smoke Detector	classroom 14 west		08467634	1-02 008	09/08-P
Smoke Detector	classroom 15		08467642	1-01 005	09/08-P
Smoke Detector	classroom 15 west		08467705	1-01 006	09/08-P
Smoke Detector	classroom 16 east		08467706	1-01 003	09/08-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	classroom 17 south	08467639	1-01 002	09/08-P
Smoke Detector	classroom 18 front	08467707	1-01 038	09/08-P
Smoke Detector	classroom 18 north	08467637	1-01 035	09/08-P
Smoke Detector	classroom 18 south	3980642802	1-01 036	09/08-P
Smoke Detector	classroom 19 north	08467688	1-02 023	09/08-P
Smoke Detector	classroom 19 south	08467687	1-02 024	09/08-P
Smoke Detector	classroom 2 southwest	08467511	1-01 029	09/08-P
Smoke Detector	classroom 2 northeast	08467509	1-01 032	09/08-P
Smoke Detector	classroom 2 southeast	08467510	1-01 030	09/08-P
Smoke Detector	classroom 2 northwest	08467508	1-01 031	09/08-P
Smoke Detector	classroom 20 north	08467689	1-02 025	09/08-P
Smoke Detector	classroom 20 south	08467690	1-02 026	09/08-P
Smoke Detector	classroom 21 north	08467694	1-02 027	09/08-P
Smoke Detector	classroom 21 south	08467693	1-02 028	09/08-P
Smoke Detector	classroom 22 north	08467695	1-02 029	09/08-P
Smoke Detector	classroom 22 south	08467696	1-02 030	09/08-P
Smoke Detector	classroom 23 north	08467700	1-02 031	09/08-P
Smoke Detector	classroom 23 south	08467699	1-02 032	09/08-P
Smoke Detector	classroom 24 north	08467701	1-02 095	09/08-P
Smoke Detector	classroom 24 south	08467702	1-02 094	09/08-P
Smoke Detector	classroom 4 northeast	08467525	1-01 023	09/08-P
Smoke Detector	classroom 4 northeast	44812964	1-1 21	09/08-P
Smoke Detector	classroom 4 northwest	08467524	1-01 022	09/08-P
Smoke Detector	classroom 4 southeast	08467526	1-01 021	09/08-P
Smoke Detector	classroom 4 southwest	08467527	1-01 020	09/08-P
Smoke Detector	classroom 5 northwest	08467521	1-01 008	09/08-P
Smoke Detector	classroom 5 southeast	08467523	1-01 007	09/08-P
Smoke Detector	classroom 5 southwest	08467522	1-01 024	09/08-P
Smoke Detector	classroom 5 northeast	08467520	1-01 009	09/08-P
Smoke Detector	classroom 6 southeast	08467518	1-01 011	09/08-P
Smoke Detector	classroom 6 northeast	08467517	1-01 013	09/08-P
Smoke Detector	classroom 6 southwest	08467519	1-01 010	09/08-P
Smoke Detector	classroom 6 northwest	08467516	1-01 012	09/08-P
Smoke Detector	classroom 7 east	08467594	1-02 058	09/07-P
Smoke Detector	classroom 7 west .	08467593	1-02 057	09/07-P
Smoke Detector	classroom 8 south	08467596	1-02 056	09/07-P
Smoke Detector	classroom 8 north	08467595	1-02 055	09/07-P
Smoke Detector	classroom 9 front door	08467683	1-02 016	09/08-P
Smoke Detector	classroom 9 middle	08467681	1-02 021	09/08-P
Smoke Detector	classroom 9 north	08467680	1-02 010	09/08-P
Smoke Detector	classroom 9 office	08467684	1-02 017	09/08-P
Smoke Detector	classroom 9 restroom north	08467678	1-02 019	09/08-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	classroom 9 restroom south	08467679	1-02 018	09/08-P
Smoke Detector	classroom 9 south	08467682	1-02 011	09/08-P
Smoke Detector	computer lab north	08467591	1-02 059	09/07-P
Smoke Detector	computer lab south	08467592	1-02 060	09/07-P
Smoke Detector	counselor office	08467616	1-02 083	09/07-P
Smoke Detector	data room next to psychologist rm	08467586	1-02 033	09/07-P
Smoke Detector	data room south	08467501	1-01 014	09/08-P
Smoke Detector	food service room office	08467715	1-02 039	09/07-P
Smoke Detector	girls restroom north	08467672	1-02 015	09/08-P
Smoke Detector	girls restroom south	08467503	1-01 018	09/08-P
Smoke Detector	hallway 2	08467607	1-02 078	09/08-P
Smoke Detector	hallway 3	08467606	1-02 077	09/08-P
Smoke Detector	hallway 4	08467605	1-02 076	09/08-P
Smoke Detector	hallway 5 outside administration	08467604	1-02 071	09/08-P
Smoke Detector	hallway 6	08467603	1-02 070	09/08-P
Smoke Detector	hallway 10	08467599	1-02 066	09/07-P
Smoke Detector	hallway 11	08467598	1-02 065	09/07-P
Smoke Detector	hallway 12 at north exit	08467597	1-02 064	09/07-P
Smoke Detector	hallway 7	08467602	1-02 069	09/08-P
Smoke Detector	hallway 8	08467601	1-02 068	09/08-P
Smoke Detector	hallway 9	08467600	1-02 067	09/07-P
Smoke Detector	hallway 1 at south exit I	08467608	1-02 079	09/08-P
Smoke Detector	hallway near data and psychologist room	09162712	1-02 073	09/08-P
Smoke Detector	inside front door	3980642420	1-02 074	09/07-P
Smoke Detector	library center	08467589	1-02 062	09/07-P
Smoke Detector	library north	08467590	1-02 063	09/07-P
Smoke Detector	library south	08467588	1-02 061	09/07-P
Smoke Detector	near main fire control panel	08467528	1-01 019	09/08-P
Smoke Detector	nurse office	08467610	1-02 048	09/07-P
Smoke Detector	nurse office restroom	08467609	1-02 089	09/07-P
Smoke Detector	office hallway	08467614	1-02 086	09/07-P
Smoke Detector	office hallway between restrooms	08467621	1-02 092	09/07-P
Smoke Detector	office mail area	08467619	1-02 080	09/07-P
Smoke Detector	office mens room	08467622	1-02 050	09/07-P
Smoke Detector	office womens restroom	08467620	1-02 049	09/07-P
Smoke Detector	outside principals office	08467612	1-02 051	09/07-P
Smoke Detector	principal office	08467611	1-02 088	09/07-P
Smoke Detector	private office	08467613	1-02 087	09/07-P
Smoke Detector	psychologist room	08467587	1-02 090	09/07-P
Smoke Detector	safety patrol room	08467581	1-02 075	09/07-P
Smoke Detector	staff room	08467623	1-02 091	09/07-P
Smoke Detector	staff office	08467618	1-02 082	09/07-P

Device Type	Location	ScanID	Address	Q3/22
Smoke Detector	staff office work area	08467617	1-02 081	09/07-P
Smoke Detector	stage east 1	08467804	1-01 044	09/07-P
Smoke Detector	stage east 2	08467805	1-01 043	09/07-P
Smoke Detector	stage east 3	08467806	1-01 042	09/07-P
Smoke Detector	stage storage room	08467800	1-02 053	09/07-P
Smoke Detector	stage west 1	08467801	1-01 052	09/07-P
Smoke Detector	stage west 2	08467802	1-01 046	09/07-P
Smoke Detector	stage west 3	08467803	1-01 045	09/07-P
Smoke Detector	Northeast classroom 18 storage	08467636	1-01 037	09/08-P
Smoke Detector	Southeast classroom 18 storage	08467635	1-01 039	09/08-P
Smoke Detector	West classroom 16	08467641	1-01 004	09/08-P
Device Total: 127 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Bell	2	2	0	2	2
Device Type	Location		ScanID	Address	Q3/22
Bell	West Outside multi purpose room		09162714	1	09/08-P
Bell	West Outside multi purpose room		61242167	1	09/08-P
Device Total: 2		Return to Executive Summary			

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18 where building, system, or occupancy changes have occurred. The sound level meter shall be set in accordance with ANSI S3.41, American National Standard Audible Evacuation Signal, using the time-weighted characteristic F (FAST). (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn	19	19	0	19	19
Device Type	Location		ScanID	Address	Q3/22
Horn	outside across class 21		08467537	1	09/08-P
Horn	outside class 10		08467539	1	09/08-P
Horn	outside class 14		08467532	1	09/08-P
Horn	outside class 21		08467538	1	09/08-P
Horn	outside class 24		08467536	1	09/08-P
Horn	outside class16		08467530	1	09/08-P
Horn	outside front door		08467542	1	09/08-P
Horn	outside front driveway		08467541	1	09/08-P
Horn	outside lunch area		08467540	1	09/08-P
Horn	outside lunch area		08467529	1	09/08-P
Horn	outside near bikecycle stand		08467544	1	09/08-P
Horn	outside near class 2 and 3		09162711	1	09/08-P
Horn	outside near class 3		08467546	1	09/08-P
Horn	outside near class 5		08467547	1	09/08-P
Horn	outside near lunch area		08467531	1	09/08-P
Horn	outside near main sprinkler system		08467543	1	09/08-P
Horn	outside near playground		08467534	1	09/08-P
Horn	outside playground		08467533	1	09/08-P
Horn	outside south door		08467545	1	09/08-P
Device Total: 19 Return to Executive Summary					

EC 02.03.05 EP 04	Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5
-------------------	---

Audibles: Periodic Testing shall comply with the following: Sound pressure levels shall be measured with a sound level meter meeting ANSI S1.4a, Specifications for Sound Level Meters, Type 2 requirements. Sound pressure levels throughout the protected area shall be measured to confirm that they are in compliance with Chapter 18.

Visibles: Test shall be performed in accordance with the manufacturer's published instructions. (2010 ed.) (NFPA 72 Table 14.4.2.2 (15a,c))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Horn/Strobe	63	63	0	63	63

Device Type	Location	ScanID	Address	Q3/22
Horn/Strobe	4th At computer room	08467552	1	09/08-P
Horn/Strobe	Boiler Room, near psychologist room	09162716	1	09/08-P
Horn/Strobe	Conference room	08467566	1	09/08-P
Horn/Strobe	boys restroom	08467549	1	09/08-P
Horn/Strobe	boys restroom north	08467656	1	09/08-P
Horn/Strobe	by bridge program rm	08467560	1	09/08-P
Horn/Strobe	classroom 1	08467670	1	09/08-P
Horn/Strobe	classroom 10	08467657	1	09/08-P
Horn/Strobe	classroom 19	08467686	1	09/08-P
Horn/Strobe	classroom 2	08467669	1	09/08-P
Horn/Strobe	classroom 20	08467691	1	09/08-P
Horn/Strobe	classroom 21	08467692	1	09/08-P
Horn/Strobe	classroom 22	08467697	1	09/08-P
Horn/Strobe	classroom 23	08467698	1	09/08-P
Horn/Strobe	classroom 24	08467703	1	09/08-P
Horn/Strobe	classroom 3	08467668	1	09/08-P
Horn/Strobe	classroom 4	08467667	1	09/08-P
Horn/Strobe	classroom 9	08467661	1	09/08-P
Horn/Strobe	classroom 9 office	08467685	1	09/08-P
Horn/Strobe	classroom 11	08467654	1	09/08-P
Horn/Strobe	classroom 11 restroom	08467653	1	09/08-P
Horn/Strobe	classroom 12	08467652	1	09/08-P
Horn/Strobe	classroom 13	08467651	1	09/08-P
Horn/Strobe	classroom 14	08467650	1	09/08-P
Horn/Strobe	classroom 15	08467649	1	09/08-P
Horn/Strobe	classroom 16	08467648	1	09/08-P
Horn/Strobe	classroom 17	08467647	1	09/08-P
Horn/Strobe	classroom 18	08467643	1	09/08-P
Horn/Strobe	classroom 5	08467666	1	09/08-P
Horn/Strobe	classroom 6	08467665	1	09/08-P
Horn/Strobe	classroom 8	08467554	1	09/08-P
Horn/Strobe	classroom7	08467553	1	09/08-P
Horn/Strobe	east end stage	08467796	1	09/08-P

Device Type	Location	ScanID	Address	Q3/22
Horn/Strobe	girls restroom north	08467655	1	09/08-P
Horn/Strobe	girls restroom south	08467548	1	09/08-P
Horn/Strobe	hallway next to sliding emergency gate	08467556	1	09/08-P
Horn/Strobe	hallway north exit	08467555	1	09/08-P
Horn/Strobe	inside classroom 10 restroom	08467658	1	09/08-P
Horn/Strobe	inside classroom 9 restroom north	08467660	1	09/08-P
Horn/Strobe	inside classroom 9 restroom south	08467659	1	09/08-P
Horn/Strobe	inside food service room	08467573	1	09/08-P
Horn/Strobe	library north	08467551	1	09/08-P
Horn/Strobe	library south	08467550	1	09/08-P
Horn/Strobe	multi purpose room north	08467798	1	09/08-P
Horn/Strobe	multi purpose room south	08467799	1	09/08-P
Horn/Strobe	nurse office	08467561	1	09/08-P
Horn/Strobe	nurses restroom	09162719	1	09/08-P
Horn/Strobe	office between mens and womens restroom	08467571	1	09/08-P
Horn/Strobe	office hallway	08467567	1	09/08-P
Horn/Strobe	office room	08467564	1	09/08-P
Horn/Strobe	office room	08467568	1	09/08-P
Horn/Strobe	office womens restroom	08467570	1	09/08-P
Horn/Strobe	outside administration	08467559	1	09/08-P
Horn/Strobe	outside conference room	08467558	1	09/08-P
Horn/Strobe	outside custodial room	08467569	1	09/08-P
Horn/Strobe	outside food service room	08467574	1	09/08-P
Horn/Strobe	outside nurse room	08467563	1	09/08-P
Horn/Strobe	principal office	08467562	1	09/08-P
Horn/Strobe	psychologist rm	08467557	1	09/08-P
Horn/Strobe	reception area	08467565	1	09/08-P
Horn/Strobe	staff room	08467572	1	09/08-P
Horn/Strobe	stage storage room	08467797	1	09/08-P
Horn/Strobe	west end stage	08467795	1	09/08-P
Device Total: 63 Return to Executive Summary				

EC 02.03.05 EP 04		Annual test of visual and audible fire alarms, including speakers and door-releasing devices. NFPA 72-2010 Table 14.4.5			
Emergency control functions (i.e. fan control, smoke damper operation, elevator recall, elevator power shutdown, door holder release, shutter release, door unlocking, etc.) shall be tested by operating or simulating alarm signals. (2010 ed.) (NFPA 72 Table 14.4.2.2 (23))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Releasing Device	7	7	0	7	7
Device Type	Location		ScanID	Address	Q3/22
Releasing Device	Reception area		09162709	1	09/08-P
Releasing Device	inside food service room		08467575	1	09/08-P
Releasing Device	multi purpose across PE/music room		08467580	1	09/07-P
Releasing Device	multi purpose across food service		08467577	1	09/08-P
Releasing Device	multi purpose across food service		08467578	1	09/08-P
Releasing Device	multi purpose across main door		08467579	1	09/07-P
Releasing Device	North inside food service room		08467576	1	09/08-P
Device Total: 7 Return to Executive Summary					

EC 02.03.05 EP 05		Annual test of fire alarm equipment for notifying off-site fire responders. NFPA 72-2010 Table 14.4.5			
Test shall be performed on all system functions and features in accordance with the equipment manufacturer's published instructions for correct operation in conformance with the applicable sections of Chapter 26. Initiating device shall be actuated. Receipt of the correct initiating device signal at the supervising station within 90 seconds shall be verified. Upon completion of the test, the system shall be restored to its functional operating condition. (2010 ed.) (NFPA 72 Table 14.4.2.2 (19a))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Communicator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Communicator	Electrical/Custodial Room		45703850	1	09/08-P
Device Total: 1 Return to Executive Summary					

EC 02.03.05 EP 20		Annual operation and full closure of sliding and rolling fire and smoke barrier doors for proper operation and full closure. NFPA 80-2010 5.2.14.3; NFPA 105-2010 5.2.1; 5.2.2			
All horizontal or vertical sliding and rolling fire doors shall be inspected and tested annually to check for proper operation and full closure. Emergency control functions (i.e. fan control, smoke damper operation, elevator recall, elevator power shutdown, door holder release, shutter release, door unlocking, etc.) shall be tested by operating or simulating alarm signals. (2010 ed.) (NFPA 80 Section 5.2.14.3; NFPA 72 Table 14.4.2.2)					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Roll Down Door	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Roll Down Door	Reception area		09162708	1	09/08-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 02						Protected master fire alarm control panel						
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))												
Devices			Tested Q3/22		Pass Q3/22		Fail Q3/22		Tested YTD (2022)		Total Quantity	
Control Panel			1		1		0		1		1	
Device Type			Location				ScanID		Address		Q3/22	
Control Panel			Electrical/Custodial Room				05657206		1		09/08-P	
Device Total: 1			Return to Executive Summary									

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5			
The correct operation and identification of annunciators shall be verified. If provided, the correct operation of annunciator under a fault condition shall be verified. (2010 ed.) (NFPA 72 Table 14.4.2.2 (11))					
Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Annunciator	1	1	0	1	1
Device Type	Location		ScanID	Address	Q3/22
Annunciator	Main Admin		08474595	1	09/07-P
Device Total: 1 Return to Executive Summary					

LS 02.01.34 EP 10

All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5

Annually - With the batteries fully charged and connected to the charger, the voltage across the batteries shall be measured with a voltmeter. Semi-annually, under load, the battery shall perform in accordance with the battery manufacturer's specifications. (2010 ed.) (NFPA 72 Table 14.4.2.2 (6d.1,2))

Devices	Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Battery	17	13	4	17	17
Device Type	Location	ScanID	Address	Q3/22	
Battery	Classroom 11 (restroom)	45703859	1	09/08-P	
Battery	Classroom 11 (restroom)	45703860	1	09/08-P	
Battery	Classroom 15	45703862	1	09/08-F	
Battery	Classroom 15	45703861	1	09/08-F	
Battery	Classroom 19	45703855	1	09/08-P	
Battery	Classroom 19	45703856	1	09/08-P	
Battery	Classroom 24	45703857	1	09/08-P	
Battery	Classroom 24	45703858	1	09/08-P	
Battery	Classroom 9_Outside Storage (North)	45703853	1	09/08-P	
Battery	Classroom 9_Outside Storage (North)	45703854	1	09/08-P	
Battery	Data room next to Psychologist room	45703851	1	09/08-P	
Battery	Data room next to Psychologist room	45703852	1	09/08-P	
Battery	Electrical/Custodial Room	45703846	1	09/08-P	
Battery	Electrical/Custodial Room	45703847	1	09/08-P	
Battery	Electrical/Custodial Room BPS by FACP	45703849	1	09/08-F	
Battery	Electrical/Custodial Room BPS by FACP	45703848	1	09/08-F	
Battery	Electrical/Custodial Room Dailer	05657212	1	09/08-P	
Device Total: 17					Return to Executive Summary

LS 02.01.34 EP 10		All other Life Safety Code fire alarm requirements related to NFPA 101-2012 18/19.3.4 and NFPA 72-2010 Table 14.4.5				
At a minimum, control equipment shall be tested to verify correct receipt of alarm, supervisory and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults, and power supply supervision for detection of loss of ac power and disconnection of secondary batteries. (2010 ed.) (NFPA 72 Table 14.4.2.2 (1.a))						
Devices		Tested Q3/22	Pass Q3/22	Fail Q3/22	Tested YTD (2022)	Total Quantity
Device Type		Location		ScanID	Address	Q3/22
Power Supply		Classroom 15		08467644	1	09/08-P
Power Supply		Classroom 24		08467760	1	09/08-P
Power Supply		Classroom 9_Outside Storage (North)		08467792	1	09/08-P
Power Supply		Data Rm next Psychologist Rm		08467626	1	09/08-P
Power Supply		Electrical/Custodial Room		05657209	1	09/08-P
Power Supply		inside classroom 19		08467712	1	09/08-P
Device Total: 7 Return to Executive Summary						

Service Summary

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD

Device Type	Service	Quantity
<i>Failed/Other</i>		
		4
<i>Passed</i>		
		1
Battery	Tested	13
Beam Detector	Annual	2
Bell	Annual	2
Communicator	Annual	1
Control Panel	Annual	1
Duct Detector	Annual	1
Heat Detector	Annual	19
Horn/Strobe	Annual	63
Horn	Annual	19
Power Supply	Annual	7
Pull Station	Annual	5
Releasing Device	Annual	7
Roll Down Door	Annual	1
Smoke Detector	Annual	127
Waterflow Switch	Tested	2
		271
<i>Untested</i>		

Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD		Control Panel: 1 - EST Quickstart		
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
<i>Passed</i>				
Releasing Device				
	Reception area	Passed	09162709	☐
	inside food service room	Passed	08467575	☐
	multi purpose across PE/music room	Passed	08467580	☐
	multi purpose across food service	Passed	08467577	☐
	multi purpose across food service	Passed	08467578	☐
	multi purpose across main door	Passed	08467579	☐
	North inside food service room	Passed	08467576	☐
Roll Down Door				
	Reception area	Passed	09162708	☐

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD				Control Panel: 1 - EST Quickstart			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	Classroom 11 (restroom)	7Ah	12V	13.2	12.9	80%	100%
Sealed Lead Acid	Classroom 19	7Ah	12V	13.3	12.9	80%	100%
Sealed Lead Acid	Classroom 19	7Ah	12V	13.3	13	80%	100%
Sealed Lead Acid	Classroom 24	7Ah	12V	13.4		80%	80%
Sealed Lead Acid	Classroom 24	7Ah	12V	13.4		80%	80%
Sealed Lead Acid	Classroom 9_Outside Storage (North)	7Ah	12V	13.3	13	80%	100%
Sealed Lead Acid	Data room next to Psychologist room	7Ah	12V	13.2	12.9	80%	90%
Sealed Lead Acid	Data room next to Psychologist room	7Ah	12V	13.2	12.9	80%	90%
Sealed Lead Acid	Electrical/Custodial Room	18Ah	12V	13.4		80%	100%
Sealed Lead Acid	Electrical/Custodial Room	18Ah	12V	13.5		80%	100%
Sealed Lead Acid	Electrical/Custodial Room Dailer	7Ah	12V	13.5	13.2	80%	100%
Failed/Other							
Lead Acid	Classroom 15	7Ah	12V	13		80%	70%
Sealed Lead Acid	Electrical/Custodial Room BPS by FACP	7Ah	12V	13.1		80%	60%
Sealed Lead Acid	Electrical/Custodial Room BPS by FACP	7Ah	12V	13.1		80%	90%
Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Power Supply							
Passed							

Protection Type	Location	Rated Ah	Rated Volts		Charging Voltage		
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
<i>Passed</i>							
	Classroom 9_Outside Storage (North)	7Ah	12V	13.3	13	80%	100%

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD	Control Panel: 1 - EST Quickstart
-------------------------------	-----------------------------------

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Battery	Control	5.52%	17
Beam Detector	Initiating	0.65%	2
Bell	Indicating	0.65%	2
Communicator	Control	0.32%	1
Control Panel	Control	0.32%	1
Duct Detector	Initiating	0.32%	1
Heat Detector	Initiating	16.88%	52
Horn	Indicating	6.17%	19
Horn/Strobe	Indicating	20.45%	63
Power Supply	Control	2.27%	7
Pull Station	Initiating	1.62%	5
Releasing Device	Auxiliary	2.27%	7
Roll Down Door	Auxiliary	0.32%	1
Smoke Detector	Initiating	41.23%	127
Waterflow Switch	Initiating	0.65%	2

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 3 Years to 5 Years

Power-Sonic

Yuasa

In Service - 5 Years to 10 Years

Power-Sonic

Battery	1	PS-1270	Sealed Lead Acid	06/12/2018
duracell				

Duracell ultra

Durcell

In Service - 10 Years to 15 Years

Yuasa

Battery	2	NP7-12	Sealed Lead Acid	06/25/2013
<i>In Service - 15 Years to 25 Years</i>				
Beam Detector	2			12/20/2007
EST				
Annunciator	1	EST2	LCD Display	12/20/2007
Control Panel	1	Quickstart		12/20/2007
Duct Detector	1			12/20/2007
Edward.				
Horn/Strobe	1	G1F HDVM		12/20/2007
Edwards				
Heat Detector	1	sig a hrs		12/20/2007
Horn	19	2459		12/20/2007
Horn/Strobe	62	G1F HDVM		12/20/2007
Power Supply	3	BPS		12/20/2007
Power Supply	1	BPS6		12/20/2007
Power Supply	2	bps6		12/20/2007
Power Supply	1	s3424		12/20/2007
Pull Station	4	BG 12L		12/20/2007
Releasing Device	1			12/20/2007
Releasing Device	5	1504 AQN5		12/20/2007
Releasing Device	1	1504AQN5		12/20/2007
Roll Down Door	1			12/20/2007
Smoke Detector	127	sig a ps		12/20/2007
Potter				
Bell	2	PB- 24-10P		12/20/2007
Waterflow Switch	2			12/20/2007
Silent Knight				
Communicator	1	5104b		12/20/2007
edwards				
Heat Detector	2	est		12/20/2007
Heat Detector	3	sig a hrs		12/20/2007
fire lite				
Pull Station	1	gb 12		12/20/2007
thermo				
Heat Detector	1	302		12/20/2007
thermotech				
Heat Detector	44	302 194		12/20/2007
thermtech				
Heat Detector	1	302		12/20/2007

Zone Address Report

Generated by: BuildingReports.com

Building: WoodBridge Lodi USD			Control Panel: 1 - EST Quickstart	
The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.				
Address	Device Type	Location	Type	ScanID
Zone/Circuit: 01				
002	Smoke Detector	classroom 17 south		08467639
003	Smoke Detector	classroom 16 east		08467706
004	Smoke Detector	West classroom 16		08467641
005	Smoke Detector	classroom 15		08467642
006	Smoke Detector	classroom 15 west		08467705
007	Smoke Detector	classroom 5 southeast		08467523
008	Smoke Detector	classroom 5 northwest		08467521
009	Smoke Detector	classroom 5 northeast		08467520
010	Smoke Detector	classroom 6 southwest		08467519
011	Smoke Detector	classroom 6 southeast		08467518
012	Smoke Detector	classroom 6 northwest		08467516
013	Smoke Detector	classroom 6 northeast		08467517
014	Smoke Detector	data room south		08467501
015	Smoke Detector	classroom 3 northwest		08467504
016	Smoke Detector	classroom 3 norhest		08467505
017	Smoke Detector	boys restroom south		08467502
018	Smoke Detector	girls restroom south		08467503
019	Smoke Detector	near main fire control panel		08467528
020	Smoke Detector	classroom 4 southwest		08467527
Zone/Circuit: 1				
21	Smoke Detector	classroom 4 northeast		44812964
Zone/Circuit: 01				
021	Smoke Detector	classroom 4 southeast		08467526
022	Smoke Detector	classroom 4 northwest		08467524
023	Smoke Detector	classroom 4 northeast		08467525
024	Smoke Detector	classroom 5 southwest		08467522
025	Smoke Detector	classroom 1 southeast		08467512
026	Smoke Detector	classroom 1 northeast		08467515
027	Smoke Detector	classroom 1 southwest		08467513
028	Smoke Detector	classroom 1 northwest		08467514
029	Smoke Detector	classroom 2 southwest		08467511
030	Smoke Detector	classroom 2 southeast		08467510
031	Smoke Detector	classroom 2 northwest		08467508
032	Smoke Detector	classroom 2 northeast		08467509
033	Smoke Detector	classroom 3 southwest		08467507
034	Smoke Detector	classroom 3 southeast		08467506

Address	Device Type	Location	Type	ScanID
035	Smoke Detector	classroom 18 north		08467637
036	Smoke Detector	classroom 18 south		3980642802
037	Smoke Detector	Northeast classroom 18 storage		08467636
038	Smoke Detector	classroom 18 front		08467707
039	Smoke Detector	Southeast classroom 18 storage		08467635
042	Smoke Detector	stage east 3		08467806
043	Smoke Detector	stage east 2		08467805
044	Smoke Detector	stage east 1		08467804
045	Smoke Detector	stage west 3		08467803
046	Smoke Detector	stage west 2		08467802
052	Smoke Detector	stage west 1		08467801
126	Heat Detector	near main fire control panel		09162713
129	Heat Detector	inside of class 16 storage room		09162715
Zone/Circuit: 02				
001	Smoke Detector	classroom 11west		08467627
002	Smoke Detector	classroom 11east		08467628
003	Smoke Detector	classroom 11 restroom		08467671
004	Smoke Detector	classroom 12 west		08467630
005	Smoke Detector	classroom 12 east		08467629
006	Smoke Detector	classroom 13 west		08467631
007	Smoke Detector	classroom 13 east		08467632
008	Smoke Detector	classroom 14 west		08467634
009	Smoke Detector	classroom 14 east		08467633
010	Smoke Detector	classroom 9 north		08467680
011	Smoke Detector	classroom 9 south		08467682
012	Smoke Detector	classroom 10 north		08467676
013	Smoke Detector	classroom 10 south		08467674
014	Smoke Detector	classroom 10 restroom		08467677
015	Smoke Detector	girls restroom north		08467672
016	Smoke Detector	classroom 9 front door		08467683
017	Smoke Detector	classroom 9 office		08467684
018	Smoke Detector	classroom 9 restroom south		08467679
019	Smoke Detector	classroom 9 restroom north		08467678
021	Smoke Detector	classroom 9 middle		08467681
022	Smoke Detector	classroom 10 south		08467675
023	Smoke Detector	classroom 19 north		08467688
024	Smoke Detector	classroom 19 south		08467687
025	Smoke Detector	classroom 20 north		08467689
026	Smoke Detector	classroom 20 south		08467690
0027	Heat Detector	back of class 09 storage room west		08467791
027	Smoke Detector	classroom 21 north		08467694
028	Smoke Detector	classroom 21 south		08467693
029	Smoke Detector	classroom 22 north		08467695
030	Smoke Detector	classroom 22 south		08467696
031	Smoke Detector	classroom 23 north		08467700

Address	Device Type	Location	Type	ScanID
032	Smoke Detector	classroom 23 south		08467699
033	Smoke Detector	data room next to psychologist rm		08467586
034	Smoke Detector	bridge program rm		08467584
035	Smoke Detector	bridge program rm		08467585
037	Heat Detector	multi purpose room storage north end		08467807
039	Smoke Detector	food service room office		08467715
040	Heat Detector	food service room north		08467717
Zone/Circuit: 2				
41	Heat Detector	food service room south		44812909
Zone/Circuit: 02				
047	Smoke Detector	boys restroom north		08467673
048	Smoke Detector	nurse office		08467610
049	Smoke Detector	office womens restroom		08467620
050	Smoke Detector	office mens room		08467622
051	Smoke Detector	outside principals office		08467612
053	Smoke Detector	stage storage room		08467800
054	Duct Detector	Above Boiler room(Roof), East of main building		20413802
055	Smoke Detector	classroom 8 north		08467595
056	Smoke Detector	classroom 8 south		08467596
057	Smoke Detector	classroom 7 west .		08467593
058	Smoke Detector	classroom 7 east		08467594
059	Smoke Detector	computer lab north		08467591
060	Smoke Detector	computer lab south		08467592
061	Smoke Detector	library south		08467588
062	Smoke Detector	library center		08467589
063	Smoke Detector	library north		08467590
064	Smoke Detector	hallway 12 at north exit		08467597
065	Smoke Detector	hallway 11		08467598
066	Smoke Detector	hallway 10		08467599
067	Smoke Detector	hallway 9		08467600
068	Smoke Detector	hallway 8		08467601
069	Smoke Detector	hallway 7		08467602
070	Smoke Detector	hallway 6		08467603
071	Smoke Detector	hallway 5 outside administration		08467604
072	Smoke Detector	bridge program rm		08467583
073	Smoke Detector	hallway near data and psychologist room		09162712
074	Smoke Detector	inside front door		3980642420
075	Smoke Detector	safety patrol room		08467581
076	Smoke Detector	hallway 4		08467605
Zone/Circuit: 2				
77	Smoke Detector	1st hallway 3 kitchen		3603725837
Zone/Circuit: 02				
077	Smoke Detector	hallway 3		08467606
078	Smoke Detector	hallway 2		08467607

Address	Device Type	Location	Type	ScanID
079	Smoke Detector	hallway 1 at south exit I		08467608
080	Smoke Detector	office mail area		08467619
081	Smoke Detector	staff office work area		08467617
082	Smoke Detector	staff office		08467618
083	Smoke Detector	counselor office		08467616
084	Smoke Detector	Reception area		08467615
085	Heat Detector	admin storage room		09162710
086	Smoke Detector	office hallway		08467614
087	Smoke Detector	private office		08467613
088	Smoke Detector	principal office		08467611
089	Smoke Detector	nurse office restroom		08467609
090	Smoke Detector	psychologist room		08467587
091	Smoke Detector	staff room		08467623
092	Smoke Detector	office hallway between restrooms		08467621
093	Heat Detector	mechanical RM		09162717
094	Smoke Detector	classroom 24 south		08467702
095	Smoke Detector	classroom 24 north		08467701
132	Heat Detector	class 19 above ceiling tiles near screen		08467758
132	Heat Detector	class 19 above ceiling tiles top of projector		08467759
133	Heat Detector	class 20 above ceiling tiles near projector		08467756
133	Heat Detector	class 20 above ceiling tiles near screen		08467757
134	Heat Detector	class 21 above ceiling tiles near projector		08467755
134	Heat Detector	class 21 above ceiling tiles near screen		08467754
137	Pull Station	multi purpose room		20413801
140	Pull Station	inside reception area of main admin.		08467662
141	Pull Station	near stage storage room		08467664
142	Pull Station	front door		08467663
145	Beam Detector	multi purpose room east		08467811
150	Beam Detector	multi purpose room west		08467810
164	Pull Station	inside room 24		08467704