



March 25, 2024

North Kansas City School District
2000 Northeast 46th Street
Kansas City, Missouri 64116

Project: Limited Lead in Drinking Water Testing
Address: 515 Northeast 106th Street, Kansas City, Missouri 64155

On January 15, 2024, Bradly Young of Axiom Service Professionals (ASP), conducted lead in drinking water sampling at the above referenced address. Inspector certification is provided in Appendix A. A total of 58 samples were collected from various potential drinking water outlets including sources used for drinking, cooking, or cleaning of cooking and eating utensils throughout the building.

Drinking Water Standards

The use of lead solder and other lead-containing materials as defined in the EPA Safe Drinking Water Act in connecting household plumbing to public water supplies was prohibited as of 1986. The act established the definition of "lead free" to be less than 8% as a weighted average across wetted surfaces of a pipe, pipe fitting, plumbing fitting, and fixture and 0.2% lead for solder and flux. In 2011, the definition of "lead free" as it applied to wetted surfaces of a pipe, pipe fitting, and plumbing fitting and fixture was reduced from 8% to 0.25% as a weighted average. Many older structures still have lead pipe or lead-soldered plumbing internally, which may substantially increase the lead content of water at the tap. Nationwide regulations controlling the lead content of drinking-water coolers in schools went into effect in 1989.

In 1991, the EPA published the Lead and Copper Rule establishing limits on the amount of lead and copper in drinking water. This regulation can be found under 40 CFR Part 141, Subpart I. Reference: <https://www.epa.gov/dwreginfo/lead-and-copper-rule>

The EPA has set lead in drinking water standards as outlined below.

- For lead, the maximum contaminant level goal (MCLG) is zero. This is the levels determined to be safe by toxicological and biomedical considerations, independent of feasibility. EPA's National Primary Drinking Water Regulations for Lead establish a treatment level of **0.015 mg/L** or **15 ppb** (parts per billion) in municipal drinking water systems.

The Missouri Senate Bill 681 “Get the Lead Out of School Drinking Water Act”, passed in 2022, has set the standard summarized below.

Reference: https://www.senate.mo.gov/22info/BTS_Web/Bill.aspx?SessionType=R&BillID=71259862

- On or before January 1, 2024, each school shall conduct an inventory of all drinking water outlets and all outlets that are used for dispensing water for cooking or for cleaning cooking and eating utensils in each of the school's buildings. A plan for testing should then be developed, prioritizing early childhood education programs and elementary schools, and made available to the public.
- The bill outlines that beginning in the 2023-2024 school year and for each subsequent school year, each school shall provide drinking water with a lead concentration below five parts per billion (**5 ppb**). Any school with greater than or equal to 5 ppb shall provide results and remediation plans to parents and staff within 7 business days of receiving results.

Drinking Fountain Identification

Drinking fountains throughout the school were visually assessed to determine if they matched those listed by the EPA to be lead-containing. The list of drinking fountains reported by the EPA to contain lead-lined holding tanks or solder joints is presented as Appendix B. Below is a list of drinking fountains within the school that match those reported by the EPA to be lead-containing.

Location	Make	Model #	Serial #
None Matching			

Water Sampling Methods:

Water samples were collected from each selected location as “first draw” and/or “flush”. First draw samples typically represent worst case sample results. A flush sample is typically collected to determine if an elevation is originating beyond the fixture in the fixture supply line or beyond. Samples were deposited into a non-preserved 250-milliliter sterile Nalgene screw top bottle. Immediately following sample collection, the samples were delivered to Keystone Laboratories located at 8857 Long Street, Lenexa, Kansas 66215. Upon arrival at the laboratory, samples were preserved through addition of nitric acid.

Keystone Laboratories is accredited through the Missouri Department of Natural Resources for analysis of lead in water.

Below is a summary of the water sampling results as reported in Appendix C by Keystone Laboratories. Results exceeding the applicable drinking water standards are shown in **red text**.

January 15, 2024 Water Sampling Results:

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
515-1-FD	New Mark Middle School - Room 100	Sink Tap	First Draw	<0.4
515-2-FD	New Mark Middle School - Nurse's Office	Sink Tap	First Draw	<0.4
515-3-FD	New Mark Middle School - Library	Sink Tap	First Draw	<0.4
515-4-FD	New Mark Middle School - Room 108	Sink Tap	First Draw	<0.4
515-5-FD	New Mark Middle School - Outside 203-Left	Drinking Fountain	First Draw	<0.4
515-6-FD	New Mark Middle School - Outside 203-Middle	Drinking Fountain	First Draw	<0.4
515-7-FD	New Mark Middle School - Outside 203-Right	Drinking Fountain	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
515-8-FD	New Mark Middle School - Room 203	Sink Tap	First Draw	<0.4
515-9-FD	New Mark Middle School - Room 213	Sink Tap	First Draw	0.9
515-10-FD	New Mark Middle School - Room 304	Sink Tap	First Draw	<0.4
515-11-FD	New Mark Middle School - Room 505	Sink Tap	First Draw	0.4
515-12-FD	New Mark Middle School - Room 503-Left	Sink Tap	First Draw	0.4
515-13-FD	New Mark Middle School - Room 503-Right	Sink Tap	First Draw	0.9
515-14-FD	New Mark Middle School - Room 504	Sink Tap	First Draw	0.7
515-15-FD	New Mark Middle School - Girls Locker Room	Drinking Fountain	First Draw	<0.4
515-16-FD	New Mark Middle School - Boys Locker Room	Drinking Fountain	First Draw	<0.4
515-17-FD	New Mark Middle School - Outside 412-Left	Drinking Fountain	First Draw	<0.4
515-18-FD	New Mark Middle School - Outside 412-Right	Drinking Fountain	First Draw	<0.4
515-19-FD	New Mark Middle School - Room 411-North Wall-Left	Sink Tap	First Draw	<0.4
515-20-FD	New Mark Middle School - Room 411-North Wall-Right	Sink Tap	First Draw	<0.4
515-21-FD	New Mark Middle School - Room 411-East Wall-Left	Sink Tap	First Draw	<0.4
515-22-FD	New Mark Middle School - Room 411-East Wall-Right	Sink Tap	First Draw	<0.4
515-23-FD	New Mark Middle School - Room 410-West Wall-Left	Sink Tap	First Draw	<0.4
515-24-FD	New Mark Middle School - Room 410-West Wall-Right	Sink Tap	First Draw	<0.4
515-25-FD	New Mark Middle School - Room 410-North Wall-Left	Sink Tap	First Draw	<0.4
515-26-FD	New Mark Middle School - Room 410-North Wall-Right	Sink Tap	First Draw	<0.4
515-27-FD	New Mark Middle School - Outside 410-Left	Drinking Fountain	First Draw	<0.4
515-28-FD	New Mark Middle School - Outside 410-Right	Drinking Fountain	First Draw	<0.4
515-29-FD	New Mark Middle School - Room 500	Sink Tap	First Draw	0.7
515-30-FD	New Mark Middle School - Outside 500-Left	Drinking Fountain	First Draw	<0.4
515-31-FD	New Mark Middle School - Outside 500-Right	Drinking Fountain	First Draw	<0.4
515-32-FD	New Mark Middle School - Room 508	Sink Tap	First Draw	<0.4
515-33-FD	New Mark Middle School - Room 507	Sink Tap	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
515-34-FD	New Mark Middle School - Room 506-Left	Sink Tap	First Draw	<0.4
515-35-FD	New Mark Middle School - Room 506-Right	Sink Tap	First Draw	<0.4
515-36-FD	New Mark Middle School - Room 510-Closest to Door	Sink Tap	First Draw	2.5
515-37-FD	New Mark Middle School - Room 510-Furthest from Door	Sink Tap	First Draw	0.6
515-38-FD	New Mark Middle School - Room 511-Closest to Door	Sink Tap	First Draw	4.4
515-39-FD	New Mark Middle School - Room 511-Furthest from Door	Sink Tap	First Draw	<0.4
515-40-FD	New Mark Middle School - Outside 512-Left	Drinking Fountain	First Draw	<0.4
515-41-FD	New Mark Middle School - Outside 512-Middle	Drinking Fountain	First Draw	<0.4
515-42-FD	New Mark Middle School - Outside 512-Right	Drinking Fountain	First Draw	<0.4
515-43-FD	New Mark Middle School - Room 513-Closest to Door	Sink Tap	First Draw	0.6
515-44-FD	New Mark Middle School - Room 513-Furthest from Door	Sink Tap	First Draw	0.8
515-45-FD	New Mark Middle School - Room 514	Sink Tap	First Draw	0.5
515-46-FD	New Mark Middle School - Kitchen-Three Bay Sink-Left	Sink Tap	First Draw	<0.4
515-47-FD	New Mark Middle School - Kitchen-Three Bay Sink-Right	Sink Tap	First Draw	<0.4
515-48-FD	New Mark Middle School - Kitchen-South Middle Sink	Sink Tap	First Draw	<0.4
515-49-FD	New Mark Middle School - Kitchen	Steam Kettle	First Draw	1.2
515-50-FD	New Mark Middle School - Kitchen-Middle by Steam Kettle	Sink Tap	First Draw	<0.4
515-51-FD	New Mark Middle School - Kitchen-North Middle Sink	Sink Tap	First Draw	0.4
515-52-FD	New Mark Middle School - Kitchen-Closest to Commons	Sink Tap	First Draw	<0.4
515-53-FD	New Mark Middle School - Kitchen	Ice Machine	First Draw	1.3
515-54-FD	New Mark Middle School - Kitchen-By Ice Machine	Sink Tap	First Draw	0.6
515-55-FD	New Mark Middle School - Kitchen-Northwest Sink	Sink Tap	First Draw	1.8
515-56-FD	New Mark Middle School - Commons-Left	Drinking Fountain	First Draw	<0.4
515-57-FD	New Mark Middle School - Commons-Middle	Drinking Fountain	First Draw	<0.4
515-58-FD	New Mark Middle School - Commons-Right	Drinking Fountain	First Draw	<0.4

Photos of the sampling locations are provided in Appendix D. A diagram containing identifiers on the outlets tested is provided in Appendix E.

Required Communication

- Contact staff and parents via written notification within seven (7) business days after receiving the test result.
- The notification shall include at least:
 - The test results and a summary that explains such results;
 - A description of any remedial steps taken; and
 - A description of general health effects of lead contamination and community specific resources; and
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.
- Submit such annual testing results to the Missouri Department of Health and Senior Services (DHSS).
- Before August 1, 2024, or the first day on which students will be present in the building, whichever is later, and annually thereafter, each school shall conduct testing for lead by first-draw and follow-up flush samples of a random sampling of at least twenty-five percent (25%) of remediated drinking water outlets until all remediated sources have been tested as recommended by the 2018 version of the United States Environmental Protection Agency's "Training, Testing, and Taking Action" program. The testing shall be conducted and the results analyzed for both types of tests by an entity or entities approved by the department.
- Any measures taken to remediate any elevated lead levels identified must be recorded and documented.

General Recommendations

- Retesting of all potential cooking and drinking water sources is required five (5) years from previous testing completed.
- If the condition changes or significant alterations to existing plumbing is undertaken, consider performing additional lead in drinking water sampling.
- Ensure that the plumbing system is not used as an electrical ground.
- If equipment is added that could affect water pH, alkalinity, or hardness, consider performing lead in drinking water sampling.

Any work resulting from this report should be conducted in accordance with the EPA Safe Drinking Water Act, Missouri SB 681 & 662, HUD Lead Regulations 24 CFR 35, EPA Lead Regulations 40 CFR 745, and Consumer Product Safety Commission document #5056.

If you have any questions concerning this report, please contact me at 816-678-7894.

Sincerely,



Jeff Hurst
Axiom Service Professionals LLC
jeffh@axiomservicepros.com

Limitations Drinking Water Testing

The presence or absence of lead and copper (if collected) in drinking water applies only to the test locations on the date of the field visit and it should be understood that conditions may change due to deterioration, pH, alkalinity, hardness, use levels, or maintenance. The results noted within this report were accurate at the time of the evaluation and in no way reflect the conditions at the property before or after the date of the evaluation. No other environmental concerns or conditions were addressed during this evaluation.

Appendix A Certifications

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Bradly A. Young

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Inspector
Category of License

Issuance Date: 10/4/2023
Expiration Date: 10/4/2025
License Number: 211004-300006201



Paula F. Nickelson

Paula F. Nickelson
Director

Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey A. Hurst

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **8/1/2022**
Expiration Date: **8/1/2024**
License Number: **000801-200166567**



**Missouri Department of Health
and Senior Services**

Lead Occupation License - ID Badge

License Number:

000801-200166567

Lead Risk Assessor

**Jeffrey
Hurst**

Expiration Date: **8/1/2024**

Paula F. Nickelson

Paula F. Nickelson
Acting Director

Missouri Department of Health and Senior Services

Kansas City, MO 65102

Appendix B
EPA Listed Lead Containing Drinking Fountains

Table C-1
Water Coolers With Other Lead Components

EBCO Manufacturing

- All pressure bubbler water coolers with shipping dates from 1962 through 1977 have a bubbler valve containing lead. The units contain a single, 50-50 tin-lead solder joint on the bubbler valve. Model numbers for coolers in this category are not available.
- The following models of pressure bubbler coolers produced from 1978 through 1981 contain one 50-50 tin-lead solder joint each.

CP3	DP15W	DPM8	7P	13P	DPM8H	DP15M	DP3R	DP8A
DP16M	DP5S	C10E	PX-10	DP7S	DP13SM	DP7M	DP7MH	DP7WD
WTC10	DP13M-60	DP14M	CP10-50	CP5	CP5M	DP15MW	DP3R	DP14S
DP20-50	DP7SM	DP10X	DP13A	DP13A-50	EP10F	DP5M	DP10F	CP3H
CP3-50	DP13M	DP3RH	DP5F	CP3M	EP5F	13PL	DP8AH	DP13S
CP10	DP20	DP12N	DP7WM	DP14A-50/60				

Halsey Taylor

- Lead solder was used in these models of water coolers manufactured between 1978 and the last week of 1987:

WMA-1	SCWT/SCWT-A	SWA-1	DC/DHC-1
S3/5/10D	BFC-4F/7F/4FS/7FS	S300/500/100D	

- The following coolers manufactured for Haws Drinking Faucet Company (Haws) by Halsey Taylor from November 1984 through December 18, 1987 are not lead-free because they contain 2 tin-lead solder joints. The model designations for these units are as follows:

HC8WT	HC14F	HC6W	HWC7D	HC8WTH	HC14FH	HC8W	HC2F	HC14WT
HC14FL	HC14W	HC2FH	HC14WTH	HC8FL	HC4F	HC5F	HC14WL	HCBF7D
HC4FH	HC10F	HC16WT	HCBF7HO	HC8F	HC8FH	HC4W	HWC7	

Table C-2
Halsey Taylor Water Coolers With Lead-Lined Tanks

- The following six model numbers have one or more units in the model series with lead-lined tanks:

WM8A WT8A GC10ACR GC10A GC5A RWM13A

- The following models and serial numbers contain lead-lined tanks:

WM14A Serial No. 843034	WM14A Serial No. 843006	WT11A Serial No. 222650
WT21A Serial No. 64309550	WT21A Serial No. 64309542	LL14A Serial No. 64346908

Appendix C

Laboratory Analytical Report



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

AXIOM Service Professionals

Jeff Hurst
PO Box 47166
Kansas City, MO 64188

Project Name: 515 Northeast 106th Street

Project / PO Number: 515 Northeast 106th Street
Received: 01/26/2024
Reported: 03/08/2024

Analytical Testing Parameters

Client Sample ID: 515-1-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-01

Collected By: Bradley Young
Collection Date: 01/15/2024 13:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1924	RVV

Client Sample ID: 515-2-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-02

Collected By: Bradley Young
Collection Date: 01/15/2024 13:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1927	RVV

Client Sample ID: 515-3-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-03

Collected By: Bradley Young
Collection Date: 01/15/2024 13:26

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1930	RVV

Client Sample ID: 515-4-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-04

Collected By: Bradley Young
Collection Date: 01/15/2024 13:26

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1933	RVV



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-5-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-05

Collected By: Bradley Young
Collection Date: 01/15/2024 13:27

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1936	RVV

Client Sample ID: 515-6-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-06

Collected By: Bradley Young
Collection Date: 01/15/2024 13:27

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1939	RVV

Client Sample ID: 515-7-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-07

Collected By: Bradley Young
Collection Date: 01/15/2024 13:27

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1942	RVV

Client Sample ID: 515-8-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-08

Collected By: Bradley Young
Collection Date: 01/15/2024 13:28

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 1951	RVV

Client Sample ID: 515-9-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-09

Collected By: Bradley Young
Collection Date: 01/15/2024 13:28

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.9	0.4	ppb	2		03/05/24 1519	03/06/24 1954	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-10-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-10

Collected By: Bradley Young
Collection Date: 01/15/2024 13:29

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2003	RVV

Client Sample ID: 515-11-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-11

Collected By: Bradley Young
Collection Date: 01/15/2024 13:29

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2012	RVV

Client Sample ID: 515-12-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-12

Collected By: Bradley Young
Collection Date: 01/15/2024 13:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2015	RVV

Client Sample ID: 515-13-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-13

Collected By: Bradley Young
Collection Date: 01/15/2024 13:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.9	0.4	ppb	2		03/05/24 1519	03/06/24 2018	RVV

Client Sample ID: 515-14-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-14

Collected By: Bradley Young
Collection Date: 01/15/2024 13:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.7	0.4	ppb	2		03/05/24 1519	03/06/24 2027	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-15-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-15

Collected By: Bradley Young
Collection Date: 01/15/2024 13:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2030	RVV

Client Sample ID: 515-16-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-16

Collected By: Bradley Young
Collection Date: 01/15/2024 13:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2033	RVV

Client Sample ID: 515-17-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-17

Collected By: Bradley Young
Collection Date: 01/15/2024 13:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2036	RVV

Client Sample ID: 515-18-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-18

Collected By: Bradley Young
Collection Date: 01/15/2024 13:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2039	RVV

Client Sample ID: 515-19-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-19

Collected By: Bradley Young
Collection Date: 01/15/2024 13:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2042	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-20-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-20

Collected By: Bradley Young
Collection Date: 01/15/2024 13:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2045	RVV

Client Sample ID: 515-21-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-21

Collected By: Bradley Young
Collection Date: 01/15/2024 13:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2048	RVV

Client Sample ID: 515-22-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-22

Collected By: Bradley Young
Collection Date: 01/15/2024 13:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2051	RVV

Client Sample ID: 515-23-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-23

Collected By: Bradley Young
Collection Date: 01/15/2024 13:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2054	RVV

Client Sample ID: 515-24-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-24

Collected By: Bradley Young
Collection Date: 01/15/2024 13:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2103	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-25-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-25

Collected By: Bradley Young
Collection Date: 01/15/2024 13:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2106	RVV

Client Sample ID: 515-26-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-26

Collected By: Bradley Young
Collection Date: 01/15/2024 13:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2109	RVV

Client Sample ID: 515-27-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-27

Collected By: Bradley Young
Collection Date: 01/15/2024 13:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2112	RVV

Client Sample ID: 515-28-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-28

Collected By: Bradley Young
Collection Date: 01/15/2024 13:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2115	RVV

Client Sample ID: 515-29-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-29

Collected By: Bradley Young
Collection Date: 01/15/2024 13:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.7	0.4	ppb	2		03/05/24 1519	03/06/24 2118	RVV



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-30-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-30

Collected By: Bradley Young
Collection Date: 01/15/2024 13:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2127	RVV

Client Sample ID: 515-31-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-31

Collected By: Bradley Young
Collection Date: 01/15/2024 13:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2142	RVV

Client Sample ID: 515-32-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-32

Collected By: Bradley Young
Collection Date: 01/15/2024 13:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2145	RVV

Client Sample ID: 515-33-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-33

Collected By: Bradley Young
Collection Date: 01/15/2024 13:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2148	RVV

Client Sample ID: 515-34-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-34

Collected By: Bradley Young
Collection Date: 01/15/2024 13:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2151	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-35-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-35

Collected By: Bradley Young
Collection Date: 01/15/2024 13:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2154	RVV

Client Sample ID: 515-36-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-36

Collected By: Bradley Young
Collection Date: 01/15/2024 13:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	2.5	0.4	ppb	2		03/05/24 1519	03/06/24 2157	RVV

Client Sample ID: 515-37-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-37

Collected By: Bradley Young
Collection Date: 01/15/2024 13:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.6	0.4	ppb	2		03/05/24 1519	03/06/24 2200	RVV

Client Sample ID: 515-38-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-38

Collected By: Bradley Young
Collection Date: 01/15/2024 13:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	4.4	0.4	ppb	2		03/05/24 1519	03/06/24 2203	RVV

Client Sample ID: 515-39-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-39

Collected By: Bradley Young
Collection Date: 01/15/2024 13:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2206	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-40-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-40

Collected By: Bradley Young
Collection Date: 01/15/2024 13:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2215	RVV

Client Sample ID: 515-41-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-41

Collected By: Bradley Young
Collection Date: 01/15/2024 13:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2218	RVV

Client Sample ID: 515-42-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-42

Collected By: Bradley Young
Collection Date: 01/15/2024 13:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2221	RVV

Client Sample ID: 515-43-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-43

Collected By: Bradley Young
Collection Date: 01/15/2024 13:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.6	0.4	ppb	2		03/05/24 1519	03/06/24 2224	RVV

Client Sample ID: 515-44-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-44

Collected By: Bradley Young
Collection Date: 01/15/2024 13:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.8	0.4	ppb	2		03/05/24 1519	03/06/24 2227	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-45-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-45

Collected By: Bradley Young
Collection Date: 01/15/2024 13:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.5	0.4	ppb	2		03/05/24 1519	03/06/24 2230	RVV

Client Sample ID: 515-46-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-46

Collected By: Bradley Young
Collection Date: 01/15/2024 13:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2233	RVV

Client Sample ID: 515-47-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-47

Collected By: Bradley Young
Collection Date: 01/15/2024 13:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2236	RVV

Client Sample ID: 515-48-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-48

Collected By: Bradley Young
Collection Date: 01/15/2024 13:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2239	RVV

Client Sample ID: 515-49-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-49

Collected By: Bradley Young
Collection Date: 01/15/2024 13:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.2	0.4	ppb	2		03/05/24 1519	03/06/24 2242	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-50-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-50

Collected By: Bradley Young
Collection Date: 01/15/2024 13:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2256	RVV

Client Sample ID: 515-51-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-51

Collected By: Bradley Young
Collection Date: 01/15/2024 13:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2305	RVV

Client Sample ID: 515-52-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-52

Collected By: Bradley Young
Collection Date: 01/15/2024 13:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2308	RVV

Client Sample ID: 515-53-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-53

Collected By: Bradley Young
Collection Date: 01/15/2024 13:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.3	0.4	ppb	2		03/05/24 1519	03/06/24 2311	RVV

Client Sample ID: 515-54-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-54

Collected By: Bradley Young
Collection Date: 01/15/2024 13:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.6	0.4	ppb	2		03/05/24 1519	03/06/24 2314	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HA0136

Client Sample ID: 515-55-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-55

Collected By: Bradley Young
Collection Date: 01/15/2024 13:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.8	0.4	ppb	2		03/05/24 1519	03/06/24 2317	RVV

Client Sample ID: 515-56-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-56

Collected By: Bradley Young
Collection Date: 01/15/2024 13:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2326	RVV

Client Sample ID: 515-57-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-57

Collected By: Bradley Young
Collection Date: 01/15/2024 13:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2329	RVV

Client Sample ID: 515-58-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HA0136-58

Collected By: Bradley Young
Collection Date: 01/15/2024 13:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		03/05/24 1519	03/06/24 2332	RVV

Definitions

RL: Reporting Limit

Report Comments

Reviewed and Approved By:

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Victoria Bruck
Field Technician II
03/08/24 10:02

Freystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER: <u>Bradley Young</u>		NAME: <u>Jeff Hurst</u>		NAME: <u>Jeff Hurst</u>	
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS: <u>515 Northeast 106th Street</u>		ADDRESS: <u>PO Box 47166</u>		ADDRESS: <u>PO Box 47166</u>	
CITY/ST/ZIP: <u>Kansas City, Missouri 64155</u>		CITY/ST/ZIP: <u>Kansas City, Missouri 64188</u>		CITY/ST/ZIP: <u>Kansas City, Missouri 64188</u>	
PHONE: <u>816-321-4702</u>		PHONE: <u>816-678-7894</u>		PHONE: <u>816-678-7894</u>	
		EMAIL: <u>jeffh@axiomservicepros.com</u>		EMAIL: <u>jeffh@axiomservicepros.com</u>	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	3HA0136
															Short Hold:	
															Rush:	
															Temp:	oC 9.3°C
															Sample Condition	Sample #
515-1-FD	1/15/2024	13:25	New Mark Middle School - Sink Tap - Room 100	1	Wt	Grab	X									01
515-2-FD	1/15/2024	13:25	New Mark Middle School - Sink Tap - Nurse Office	1	Wt	Grab	X									02
515-3-FD	1/15/2024	13:26	New Mark Middle School - Sink Tap - Library	1	Wt	Grab	X									03
515-4-FD	1/15/2024	13:26	New Mark Middle School - Sink Tap - Room 108	1	Wt	Grab	X									04
515-5-FD	1/15/2024	13:27	New Mark Middle School - Drinking Fountain - Outside 203-Left	1	Wt	Grab	X									05
515-6-FD	1/15/2024	13:27	New Mark Middle School - Drinking Fountain - Outside 203-Middle	1	Wt	Grab	X									06
515-7-FD	1/15/2024	13:27	New Mark Middle School - Drinking Fountain - Outside 203-Right	1	Wt	Grab	X									07

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
<u>Bradley Young</u>	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:		<u>Vita Rhr</u>	1/26/24		
				Time:		
				10:20		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	515 Northeast 106th Street	ADDRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Kansas City, Missouri 64155	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-321-4702	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	
															Short Hold:	
															Rush:	
															Temp: oC	
															Sample Condition	Sample #
515-8-FD	1/15/2024	13:28	New Mark Middle School - Sink Tap - Room 203	1	Wt	Grab	X									08
515-9-FD	1/15/2024	13:28	New Mark Middle School - Sink Tap - Room 213	1	Wt	Grab	X									09
515-10-FD	1/15/2024	13:29	New Mark Middle School - Sink Tap - Room 304	1	Wt	Grab	X									10
515-11-FD	1/15/2024	13:29	New Mark Middle School - Sink Tap - Room 505	1	Wt	Grab	X									11
515-12-FD	1/15/2024	13:30	New Mark Middle School - Sink Tap - Room 503- Left	1	Wt	Grab	X									12
515-13-FD	1/15/2024	13:30	New Mark Middle School - Sink Tap - Room 503- Right	1	Wt	Grab	X									13
515-14-FD	1/15/2024	13:30	New Mark Middle School - Sink Tap - Room 504	1	Wt	Grab	X									14

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
						
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:

SAMPLER:

SITE NAME:

ADDRESS: 515 Northeast 106th Street

CITY/ST/ZIP: Kansas City, Missouri 64155

PHONE: 816-321-4702

REPORT TO:

NAME: Jeff Hurst

CO. NAME:

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

BILL TO:

NAME: Jeff Hurst

CO. NAME:

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	Lead	ANALYSES REQUIRED						LAB USE ONLY	
														Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
515-15-FD	1/15/2024	13:32	New Mark Middle School - Drinking Fountain - Girls Locker Room	1	Wt	Grab	X								15
515-16-FD	1/15/2024	13:32	New Mark Middle School - Drinking Fountain - Boys Locker Room	1	Wt	Grab	X								16
515-17-FD	1/15/2024	13:34	New Mark Middle School - Drinking Fountain - Outside 412-Left	1	Wt	Grab	X								17
515-18-FD	1/15/2024	13:34	New Mark Middle School - Drinking Fountain - Outside 412-Right	1	Wt	Grab	X								18
515-19-FD	1/15/2024	13:35	New Mark Middle School - Sink Tap - Room 411- North Wall-Left	1	Wt	Grab	X								19
515-20-FD	1/15/2024	13:35	New Mark Middle School - Sink Tap - Room 411- North Wall-Right	1	Wt	Grab	X								20
515-21-FD	1/15/2024	13:35	New Mark Middle School - Sink Tap - Room 411- East Wall-Left	1	Wt		X								21

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:

SAMPLER: _____

SITE NAME: _____

ADDRESS: 515 Northeast 106th Street

CITY/ST/ZIP: Kansas City, Missouri 64155

PHONE: 816-321-4702

REPORT TO:

NAME: Jeff Hurst

CO. NAME: _____

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

BILL TO:

NAME: Jeff Hurst

CO. NAME: _____

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	Lead	ANALYSES REQUIRED						LAB USE ONLY	
														Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
515-22-FD	1/15/2024	13:35	New Mark Middle School - Sink Tap - Room 411- East Wall-Right	1	Wt	Grab	X								22
515-23-FD	1/15/2024	13:36	New Mark Middle School - Sink Tap - Room 410- West Wall-Left	1	Wt	Grab	X								23
515-24-FD	1/15/2024	13:36	New Mark Middle School - Sink Tap - Room 410- West Wall-Right	1	Wt	Grab	X								24
515-25-FD	1/15/2024	13:36	New Mark Middle School - Sink Tap - Room 410- North Wall-Left	1	Wt	Grab	X								25
515-26-FD	1/15/2024	13:37	New Mark Middle School - Sink Tap - Room 410- North Wall-Right	1	Wt	Grab	X								26
515-27-FD	1/15/2024	13:37	New Mark Middle School - Drinking Fountain - Outside 410-Left	1	Wt	Grab	X								27
515-28-FD	1/15/2024	13:37	New Mark Middle School - Drinking Fountain - Outside 410-Right	1	Wt	Grab	X								28

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:

SAMPLER: _____

SITE NAME: _____

ADDRESS: 515 Northeast 106th Street

CITY/ST/ZIP: Kansas City, Missouri 64155

PHONE: 816-321-4702

REPORT TO:

NAME: Jeff Hurst

CO. NAME: _____

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

BILL TO:

NAME: Jeff Hurst

CO. NAME: _____

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	Lead	ANALYSES REQUIRED						LAB USE ONLY	
														Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
515-29-FD	1/15/2024	13:39	New Mark Middle School - Sink Tap - Room 500	1	Wt	Grab	X								29
515-30-FD	1/15/2024	13:39	New Mark Middle School - Drinking Fountain - Outside 500-Left	1	Wt	Grab	X								30
515-31-FD	1/15/2024	13:39	New Mark Middle School - Drinking Fountain - Outside 500-Right	1	Wt	Grab	X								31
515-32-FD	1/15/2024	13:41	New Mark Middle School - Sink Tap - Room 508	1	Wt	Grab	X								32
515-33-FD	1/15/2024	13:41	New Mark Middle School - Sink Tap - Room 507	1	Wt	Grab	X								33
515-34-FD	1/15/2024	13:41	New Mark Middle School - Sink Tap - Room 506- Left	1	Wt	Grab	X								34
515-35-FD	1/15/2024	13:41	New Mark Middle School - Sink Tap - Room 506- Right	1	Wt	Grab	X								35

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:

SAMPLER:

SITE NAME:

ADDRESS: 515 Northeast 106th Street

CITY/ST/ZIP: Kansas City, Missouri 64155

PHONE: 816-321-4702

REPORT TO:

NAME: Jeff Hurst

CO. NAME:

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

BILL TO:

NAME: Jeff Hurst

CO. NAME:

ADDRESS: PO Box 47166

CITY/ST/ZIP: Kansas City, Missouri 64188

PHONE: 816-678-7894

EMAIL: jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	Lead	ANALYSES REQUIRED							LAB USE ONLY	
															Wk Order #:	
															Short Hold:	
															Rush:	
															Temp: oC	
															Sample Condition	Sample #
515-36-FD	1/15/2024	13:42	New Mark Middle School - Sink Tap - Room 510- Closest to Door	1	Wt	Grab	X									36
515-37-FD	1/15/2024	13:42	New Mark Middle School - Sink Tap - Room 510- Furthest from Door	1	Wt	Grab	X									37
515-38-FD	1/15/2024	13:42	New Mark Middle School - Sink Tap - Room 511- Closest to Door	1	Wt	Grab	X									38
515-39-FD	1/15/2024	13:42	New Mark Middle School - Sink Tap - Room 511- Furthest from Door	1	Wt	Grab	X									39
515-40-FD	1/15/2024	13:43	New Mark Middle School - Drinking Fountain - Outside 512-Left	1	Wt	Grab	X									40
515-41-FD	1/15/2024	13:43	New Mark Middle School - Drinking Fountain - Outside 512-Middle	1	Wt	Grab	X									41
515-42-FD	1/15/2024	13:43	New Mark Middle School - Drinking Fountain - Outside 512-Right	1	Wt	Grab	X									42

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	515 Northeast 106th Street	ADDRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Kansas City, Missouri 64155	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-321-4702	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	
															Short Hold:	
															Rush:	
															Temp: °C	
															Sample Condition	Sample #
515-43-FD	1/15/2024	13:44	New Mark Middle School - Sink Tap - Room 513- Closest to Door	1	Wt	Grab	X									43
515-44-FD	1/15/2024	13:44	New Mark Middle School - Sink Tap - Room 513- Furthest from Door	1	Wt	Grab	X									44
515-45-FD	1/15/2024	13:44	New Mark Middle School - Sink Tap - Room 514	1	Wt	Grab	X									45
515-46-FD	1/15/2024	13:46	New Mark Middle School - Sink Tap - Kitchen-3 Bay Sink-Left	1	Wt	Grab	X									46
515-47-FD	1/15/2024	13:46	New Mark Middle School - Sink Tap - Kitchen-3 Bay Sink-Right	1	Wt	Grab	X									47
515-48-FD	1/15/2024	13:46	New Mark Middle School - Sink Tap - Kitchen- South Middle Sink	1	Wt	Grab	X									48
515-49-FD	1/15/2024	13:47	New Mark Middle School - Steam Kettle - Kitchen	1	Wt	Grab	X									49

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

X

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	515 Northeast 106th Street	ADDRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Kansas City, Missouri 64155	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-321-4702	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
515-50-FD	1/15/2024	13:47	New Mark Middle School - Sink Tap - Kitchen- Middle by Steam Kettle	1	Wt	Grab	X								50
515-51-FD	1/15/2024	13:47	New Mark Middle School - Sink Tap - Kitchen- North Middle Sink	1	Wt	Grab	X								51
515-52-FD	1/15/2024	13:48	New Mark Middle School - Sink Tap - Kitchen- Closest to Commons	1	Wt	Grab	X								52
515-53-FD	1/15/2024	13:48	New Mark Middle School - Ice Machine - Kitchen	1	Wt	Grab	X								53
515-54-FD	1/15/2024	13:48	New Mark Middle School - Sink Tap - Kitchen-By Ice Machine	1	Wt	Grab	X								54
515-55-FD	1/15/2024	13:48	New Mark Middle School - Sink Tap - Kitchen- Northwest Sink	1	Wt	Grab	X								55
515-56-FD	1/15/2024	13:49	New Mark Middle School - Drinking Fountain - Commons-Left	1	Wt	Grab	X								56

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
						
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone

LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440


X

835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	515 Northeast 106th Street	ADDRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Kansas City, Missouri 64155	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-321-4702	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
515-57-FD	1/15/2024	13:49	New Mark Middle School - Drinking Fountain - Commons-Middle	1	Wt	Grab	X								57
515-58-FD	1/15/2024	13:49	New Mark Middle School - Drinking Fountain - Commons-Right	1	Wt	Grab	X								58

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		



3 H A 0 1 3 6

AXIOM Service Professionals

PM: Carolyn Jackson

Appendix D

Photo Log




1/15/2024 - 515-1 - New Mark Middle School - Room 100



1/15/2024 - 515-2 - New Mark Middle School - Nurse's Office



1/15/2024 - 515-3 - New Mark Middle School - Library



1/15/2024 - 515-4 - New Mark Middle School - Room 108



1/15/2024 - 515-5 - New Mark Middle School - Outside 203-Left



1/15/2024 - 515-6 - New Mark Middle School - Outside 203-Middle



1/15/2024 - 515-7 - New Mark Middle School - Outside 203-Right



1/15/2024 - 515-8 - New Mark Middle School - Room 203



1/15/2024 - 515-9 - New Mark Middle School - Room 213



1/15/2024 - 515-10 - New Mark Middle School - Room 304



1/15/2024 - 515-11 - New Mark Middle School - Room 505



1/15/2024 - 515-12 - New Mark Middle School - Room 503-Left




1/15/2024 - 515-13 - New Mark Middle School - Room 503-Right



1/15/2024 - 515-14 - New Mark Middle School - Room 504



1/15/2024 - 515-15 - New Mark Middle School - Girls Locker Room



1/15/2024 - 515-16 - New Mark Middle School - Boys Locker Room




1/15/2024 - 515-17 - New Mark Middle School - Outside 412-Left



1/15/2024 - 515-18 - New Mark Middle School - Outside 412-Right




1/15/2024 - 515-19 - New Mark Middle School - Room 411-North Wall-Left



1/15/2024 - 515-20 - New Mark Middle School - Room 411-North Wall-Right



1/15/2024 - 515-21 - New Mark Middle School - Room 411-East Wall-Left



1/15/2024 - 515-22 - New Mark Middle School - Room 411-East Wall-Right



1/15/2024 - 515-23 - New Mark Middle School - Room 410-West Wall-Left



1/15/2024 - 515-24 - New Mark Middle School - Room 410-West Wall-Right



1/15/2024 - 515-25 - New Mark Middle School - Room 410-North Wall-Left



1/15/2024 - 515-26 - New Mark Middle School - Room 410-North Wall-Right



1/15/2024 - 515-27 - New Mark Middle School - Outside 410-Left



1/15/2024 - 515-28 - New Mark Middle School - Outside 410-Right



1/15/2024 - 515-29 - New Mark Middle School - Room 500



1/15/2024 - 515-30 - New Mark Middle School - Outside 500-Left



1/15/2024 - 515-31 - New Mark Middle School - Outside 500-Right



1/15/2024 - 515-32 - New Mark Middle School - Room 508



1/15/2024 - 515-33 - New Mark Middle School - Room 507



1/15/2024 - 515-34 - New Mark Middle School - Room 506-Left




1/15/2024 - 515-35 - New Mark Middle School - Room 506-Right



1/15/2024 - 515-36 - New Mark Middle School - Room 510-Closest to Door



1/15/2024 - 515-37 - New Mark Middle School -
Room 510-Furthest from Door



1/15/2024 - 515-38 - New Mark Middle School -
Room 511-Closest to Door



1/15/2024 - 515-39 - New Mark Middle School -
Room 511-Furthest from Door



1/15/2024 - 515-40 - New Mark Middle School -
Outside 512-Left




1/15/2024 - 515-41 - New Mark Middle School -
Outside 512-Middle



1/15/2024 - 515-42 - New Mark Middle School -
Outside 512-Right



1/15/2024 - 515-43 - New Mark Middle School -
Room 513-Closest to Door



1/15/2024 - 515-44 - New Mark Middle School -
Room 513-Furthest from Door



1/15/2024 - 515-45 - New Mark Middle School - Room 514



1/15/2024 - 515-46 - New Mark Middle School - Kitchen-Three Bay Sink-Left



1/15/2024 - 515-47 - New Mark Middle School - Kitchen-Three Bay Sink-Right



1/15/2024 - 515-48 - New Mark Middle School - Kitchen-South Middle Sink




1/15/2024 - 515-49 - New Mark Middle School - Kitchen




1/15/2024 - 515-50 - New Mark Middle School - Kitchen-Middle by Steam Kettle



1/15/2024 - 515-51 - New Mark Middle School - Kitchen-North Middle Sink



1/15/2024 - 515-52 - New Mark Middle School - Kitchen-Closest to Commons



1/15/2024 - 515-53 - New Mark Middle School - Kitchen



1/15/2024 - 515-54 - New Mark Middle School - Kitchen-By Ice Machine



1/15/2024 - 515-55 - New Mark Middle School - Kitchen-Northwest Sink



1/15/2024 - 515-56 - New Mark Middle School - Commons-Left



1/15/2024 - 515-57 - New Mark Middle School -
Commons-Middle




1/15/2024 - 515-58 - New Mark Middle School -
Commons-Right

Appendix E

Source Identification Diagram

ASP was provided sample locations by
North Kansas City School District



EMERGENCY INFORMATION

New Mark Middle School
515 NE 106th Street
Kansas City, MO 64155

-  Primary Exit Route
-  Secondary Exit Route
-  You Are Here
-  Exit Location
-  Stairway
-  Defibrillator
-  Severe Weather Shelter

IN CASE OF SEVERE WEATHER

