

CHEMTECH

ANALYTICAL RESULTS SUMMARY

METAL
S

PROJECT NAME : DRINKING WATER - LEAD & COPPER

**ANNA L. KLEIN
SCHOOL**

**301 69th.
Street**

Guttenberg, NJ - 07093

Phone No: 201-861-3100

**ORDER ID: M2104 ATTENTION : Karen
Huebsch**

ACCRE
DIA

TNI
BORATO
RY

ANAB

C R E D I T E D
ISO/IEC 17025
DOD ELAP

CHEMTECH

284 Sheffield Street, Mountainside, NJ 07092 Phone: 908 789 8900 Fax: 908
789 8922

Hit Summary Sheet SW-846

SDG No.:
M2104

Order ID: Project ID:
M2104 Drinking Water - Lead & Copper

Client:
Anna L. Klein School

Matrix
Parameter

Concentration

C

MDL

RDL Units

Sample ID Client ID : M2104-01

Client ID FB-04-20-21 F B-04-20-21

Water

Copper

0.220

J

0.19

2.00

ug/L

Client ID : M2104-02 M2104-02

OB-3RD-FL-WATER-FOUNTAIN

OB-3RD-FL-WATER-FOUNTAIN Water OB-3RD-FL-WATER-FOUNTAIN Water

Copper Lead

360.000 0.470

J

0.19 **0.23**

2.00 1.00

ug/L ug/L

Client ID : M2104-03 M2104-03

OB-3RD-FL-BOYS-BATHROOM

OB-3RD-FL-BOYS-BATHROOM Water OB-3RD-FL-BOYS-BATHROOM Water

Copper Lead

72.100 0.470

0.19 0.23

2.00 **1.00**

ug/L ug/L

J

Client ID : M2104-04 M2104-04
OB-3RD-FL-GIRLS-BATHROOM

OB-3RD-FL-GIRLS-BATHROO Water OB-3RD-FL-GIRLS-BATHROO Water

Copper Lead

64.400

0.460

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-05 M2104-05
NB-3RD-FL-GIRLS-BATHROOM

NB-3RD-FL-GIRLS-BATHROO Water NB-3RD-FL-GIRLS-BATHROO Water

0.19

Copper Lead

178.000 2.540

2.00 1.00

ug/L ug/L

UNI
FL-G
VIV

0.23

Client ID : M2104-06 M2104-06
NB-3RD-FL-WATER-FOUNTAIN

NB-3RD-FL-WATER-FOUNTAI Water NB-3RD-FL-WATER-FOUNTAI Water

Copper Lead

502.000 0.260

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-07 M2104-07
NB-3RD-FL-BOYS-BATHROOM

NB-3RD-FL-BOYS-BATHROOI Water NB-3RD-FL-BOYS-BATHROOI Water

Copper Lead

109.000 0.460

0.19 0.23
2.00 1.00

ug/L ug/L

Client ID : M2104-08

NB-3RD-FL-N-WATER-FOUNTAIN

NB-3RD-FL-N-WATER-FOUNT Water

Copper

743.000

0.19

2.00

ug/L

Client ID : M2104-09 M2104-09

OB-2ND-FL-WATER-FOUNTAIN

OB-2ND-FL-WATER-FOUNTAI Water OB-2ND-FL-WATER-FOUNTAI Water

Copper

0.19

138.000 0.420

2.00 1.00

ug/L ug/L

Lead

0.23

Client ID : M2104-10 M2104-10

OB-2ND-FL-BOYS-BATHROOM

OB-2ND-FL-BOYS-BATHROOI Water OB-2ND-FL-BOYS-BATHROOI Water

Copper Lead

105.000 0.950

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-11 M2104-11

OB-2ND-FL-GIRLS-BATHROOM

OB-2ND-FL-GIRLS-BATHROO Water OB-2ND-FL-GIRLS-BATHROO Water

Copper Lead

102.000

0.330

J

0.19 **0.23**

2.00 1.00

ug/L ug/L

Client ID: M2104-12

NB-2ND-FL-BOYS-BATHROOM

NB-2ND-FL-BOYS-BATHROOI Water

Copper

72.900

0.19

2.00

ug/L

CHEMTECH

284 Sheffield Street, Mountainside, NJ 07092 Phone: 908 789 8900 Fax:
908 789 8922

Hit Summary Sheet

SW-846

SDG No.:

M2104

Order ID:

M2104

Client:

Anna L. Klein School

Project ID:

Drinking Water - Lead & Copper

Sample ID M2104-12

Client ID

Matrix NB-2ND-FL-BOYS-BATHROOI Water

Parameter Lead

Concentration **C**

1.590

MDL

0.23

RDL Units

1.00 ug/L

Client ID : M2104-13 M2104-13

NB-2ND-FL-N-WATER-FOUNTAIN

NB-2ND-FL-N-WATER-FOUNTI Water NB-2ND-FL-N-WATER-FOUNT Water

Copper Lead

999.000 0.590

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-14 M2104-14

NB-2ND-FL-GIRLS-BATHROOM

NB-2ND-FL-GIRLS-BATHROO Water NB-2ND-FL-GIRLS-BATHROO Water

Copper Lead

111.000 0.770

0.19

0.23

2.00 ug/L 1.00 ug/L

Client ID : M2104-15 M2104-15

OB-1ST-FL-WATER-FOUNTAIN

OB-1ST-FL-WATER-FOUNTAN Water OB-1ST-FL-WATER-FOUNTAN Water

Copper Lead

207.000 0.330

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-16 M2104-16

OB-1ST-FL-BOYS-BATHROOM

OB-1ST-FL-BOYS-BATHROON Water OB-1ST-FL-BOYS-BATHROOM Water

Copper Lead

168.000 0.750

0.19 0.23

J

2.00 1.00

ug/L ug/L

Client ID : M2104-17 M2104-17

OB-1ST-FL-GIRLS-BATHROOM

OB-1ST-FL-GIRLS-BATHROOI Water OB-1ST-FL-GIRLS-BATHROOI Water

Copper Lead

47.300 0.420

J

0.19 0.23

2.00 1.00

ug/L ug/L

vater

Client ID : M2104-18 M2104-18

NB-1ST-FL-E-WATER-FOUNTAIN

NB-1ST-FL-E-WATER-FOUNT/ Water NB-1ST-FL-E-WATER-FOUNTA Water

Copper Lead

558.000 0.680

0.19 0.23

2.00 1.00

ug/L ug/L

J

Client ID : M2104-19

NB-1ST-FL-GIRLS-BATHROOM

NB-1ST-FL-GIRLS-BATHROOI Water

Copper

136.000

0.19

2.00

ug/L

Client ID: M2104-20 M2104-20

NB-1ST-FL-BOYS-BATHROOM

NB-1ST-FL-BOYS-BATHROOM Water NB-1ST-FL-BOYS-BATHROOM Water

Copper Lead

61.900 1.330

0.19 **0.23**

2.00 1.00

ug/L ug/L

Client ID : M2104-21 M2104-21

BASEMENT-GIRLS-BATHROOM

BASEMENT-GIRLS-BATHROOC Water BASEMENT-GIRLS-BATHROOC Water

Copper Lead

319.000 2.700

0.19 0.23

2.00 1.00

ug/L ug/L

Client ID : M2104-22 M2104-22

BASEMENT-BOYS-BATHROOM

BASEMENT-BOYS-BATHROO Water BASEMENT-BOYS-BATHROO Water

Copper Lead

35.600 0.730

0.19 **0.23**

2.00 1.00

ug/L ug/L

:

Client ID M2104-23

M2104-23

BASEMENT-WATER-FOUNTAIN

BASEMENT-WATER-FOUNTA Water BASEMENT-WATER-FOUNTA Water

Copper Lead

352.000 0.280

0.19 0.23

2.00 1.00

ug/L ug/L

CHEMTECH

284 Sheffield Street, Mountainside, NJ 07092 Phone: 908 789 8900 Fax:
908 789 8922

Hit Summary Sheet

SW-846

SDG No.:

M2104

Order ID:

M2104

Client:

Anna L. Klein School

Project ID:

Drinking Water - Lead & Copper

Sample ID

Client ID

Matrix

Parameter

Concentration

C

MDL

RDL

Units