

April 2024

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The State mandated inspection reports as part of the Tools for Schools program have been completed.
- Air filter changes were completed on all units district-wide by our in house HVAC maintainer.
- Roof top exhaust fans at the middle schools were serviced by our in house HVAC maintainer.

Projects in Process:

- A compressor for the air handler that serves the black box theater at ARHS is being replaced by our in house HVAC tech.
- The underground sump pump discharge line for the well pit at AMSB is being repaired by an outside contractor.
- All of the failed parking lot light fixtures at ARHS have been replaced. We are working on scheduling lift rentals around the weather to finish replacing the remaining fixtures.
- The ticket booth for the Athletic Department is currently being built by the ARHS Tech Ed. Department.
- The District is working with the Town of Woodbridge to address concerns with the fuel cell and microgrid.
- A leaking circulator pump on the AMSB main heating loop is scheduled for repair by an outside contractor.
- One of the two automatic transfer switches for generator power at ARHS needs to be replaced. Work is being scheduled with our generator service company.
- Facilities and an outside electrical contractor are working with United Illuminating to schedule the final connection from the pole to the scoreboard to complete the new service drop that will power the scoreboard/videoboard. Work should be completed within a week.

Outstanding issues to be addressed:

- Now that the gym floor has been repaired at AMSO, Dalene Flooring is scheduled to return this summer to sand and refinish the entire floor.