

Lead in Drinking Water – Public and Nonpublic Schools

Updated in response to legislation effective as of June 1, 2021

IMPORTANT NOTICE: ELEVATED LEAD WATER SAMPLE RESULT(S) **North East Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On **December 12, 2018, ninety-one (91)** lead water samples were collected from **North East Elementary School**. Of these lead water samples, **two (2)** had levels of lead exceeding the State’s revised action level of 5 parts per billion (ppb) (*formerly 20 ppb; 5 ppb effective June 1, 2021*) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at **North East Elementary School** were as follows:

- 13.1 parts per billion (ppb) Room 126 bathroom (use: non-consumption)
- 25.7 parts per billion (ppb) Art Room (left) (use: non-consumption)

ACTION LEVEL (AL)

Effective June 1, 2021, the State’s AL for lead in drinking water samples collected from outlets in school buildings has been lowered to 5 ppb. The AL is the concentration of lead which, if exceeded, triggers required remediation of drinking water outlets.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother’s bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These sources include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person’s potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

A sign was posted at each sink noted above, indicating that they are not to be used for consumption purposes.

NEXT STEPS

The sink in Room 126 bathroom will continue to be used only for non-consumption purposes (e.g., hand washing). The fixture in the Art room has been replaced, and follow up testing confirmed successful remediation.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

For additional information, please contact **Andrew Curran, Assistant in Safety**, at **410-287-4653**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

MARTEL

Cecil County Public Schools
201 Booth St.

Monday, March 11, 2019

Elkton, MD 21921

Attention: Andrew Curran

Report for Lab No: 40707.

Samples received by Martel from: North East Elementary School.

Project Identification: Water Analysis HB 270, sampled by Cecil County personnel.

December 12, 2018

Certificate of Analysis **FINAL**

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000001	14-BS-01: Room 140 bathroom	12/12/2018 05:22
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 16:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000002	14-CR-02: Room 140	12/12/2018 05:22
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000003	14-DF-03: Outside room 140 (left)	12/12/2018 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000004	14-DF-04: Outside room 140 (right)	12/12/2018 05:24
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000005	14-BS-05: Room 131 bathroom	12/12/2018 05:26
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000006	14-CR-06: Room 131	12/12/2018 05:26
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:22 BJ

Martel Laboratories JDS Inc.

CECILS

Page 1 OF 12

1025 Cromwell Bridge Road - Baltimore, Maryland 21286 Questions, comments or concerns? Contact your Martel representative or email martel@martellabs.com

03/11/2019

Certificate of Analysis

MARTEL NO. 40707	000007	CLIENT SAMPLE IDENTIFICATION 14-CR-07: Room 135	Sample Date/Time 12/12/2018 05:27
---------------------	--------	--	--------------------------------------

Compound	1	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:24 BJ	

MARTEL NO. 40707	000008	CLIENT SAMPLE IDENTIFICATION 14-BS-08: Room 135 bathroom	Sample Date/Time 12/12/2018 05:27
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:27 BJ

MARTEL NO. 40707	000009	CLIENT SAMPLE IDENTIFICATION 14-CR-09: Room 137	Sample Date/Time 12/12/2018 05:28
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:29 BJ

MARTEL NO. 40707	000010	CLIENT SAMPLE IDENTIFICATION 14-CR-10: Room 126 (right)	Sample Date/Time 12/12/2018 05:29
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:31 BJ

MARTEL NO. 40707	000011	CLIENT SAMPLE IDENTIFICATION 14-CR-11: Room 126 (left)	Sample Date/Time 12/12/2018 05:29
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.72	ug/l	EPA .200.8	2	03/04/2019 17:42 BJ

MARTEL NO. 40707	000012	CLIENT SAMPLE IDENTIFICATION 14-BS-12: Room 126 bathroom	Sample Date/Time 12/12/2018 05:29
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.1	ug/l	EPA .200.8	2	03/04/2019 17:47 BJ

MARTEL NO. 40707	000013	CLIENT SAMPLE IDENTIFICATION 14-BS-13: Room 127 bathroom	Sample Date/Time 12/12/2018 05:30
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:50 BJ

MARTEL NO. 40707	000014	CLIENT SAMPLE IDENTIFICATION 14-CR-14: Room 127	Sample Date/Time 12/12/2018 05:30
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 17:52 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000015	14-BS-15: Room 102 bathroom	12/12/2018 05:31
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:55 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000016	14-CR-16: Room 102	12/12/2018 05:31
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000017	14-BS-17: Room 124 bathroom	12/12/2018 05:33
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 17:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000018	14-CR-18: Room 124	12/12/2018 05:33
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 18:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000019	14-BS-19: Room 105 bathroom	12/12/2018 05:34
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 18:04 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000020	14-CR-20: Room 105	12/12/2018 05:34
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 18:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000021	14-CR-21: Room 106	12/12/2018 05:35
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 18:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000022	14-OT-22: Grade 1 sensory room	12/12/2018 05:35
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/04/2019 18:22 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40707	000023	14-CR-23: Room 121			12/12/2018 05:36
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:25 BJ
40707	000024	14-BS-24: Bathroom next to Art room			12/12/2018 05:37
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:27 BJ
40707	000025	14-CR-25: Room 120			12/12/2018 05:38
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:30 BJ
40707	000026	14-CR-26: Room 119			12/12/2018 05:40
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:32 BJ
40707	000027	14-CR-27: Art room (right)			12/12/2018 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:35 BJ
40707	000028	14-CR-28: Art room (middle)			12/12/2018 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:37 BJ
40707	000029	14-CR-29: Art room (left)			12/12/2018 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.7	ug/l*	EPA .200.8	2	03/04/2019 18:40 BJ
40707	000030	14-DF-30: Fountain near Music (right)			12/12/2018 05:43
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 18:42 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000031	14-DF-31 : Fountain near Music (left)	12/12/2018 05:43		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 18:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000032	14-BS-32: Outside bathrooms near music (right)	12/12/2018 05:48		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 18:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000033	14-BS-33: Outside bathrooms near music (left)	12/12/2018 05:48		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 18:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000034	14-BS-34: Staff bathroom across from faculty room	12/12/2018 05:47		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 19:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000035	14-BS-35: Bathroom on left near music (right)	12/12/2018 05:45		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 19:04 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000036	14-BS-36: Bathroom on left near music (left)	12/12/2018 05:45		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 19:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000037	14-TL-37: Teacher's lounge	12/12/2018 05:50		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 19:09 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40707 000038	14-CR-38: Music room	12/12/2018 05:51		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/04/2019 19:12 BJ



MARTEL NO. 40707	000039	CLIENT SAMPLE IDENTIFICATION 14-CR-39: Music storage room	Sample Date/Time 12/12/2018 05:51
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:14 BJ

MARTEL NO. 40707	000040	CLIENT SAMPLE IDENTIFICATION 14-CR-40: Room 121	Sample Date/Time 12/12/2018 05:52
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:17 BJ

MARTEL NO. 40707	000041	CLIENT SAMPLE IDENTIFICATION 14-CR-41: Room 120	Sample Date/Time 12/12/2018 05:53
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.95	ug/l	EPA .200.8	2	03/04/2019 19:24 BJ

MARTEL NO. 40707	000042	CLIENT SAMPLE IDENTIFICATION 14-CR-42: Room 119	Sample Date/Time 12/12/2018 05:53
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:32 BJ

MARTEL NO. 40707	000043	CLIENT SAMPLE IDENTIFICATION 14-OT-43: Office in media center	Sample Date/Time 12/12/2018 05:57
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:34 BJ

MARTEL NO. 40707	000044	CLIENT SAMPLE IDENTIFICATION 14-CR-44: Comm room in media center	Sample Date/Time 12/12/2018 05:57
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:37 BJ

MARTEL NO. 40707	000045	CLIENT SAMPLE IDENTIFICATION 14-CR-45: Room 123	Sample Date/Time 12/12/2018 06:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:39 BJ

MARTEL NO. 40707	000046	CLIENT SAMPLE IDENTIFICATION 14-DF-46: Cafeteria (left)	Sample Date/Time 12/12/2018 06:01
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 19:42 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000047	14-DF-47: Cafeteria (right)	12/12/2018 06:01
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 19:44 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000048	14-BS-48: Bathroom in cafeteria on right (front/right) Girls	12/12/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 19:47 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000049	14-BS-49: Bathroom in cafeteria on right (front/left) Girls	12/12/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 19:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000050	14-BS-50: Bathroom in cafeteria on right (back/left) Girls	12/12/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 19:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000051	14-BS-51 : Bathroom in cafeteria on right (back/middle) Girl	12/12/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 20:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000052	14-BS-52: Bathroom in cafeteria on right (back/right) Girls	12/12/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 20:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000053	14-BS-53: Bathroom in cafeteria on left (left) Boys	12/12/2018 06:05
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 20:09 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000054	14-BS-54: Bathroom in cafeteria on left (middle/left) Boys	12/12/2018 06:05
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/04/2019 20:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000055	14-BS-55: Bathroom in cafeteria on left (middle/right) Boys	12/12/2018 06:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000056	14-BS-56: Bathroom in cafeteria on left (right) Boys	12/12/2018 06:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000057	14-IM-57: Kitchen	12/12/2018 06:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000058	14-KS-58: Kitchen (next to ice machine)	12/12/2018 06:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:22 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000060	14-KS-60: Kitchen (right side/right)	12/12/2018 06:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000061	14-KS-61: Kitchen (right side/left)	12/12/2018 06:10
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:27 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000062	14-BS-62: Kitchen bathroom	12/12/2018 06:10
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:35 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000063	14-KS-63: Kitchen (back corner)	12/12/2018 06:12
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	03/04/2019 20:42 BJ



MARTEL NO. 40707 000064 CLIENT SAMPLE IDENTIFICATION 14-BS-64: PE office bathroom Sample Date/Time 12/12/2018 06:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.19	ug/l	EPA .200.8	2	03/04/2019 20:45 BJ

MARTEL NO. 40707 000065 CLIENT SAMPLE IDENTIFICATION 14-CR-65: Room 108 Sample Date/Time 12/12/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 20:47 BJ

MARTEL NO. 40707 000066 CLIENT SAMPLE IDENTIFICATION 14-OT-66: Building Coord. Office Sample Date/Time 12/12/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 20:50 BJ

MARTEL NO. 40707 000067 CLIENT SAMPLE IDENTIFICATION 14-NO-67: Nurses office Sample Date/Time 12/12/2018 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 20:52 BJ

MARTEL NO. 40707 000068 CLIENT SAMPLE IDENTIFICATION 14-BS-68: Main office bathroom Sample Date/Time 12/12/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 20:55 BJ

MARTEL NO. 40707 000069 CLIENT SAMPLE IDENTIFICATION 14-TL-69: Main office work room Sample Date/Time 12/12/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 20:57 BJ

MARTEL NO. 40707 000070 CLIENT SAMPLE IDENTIFICATION 14-OT-70: Teacher Planning (main office) Sample Date/Time 12/12/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 21:00 BJ

MARTEL NO. 40707 000071 CLIENT SAMPLE IDENTIFICATION 14-BS-71 : Bathroom in storage room across from 107 Sample Date/Time 12/12/2018 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/04/2019 21:02 BJ



MARTEL NO. 40707	000072	CLIENT SAMPLE IDENTIFICATION 14-CR-72: Room 107	Sample Date/Time 12/12/2018 06:22
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:12 BJ

MARTEL NO. 40707	000073	CLIENT SAMPLE IDENTIFICATION 14-CR-73: Room 106	Sample Date/Time 12/12/2018 06:23
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	11	<2 ug/l	EPA .200.8 2 03/04/2019 21:17 BJ

MARTEL NO. 40707	000074	CLIENT SAMPLE IDENTIFICATION 14-CR-74: Room 105	Sample Date/Time 12/12/2018 06:24
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		3.43 ug/l	EPA .200.8 2 03/04/2019 21:20 BJ

MARTEL NO. 40707	000075	CLIENT SAMPLE IDENTIFICATION 14-CR-75: Room 104	Sample Date/Time 12/12/2018 06:25
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:22 BJ

MARTEL NO. 40707	000076	CLIENT SAMPLE IDENTIFICATION 14-CR-76: Room 103	Sample Date/Time 12/12/2018 06:25
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:25 BJ

MARTEL NO. 40707	000077	CLIENT SAMPLE IDENTIFICATION 14-CR-77: Room 102 (left side)	Sample Date/Time 12/12/2018 06:27
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:27 BJ

MARTEL NO. 40707	000078	CLIENT SAMPLE IDENTIFICATION 14-CR-78: Room 102 (right side)	Sample Date/Time 12/12/2018 06:27
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:30 BJ

MARTEL NO. 40707	000079	CLIENT SAMPLE IDENTIFICATION 14-BS-79: Bathroom on left across from 118 (left)	Sample Date/Time 12/12/2018 06:30
Compound		Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8 2 03/04/2019 21:32 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000080	14-BS-80: Bathroom on left across from 118 (middle left)	12/12/2018 06:30
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:35 BJ
40707 000081	14-BS-81: Bathroom on left across from 118 (middle right)	12/12/2018 06:30
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:37 BJ
40707 000082	14-CR-82: Room 118	12/12/2018 06:33
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:45 BJ
40707 000083	14-BS-83: Staff bathroom across from 118	12/12/2018 06:33
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:53 BJ
40707 000084	14-DF-84: Fountain near 118 (right)	12/12/2018 06:34
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:55 BJ
40707 000085	14-DF-85: Fountain near 118 (left)	12/12/2018 06:34
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 21:58 BJ
40707 000086	14-BS-86: Bathroom on right across from 118 (right)	12/12/2018 06:34
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:00 BJ
40707 000087	14-BS-87: Bathroom on right across from 118 (left)	12/12/2018 06:34
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40707 000088	14-CR-88: Room 117	12/12/2018 06:35
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:05 BJ
40707 000089	14-CR-89: Room 114	12/12/2018 06:36
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:08 BJ
40707 000090	14-CR-90: Room 103	12/12/2018 06:38
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:10 BJ
40707 000091	14-CR-91: Room 116	12/12/2018 06:38
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:13 BJ
40707 000092	14-BS-92: Girls Bathroom near 118 (right)	12/12/2018 06:32
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/04/2019 22:23 BJ

Page 12 OF 12

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdi.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act

* Results exceed 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager