

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S)

North East High School

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On March 21, 2019, **one hundred sixty-six (166)** lead water samples were collected from **North East High School**. Of these lead water samples, **thirty-nine (39)** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at North East High were as follows:

- 61.5** parts per billion (ppb) **C building - faculty room sink (use: consumption)**
- 32.5** parts per billion (ppb) **A building – concessions stand sink (use: consumption)**
- 65.9** parts per billion (ppb) **Room C208 left wall (middle sink) (use: non-consumption)**
- 60.4** parts per billion (ppb) **Room C208 left wall (middle/right sink) (use: non-consumption)**
- 150** parts per billion (ppb) **Room C208 left wall (right sink) (use: non-consumption)**
- 147** parts per billion (ppb) **Room C208 right wall (left sink) (use: non-consumption)**
- 37.3** parts per billion (ppb) **Room C207 storage room sink (use: non-consumption)**
- 48.1** parts per billion (ppb) **Room C207 front wall (left sink) (use: non-consumption)**
- 3270** parts per billion (ppb) **Room C207 front wall (right sink) (use: non-consumption)**
- 47.6** parts per billion (ppb) **Room C207 right wall (left sink) (use: non-consumption)**
- 112** parts per billion (ppb) **Room C207 right wall (middle/right sink) (use: non-consumption)**
- 53.3** parts per billion (ppb) **Room C203 left wall (left sink) (use: non-consumption)**
- 55.3** parts per billion (ppb) **Room C203 left wall (middle sink) (use: non-consumption)**
- 34.3** parts per billion (ppb) **Room C203 left wall (right sink) (use: non-consumption)**
- 108** parts per billion (ppb) **Room C203 right wall (middle/left sink) (use: non-consumption)**
- 23.1** parts per billion (ppb) **Room C203 right wall (middle/right sink) (use: non-consumption)**
- 30.6** parts per billion (ppb) **Room C203 right wall (right sink) (use: non-consumption)**
- 52.0** parts per billion (ppb) **Room C214 left wall (middle/left sink) (use: non-consumption)**
- 63.2** parts per billion (ppb) **Room C214 left wall (middle sink) (use: non-consumption)**
- 159** parts per billion (ppb) **Room C214 left wall (middle/right sink) (use: non-consumption)**
- 94.4** parts per billion (ppb) **Room C214 left wall (right sink) (use: non-consumption)**
- 50.8** parts per billion (ppb) **Room C214 back wall (left sink) (use: non-consumption)**
- 55.3** parts per billion (ppb) **Room C214 sink in middle of room (use: non-consumption)**
- 54.8** parts per billion (ppb) **Room C226 left wall (left sink) (use: non-consumption)**
- 83.7** parts per billion (ppb) **Room C226 left wall (middle/left sink) (use: non-consumption)**
- 23.7** parts per billion (ppb) **Room C226 left wall (middle/right sink) (use: non-consumption)**
- 27.7** parts per billion (ppb) **Room C226 back wall (left sink) (use: non-consumption)**
- 26.9** parts per billion (ppb) **Room C226 back wall (right sink) (use: non-consumption)**
- 93.0** parts per billion (ppb) **Room C226 front wall sink (use: non-consumption)**
- 49.2** parts per billion (ppb) **C229 Storage Room sink (use: non-consumption)**
- 25.5** parts per billion (ppb) **Room C229 back wall (right sink) (use: non-consumption)**
- 474** parts per billion (ppb) **Room C229 front wall (left sink) (use: non-consumption)**
- 123** parts per billion (ppb) **Room C229 front wall (middle sink) (use: non-consumption)**
- 27.3** parts per billion (ppb) **Room C229 front wall (right sink) (use: non-consumption)**
- 31.4** parts per billion (ppb) **A building – dark room (right sink) (use: non-consumption)**
- 25.7** parts per billion (ppb) **Sport Service (SS) building – home room left sink (use: non-consumption)**
- 20.5** parts per billion (ppb) **SS building – home room right sink (use: non-consumption)**
- 31.4** parts per billion (ppb) **SS building – women’s bathroom middle sink (use: non-consumption)**
- 43.1** parts per billion (ppb) **SS building – women’s bathroom left sink (use: non-consumption)**

IMMEDIATE ACTIONS TAKEN

Results were received on May 15, 2019. A sign has been posted at each sink noted above, indicating that they are not to be used for consumption purposes.

NEXT STEPS

The sinks will continue to be used only for non-consumption purposes (e.g., hand washing) until remedial actions have taken place and follow up sampling shows results with levels below the action level.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact **Perry Willis, Executive Director for Support Services**, at **410-996-5400**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



Cecil County Public Schools
201 Booth St.

Tuesday, May 14, 2019

Elkton, MD 21921

Certificate of Analysis

Attention: Andrew Curran

FINAL

Report for Lab No: 41966.

Samples received by Martel from: North East High School

Project Identification: Water Analysis HB 270, sampled by Cecil County personnel.

Received on March 26, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000001	33-BS-01: Custodians bathroom near boiler room	03/21/2019 03:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:35 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000002	33-DF-02: C building fountain	03/21/2019 03:46
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:47 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000003	33-BS-03: C building girls bathroom (left)	03/21/2019 03:47
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:49 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000004	33-BS-04: C building girls bathroom (middle)	03/21/2019 03:47
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:52 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000005	33-BS-05: C building girls bathroom (right)	03/21/2019 03:47
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:54 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000006	33-BS-06: C building boys bathroom (right)	03/21/2019 03:47
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:57 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000007	33-BS-07: C building boys bathroom (left)	03/21/2019 03:47
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 16:59 BJ
40718 000008	33-BS-08: C building single bathroom (right)	03/21/2019 03:48
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 17:02 BJ
40718 000009	33-BS-09: C building single bathroom (left)	03/21/2019 03:48
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 17:04 BJ
40718 000010	33-TL-10: C building faculty room	03/21/2019 03:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	61.5 ug/l* EPA .200.8	2 05/06/2019 17:07 BJ
40718 000011	33-CR-11: Room C125 (left)	03/21/2019 03:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 17:17 BJ
40718 000012	33-CR-12: Room C125 (middle)	03/21/2019 03:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.18 ug/l EPA .200.8	2 05/06/2019 17:22 BJ
40718 000013	33-CR-13: Room C125 (right)	03/21/2019 03:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 17:25 BJ
40718 000014	33-CR-14: Room C136	03/21/2019 03:52
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 17:27 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000015	33-CR-15: Room C137	03/21/2019 03:53
Compound	Test Value Test Unit	Method
Lead	10.4 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:30 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000016	33-HE-16: Room C145 (L to R - 1)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:32 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000017	33-HE-17: Room C145 (L to R - 2)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:34 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000018	33-HE-18: Room C145 (L to R - 3)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:37 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000019	33-HE-19: Room C145 (L to R - 4)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:39 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000020	33-HE-20: Room C145 (L to R - 5)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:42 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000021	33-HE-21 : Room C145 (L to R - 6)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:50 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000022	33-HE-22: Room C145 (L to R - 7)	03/21/2019 03:55
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
		Detection Limit
		2
		Analysis Date/Time/Initial
		05/06/2019 17:57 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000023	33-OT-23: Room C144	03/21/2019 03:55
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.44 ug/l EPA .200.8 2	05/06/2019 18:00 BJ
40718 000024	33-BS-24: Room C144 bathroom	03/21/2019 03:55
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.22 ug/l EPA .200.8 2	05/06/2019 18:02 BJ
40718 000025	33-OT-25: Media Center	03/21/2019 04:02
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.29 ug/l EPA .200.8 2	05/06/2019 18:05 BJ
40718 000026	33-BS-26: B building womens bathroom	03/21/2019 04:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 18:07 BJ
40718 000027	33-BS-27: B building mens bathroom	03/21/2019 04:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 18:10 BJ
40718 000028	33-TL-28: B building faculty room	03/21/2019 04:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.15 ug/l EPA .200.8 2	05/06/2019 18:12 BJ
40718 000029	33-BS-29: B building girls bathroom (left)	03/21/2019 04:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 18:14 BJ
40718 000030	33-BS-30: B building girls bathroom (right)	03/21/2019 04:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 18:17 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000031	33-DF-31: B building fountain	03/21/2019 04:09
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 18:27 BJ
40718 000032	33-BS-32: B building boys bathroom (right)	03/21/2019 04:09
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	5.00 ug/l EPA .200.8	2 05/06/2019 18:32 BJ
40718 000033	33-BS-33: B building boys bathroom (left)	03/21/2019 04:09
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 18:34 BJ
40718 000034	33-OT-34: A building water jug fill hose	03/21/2019 04:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 18:37 BJ
40718 000035	33-IM-35: A building ice machine	03/21/2019 04:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 18:39 BJ
40718 000036	33-BS-36: Boys locker room (right)	03/21/2019 04:15
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.06 ug/l EPA .200.8	2 05/06/2019 18:42 BJ
40718 000037	33-BS-37: Boys locker room (middle)	03/21/2019 04:15
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	5.18 ug/l EPA .200.8	2 05/06/2019 18:44 BJ
40718 000038	33-BS-38: Boys locker room (left)	03/21/2019 04:15
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 18:47 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000039	33-BS-39: Girls locker room (right)	03/21/2019 04:15
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 18:49 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000040	33-BS-40: Girls locker room (middle)	03/21/2019 04:15
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 18:52 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000041	33-BS-41: Girls locker room (left)	03/21/2019 04:15
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 18:59 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000042	33-BS-42: Girls locker room office	03/21/2019 04:15
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 19:07 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000043	33-OT-43: A building concession	03/21/2019 04:20
Compound	Test Value Test Unit	Method
Lead	32.5 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 19:09 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000044	33-DF-44: A building fountain	03/21/2019 04:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 19:12 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000045	33-BS-45: A building boys bathroom (right)	03/21/2019 04:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 19:14 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000046	33-BS-46: A building boys bathroom (left)	03/21/2019 04:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 19:17 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000047	33-BS-47: A building girls bathroom (right)	03/21/2019 04:20
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:19 BJ
40718 000048	33-BS-48: A building girls bathroom (left)	03/21/2019 04:20
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:21 BJ
40718 000049	33-NO-49: Nurses office	03/21/2019 04:18
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	2.66 ug/l EPA .200.8	2 05/06/2019 19:24 BJ
40718 000050	33-BS-50: Main office bathroom (right)	03/21/2019 04:22
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:26 BJ
40718 000051	33-BS-51: Main office bathroom (left)	03/21/2019 04:22
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:36 BJ
40718 000052	33-CR-52: D building science room	03/21/2019 04:26
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:41 BJ
40718 000053	33-KS-53: Kitchen - hand wash sink near bathro	03/21/2019 04:30
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:44 BJ
40718 000054	33-BS-54: Kitchen - bathroom	03/21/2019 04:30
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 19:46 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000055	33-KS-55: Kitchen wash area (right)	03/21/2019 04:30		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	05/06/2019 19:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000056	33-KS-56: Kitchen wash area (left)	03/21/2019 04:30		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.18 ug/l	EPA .200.8	2	05/06/2019 19:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000057	33-KS-57: Kitchen - kettle filler	03/21/2019 04:30		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	05/06/2019 19:54 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000058	33-KS-58: Kitchen - prep sink	03/21/2019 04:30		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	05/06/2019 19:56 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000059	33-KS-59: Kitchen - hand wash sink	03/21/2019 04:31		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	05/06/2019 19:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000060	33-OT-60: Kitchen - back room	03/21/2019 04:00		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	no fixture	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000061	33-DF-61: Cafeteria fountain (left)	03/21/2019 04:39		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66 ug/l	EPA .200.8	2	05/06/2019 20:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000062	33-DF-62: Cafeteria fountain (right)	03/21/2019 04:39		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.05 ug/l	EPA .200.8	2	05/06/2019 20:14 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000063	33-BS-63: D building mens bathroom	03/21/2019 04:39
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 20:17 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000064	33-BS-64: D building womens bathroom	03/21/2019 04:39
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 20:19 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000065	33-BS-65: D building girls bathroom (right)	03/21/2019 04:39
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 20:22 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000066	33-BS-66: D building girls bathroom (left)	03/21/2019 04:39
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 20:24 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000067	33-BS-67: D building boys bathroom (left)	03/21/2019 04:39
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.13 ug/l EPA .200.8 2	05/06/2019 20:27 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000068	33-BS-68: D building boys bathroom (right)	03/21/2019 04:39
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/06/2019 20:29 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000069	33-DF-69: Fountain near C/D stairwell (left)	03/21/2019 04:39
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	no fixture EPA .200.8 2	//
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000070	33-DF-70: Fountain near C/D stairwell (right)	03/21/2019 04:39
Compound	Test Value TestUnit Method Detection Limit	Analysis Date/Time/Initial
Lead	no fixture EPA .200.8 2	//



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000071	33-SS-BS-71: DS building - home room (left) F	03/21/2019 04:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	18.3 ug/l EPA .200.8	2 05/06/2019 20:39 BJ
40718 000072	33-SS-BS-72: SS building - home room (middle)	03/21/2019 04:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	25.7 ug/l* EPA .200.8	2 05/09/2019 01:02 BJ
40718 000073	33-SS-BS-73: SS building - home room (right)	03/21/2019 04:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	20.5 ug/l EPA .200.8	2 05/06/2019 20:47 BJ
40718 000074	33-SS-BS-74: SS building - womens bathroom (ri	03/21/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	4.50 ug/l EPA .200.8	2 05/06/2019 20:49 BJ
40718 000075	33-SS-BS-75: SS building - womens bathroom (mi	03/21/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	31.4 ug/l* EPA .200.8	2 05/06/2019 20:52 BJ
40718 000076	33-SS-BS-76: SS building - womens bathroom (le	03/21/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	43.1 ug/l* EPA .200.8	2 05/06/2019 20:54 BJ
40718 000077	33-SS-BS-77: SS building -mens bathroom (right	03/21/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	9.05 ug/l EPA .200.8	2 05/06/2019 20:57 BJ
40718 000078	33-SS-BS-78: SS building -mens bathroom (middl	03/21/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	4.79 ug/l EPA .200.8	2 05/06/2019 20:59 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000079	33-SS-BS-79: SS building -mens bathroom (left)	03/21/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non ug/l* EPA .200.8	2 05/06/2019 21:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000080	33-SS-IM-80: SS building -concession ice machi	03/21/2019 06:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 21:04 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000081	33-SS-OT-81: SS building -concession sink	03/21/2019 06:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/06/2019 21:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000082	33-SS-BS-82: SS building - visitors room (left)	03/21/2019 06:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000083	33-SS-BS-83: SS building - visitors room (midd	03/21/2019 06:03
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	9.43 ug/l EPA .200.8	2 05/06/2019 21:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000084	33-SS-DF-84: SS building - visitors room (right) Fountain	03/21/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000085	33-SS-BS-85: SS building Office Bathroom	03/21/2019 06:15
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.65 ug/l EPA .200.8	2 05/06/2019 21:22 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000201	33-OT-201: Room C208 storage	03/21/2019 04:46
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.87 ug/l EPA .200.8	2 05/06/2019 21:24 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000202	33-CR-202: Room C208 (L to R - 1)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	2.02 ug/l	EPA .200.8 2 05/06/2019 21:27 BJ
40718 000203	33-CR-203: Room C208 (L to R - 2)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	19.2 ug/l	EPA .200.8 2 05/06/2019 21:29 BJ
40718 000204	33-CR-204: Room C208 (L to R - 3)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	65.9 ug/l*	EPA .200.8 2 05/09/2019 01:09 BJ
40718 000205	33-CR-205: Room C208 (L to R - 4)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	60.4 ug/l*	EPA .200.8 2 05/06/2019 21:34 BJ
40718 000206	33-CR-206: Room C208 (L to R - 5)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	150 ug/l*	EPA .200.8 2 05/06/2019 21:44 BJ
40718 000207	33-CR-207: Room C208 (L to R - 6)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	147 ug/l*	EPA .200.8 2 05/06/2019 21:49 BJ
40718 000208	33-CR-208: Room C208 (L to R - 7)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	18.5 ug/l	EPA .200.8 2 05/06/2019 21:52 BJ
40718 000209	33-CR-209: Room C208 (L to R - 8)	03/21/2019 04:48
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	19.8 ug/l	EPA .200.8 2 05/06/2019 21:54 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000210	33-OT-210: Room C207 storage	03/21/2019 04:51		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	37.3 ug/l*	EPA .200.8	2	05/06/2019 21:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000211	33-CR-211: Room C207 (L to R - 1)	03/21/2019 04:52		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	48.1 ug/l*	EPA .200.8	2	05/09/2019 01:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000212	33-CR-212: Room C207 (L to R - 2)	03/21/2019 04:52		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3270 ug/l*	EPA .200.8	2	05/09/2019 01:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000213	33-CR-213: Room C207 (L to R - 3)	03/21/2019 04:52		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	47.6 ug/l*	EPA .200.8	2	05/06/2019 22:05 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000214	33-CR-214: Room C207 (L to R - 4)	03/21/2019 04:52		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1 ug/l	EPA .200.8	2	05/06/2019 22:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000215	33-CR-215: Room C207 (L to R - 5)	03/21/2019 04:00		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non operational	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000216	33-CR-216: Room C207 (L to R - 6)	03/21/2019 04:52		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	112 ug/l*	EPA .200.8	2	05/06/2019 22:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40718 000217	33-CR-217: Room C207 (L to R - 7)	03/21/2019 04:52		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.12 ug/l	EPA .200.8	2	05/06/2019 22:22 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000218	33-CR-218: Room C203 (L to R - 1)	03/21/2019 04:59
Compound	Test Value Test Unit	Method
Lead	7.92 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:25 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000219	33-CR-219: Room C203 (L to R - 2)	03/21/2019 04:59
Compound	Test Value Test Unit	Method
Lead	53.3 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:27 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000220	33-CR-220: Room C203 (L to R - 3)	03/21/2019 04:59
Compound	Test Value TestUnit	Method
Lead	55.3 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:30 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000221	33-CR-221: Room C203 (L to R - 4)	03/21/2019 04:59
Compound	Test Value TestUnit	Method
Lead	34.3 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:32 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000222	33-CR-222: Room C203 (L to R - 5)	03/21/2019 04:59
Compound	Test Value TestUnit	Method
Lead	16.5 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:35 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000223	33-CR-223: Room C203 (L to R - 6)	03/21/2019 04:59
Compound	Test Value Test Unit	Method
Lead	108 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:37 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000224	33-CR-224: Room C203 (L to R - 7)	03/21/2019 04:59
Compound	Test Value TestUnit	Method
Lead	23.1 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:40 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000225	33-CR-225: Room C203 (L to R - 8)	03/21/2019 04:59
Compound	Test Value TestUnit	Method
Lead	30.6 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/06/2019 22:43 BJ



MARTEL NO. 40718	000226	CLIENT SAMPLE IDENTIFICATION 33-OT-226: Room C201				Sample Date/Time 03/21/2019 05:02	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			4.13	ug/l	EPA .200.8	2	05/06/2019 22:53 BJ

MARTEL NO. 40718	000227	CLIENT SAMPLE IDENTIFICATION 33-CR-227: Room C214 (L to R - 1)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			7.25	ug/l	EPA .200.8	2	05/06/2019 22:58 BJ

MARTEL NO. 40718	000228	CLIENT SAMPLE IDENTIFICATION 33-CR-228: Room C214 (L to R - 2)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			52.0	ug/l*	EPA .200.8	2	05/06/2019 23:00 BJ

MARTEL NO. 40718	000229	CLIENT SAMPLE IDENTIFICATION 33-CR-229: Room C214 (L to R - 3)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			63.2	ug/l*	EPA .200.8	2	05/06/2019 23:03 BJ

MARTEL NO. 40718	000230	CLIENT SAMPLE IDENTIFICATION 33-CR-230: Room C214 (L to R - 4)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			159	ug/l*	EPA .200.8	2	05/06/2019 23:05 BJ

MARTEL NO. 40718	000231	CLIENT SAMPLE IDENTIFICATION 33-CR-231: Room C214 (L to R - 5)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			94.4	ug/l*	EPA .200.8	2	05/06/2019 23:08 BJ

MARTEL NO. 40718	000232	CLIENT SAMPLE IDENTIFICATION 33-CR-232: Room C214 (L to R - 6)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			50.8	ug/l*	EPA .200.8	2	05/06/2019 23:10 BJ

MARTEL NO. 40718	000233	CLIENT SAMPLE IDENTIFICATION 33-CR-233: Room C214 (L to R - 7)				Sample Date/Time 03/21/2019 05:03	
Compound			Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead			16.8	ug/l	EPA .200.8	2	05/06/2019 23:13 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40718	000234	33-CR-234: Room C214 (L to R - 8)			03/21/2019 05:03
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		8.16	ug/l	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:15 BJ
40718	000235	33-CR-235: Room C214 (L to R - 9)			03/21/2019 05:03
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		55.3	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/09/2019 01:17 BJ
40718	000236	33-OT-236: Room C214/C226 storage (front)			03/21/2019 05:08
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		12.9	ug/l	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:25 BJ
40718	000237	33-CR-237: Room C226 (L to R - 1)			03/21/2019 05:10
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		54.8	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:33 BJ
40718	000238	33-CR-238: Room C226 (L to R - 2)			03/21/2019 05:10
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		83.7	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:36 BJ
40718	000239	33-CR-239: Room C226 (L to R - 3)			03/21/2019 05:10
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		23.7	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:38 BJ
40718	000240	33-CR-240: Room C226 (L to R - 4)			03/21/2019 05:10
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		9.96	ug/i	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:41 BJ
40718	000241	33-CR-241 : Room C226 (L to R - 5)			03/21/2019 05:10
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		27.7	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/06/2019 23:43 BJ



MARTEL NO. 40718	000242	CLIENT SAMPLE IDENTIFICATION 33-CR-242: Room C226 (L to R - 6)			Sample Date/Time 03/21/2019 05:10	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		26.9	ug/l*	EPA .200.8	2	05/06/2019 23:46 BJ

MARTEL NO. 40718	000243	CLIENT SAMPLE IDENTIFICATION 33-CR-243: Room C226 (L to R - 7)			Sample Date/Time 03/21/2019 05:10	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		93.0	ug/l*	EPA .200.8	2	05/06/2019 23:48 BJ

MARTEL NO. 40718	000244	CLIENT SAMPLE IDENTIFICATION 33-OT-244: /C229 Storage			Sample Date/Time 03/21/2019 05:12	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		49.2	ug/l*	EPA .200.8	2	05/06/2019 23:51 BJ

MARTEL NO. 40718	000245	CLIENT SAMPLE IDENTIFICATION 33-CR-245: Room C229 (L to R - 1)			Sample Date/Time 03/21/2019 05:13	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		11.3	ug/l	EPA .200.8	2	05/06/2019 23:53 BJ

MARTEL NO. 40718	000246	CLIENT SAMPLE IDENTIFICATION 33-CR-246: Room C229 (L to R - 2)			Sample Date/Time 03/21/2019 05:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		10.8	ug/l	EPA .200.8	2	05/07/2019 00:03 BJ

MARTEL NO. 40718	000247	CLIENT SAMPLE IDENTIFICATION 33-CR-247: Room C229 (L to R - 3)			Sample Date/Time 03/21/2019 05:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		14.4	ug/l	EPA .200.8	2	05/07/2019 00:09 BJ

MARTEL NO. 40718	000248	CLIENT SAMPLE IDENTIFICATION 33-CR-248: Room C229 (L to R - 4)			Sample Date/Time 03/21/2019 05:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		25.5	ug/l*	EPA .200.8	2	05/07/2019 00:11 BJ

MARTEL NO. 40718	000249	CLIENT SAMPLE IDENTIFICATION 33-CR-249: Room C229 (L to R - 5)			Sample Date/Time 03/21/2019 05:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		474	ug/l*	EPA .200.8	2	05/13/2019 17:07 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000250	33-CR-250: Room C229 (L to R - 6)	03/21/2019 05:15
Compound	Test Value Test Unit	Method
Lead	123 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/13/2019 17:10 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000251	33-CR-251: Room C229 (L to R - 7)	03/21/2019 05:15
Compound	Test Value Test Unit	Method
Lead	27.3 ug/l*	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000252	33-OT-252: Room C205	03/21/2019 05:16
Compound	Test Value Test Unit	Method
Lead	8.49 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000253	33-BS-253: C building 2nd floor single bathroom	03/21/2019 05:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000254	33-BS-254: C building 2nd floor single bathroom	03/21/2019 05:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000255	33-BS-255: C building 2nd floor girls bathroom	03/21/2019 05:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000256	33-BS-256: C building 2nd floor girls bathroom	03/21/2019 05:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:32 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000257	33-BS-257: C building 2nd floor boys bathroom	03/21/2019 05:20
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	05/07/2019 00:39 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000258	33-BS-258: C building 2nd floor boys bathroom	03/21/2019 05:20
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 00:42 BJ
40718 000259	33-TL-259: B building 2nd floor faculty room	03/21/2019 05:21
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	5.45 ug/l EPA .200.8	2 05/07/2019 00:44 BJ
40718 000260	33-OT-260: B building 2nd floor faculty room n	03/21/2019 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	15.8 ug/l EPA .200.8	2 05/07/2019 00:47 BJ
40718 000261	33-BS-261: B building 2nd floor single bathroo	03/21/2019 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 00:49 BJ
40718 000262	33-BS-262: B building 2nd floor single bathroom	03/21/2019 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 00:52 BJ
40718 000263	33-BS-263: B building 2nd floor girls bathroom	03/21/2019 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 00:54 BJ
40718 000264	33-BS-264: B building 2nd floor girls bathroom	03/21/2019 05:24
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 00:57 BJ
40718 000265	33-DF-265: B building 2nd floor fountain	03/21/2019 05:26
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/07/2019 01:00 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000266	33-BS-266: B building 2nd floor girls bathroom	03/21/2019 05:26
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/07/2019 01:10 BJ
40718 000267	33-BS-267: B building 2nd floor girls bathroom	03/21/2019 05:26
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/07/2019 01:15 BJ
40718 000268	33-CR-268: Room A222 (right)	03/21/2019 05:29
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.87 ug/l EPA .200.8 2	05/07/2019 01:17 BJ
40718 000269	33-CR-269: Room A222 (left)	03/21/2019 05:29
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.13 ug/l EPA .200.8 2	05/07/2019 01:20 BJ
40718 000270	33-CR-270: Room A221 (left)	03/21/2019 05:30
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.41 ug/l EPA .200.8 2	05/07/2019 01:22 BJ
40718 000271	33-CR-271: Room A221 (right)	03/21/2019 05:30
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/07/2019 01:25 BJ
40718 000272	33-BS-272: A building 2nd floor bathroom (left)	03/21/2019 05:31
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.88 ug/l EPA .200.8 2	05/07/2019 01:27 BJ
40718 000273	33-BS-273: A building 2nd floor bathroom (right)	03/21/2019 05:31
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	05/07/2019 01:30 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000274	33-DF-274: A building 2nd floor fountain (righ	03/21/2019 05:31
Compound	Test Value Test Unit	Method
Lead	2.01 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:33 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000275	33-DF-275: A building 2nd floor fountain (left	03/21/2019 05:31
Compound	Test Value Test Unit	Method
Lead	7.19 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:35 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000276	33-OT-276: A building dark room (right)	03/21/2019 05:33
Compound	Test Value Test Unit	Method
Lead	31.4 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000277	33-OT-277: A building dark room (left)	03/21/2019 05:33
Compound	Test Value Test Unit	Method
Lead	9.59 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000278	33-CR-278: Room D208	03/21/2019 05:35
Compound	Test Value Test Unit	Method
Lead	18.9 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:53 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000279	33-OT-279: D building SE storage	03/21/2019 05:36
Compound	Test Value Test Unit	Method
Lead	17.7 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000280	33-BS-280: D building 2nd floor single bathroo	03/21/2019 05:36
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 01:58 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40718 000281	33-BS-281: D building 2nd floor single bathroo	03/21/2019 05:36
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/07/2019 02:01 BJ	



MARTEL NO. 40718	000282	CLIENT SAMPLE IDENTIFICATION 33-DF-282: D building 2nd floor fountain	Sample Date/Time 03/21/2019 05:37		
Compound		Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8	2	05/07/2019 02:03 BJ

MARTEL NO. 40718	000283	CLIENT SAMPLE IDENTIFICATION 33-BS-283: D building 2nd floor girls bathroom	Sample Date/Time 03/21/2019 05:37		
Compound		Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8	2	05/07/2019 02:06 BJ

MARTEL NO. 40718	000284	CLIENT SAMPLE IDENTIFICATION 33-BS-284: D building 2nd floor girls bathroom	Sample Date/Time 03/21/2019 05:37		
Compound		Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8	2	05/07/2019 02:09 BJ

MARTEL NO. 40718	000285	CLIENT SAMPLE IDENTIFICATION 33-BS-285: D building 2nd floor boys bathroom	Sample Date/Time 03/21/2019 05:38		
Compound		Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		2.64 ug/l	EPA .200.8	2	05/07/2019 02:11 BJ

MARTEL NO. 40718	000286	CLIENT SAMPLE IDENTIFICATION 33-BS-286: D building 2nd floor boys bathroom	Sample Date/Time 03/21/2019 05:38		
Compound		Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		2.69 ug/l	EPA .200.8	2	05/07/2019 02:21 BJ

MARTEL NO. 40718	000287	CLIENT SAMPLE IDENTIFICATION 33-OT-287: Room C214/C226 storage (back)	Sample Date/Time 03/21/2019 05:07		
Compound		Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		6.12 ug/l	EPA .200.8	2	05/07/2019 02:26 BJ

MARTEL NO. 40718	000288	CLIENT SAMPLE IDENTIFICATION 33-DF-288: C building 2nd Floor Fountain	Sample Date/Time 03/21/2019 05:17		
Compound		Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2 ug/l	EPA .200.8	2	05/07/2019 02:29 BJ



Certificate of Analysis

Martel Laboratories_{JDS} Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CECILS

Page 23 OF 23

05/14/2019

stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Results exceed 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.