

Lead in Drinking Water – Public and Nonpublic Schools

NOTICE: WATER SAMPLE RESULT(S) **Perryville Elementary School**

WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On December 20, 2018, **seventy-six (76)** lead water samples were collected from **Perryville Elementary School**. Of these lead water samples, **zero (0)** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings.

IMMEDIATE ACTIONS TAKEN

Results were received on March 26, 2019. Because all water sample results were below the action level, no further action is required.

NEXT STEPS

The school will be resampled every three years in accordance with State regulations.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.


TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact **Perry Willis, Executive Director for Support Services**, at **410-996-5400**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



Cecil County Public Schools
201 Booth St.

Monday, March 25, 2019

Elkton, MD 21921

Attention: Andrew Curran

Report for Lab No: 40710.

Certificate of Analysis
FINAL

*Samples received by Martel from: Perryville Elementary School.
Project Identification: Water Analysis HB 270, sampled by Cecil County personnel.
December 20, 2018.*

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000001	15-BS-01: Room 105T	12/20/2018 05:30
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/05/2019 16:08 BJ
40710 000002	15-BS-02: Room 102T	12/20/2018 05:30
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/05/2019 16:21 BJ
40710 000003	15-IM-03: Nurses Office	12/20/2018 06:30
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/05/2019 16:23 BJ
40710 000004	15-BS-04: Kitchen bathroom	12/20/2018 05:34
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/05/2019 16:26 BJ
40710 000005	15-KS-05: Near kitchen office (right)	12/20/2018 05:35
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8 2 03/05/2019 16:28 BJ
40710 000006	15-KS-06: Near kitchen office (left)	12/20/2018 05:35
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40710 000006	15-KS-06: Near kitchen office (left)	12/20/2018 05:35		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.28 ug/l	EPA .200.8	2	03/21/2019 11:42 CSG
40710 000007	15-KS-07: Kitchen (south end)	12/20/2018 05:36		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:31 BJ
40710 000008	15-KS-08: Center of kitchen	12/20/2018 05:36		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:33 BJ
40710 000009	15-KS-09: Kitchen wash area (left)	12/20/2018 05:36		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:35 BJ
40710 000010	15-KS-10: Kitchen wash area (middle)	12/20/2018 05:36		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:38 BJ
40710 000011	15-KS-11 : Kitchen wash area (right)	12/20/2018 05:36		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:48 BJ
40710 000012	15-BS-12: Staff bathroom 1T	12/20/2018 05:39		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:53 BJ
40710 000013	15-BS-13: Boys bathroom 1B (right)	12/20/2018 05:40		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l	EPA .200.8	2	03/05/2019 16:56 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000014	15-BS-14: Boys bathroom 1B (left)	12/20/2018 05:40
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 16:58 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000015	15-BS-15: Girls bathroom 1G (right)	12/20/2018 05:40
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:01 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000016	15-BS-16: Girls bathroom 1G (left)	12/20/2018 05:40
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:03 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000017	15-DF-17: Fountain near Art (right)	12/20/2018 05:42
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:06 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000018	15-DF-18: Fountain near Art (left)	12/20/2018 05:42
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:08 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000019	15-CR-19: Music room	12/20/2018 05:43
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:11 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000020	15-CR-20: Art room (left)	12/20/2018 05:43
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:13 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000021	15-CR-21: Art room (middle)	12/20/2018 05:43
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 17:21 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000022	15-CR-22: Art room (right)	12/20/2018 05:43
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:28 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000023	15-TL-23: Teachers lounge (7)	12/20/2018 05:45
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:31 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000024	15-OT-24: Planning room (6)	12/20/2018 05:45
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:33 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000025	15-CR-25: Classroom 8	12/20/2018 05:46
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:36 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000026	15-CR-26: Classroom 8 (bathroom)	12/20/2018 05:46
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:38 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000027	15-BS-27: Classroom 9 (bathroom)	12/20/2018 05:48
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:41 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000028	15-CR-28: Classroom 9	12/20/2018 05:48
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:43 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000029	15-DF-29: Fountain near room 11 (left)	12/20/2018 05:50
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial
		03/05/2019 17:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000030	15-DF-30: Fountain near room 11 (right)	12/20/2018 05:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 17:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000031	15-CR-31: Classroom 11	12/20/2018 05:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 17:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000032	15-CR-32: Classroom 11 (bathroom)	12/20/2018 05:50
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA,200.8	2 03/05/2019 18:03 BJ


MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000033	15-CR-33: Classroom 13 (bathroom)	12/20/2018 05:52
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000034	15-CR-34: Classroom 13	12/20/2018 05:52
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000035	15-OT-35: Room 18	12/20/2018 05:52
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000036	15-OT-36: Room 101A (Media Center)	12/20/2018 05:54
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000037	15-DF-37: Fountain near cafeteria (right)	12/20/2018 05:59
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:16 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000038	15-DF-38: Fountain near cafeteria Bottle Fill	12/20/2018 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:18 BJ
40710 000039	15-DF-39: Fountain near cafeteria (left)	12/20/2018 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:21 BJ
40710 000040	15-BS-40: Boys bathroom nearcaf. (left)	12/20/2018 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:23 BJ
40710 000041	15-BS-41: Boys bathroom nearcaf. (right)	12/20/2018 06:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:31 BJ
40710 000042	15-BS-42: Girls bathroom near caf. (right)	12/20/2018 06:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:38 BJ
40710 000043	15-BS-43: Girls bathroom near caf. (left)	12/20/2018 06:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:41 BJ
40710 000044	15-CR-44: Classroom 24	12/20/2018 06:01
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:43 BJ
40710 000045	15-BS-45: Classroom 24 (bathroom)	12/20/2018 06:01
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 03/05/2019 18:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000046	15-CR-46: Classroom 25	12/20/2018 06:02
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 18:48 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000047	15-BS-47: Classroom 25 (bathroom)	12/20/2018 06:02
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 18:51 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000048	15-CR-48: Classroom 27	12/20/2018 06:03
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 18:53 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000049	15-BS-49: Classroom 27 (bathroom)	12/20/2018 06:03
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 18:56 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000050	15-CR-50: Classroom 28	12/20/2018 06:04
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 18:58 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000051	15-BS-51 : Classroom 28 (bathroom)	12/20/2018 06:04
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:08 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000052	15-CR-52: Classroom 31	12/20/2018 06:05
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:13 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000053	15-CR-53: Classroom 32	12/20/2018 06:05
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:16 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000054	15-OT-54: Classroom 34	12/20/2018 06:06
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:18 BJ
40710 000055	15-CR-55: Classroom 33	12/20/2018 06:07
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:21 BJ
40710 000056	15-CR-56: Classroom 36	12/20/2018 06:08
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:23 BJ
40710 000057	15-CR-57: Classroom 38	12/20/2018 06:08
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:26 BJ
40710 000058	15-CR-58: Classroom 41	12/20/2018 06:09
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:28 BJ
40710 000059	15-CR-59: Classroom 40	12/20/2018 06:09
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:31 BJ
40710 000060	15-CR-60: Classroom 39	12/20/2018 06:10
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:33 BJ
40710 000061	15-CR-61: Classroom 37	12/20/2018 06:10
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:41 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000062	15-BS-62: Boys bathroom 3B (right)	12/20/2018 06:12
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:48 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000063	15-BS-63: Boys bathroom 3B (left)	12/20/2018 06:12
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:51 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000064	15-BS-64: Girls bathroom 3G (left)	12/20/2018 06:12
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:53 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000065	15-BS-65: Girls bathroom 3G (right)	12/20/2018 06:12
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:56 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000066	15-BS-66: Staff bathroom 3T	12/20/2018 06:14
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 19:58 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000067	15-DF-67: Fountain near room 31 (left)	12/20/2018 06:15
Compound	Test Value TestUnit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 20:01 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000068	15-DF-68: Fountain near room 31 (right)	12/20/2018 06:15
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 20:03 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40710 000069	15-CR-69: Classroom 29	12/20/2018 06:16
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
	Detection Limit	Analysis Date/Time/Initial
	2	03/05/2019 20:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000070	15-CR-70: Classroom 26				12/20/2018 06:16
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:08 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000071	15-NO-71: Nurses office				12/20/2018 06:17
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:18 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000072	15-NO-72: Nurses office (exam room)				12/20/2018 06:17
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:23 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000073	15-BS-73: Nurses office (bathroom)				12/20/2018 06:17
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:26 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000074	15-OT-74: Guidance (room 100P)				12/20/2018 06:18
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:29 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000075	15-BS-75: Main office bathroom (left)				12/20/2018 06:19
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:31 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40710 000076	15-BS-76: Main office bathroom (right)				12/20/2018 06:19
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/05/2019 20:34 BJ



Certificate of Analysis

Martel Laboratories, JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CECILS

Page 11 OF 11

03/25/2019

stddl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager