

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Perryville High School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On March 28 & 29, 2019, **one hundred thirty-eight (138)** lead water samples were collected from **Perryville High School**. Of these lead water samples, **eighty-one (81)** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Perryville High were as follows:

111 parts per billion (ppb) Custodian locker bathroom (use: non-consumption)
53.3 parts per billion (ppb) Kitchen hand sink (use: non-consumption)
59.1 parts per billion (ppb) Kitchen bathroom (use: non-consumption)
21.5 parts per billion (ppb) Kitchen hand sink (use: non-consumption)
37.0 parts per billion (ppb) Kitchen sink (right) (use: consumption)
201 parts per billion (ppb) Kitchen sink (left) (use: consumption)
126 parts per billion (ppb) Room C106 plan room (use: consumption)
25.2 parts per billion (ppb) Room C107 (use: non-consumption)
210 parts per billion (ppb) Room C108 (left) (use: non-consumption)
581 parts per billion (ppb) Room C108 (right) (use: non-consumption)
226 parts per billion (ppb) Room C108 fountain (use: non-consumption)
28.6 parts per billion (ppb) Room C112 – CTE (use: non-consumption)
217 parts per billion (ppb) Room C110 - CTE (left) (use: non-consumption)
186 parts per billion (ppb) Room C110 - CTE (right) (use: non-consumption)
28.7 parts per billion (ppb) Room C113 - F&CS (L to R - 5) (use: consumption)
188 parts per billion (ppb) Girls bathroom (right) (use: non-consumption)
56.9 parts per billion (ppb) Girls bathroom (left) (use: non-consumption)
79.0 parts per billion (ppb) Room C118 - comp lab (use: non-consumption)
29.0 parts per billion (ppb) Room C123 (use: non-consumption)
135 parts per billion (ppb) Room C122 (use: consumption)
1890 parts per billion (ppb) Room C121 (use: consumption)
46.6 parts per billion (ppb) Faculty room C304 (use: consumption)
33.1 parts per billion (ppb) Faculty C304 bathroom (right) (use: non-consumption)
192 parts per billion (ppb) Boys locker room (left) (use: non-consumption)
227 parts per billion (ppb) Boys locker room (middle) (use: non-consumption)
43.8 parts per billion (ppb) Boys locker room (right) (use: non-consumption)
34.7 parts per billion (ppb) Women's bathroom at tennis courts (right) (use: non-consumption)
44.2 parts per billion (ppb) Women's bathroom near tennis courts (left) (use: non-consumption)
49.7 parts per billion (ppb) Men's bathroom near tennis courts (right) (use: non-consumption)
104 parts per billion (ppb) Girls locker room (left) (use: non-consumption)
112 parts per billion (ppb) Girls locker room (middle) (use: non-consumption)
50.9 parts per billion (ppb) Girls locker room (right) (use: non-consumption)
643 parts per billion (ppb) Girls locker room fountain (use: consumption)
41.9 parts per billion (ppb) Main office men's bathroom (use: non-consumption)
1880 parts per billion (ppb) Dressing room left of stage (left) (use: non-consumption)
138 parts per billion (ppb) Dressing room left of stage (middle) (use: non-consumption)
231 parts per billion (ppb) Dressing room left of stage (right) (use: non-consumption)
26.2 parts per billion (ppb) Dressing room right of stage (right) (use: non-consumption)
27.6 parts per billion (ppb) Stadium Building Men's Bathroom (right) (use: non-consumption)
20.5 parts per billion (ppb) Room F239 (bathroom) (use: non-consumption)
966 parts per billion (ppb) Room F239 dressing room (left) (use: non-consumption)

33.7 parts per billion (ppb) Room F237 (use: non-consumption)
24.1 parts per billion (ppb) 2nd floor boy's bathroom near F-wing (right) (use: non-consumption)
23.2 parts per billion (ppb) Media center work room (use: consumption)
37.2 parts per billion (ppb) Room E216 (use: non-consumption)
145 parts per billion (ppb) Room E217 (use: non-consumption)
191 parts per billion (ppb) Room D204 (use: non-consumption)
62.0 parts per billion (ppb) Room E212 (left) (use: non-consumption)
23.6 parts per billion (ppb) Room E218 storage room (use: non-consumption)
81.0 parts per billion (ppb) Room E218 (R to L - 1) (use: non-consumption)
23.5 parts per billion (ppb) Room E218 (R to L - 2) (use: non-consumption)
149 parts per billion (ppb) Room E218 (R to L - 3) (use: non-consumption)
38.8 parts per billion (ppb) Room E218 (R to L - 4) (use: non-consumption)
69.1 parts per billion (ppb) Room E218 (R to L - 5) (use: non-consumption)
282 parts per billion (ppb) Room E218 (R to L - 6) (use: non-consumption)
155 parts per billion (ppb) Room E219 (L to R - 1) (use: non-consumption)
174 parts per billion (ppb) Room E219 (L to R - 2) (use: non-consumption)
159 parts per billion (ppb) Room E219 (L to R - 3) (use: non-consumption)
69.6 parts per billion (ppb) Room E219 (L to R - 4) (use: non-consumption)
507 parts per billion (ppb) Room E219 (L to R - 6) (use: non-consumption)
53.6 parts per billion (ppb) Room E219 (L to R - 7) (use: non-consumption)
209 parts per billion (ppb) Room E219 (L to R - 8) (use: non-consumption)
95.1 parts per billion (ppb) Room E220 (L to R - 2) (use: non-consumption)
1080 parts per billion (ppb) Room E220 (L to R - 5) (use: non-consumption)
118 parts per billion (ppb) Room E220 (L to R - 6) (use: non-consumption)
73.8 parts per billion (ppb) Room E220 (L to R - 7) (use: non-consumption)
171 parts per billion (ppb) Room E221 (L to R - 1) (use: non-consumption)
308 parts per billion (ppb) Room E221 (L to R - 2) (use: non-consumption)
125 parts per billion (ppb) Room E221 (L to R - 3) (use: non-consumption)
2630 parts per billion (ppb) Room E221 (L to R - 4) (use: non-consumption)
623 parts per billion (ppb) Room E221 (L to R - 5) (use: non-consumption)
97.0 parts per billion (ppb) Room E221 (L to R - 6) (use: non-consumption)
110 parts per billion (ppb) Room E221 (L to R - 7) (use: non-consumption)
49.7 parts per billion (ppb) Room E221 (L to R - 8) (use: non-consumption)
38.4 parts per billion (ppb) Room E222 (L to R - 1) (use: non-consumption)
58.1 parts per billion (ppb) Room E222 (L to R - 2) (use: non-consumption)
394 parts per billion (ppb) Room E222 (L to R - 3) (use: non-consumption)
73.6 parts per billion (ppb) Room E222 (L to R - 4) (use: non-consumption)
96.8 parts per billion (ppb) Room E222 (L to R - 5) (use: non-consumption)
293 parts per billion (ppb) Room E222 (L to R - 6) (use: non-consumption)
107 parts per billion (ppb) Room E222 (L to R - 7) (use: non-consumption)

IMMEDIATE ACTIONS TAKEN

Results were received on June 12, 2019. A sign has been posted at each sink noted above, indicating that they are not to be used for consumption purposes. The two water fountains have been taken out of operation.

NEXT STEPS

All water outlets noted above will continue to be used only for non-consumption purposes (e.g., hand washing), or remain out of service, until remedial actions have taken place and follow up sampling shows results with levels below the action level.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact **Perry Willis, Executive Director for Support Services**, at **410-996-5400**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



Cecil County Public Schools
201 Booth St.

Tuesday, June 11, 2019

Elkton, MD 21921

Certificate of Analysis

Attention: Andrew Curran

FINAL

Report for Lab No: 40719.

Samples received by Martel from: Perryville HS

Project Identification: Water Analysis HB 270, sampled by Cecil County personnel.

Received on April 2, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000001	34-OT-01: Room C138	03/28/2019 05:00
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	not tested EPA .200.8	2 //
40719 000002	34-BS-02: Custodian Office bathroom	03/28/2019 05:01
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	9.38 ug/l EPA .200.8	2 05/08/2019 16:53 BJ
40719 000003	34-BS-03: Custodian locker room bathroom	03/28/2019 05:01
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	111 ug/l* EPA .200.8	2 05/08/2019 17:05 BJ
40719 000004	34-OT-04: Room A102	03/28/2019 05:02
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	5.83 ug/l EPA .200.8	2 05/08/2019 17:08 BJ
40719 000005	34-DF-05: Fountain near back entrance of kitchen	03/28/2019 05:02
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/08/2019 17:10 BJ
40719 000006	34-KS-06: Kitchen	03/28/2019 06:10
Compound	Test Value Test Unit	Method Detection Limit Analysis Date/Time/Initial
Lead	53.3 ug/l* EPA .200.8	2 05/08/2019 17:12 BJ

A

MARTEL NO. 40719	000007	CLIENT SAMPLE IDENTIFICATION 34-BS-07: Kitchen bathroom	Sample Date/Time 03/28/2019 06:10
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	59.1	ug/l*	EPA .200.8	2	05/08/2019 17:15 BJ

MARTEL NO. 40719	000008	CLIENT SAMPLE IDENTIFICATION 34-KS-08: Kitchen	Sample Date/Time 03/28/2019 06:12
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	21.5	ug/l*	EPA .200.8	2	05/08/2019 17:17 BJ

MARTEL NO. 40719	000009	CLIENT SAMPLE IDENTIFICATION 34-KS-09: Kitchen	Sample Date/Time 03/28/2019 06:12
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	37.0	ug/l*	EPA .200.8	2	05/08/2019 17:20 BJ

MARTEL NO. 40719	000010	CLIENT SAMPLE IDENTIFICATION 34-KS-10: Kitchen	Sample Date/Time 03/28/2019 06:12
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	201	ug/l*	EPA .200.8	2	05/08/2019 17:22 BJ

MARTEL NO. 40719	000011	CLIENT SAMPLE IDENTIFICATION 34-KS-11: Kitchen	Sample Date/Time 03/28/2019 06:12
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.8	ug/l	EPA .200.8	2	05/08/2019 17:33 BJ

MARTEL NO. 40719	000012	CLIENT SAMPLE IDENTIFICATION 34-OT-12: Room C106 side room (right)	Sample Date/Time 03/28/2019 05:04
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.04	ug/l	EPA .200.8	2	05/08/2019 17:38 BJ

MARTEL NO. 40719	000013	CLIENT SAMPLE IDENTIFICATION 34-OT-13: Room C106 side room (left)	Sample Date/Time 03/28/2019 05:04
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.82	ug/l	EPA .200.8	2	05/08/2019 17:40 BJ

MARTEL NO. 40719	000014	CLIENT SAMPLE IDENTIFICATION 34-CR-14: Room C106	Sample Date/Time 03/28/2019 05:04
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.4	ug/l	EPA .200.8	2	05/08/2019 17:43 BJ

A

MARTEL NO. 40719	000015	CLIENT SAMPLE IDENTIFICATION 34-OT-15: Room C106 plan room	Sample Date/Time 03/28/2019 05:04
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/initial
Lead	126	ug/l*	EPA .200.8	2	05/08/2019 17:45 BJ

MARTEL NO. 40719	000016	CLIENT SAMPLE IDENTIFICATION 34-HE-16: Room C107	Sample Date/Time 03/28/2019 05:05
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.2	ug/l*	EPA .200.8	2	05/08/2019 17:48 BJ

MARTEL NO. 40719	000017	CLIENT SAMPLE IDENTIFICATION 34-CR-17: Room C105 (left)	Sample Date/Time 03/28/2019 05:05
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 17:50 BJ

MARTEL NO. 40719	000018	CLIENT SAMPLE IDENTIFICATION 34-CR-18: Room C105 (right)	Sample Date/Time 03/28/2019 05:05
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 17:53 BJ

MARTEL NO. 40719	000019	CLIENT SAMPLE IDENTIFICATION 34-CR-19: Room C108 (left)	Sample Date/Time 03/28/2019 05:07
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	210	ug/l*	EPA .200.8	2	05/08/2019 17:55 BJ

MARTEL NO. 40719	000020	CLIENT SAMPLE IDENTIFICATION 34-CR-20: Room C108 (right)	Sample Date/Time 03/28/2019 05:07
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	581	ug/l*	EPA .200.8	2	05/08/2019 17:58 BJ

MARTEL NO. 40719	000021	CLIENT SAMPLE IDENTIFICATION 34-CF-21: Room C108 fountain	Sample Date/Time 03/28/2019 05:07
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	226	ug/l*	EPA .200.8	2	05/08/2019 18:05 BJ

MARTEL NO. 40719	000022	CLIENT SAMPLE IDENTIFICATION 34-CR-22: Room C112 - CTE	Sample Date/Time 03/28/2019 05:10
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	28.6	ug/l*	EPA .200.8	2	05/08/2019 18:13 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000023	34-CR-23: Room C110 - CTE (left)	03/28/2019 05:12		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	217 ug/l*	EPA .200.8	2	05/08/2019 18:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000024	34-CR-24: Room C110 - CTE (right)	03/28/2019 05:12		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	186 ug/l*	EPA .200.8	2	05/08/2019 18:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000025	34-HE-25: Room C113 - F&CS (L to R - 1)	03/28/2019 05:15		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.94 ug/l	EPA .200.8	2	05/08/2019 18:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000026	34-HE-26: Room C113 - F&CS (L to R - 2)	03/28/2019 05:15		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.69 ug/l	EPA .200.8	2	05/08/2019 18:23 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000027	34-HE-27: Room C113 - F&CS (L to R - 3)	03/28/2019 05:15		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.2 ug/l	EPA .200.8	2	05/08/2019 18:25 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000028	34-HE-28: Room C113 - F&CS (L to R - 4)	03/28/2019 05:15		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.48 ug/l	EPA .200.8	2	05/08/2019 18:28 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000029	34-HE-29: Room C113 - F&CS (L to R - 5)	03/28/2019 05:15		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	28.7 ug/l*	EPA .200.8	2	05/08/2019 18:30 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000030	34-BS-30: Room C114 bathroom	03/28/2019 05:18		
Compound	Test Value TestUnit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.4 ug/l	EPA .200.8	2	05/08/2019 18:33 BJ

MARTEL NO. 40719	000031	CLIENT SAMPLE IDENTIFICATION 34-CR-31 : Room C115 - CTE	Sample Date/Time 03/28/2019 05:18
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.9	ug/l	EPA .200.8	2	05/08/2019 18:43 BJ

MARTEL NO. 40719	000032	CLIENT SAMPLE IDENTIFICATION 34-OT-32: Room C114	Sample Date/Time 03/28/2019 05:18
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.5	ug/l	EPA .200.8	2	05/08/2019 18:48 BJ

MARTEL NO. 40719	000033	CLIENT SAMPLE IDENTIFICATION 34-BS-33: Girls bathroom (right)	Sample Date/Time 03/28/2019 05:21
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	188	ug/l*	EPA .200.8	2	05/08/2019 18:50 BJ

MARTEL NO. 40719	000034	CLIENT SAMPLE IDENTIFICATION 34-BS-34: Girls bathroom (left)	Sample Date/Time 03/28/2019 05:21
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	56.9	ug/l*	EPA .200.8	2	05/08/2019 18:53 BJ

MARTEL NO. 40719	000035	CLIENT SAMPLE IDENTIFICATION 34-BS-35: Boys bathroom (left)	Sample Date/Time 03/28/2019 05:21
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.9	ug/l	EPA .200.8	2	05/08/2019 18:55 BJ

MARTEL NO. 40719	000036	CLIENT SAMPLE IDENTIFICATION 34-BS-36: Boys bathroom (right)	Sample Date/Time 03/28/2019 05:21
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.00	ug/l	EPA .200.8	2	05/08/2019 18:58 BJ

MARTEL NO. 40719	000037	CLIENT SAMPLE IDENTIFICATION 34-DF-37: Fountain outside of room C110	Sample Date/Time 03/28/2019 05:21
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 19:00 BJ

MARTEL NO. 40719	000038	CLIENT SAMPLE IDENTIFICATION 34-BS-38: Room C305 bathroom	Sample Date/Time 03/28/2019 05:30
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 19:03 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000039	34-CR-39: Room C118 - comp lab				03/28/2019 05:30
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	79.0	ug/l*	EPA .200.8	2	05/08/2019 19:05 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000040	34-CR-40: Room C123				03/28/2019 05:30
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.0	ug/l*	EPA .200.8	2	05/08/2019 19:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000041	34-CR-41: Room C122				03/28/2019 05:30
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	135	ug/l*	EPA .200.8	2	06/10/2019 14:28 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000042	34-CR-42: Room C121				03/28/2019 06:20
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1890	ug/l*	EPA .200.8	2	06/10/2019 14:30 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000043	34-TL-43: Faculty room C304				03/28/2019 05:35
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	46.6	ug/l*	EPA .200.8	2	05/08/2019 19:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000044	34-BS-44: Faculty room C304 bathroom (left)				03/28/2019 05:35
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.5	ug/l	EPA .200.8	2	05/08/2019 19:23 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000045	34-BS-45: Faculty room C304 bathroom (right)				03/28/2019 05:35
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	33.1	ug/l*	EPA .200.8	2	05/08/2019 19:25 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000046	34-DF-46: Boys locker room fountain				03/28/2019 05:38
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 19:28 BJ



MARTEL NO. 40719	000047	CLIENT SAMPLE IDENTIFICATION 34-BS-47: Boys locker room office bathroom	Sample Date/Time 03/28/2019 05:40
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.7	ug/l	EPA .200.8	2	05/08/2019 19:30 BJ

MARTEL NO. 40719	000048	CLIENT SAMPLE IDENTIFICATION 34-BS-48: Boys locker room (left)	Sample Date/Time 03/28/2019 05:40
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	192	ug/l*	EPA .200.8	2	05/08/2019 19:33 BJ

MARTEL NO. 40719	000049	CLIENT SAMPLE IDENTIFICATION 34-BS-49: Boys locker room (middle)	Sample Date/Time 03/28/2019 05:40
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	227	ug/l*	EPA .200.8	2	05/08/2019 19:35 BJ

MARTEL NO. 40719	000050	CLIENT SAMPLE IDENTIFICATION 34-BS-50: Boys locker room (right)	Sample Date/Time 03/28/2019 05:40
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	43.8	ug/l*	EPA .200.8	2	05/08/2019 19:38 BJ

MARTEL NO. 40719	000051	CLIENT SAMPLE IDENTIFICATION 34-OT-51: Laundry room	Sample Date/Time 03/28/2019 05:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	tested	EPA .200.8	2	//

MARTEL NO. 40719	000052	CLIENT SAMPLE IDENTIFICATION 34-BS-52: Womens bathroom near tennis courts (ri	Sample Date/Time 03/28/2019 06:28
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	34.7	ug/l*	EPA .200.8	2	05/08/2019 19:48 BJ

MARTEL NO. 40719	000053	CLIENT SAMPLE IDENTIFICATION 34-BS-53: Womens bathroom near tennis courts (le	Sample Date/Time 03/28/2019 06:28
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	44.2	ug/l*	EPA .200.8	2	06/10/2019 14:33 BJ

MARTEL NO. 40719	000054	CLIENT SAMPLE IDENTIFICATION 34-BS-54: Mens bathroom near tennis courts (righ	Sample Date/Time 03/28/2019 06:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	49.7	ug/l*	EPA .200.8	2	06/10/2019 14:35 BJ

MARTEL NO. 40719 000055 CLIENT SAMPLE IDENTIFICATION 34-BS-55: Mens bathroom near tennis courts (left) Sample Date/Time 03/28/2019 06:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational EPA	.200.8	2	//

MARTEL NO. 40719 000056 CLIENT SAMPLE IDENTIFICATION 34-OT-56: Ice room near tennis courts (left) Sample Date/Time 03/28/2019 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/08/2019 19:53 BJ

MARTEL NO. 40719 000057 CLIENT SAMPLE IDENTIFICATION 34-OT-57: Ice room near tennis courts (right) Sample Date/Time 03/28/2019 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	tested	EPA .200.8	2	//

MARTEL NO. 40719 000058 CLIENT SAMPLE IDENTIFICATION 34-IM-58: Ice room near tennis courts - ice mach Sample Date/Time 03/28/2019 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.91	ug/l	EPA .200.8	2	05/08/2019 19:55 BJ

MARTEL NO. 40719 000059 CLIENT SAMPLE IDENTIFICATION 34-DF-59: Outside fountain near tennis courts Sample Date/Time 03/28/2019 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational EPA	.200.8	2	//

MARTEL NO. 40719 000060 CLIENT SAMPLE IDENTIFICATION 34-BS-60: Girls locker room (left) Sample Date/Time 03/28/2019 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	104	ug/l*	EPA .200.8	2	06/10/2019 14:38 BJ

MARTEL NO. 40719 000061 CLIENT SAMPLE IDENTIFICATION 34-BS-61: Girls locker room (middle) Sample Date/Time 03/28/2019 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	112	ug/l*	EPA .200.8	2	06/10/2019 14:40 BJ

MARTEL NO. 40719 000062 CLIENT SAMPLE IDENTIFICATION 34-BS-62: Girls locker room (right) Sample Date/Time 03/28/2019 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	50.9	ug/l*	EPA .200.8	2	05/08/2019 20:03 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000063	34-BS-63: Girls locker room office bathroom	03/28/2019 05:46
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	9.47 ug/l EPA .200.8	2 05/08/2019 20:10 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000064	34-DF-64: Girls locker room fountain	03/28/2019 05:46
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	643 ug/l* EPA .200.8	2 05/08/2019 20:13 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000065	34-IM-65: Gym storage room ice machine	03/28/2019 06:16
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/08/2019 20:15 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000066	34-OT-66: Gym storage room	03/28/2019 06:16
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	7.37 ug/l EPA .200.8	2 05/08/2019 20:18 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000067	34-DF-67: Fountain near main entrance	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000068	34-BS-68: Nurses office bathroom	03/28/2019 05:51
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.35 ug/l EPA .200.8	2 05/08/2019 20:20 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000069	34-NO-69: Nurses office	03/28/2019 05:51
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/08/2019 20:23 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000070	34-BS-70: Asst. Principal office bathroom	03/28/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	no fixture EPA .200.8	2 //

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000071	34-OT-71 : Main office work room	03/28/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	no fixture EPA .200.8	2 //
40719 000072	34-BS-72: Main office mens bathroom	03/28/2019 05:55
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	41.9 ug/l* EPA .200.8	2 05/08/2019 20:33 BJ
40719 000073	34-BS-73: Main office womens bathroom	03/28/2019 05:55
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	16.0 ug/l EPA .200.8	2 05/08/2019 20:38 BJ
40719 000074	34-BS-74: Main entrance mens bathroom (right)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	12.1 ug/l EPA .200.8	2 05/08/2019 20:40 BJ
40719 000075	34-BS-75: Main entrance mens bathroom (left)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	4.70 ug/l EPA .200.8	2 05/08/2019 20:43 BJ
40719 000076	34-BS-76: Main entrance womens bathroom (left)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //
40719 000077	34-BS-77: Main entrance womens bathroom (right)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	4.00 ug/l EPA .200.8	2 05/08/2019 20:45 BJ
40719 000078	34-BS-78: Dress room left of stage (bathroom)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000079	34-OT-79: Dress room left of stage (left)	03/28/2019 06:03		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1880 ug/l*	EPA .200.8	2	06/10/2019 14:42 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000080	34-OT-80: Dress room left of stage (middle)	03/28/2019 06:03		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	138 ug/l*	EPA .200.8	2	06/10/2019 14:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000081	34-OT-81: Dress room left of stage (right)	03/28/2019 06:03		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	231 ug/l*	EPA .200.8	2	05/08/2019 20:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000082	34-BS-82: Dress room right of stage (bathroom)	03/28/2019 06:07		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.81 ug/l	EPA .200.8	2	05/08/2019 21:01 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000083	34-OT-83: Dress room right of stage (left)	03/28/2019 06:07		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.0 ug/l	EPA .200.8	2	05/08/2019 21:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000084	34-OT-84: Dress room right of stage (middle)	03/28/2019 06:07		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.02 ug/l	EPA .200.8	2	05/08/2019 21:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000085	34-OT-85: Dress room right of stage (right)	03/28/2019 06:07		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.2 ug/l*	EPA .200.8	2	05/08/2019 21:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000086	34-DF-86: Fountain outside of counselors office	03/28/2019 06:08		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.50 ug/l	EPA .200.8	2	05/08/2019 21:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000087	34-DF-87: Fountain in cafeteria	03/28/2019 06:08
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/08/2019 21:13 BJ
40719 000088	34-HE-88: Room (113-F + CS(L-R-6))	03/28/2019 05:15
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	19.1 ug/l EPA .200.8	2 05/08/2019 21:16 BJ
40719 000089	34-BS-89: Stadium Building Mens Bathroom (left)	03/28/2019 06:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.83 ug/l EPA .200.8	2 05/08/2019 21:18 BJ
40719 000090	34-BS-90: Stadium Building Mens Bathroom (right)	03/28/2019 06:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	27.6 ug/l* EPA .200.8	2 05/08/2019 21:21 BJ
40719 000091	34-OT-91: Stadium Building Concession Stand	03/28/2019 06:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.67 ug/l EPA .200.8	2 05/08/2019 21:31 BJ
40719 000092	34-BS-92: Stadium Building Womens Bathroom (left)	03/28/2019 06:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.91 ug/l EPA .200.8	2 05/08/2019 21:36 BJ
40719 000093	34-BS-93: Stadium Building Womens Bathroom (right)	03/28/2019 06:45
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.05 ug/l EPA .200.8	2 05/08/2019 21:38 BJ
40719 000201	34-OT-201: 2nd floor ""stage"" dress room (right)	03/28/2019 06:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000202	34-BS-202: 2nd floor ""stage"" dress room (bath)	03/28/2019 05:25
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	20.5 ug/l EPA .200.8	2 05/08/2019 21:41 BJ
40719 000203	34-OT-203: 2nd floor ""stage"" dress room (I	03/28/2019 05:25
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	966 ug/l* EPA .200.8	2 05/08/2019 21:43 BJ
40719 000204	34-OT-204: Room F237 Pub. Room	03/28/2019 05:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //
40719 000205	34-CR-205: Room F237	03/28/2019 05:28
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	33.7 ug/l* EPA .200.8	2 05/08/2019 21:46 BJ
40719 000206	34-BS-206: 2nd floor boys bathroom near F-wing (03/28/2019 05:30
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	17.8 ug/l EPA .200.8	2 05/08/2019 21:48 BJ
40719 000207	34-BS-207: 2nd floor boys bathroom near F-wing (03/28/2019 05:30
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	24.1 ug/l* EPA .200.8	2 05/08/2019 21:51 BJ
40719 000208	34-BS-208: 2nd floor girls bathroom near F-wing	03/28/2019 05:30
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	15.2 ug/l EPA .200.8	2 05/08/2019 21:59 BJ
40719 000209	34-BS-209: 2nd floor girls bathroom near F-wing	03/28/2019 05:30
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	14.5 ug/l EPA .200.8	2 05/08/2019 22:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000210	34-DF-210: Fountain near 2nd floor F-wing bathro	03/28/2019 05:31
Compound	Test Value Test Unit	Method
Lead	2.77 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:09 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000211	34-DF-211 : Fountain near 2nd floor elevator	03/28/2019 05:34
Compound	Test Value Test Unit	Method
Lead	2.24 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:11 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000212	34-OT-212: Media center work room	03/28/2019 06:12
Compound	Test Value Test Unit	Method
Lead	23.2 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:14 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000213	34-OT-213: Room E216	03/28/2019 05:36
Compound	Test Value Test Unit	Method
Lead	37.2 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:16 BJ	


MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000214	34-OT-214: Room E217	03/28/2019 05:37
Compound	Test Value TestUnit	Method
Lead	145 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:19 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000215	34-BS-215: 2nd floor mens bathroom	03/28/2019 05:39
Compound	Test Value TestUnit	Method
Lead	20.3 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:21 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000216	34-BS-216: 2nd floor womens bathroom	03/28/2019 05:39
Compound	Test Value Test Unit	Method
Lead	15.7 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:24 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000217	34-DF-217: Fountain outside of 2nd floor E-wing	03/28/2019 05:39
Compound	Test Value Test Unit	Method
Lead	<2 ug/l	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/08/2019 22:27 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000218	34-BS-218: 2nd floor boys bathroom near E-wing (03/28/2019 05:41
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	14.6 ug/l EPA .200.8	2 05/08/2019 22:36 BJ
40719 000219	34-BS-219: 2nd floor boys bathroom near E-wing (03/28/2019 05:41
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	7.45 ug/l EPA .200.8	2 05/08/2019 22:42 BJ
40719 000220	34-BS-220: 2nd floor girls bathroom near E-wing	03/28/2019 05:41
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	9.62 ug/l EPA .200.8	2 05/08/2019 22:44 BJ
40719 000221	34-BS-221: 2nd floor girls bathroom near E-wing	03/28/2019 05:41
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	4.21 ug/l EPA .200.8	2 05/08/2019 22:47 BJ
40719 000222	34-BS-222: Room D204 bathroom	03/28/2019 06:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	11.0 ug/l EPA .200.8	2 05/08/2019 22:49 BJ
40719 000223	34-CR-223: Room D204	03/28/2019 06:12
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	191 ug/l* EPA .200.8	2 05/08/2019 22:52 BJ
40719 000224	34-CR-224: Room E212 (left)	03/28/2019 05:44
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	62.0 ug/l* EPA .200.8	2 05/08/2019 22:54 BJ
40719 000225	34-CR-225: Room E212 (right)	03/28/2019 05:00
Compound	Test Value TestUnit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 //



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000226	34-OT-226: Room E218 storage room			03/28/2019 05:47
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		23.6	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 22:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000227	34-CR-227: Room E218 (R to L - 1)			03/28/2019 05:47
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		81.0	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					06/10/2019 14:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000228	34-CR-228: Room E218 (R to L - 2)			03/28/2019 05:47
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		23.5	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 23:05 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000229	34-CR-229: Room E218 (R to L - 3)			03/28/2019 05:47
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		149	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 23:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000230	34-CR-230: Room E218 (R to L - 4)			03/28/2019 05:47
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		38.8	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 23:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000231	34-CR-231: Room E218 (R to L - 5)			03/28/2019 05:49
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		69.1	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 23:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000232	34-CR-232: Room E218 (R to L - 6)			03/28/2019 05:49
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		282	ug/l*	EPA .200.8	2
					Analysis Date/Time/Initial
					05/08/2019 23:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719	000233	34-CR-233: Room E218 (R to L - 7)			03/29/2019 05:00
Compound		Test Value	Test Unit	Method	Detection Limit
Lead		non	operational	EPA .200.8	2
					Analysis Date/Time/Initial
					//

MARTEL NO. 40719 000234 CLIENT SAMPLE IDENTIFICATION 34-OT-234: Room E218 (R to L - 8) Sample Date/Time 03/29/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational EPA .200.8		2	//

MARTEL NO. 40719 000235 CLIENT SAMPLE IDENTIFICATION 34-CR-235: Room E218 (center) Sample Date/Time 03/29/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational EPA .200.8		2	//

MARTEL NO. 40719 000236 CLIENT SAMPLE IDENTIFICATION 34-CR-236: Room E219 (L to R - 1) Sample Date/Time 03/29/2019 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	155	ug/l*	EPA .200.8	2	05/08/2019 23:22 BJ

MARTEL NO. 40719 000237 CLIENT SAMPLE IDENTIFICATION 34-CR-237: Room E219 (L to R - 2) Sample Date/Time 03/29/2019 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	174	ug/l*	EPA .200.8	2	05/08/2019 23:25 BJ

MARTEL NO. 40719 000238 CLIENT SAMPLE IDENTIFICATION 34-CR-238: Room E219 (L to R - 3) Sample Date/Time 03/29/2019 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	159	ug/l*	EPA .200.8	2	05/08/2019 23:35 BJ

MARTEL NO. 40719 000239 CLIENT SAMPLE IDENTIFICATION 34-CR-239: Room E219 (L to R - 4) Sample Date/Time 03/29/2019 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	69.6	ug/l*	EPA .200.8	2	05/08/2019 23:40 BJ

MARTEL NO. 40719 000240 CLIENT SAMPLE IDENTIFICATION 34-CR-240: Room E219 (L to R - 5) Sample Date/Time 03/29/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational EPA .200.8		2	//

MARTEL NO. 40719 000241 CLIENT SAMPLE IDENTIFICATION 34-CR-241: Room E219 (L to R - 6) Sample Date/Time 03/29/2019 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	507	ug/l*	EPA .200.8	2	05/08/2019 23:43 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000242	34-CR-242: Room E219 (L to R - 7)				03/29/2019 05:54
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	53.6	ug/l*	EPA .200.8	2	06/10/2019 15:00 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000243	34-CR-243: Room E219 (L to R - 8)				03/29/2019 05:54
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	209	ug/l*	EPA .200.8	2	05/08/2019 23:45 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000244	34-CR-244: Room E220 (L to R - 1)				03/29/2019 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000245	34-CR-245: Room E220 (L to R - 2)				03/29/2019 05:58
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	95.1	ug/l*	EPA .200.8	2	05/08/2019 23:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000246	34-CR-246: Room E220 (L to R - 3)				03/29/2019 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000247	34-CR-247: Room E220 (L to R - 4)				03/29/2019 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000248	34-CR-248: Room E220 (L to R - 5)				03/29/2019 05:58
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1080	ug/l*	EPA .200.8	2	05/08/2019 23:55 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40719 000249	34-CR-249: Room E220 (L to R - 6)				03/29/2019 05:58
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	118	ug/l*	EPA .200.8	2	05/09/2019 00:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000250	34-CR-250: Room E220 (L to R - 7)	03/29/2019 05:58		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	73.8 ug/l*	EPA .200.8	2	05/09/2019 00:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000251	34-CR-251: Room E221 (L to R - 1)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	171 ug/l*	EPA .200.8	2	05/09/2019 00:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000252	34-CR-252: Room E221 (L to R - 2)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	308 ug/l*	EPA .200.8	2	05/09/2019 00:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000253	34-CR-253: Room E221 (L to R - 3)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	125 ug/l*	EPA .200.8	2	05/09/2019 00:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000254	34-CR-254: Room E221 (L to R - 4)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2630 ug/l*	EPA .200.8	2	05/09/2019 00:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000255	34-CR-255: Room E221 (L to R - 5)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	623 ug/l*	EPA .200.8	2	05/09/2019 00:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000256	34-CR-256: Room E221 (L to R - 6)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	97.0 ug/l*	EPA .200.8	2	05/09/2019 00:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time		
40719 000257	34-CR-257: Room E221 (L to R - 7)	03/29/2019 06:01		
Compound	Test Value Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	110 ug/l*	EPA .200.8	2	05/09/2019 00:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000258	34-CR-258: Room E221 (L to R - 8)	03/29/2019 06:01
Compound	Test Value Test Unit	Method
Lead	49.7 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:34 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000259	34-CR-259: Room E222 (L to R - 1)	03/29/2019 06:05
Compound	Test Value TestUnit	Method
Lead	38.4 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:39 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000260	34-CR-260: Room E222 (L to R - 2)	03/29/2019 06:05
Compound	Test Value TestUnit	Method
Lead	58.1 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000261	34-CR-261: Room E222 (L to R - 3)	03/29/2019 06:05
Compound	Test Value TestUnit	Method
Lead	394 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:44 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000262	34-CR-262: Room E222 (L to R - 4)	03/29/2019 06:05
Compound	Test Value Test Unit	Method
Lead	73.6 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000263	34-CR-263: Room E222 (L to R - 5)	03/29/2019 06:05
Compound	Test Value Test Unit	Method
Lead	96.8 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:49 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000264	34-CR-264: Room E222 (L to R - 6)	03/29/2019 06:05
Compound	Test Value Test Unit	Method
Lead	293 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40719 000265	34-CR-265: Room E222 (L to R - 7)	03/29/2019 06:05
Compound	Test Value TestUnit	Method
Lead	107 ug/l*	EPA .200.8
Detection Limit	Analysis Date/Time/Initial	
2	05/09/2019 00:54 BJ	

Certificate of Analysis

MARTEL NO. 40719	000266	CLIENT SAMPLE IDENTIFICATION 34-CR-266: Room E222 (L to R - 8)	Sample Date/Time 03/29/2019 06:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

Page 21 OF 21

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com


stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Results exceed 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager