

# Lead in Drinking Water – Public and Nonpublic Schools

## **IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S)** **Perryville Middle School**

### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On March 13, 2019, **one hundred sixty-eight (168)** lead water samples were collected from **Perryville Middle School**. Of these lead water samples, **six (6)** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Perryville Middle were as follows:

**23.6** parts per billion (ppb) **Science Room 208 (back middle/left sink) (use: non-consumption)**  
**51.4** parts per billion (ppb) **Science Room 201 (back left sink) (use: non-consumption)**  
**21.7** parts per billion (ppb) **Science Room 201 (back middle sink) (use: non-consumption)**  
**85.6** parts per billion (ppb) **Science Storage Room 427 sink (use: non-consumption)**  
**20.9** parts per billion (ppb) **Science Storage Room 308 sink (use: non-consumption)**  
**29.1** parts per billion (ppb) **Science Room 301 (back left sink) (use: non-consumption)**

### **IMMEDIATE ACTIONS TAKEN**

Results were received on May 15, 2019. A sign has been posted at each sink noted above, indicating that they are not to be used for consumption purposes.

### **NEXT STEPS**

The sinks will continue to be used only for non-consumption purposes (e.g., hand washing) until remedial actions have taken place and follow up sampling shows results with levels below the action level.

### **ACTION LEVEL (AL)**

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

**TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

**ADDITIONAL INFORMATION**

1. For additional information, please contact **Perry Willis, Executive Director for Support Services**, at **410-996-5400**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



Cecil County Public Schools  
201 Booth St.

Tuesday, May 14, 2019

Elkton, MD 21921

**Certificate of Analysis**

Attention: Andrew Curran

**FINAL**

Report for Lab No: 40717.

Samples received by Martel from: Perryville Middle School

Project Identification : Water Analysis HB 270, sampled by Cecil County personnel.

Received on March 19, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000001	26-BS-01: Custodian office bathroom	03/12/2019 04:32
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 15 :54 BJ
40717 000002	26-OT-02: Main office outside of bathroom	03/12/2019 04:34
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 16:06 BJ
40717 000003	26-BS-03: Main office bathroom	03/12/2019 04:35
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 16:09 BJ
40717 000004	26-OT-04: Main office faculty workroom	03/12/2019 04:35
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 16:11 BJ
40717 000005	26-BS-05: MO faculty workroom bathroom	03/12/2019 04:36
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 16:14 BJ
40717 000006	26-BS-06: Guidance office bathroom	03/12/2019 04:39
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 16:16 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000007	26-OT-07: Media Center 120A		03/12/2019 04:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	2.34	ug/1	EPA .200.8	2	05/03/2019 16:18 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000008	26-OT-08: Media Center 120C		03/12/2019 04:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	19.7	ug/1	EPA .200.8	2	05/03/2019 16:21 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000009	26-CR-09: Science 208 (L to R - 1)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	14.6	ug/1	EPA .200.8	2	05/03/2019 16:23 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000010	26-CR-10: Science 208 (L to R - 2)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	23.6	ug/1*	EPA .200.8	2	05/07/2019 02:31 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000011	26-CR-11: Science 208 (L to R - 3)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	11.8	ug/1	EPA .200.8	2	05/03/2019 16:36 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000012	26-CR-12: Science 208 (L to R - 4)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	10.5	ug/1	EPA .200.8	2	05/03/2019 16:41 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000013	26-CR-13: Science 208 (L to R - 5)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 16:44 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000014	26-CR-14: Science 208 (L to R - 6)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	13.1	ug/1	EPA .200.8	2	05/03/2019 16:46 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000015	26-CR-15: Science 208 (L to R - 7)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.77	ug/1	EPA .200.8	2	05/03/2019 16:49 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000016	26-CR-16: Science 208 (L to R - 8)		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.3	ug/1	EPA .200.8	2	05/03/2019 16:51 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000017	26-OT-17: Science 208 prep closet		03/12/2019 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.1	ug/1	EPA .200.8	2	05/03/2019 16:54 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000018	26-CR-18: Room 207		03/12/2019 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 16:56 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000019	26-CR-19: Room 204		03/12/2019 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 16:59 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000020	26-CR-20: Room 205		03/12/2019 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:01 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000021	26-BS-21: Bathroom near room 200 (left)		03/12/2019 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:09 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000022	26-BS-22: Bathroom near room 200 (right)		03/12/2019 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:16 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000023	26-CR-23: Science 201 (L to R - 1)		03/12/2019 04:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.1	ug/1	EPA .200.8	2	05/03/2019 17:19 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000024	26-CR-24 : Science 201 (L to R - 2)		03/12/2019 04:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.64	ug/1	EPA .200.8	2	05/03/2019 17:21 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000025	26-CR-25: Science 201 (L to R - 3)		03/12/2019 04:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.3	ug/1	EPA .200.8	2	05/03/2019 17:24 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000026	26-CR-26: Science 201 (L to R - 4)		03/12/2019 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.2	ug/1	EPA .200.8	2	05/03/2019 17:26 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000027	26-CR-27: Science 201 (L to R - 5)		03/12/2019 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.7	ug/1	EPA .200.8	2	05/03/2019 17:29 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000028	26-CR-28: Science 201 (L to R - 6)		03/12/2019 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	51.4	ug/1*	EPA .200.8	2	05/03/2019 17:31 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000029	26-CR-29: Science 201 (L to R - 7)		03/12/2019 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	21.7	ug/1*	EPA .200.8	2	05/13/2019 16:52 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000030	26-CR-30: Science 201 (L to R - 8)		03/12/2019 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.3	ug/1	EPA .200.8	2	05/03/2019 17:34 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000031	26-CR-31: Room 220	03/12/2019 04:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	11

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000032	26-OT-32: Work room 224	03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.47	ug/1	EPA .200.8	2	05/03/2019 17:44 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000033	26-BS-33: Work room 224 bathroom (left)	03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:49 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000034	26-BS-34: Work room 224 bathroom (right)	03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:51 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000035	26-CR-35: Room 225	03/12/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:54 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000036	26-DF-36: Fountain outside of 227	03/12/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:56 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000037	26-CR-37: Room 227	03/12/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 17:59 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000038	26-CR-38: Tech Ed 222 (L to R - 1)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.58	ug/1	EPA .200.8	2	05/03/2019 18:01 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000039	26-CR-39: Tech Ed 222 (L to R - 2)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:03 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000040	26-CR-40: Tech Ed 222 (L to R - 3)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:06 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000041	26-CR-41: Tech Ed 222 (L to R - 4)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.99	ug/1	EPA .200.8	2	05/03/2019 18:13 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000042	26-CR-42: Tech Ed 222 (L to R - 5)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:21 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000043	26-CR-43: Tech Ed 222 (L to R - 6)	03/12/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.96	ug/1	EPA .200.8	2	05/03/2019 18:23 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000044	26-BS-44: Women bathroom near caf. (R to L - 1)	03/12/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:26 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000045	26-BS-45: Women bathroom near caf. (R to L - 2)	03/12/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:28 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000046	26-BS-46: Women bathroom near caf. (R to L - 3)	03/12/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 18:31 BJ





## Certificate of Analysis

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000047	26-BS-47: Women bathroom near caf. (R to L - 4	03/12/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:33 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000048	26-BS-48: Women bathroom near caf. (R to L - 5	03/12/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:36 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000049	26-BS-49: Men bathroom near caf. (right)	03/12/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:38 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000050	26-BS-50: Men bathroom near caf. (left)	03/12/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:41 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000051	26-TL-51: Faculty Dining	03/12/2019 05:14
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:51 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000052	26-BS-52: Faculty Dining bathroom (right)	03/12/2019 05:14
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:56 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000053	26-BS-53: Faculty Dining bathroom (left)	03/12/2019 05:14
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 18:58 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000054	26-KS-54: Kitchen (see floor plan) Hand Sink	03/12/2019 05:17
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 05/03/2019 19:01 BJ

---



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000055	26-KS-55: Kitchen (see floor plan) Hand Sink	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:03 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000056	26-KS-56: Kitchen (see floor plan) Prep Sink	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:06 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000057	26-IM-57: Kitchen ice machine	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:08 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000058	26-KS-58: Kitchen (see floor plan) Hand Sink	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:11 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000059	26-BS-59: Kitchen bathroom	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:13 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000060	26-KS-60: Kitchen (see floor plan) Hand Sink	03/12/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:16 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000061	26-KS-61: Kitchen (see floor plan) Dish Wash	03/12/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:23 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000062	26-KS-62: Kitchen (see floor plan) Dish Wash	03/12/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:31 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000063	26-BS-63: Nurses office bathroom (small)	03/12/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:33 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000064	26-NO-64: Nurses office (see floor plan) 102A	03/12/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:36 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000065	26-IM-65: Nurses office ice machine 102A	03/12/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:38 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000066	26-NO-66: Nurses office (see floor plan) Exam	03/12/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:41 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000067	26-BS-67: Nurses office bathroom (large)	03/12/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:43 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000068	26-BS-68: Boys bathroom near 407 (R to L - 1)	03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:46 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000069	26-BS-69: Boys bathroom near 407 (R to L - 2)	03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:48 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000070	26-BS-70: Boys bathroom near 407 (R to L - 3)	03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 19:51 BJ



MARTEL NO. 40717 000071 26-BS-71: Boys bathroom near 407 (R to L - 4) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:01 BJ

MARTEL NO. 40717 000072 26-BS-72: Room 413 MIP bathroom CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:06 BJ

MARTEL NO. 40717 000073 26-DF-73: Fountain near 407 CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:08 BJ

MARTEL NO. 40717 000074 26-BS-74: Girls bathroom near 407 (R to L - 1) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:11 BJ

MARTEL NO. 40717 000075 26-BS-75: Girls bathroom near 407 (R to L - 2) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:13 BJ

MARTEL NO. 40717 000076 26-BS-76: Girls bathroom near 407 (R to L - 3) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:16 BJ

MARTEL NO. 40717 000077 26-BS-77: Girls bathroom near 407 (R to L - 4) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200 .8	2	05/03/2019 20:18 BJ

MARTEL NO. 40717 000078 26-CR-78: Room 407 CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/12/2019 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.36	ug/1	EPA .200 .8	2	05/03/2019 20:21 BJ



## Certificate of Analysis

---

MARTEL NO. 40717	000079	CLIENT SAMPLE IDENTIFICATION 26-CR-79: Room 405	Sample Date/Time 03/12/2019 05:40
---------------------	--------	----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/1	EPA .200.8	2	05/03/2019 20:23 BJ

---

MARTEL NO. 40717	000080	CLIENT SAMPLE IDENTIFICATION 26-CR-80: Room 403	Sample Date/Time 03/12/2019 05:40
---------------------	--------	----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 20:26 BJ

---

MARTEL NO. 40717	000081	CLIENT SAMPLE IDENTIFICATION 26-CR-81: Room 401	Sample Date/Time 03/12/2019 05:40
---------------------	--------	----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 20:33 BJ

---

MARTEL NO. 40717	000082	CLIENT SAMPLE IDENTIFICATION 26-DF-82: Fountain near 427	Sample Date/Time 03/12/2019 05:44
---------------------	--------	-------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 20:41 BJ

---

MARTEL NO. 40717	000083	CLIENT SAMPLE IDENTIFICATION 26-BS-83: Bathroom near 427 (right) men	Sample Date/Time 03/12/2019 05:44
---------------------	--------	-------------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 20:44 BJ

---

MARTEL NO. 40717	000084	CLIENT SAMPLE IDENTIFICATION 26-BS-84: Bathroom near 427 (left) women	Sample Date/Time 03/12/2019 05:44
---------------------	--------	--------------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 20:46 BJ

---

MARTEL NO. 40717	000085	CLIENT SAMPLE IDENTIFICATION 26-CR-85: Science 427 (L to R - 1)	Sample Date/Time 03/12/2019 05:48
---------------------	--------	--------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.30	ug/1	EPA .200.8	2	05/03/2019 20:49 BJ

---

MARTEL NO. 40717	000086	CLIENT SAMPLE IDENTIFICATION 26-CR-86: Science 427 (L to R - 2)	Sample Date/Time 03/12/2019 05:48
---------------------	--------	--------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.18	ug/1	EPA .200.8	2	05/03/2019 20:51 BJ



# Certificate of Analysis

MARTEL NO. 40717 000087 CLIENT SAMPLE IDENTIFICATION 26-CR-87: Science 427 (L to R - 3) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1	ug/1	EPA .200.8	2	05/03/2019 20:54 BJ

MARTEL NO. 40717 000088 CLIENT SAMPLE IDENTIFICATION 26-CR-88: Science 427 (L to R - 4) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.36	ug/1	EPA .200.8	2	05/03/2019 20:56 BJ

MARTEL NO. 40717 000089 CLIENT SAMPLE IDENTIFICATION 26-CR-89: Science 427 (L to R - 5) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.44	ug/1	EPA .200.8	2	05/03/2019 20:59 BJ

MARTEL NO. 40717 000090 CLIENT SAMPLE IDENTIFICATION 26-CR-90: Science 427 (L to R - 6) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.81	ug/1	EPA .200.8	2	05/03/2019 21:01 BJ

MARTEL NO. 40717 000091 CLIENT SAMPLE IDENTIFICATION 26-CR-91: Science 427 (L to R - 7) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	no	fixture	EPA .200.8	2	/ /

MARTEL NO. 40717 000092 CLIENT SAMPLE IDENTIFICATION 26-CR-92: Science 427 (L to R - 8) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 21:11 BJ

MARTEL NO. 40717 000093 CLIENT SAMPLE IDENTIFICATION 26-CR-93: Science 427 (L to R - 9) Sample Date/Time 03/12/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.89	ug/1	EPA .200.8	2	05/03/2019 21:16 BJ

MARTEL NO. 40717 000094 CLIENT SAMPLE IDENTIFICATION 26-OT-94: Science 427 prep closet Sample Date/Time 03/12/2019 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	85.6	ug/1*	EPA .200.8	2	05/13/2019 17:05 BJ



MARTEL NO. 40717 000095 CLIENT SAMPLE IDENTIFICATION 26-CR-95: Science 429 (L to R - 1) Sample Date/Time 03/12/2019 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.9	ug/1	EPA .200.8	2	05/03/2019 21:19 BJ

MARTEL NO. 40717 000096 CLIENT SAMPLE IDENTIFICATION 26-CR-96: Science 429 (L to R - 2) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40717 000097 CLIENT SAMPLE IDENTIFICATION 26-CR-97: Science 429 (L to R - 3) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40717 000098 CLIENT SAMPLE IDENTIFICATION 26-CR-98: Science 429 (L to R - 4) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40717 000099 CLIENT SAMPLE IDENTIFICATION 26-CR-99: Science 429 (L to R - 5) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40717 000100 CLIENT SAMPLE IDENTIFICATION 26-CR-100: Science 429 (L to R - 6) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40717 000101 CLIENT SAMPLE IDENTIFICATION 26-CR-101: Science 429 (L to R - 7) Sample Date/Time 03/12/2019 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.1	ug/1	EPA .200.8	2	05/03/2019 21:26 BJ

MARTEL NO. 40717 000102 CLIENT SAMPLE IDENTIFICATION 26-CR-102: Science 429 (L to R - 8) Sample Date/Time 03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//



## Certificate of Analysis

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000103	26-CR-103: Science 429 (L to R - 9)	03/12/2019 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:34 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000104	26-HE-104: HHS room 431 (L to R - 1)	03/12/2019 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:36 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000105	26-HE-105: HHS room 431 (L to R - 2)	03/12/2019 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:39 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000106	26-HE-106: HHS room 431 (L to R - 3)	03/12/2019 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:41 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000107	26-HE-107: HHS room 431 (L to R - 4)	03/12/2019 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:44 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000108	26-CR-108: Room 430	03/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	///

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000109	26-CR-109: Room 433	03/12/2019 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:46 BJ

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717	000110	26-BS-110: Girls locker room (R to L - 1)	03/12/2019 05:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	05/03/2019 21:49 BJ





# Certificate of Analysis

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000111	26-BS-111: Girls locker room (R to L - 2)	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 21:59 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000112	26-BS-112: Girls locker room (R to L - 3)	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:04 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000113	26-BS-113: Girls locker room (R to L -4)	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:07 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000114	26-DF-114: Girls locker room fountain (left)	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:09 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000115	26-DF-115: Girls locker room fountain (right)	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:12 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000116	26-BS-116: Girls locker room office bathroom	03/12/2019 05:59
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:14 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000117	26-BS-117: Boys locker room (L to R - 1)	03/12/2019 06:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:17 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000118	26-BS-118: Boys locker room (L to R - 2)	03/12/2019 06:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/1 EPA .200.8	2 05/03/2019 22:19 BJ

---



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000119	26-BS-119: Boys locker room (L to R - 3)		03/12/2019 06:02

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:22 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000120	26-BS-120: Boys locker room (L to R - 4 )		03/12/2019 06:02

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:24 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000121	26-DF-121: Boys locker room fountain (right)		03/12/2019 06:02

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:32 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000122	26-DF-122: Boys locker room fountain (left)		03/12/2019 06:02

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:40 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000123	26-BS-123: Boys locker room office bathroom		03/12/2019 06:02

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:42 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000124	26-CR-124: Room 435		03/12/2019 06:05

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:45 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000125	26-CR-125: Room 437		03/12/2019 06:05

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:47 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000126	26-CR-126: Room 439		03/12/2019 06:06

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 22:50 BJ



## Certificate of Analysis

---

MARTEL NO. 40717	000127	CLIENT SAMPLE IDENTIFICATION 26-CR-127: Room 441	Sample Date/Time 03/12/2019 06:06
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 22:52 BJ

---

MARTEL NO. 40717	000128	CLIENT SAMPLE IDENTIFICATION 26-CR-128: Room 443	Sample Date/Time 03/12/2019 06:06
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 22:55 BJ

---

MARTEL NO. 40717	000129	CLIENT SAMPLE IDENTIFICATION 26-DF-129: Fountain near room 443	Sample Date/Time 03/12/2019 06:06
---------------------	--------	-------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 22:57 BJ

---

MARTEL NO. 40717	000130	CLIENT SAMPLE IDENTIFICATION 26-DF-130: Band/Orch 445 fountain (left)	Sample Date/Time 03/12/2019 06:09
---------------------	--------	--------------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 23:00 BJ

---

MARTEL NO. 40717	000131	CLIENT SAMPLE IDENTIFICATION 26-DF-131: Band/Orch 445 fountain (right)	Sample Date/Time 03/12/2019 06:09
---------------------	--------	---------------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 23:10 BJ

---

MARTEL NO. 40717	000132	CLIENT SAMPLE IDENTIFICATION 26-CR-132: Band/Orch 445	Sample Date/Time 03/12/2019 06:09
---------------------	--------	----------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 23:15 BJ

---

MARTEL NO. 40717	000133	CLIENT SAMPLE IDENTIFICATION 26-OT-133: Teach prep across from 445	Sample Date/Time 03/12/2019 06:10
---------------------	--------	-----------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	<2	ug/1	EPA .200.8	2	05/03/2019 23:18 BJ

---

MARTEL NO. 40717	000134	CLIENT SAMPLE IDENTIFICATION 26-CR-134: Music447	Sample Date/Time 03/12/2019 06:12
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/mme/Initial
Lead	2.53	ug/1	EPA .200.8	2	05/03/2019 23:20 BJ



## Certificate of Analysis

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000135	26-DF-135: Music 447 fountain (right)		03/12/2019 06:12

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:23 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000136	26-DF-136: Music 447 fountain (left)		03/12/2019 06:12

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:25 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000137	26-OT-137 Room 104		03/12/2019 04:37

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:28 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000138	26-KS-138 Kitchen Kettle Fill A		03/12/2019 05:25

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:30 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000139	26-KS-139 Kitchen Food Prep		03/12/2019 05:25

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		2.74	ug/1	EPA .200.8	2	05/03/2019 23:33 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000140	26-KS-140 Kitchen Sprayer in prep area		03/12/2019 05:25

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		6.62	ug/1	EPA .200.8	2	05/03/2019 23:35 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000141	26-DF-141 Caf. fountain (left)		03/12/2019 06:42

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:43 BJ

---

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40717	000142	26-DF-142 Caf. fountain (right)		03/12/2019 06:42

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:51 BJ



## Certificate of Analysis

---

MARTEL NO. 40717	000201	CLIENT SAMPLE IDENTIFICATION 26-CR-201: Room 325				Sample Date/Time 03/12/2019 06:18
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:53 BJ

---

MARTEL NO. 40717	000202	CLIENT SAMPLE IDENTIFICATION 26-CR-202: Room 327				Sample Date/Time 03/12/2019 06:18
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:56 BJ

---

MARTEL NO. 40717	000203	CLIENT SAMPLE IDENTIFICATION 26-DF-203: 2nd floor fountain				Sample Date/Time 03/12/2019 06:18
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/03/2019 23:58 BJ

---

MARTEL NO. 40717	000204	CLIENT SAMPLE IDENTIFICATION 26-BS-204: 2nd floor girls bathroom (right)				Sample Date/Time 03/12/2019 06:20
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/04/2019 00:01 BJ

---

MARTEL NO. 40717	000205	CLIENT SAMPLE IDENTIFICATION 26-BS-205: 2nd floor girls bathroom (left)				Sample Date/Time 03/12/2019 06:20
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/04/2019 00:03 BJ

---

MARTEL NO. 40717	000206	CLIENT SAMPLE IDENTIFICATION 26-BS-206: 2nd floor boys bathroom (R to L - 1)				Sample Date/Time 03/12/2019 06:20
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/04/2019 00:06 BJ

---

MARTEL NO. 40717	000207	CLIENT SAMPLE IDENTIFICATION 26-BS-207: 2nd floor boys bathroom (R to L - 2)				Sample Date/Time 03/12/2019 06:20
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/04/2019 00:09 BJ

---

MARTEL NO. 40717	000208	CLIENT SAMPLE IDENTIFICATION 26-BS-208: 2nd floor boys bathroom (R to L - 3)				Sample Date/Time 03/12/2019 06:20
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/1	EPA .200.8	2	05/04/2019 00:11 BJ

---



## Certificate of Analysis

MARTEL NO. 40717 000209 CLIENT SAMPLE IDENTIFICATION 26-BS-209: 2nd floor boys bathroom (R to L - 4) Sample Date/Time 03/12/2019 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:21 BJ

MARTEL NO. 40717 000210 CLIENT SAMPLE IDENTIFICATION 26-BS-210: 2nd floor boys bathroom (R to L - 5) Sample Date/Time 03/12/2019 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:26 BJ

MARTEL NO. 40717 000211 CLIENT SAMPLE IDENTIFICATION 26-CR-211: Art 328 (L to R - 1) Sample Date/Time 03/12/2019 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:29 BJ

MARTEL NO. 40717 000212 CLIENT SAMPLE IDENTIFICATION 26-CR-212: Art 328 (L to R - 2) Sample Date/Time 03/12/2019 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:31 BJ

MARTEL NO. 40717 000213 CLIENT SAMPLE IDENTIFICATION 26-CR-213: Art 328 (L to R - 3) Sample Date/Time 03/12/2019 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:34 BJ

MARTEL NO. 40717 000214 CLIENT SAMPLE IDENTIFICATION 26-CR-214: Art 328 (L to R - 4) Sample Date/Time 03/12/2019 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:36 BJ

MARTEL NO. 40717 000215 CLIENT SAMPLE IDENTIFICATION 26-CR-215: Room 320 Sample Date/Time 03/12/2019 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:39 BJ

MARTEL NO. 40717 000216 CLIENT SAMPLE IDENTIFICATION 26-OT-216: Workroom 310 Sample Date/Time 03/12/2019 06:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.64	ug/1	EPA .200.8	2	05/04/2019 00:42 BJ



## Certificate of Analysis

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000217	26-BS-217: Workroom 310 bathroom	03/12/2019 06:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 00:44 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000218	26-CR-218: Science 308 (L to R - 1)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.65	ug/1	EPA .200.8	2	05/04/2019 00:47 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000219	26-CR-219: Science 308 (L to R - 2)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.95	ug/1	EPA .200.8	2	05/04/2019 00:55 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000220	26-CR-220: Science 308 (L to R - 3)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.68	ug/1	EPA .200.8	2	05/04/2019 01:02 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000221	26-CR-221: Science 308 (L to R - 4)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.03	ug/1	EPA .200.8	2	05/04/2019 01:05 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000222	26-CR-222: Science 308 (L to R - 5)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.82	ug/1	EPA .200.8	2	05/04/2019 01:07 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000223	26-CR-223: Science 308 (L to R - 6)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1	ug/1	EPA .200.8	2	05/04/2019 01:10 BJ

---

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000224	26-CR-224: Science 308 (L to R - 7)	03/12/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.8	ug/1	EPA .200.8	2	05/04/2019 01:12 BJ

---



## Certificate of Analysis

---

MARTEL NO. 40717	000225	CLIENT SAMPLE IDENTIFICATION 26-OT-225: Science 308 prep closet	Sample Date/Time 03/12/2019 06:30
---------------------	--------	--------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.9	ug/1*	EPA .200.8	2	05/04/2019 01:15 BJ

---

MARTEL NO. 40717	000226	CLIENT SAMPLE IDENTIFICATION 26-CR-226: Room 307	Sample Date/Time 03/12/2019 06:31
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 01:18 BJ

---

MARTEL NO. 40717	000227	CLIENT SAMPLE IDENTIFICATION 26-CR-227: Room 305	Sample Date/Time 03/12/2019 06:31
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 01:20 BJ

---

MARTEL NO. 40717	000228	CLIENT SAMPLE IDENTIFICATION 26-CR-228: Room 304	Sample Date/Time 03/12/2019 06:31
---------------------	--------	-----------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/1	EPA .200.8	2	05/04/2019 01:23 BJ

---

MARTEL NO. 40717	000229	CLIENT SAMPLE IDENTIFICATION 26-CR-229: Science 301 (L to R - 1)	Sample Date/Time 03/12/2019 06:35
---------------------	--------	---------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.84	ug/1	EPA .200.8	2	05/04/2019 01:33 BJ

---

MARTEL NO. 40717	000230	CLIENT SAMPLE IDENTIFICATION 26-CR-230: Science 301 (L to R - 2)	Sample Date/Time 03/12/2019 06:35
---------------------	--------	---------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.6	ug/1	EPA .200.8	2	05/04/2019 01:38 BJ

---

MARTEL NO. 40717	000231	CLIENT SAMPLE IDENTIFICATION 26-CR-231: Science 301 (L to R - 3)	Sample Date/Time 03/12/2019 06:35
---------------------	--------	---------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.54	ug/1	EPA .200.8	2	05/04/2019 01:41 BJ

---

MARTEL NO. 40717	000232	CLIENT SAMPLE IDENTIFICATION 26-CR-232: Science 301 (L to R - 4)	Sample Date/Time 03/12/2019 06:35
---------------------	--------	---------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.1	ug/1*	EPA .200.8	2	05/04/2019 01:43 BJ





## Certificate of Analysis

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000233	26-CR-233: Science 301 (L to R - 5)	03/12/2019 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.81	ug/1	EPA .200.8	2	05/04/2019 01:46 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000234	26-CR-234: Science 301 (L to R - 6)	03/12/2019 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.72	ug/1	EPA .200.8	2	05/04/2019 01:48 BJ

---

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40717 000235	26-CR-235: Science 301 (L to R - 7)	03/12/2019 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.06	ug/1	EPA .200.8	2	05/04/2019 01:51 BJ

Page 23 OF 23

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

### Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Results exceed 20.5 ug/1.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

---

Project Manager