

Radon Tests - Wilson Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	S. File Cabinet	2815888	27-Oct-20	5:12 AM	29-Oct-20	5:57 AM	1.5	None.
2	Health Room	Computer Desk	2756531	27-Oct-20	5:14 AM	29-Oct-20	5:58 AM	1.2	None
3	Room 107	N. Wall Study Desk	2756330	27-Oct-20	5:20 AM	29-Oct-20	5:09 AM	1.8	None
4	Conference Room - Room 103	S.E. Corner File Cabinet	2815869	27-Oct-20	5:22 AM	29-Oct-20	6:00 AM	1.8	None
5	Principal's Office	S.E. Corner Cabinet	2815867	27-Oct-20	5:25 AM	29-Oct-20	6:01 AM	0.8	None
6	Principal's Office - Blank	S.E. Corner Cabinet	2817984	27-Oct-20	5:25 AM	29-Oct-20	5:25 AM	0.1	None
7	Staff Work Room	N. Paper Shelf	2756321	27-Oct-20	5:30 AM	29-Oct-20	6:02 AM	0.9	None
8	Staff Work Room - Duplicate	N. Paper Shelf	2756620	27-Oct-20	5:30 AM	29-Oct-20	6:02 AM	0.8	None
9	Staff Break Room	Left Fridge	2817650	27-Oct-20	5:33 AM	29-Oct-20	6:04 AM	0.7	None
10	Staff Break Room - Blank	Left Fridge	2756574	27-Oct-20	5:33 AM	29-Oct-20	5:33 AM	0.1	None
11	Staff Break Room - Duplicate	Left Fridge	2756615	27-Oct-20	5:34 AM	29-Oct-20	6:04 AM	0.5	None
12	Media Center # 1	W. End Center Bookcase	2756572	27-Oct-20	5:39 AM	29-Oct-20	6:07 AM	1.0	None
13	Media Center # 2	S. Wall Bookcase	2816024	27-Oct-20	5:40 AM	29-Oct-20	6:08 AM	0.8	None
14	Computer Room	SW Corner Shelf	2815874	27-Oct-20	5:43 AM	29-Oct-20	6:09 AM	0.9	None
15	Gym # 1	S. Wall Mat Cart	2756571	27-Oct-20	5:47 AM	29-Oct-20	6:12 AM	0.8	None
16	Gym # 2	S.W. Corner Desk	2756351	27-Oct-20	5:48 AM	29-Oct-20	6:13 AM	0.9	None
17	Gym # 3	W. Wall Mats	2756518	27-Oct-20	5:50 AM	29-Oct-20	6:13 AM	0.9	None
18	Stage	E. Wall Desk	2756417	27-Oct-20	5:53 AM	29-Oct-20	6:15 AM	0.9	None
19	Room 1	E. Wall Desk	2816040	27-Oct-20	5:58 AM	29-Oct-20	6:18 AM	0.3	None
20	Room 2	W. Wall Shelf	2756415	27-Oct-20	6:00 AM	29-Oct-20	6:20 AM	3.1	None
21	Room 2 - Duplicate	W. Wall Shelf	2756541	27-Oct-20	6:02 AM	29-Oct-20	6:20 AM	2.5	None
22	Room 3	N.E. Tall Bookshelf	2756607	27-Oct-20	6:04 AM	29-Oct-20	6:21 AM	1.8	None
23	Room 4	S. Wall Desk	2756400	27-Oct-20	6:06 AM	29-Oct-20	6:00 AM	2.1	None
24	Room 5	S. Wall Desk	2756610	27-Oct-20	6:09 AM	29-Oct-20	6:24 AM	1.2	None
25	Room 5 - Blank	S. Wall Desk	2756418	27-Oct-20	6:10 AM	29-Oct-20	6:10 AM	0.1	None
26	Room 6	S. Wall Desk	2756542	27-Oct-20	6:14 AM	29-Oct-20	6:27 AM	1.0	None
27	Room 7	S. Wall Desk	2756349	27-Oct-20	6:16 AM	29-Oct-20	6:29 AM	1.8	None
28	Room 7 - Duplicate	S. Wall Desk	2756600	27-Oct-20	6:17 AM	29-Oct-20	6:29 AM	1.4	None
29	Room 8	W. Wall Shelf	2815916	27-Oct-20	6:19 AM	29-Oct-20	6:30 AM	1.4	None
30	Room 8 - Blank	W. Wall Shelf	2756426	27-Oct-20	6:20 AM	29-Oct-20	6:20 AM	0.1	None
31	Room 9	E. Wall Cubbies	2756327	27-Oct-20	5:24 AM	29-Oct-20	5:59 AM	1.4	None
32	Room 10	W. Wall Cubbies	2756326	27-Oct-20	5:28 AM	29-Oct-20	6:01 AM	1.6	None
33	Cateteria # 1	Milk Cooler E. Wall	2756317	27-Oct-20	5:30 AM	29-Oct-20	6:02 AM	0.9	None
34	Cateteria # 2	N. Piano	2756621	27-Oct-20	5:32 AM	29-Oct-20	6:02 AM	1.2	None
35	Room 11	S. Wall White Board	2815881	27-Oct-20	5:38 AM	29-Oct-20	6:05 AM	1.0	None
36	Room 12	File Cabinet E. Wall	2756628	27-Oct-20	5:40 AM	29-Oct-20	6:07 AM	0.9	None
37	Room 12 - Duplicate	File Cabinet E. Call	2756344	27-Oct-20	5:40 AM	29-Oct-20	6:07 AM	3.1	None
38	Room 13	W. Coat Hanger	2756622	27-Oct-20	5:46 AM	29-Oct-20	6:09 AM	0.6	None
39	Room 14	E. Coat Hanger	2756324	27-Oct-20	5:49 AM	29-Oct-20	6:10 AM	0.2	None
40	Room 14 - Blank	E. Coat Hanger	2756419	27-Oct-20	5:49 AM	29-Oct-20	6:10 AM	0.1	None
41	Room 15	W. Coat Hanger	2756623	27-Oct-20	5:53 AM	29-Oct-20	6:11 AM	1.0	None
42	Room 16	S. Sink	2756599	27-Oct-20	5:58 AM	29-Oct-20	6:13 AM	1.1	None
43	Room 16 - Duplicate	S. Sink	2756614	27-Oct-20	6:02 AM	29-Oct-20	6:13 AM	1.0	None
44	Room 17	S. Sink	2756322	27-Oct-20	6:04 AM	29-Oct-20	6:15 AM	1.2	None
45	Room 18	S. Wall Counter	2815940	27-Oct-20	6:08 AM	29-Oct-20	6:16 AM	1.0	None
46	Room 19	S. Sink	2815876	27-Oct-20	6:08 AM	29-Oct-20	6:18 AM	1.6	None
47	Room 19 - Blank	S. Sink	2756396	27-Oct-20	6:12 AM	29-Oct-20	6:18 AM	0.1	None
48	Room 20	S. Sink	2815886	27-Oct-20	6:15 AM	29-Oct-20	6:22 AM	2.3	None
49	Room 21	N. File	2756315	27-Oct-20	6:15 AM	29-Oct-20	6:23 AM	1.5	None
50	Room 21 - Duplicate	N. File	2756414	27-Oct-20	6:15 AM	29-Oct-20	6:23 AM	1.4	None
51	Room 22	W. File	2756608	27-Oct-20	6:20 AM	29-Oct-20	6:26 AM	1.6	None
52	Room 23	N. Counter	2756416	27-Oct-20	6:22 AM	29-Oct-20	6:29 AM	0.8	None
53	Room 24	N. Counter	2756581	27-Oct-20	6:25 AM	29-Oct-20	6:31 AM	1.1	None
54	Room 24 - Blank	N. Counter	2815949	27-Oct-20	6:25 AM	29-Oct-20	6:31 AM	0.2	None
55	Room 25	S. Counter	2756576	27-Oct-20	6:28 AM	29-Oct-20	6:33 AM	1.6	None
56	Room 26	E. Desk	2756585	27-Oct-20	6:31 AM	29-Oct-20	6:35 AM	0.3	None
57	Room 27	E. Bookcase	2756399	27-Oct-20	6:34 AM	29-Oct-20	6:36 AM	0.5	None
58	Room 27 - Duplicate	E. Bookcase	2756331	27-Oct-20	6:34 AM	29-Oct-20	6:36 AM	0.3	None
59	Room 28	W. Cubbie	2756522	27-Oct-20	6:35 AM	29-Oct-20	6:37 AM	0.6	None
60	Room 28 - Blank	W. Cubbie	2756318	27-Oct-20	6:35 AM	29-Oct-20	6:37 AM	0.1	None

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
61	Spike # 1 (Room 29)	Spiked at KSU Radon Chamber (21.3 pCi/L)	2716046	26-Oct-20	10:00 AM	28-Oct-20	10:00 AM	19.9	None.
62	Spike # 2 (Room 30)	Spiked at KSU Radon Chamber (21.3 pCi/L)	2817986	26-Oct-20	10:00 AM	28-Oct-20	10:00 AM	17.1	None.
63	Spike # 3 (Room 31)	Spiked at KSU Radon Chamber (21.3 pCi/L)	2765247	26-Oct-20	10:00 AM	28-Oct-20	10:00 AM	20.9	None.

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.
 *This is not a health based number.
 *Outdoor radon levels across the country average 0.4 pCi/L.
 *If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.
 *A trend in RPE values that are more than ± 30% should be investigated