

Lead Tests - MSDEC - Main Building - # 20482100

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482100-001BF	20482100-001BF22A	100A - Women's RR - South Side Left Sink (1)	09/20/23	0.8	
2	20482100-002BF	20482100-002BF22A	100A - Women's RR - Sink (2)	08/02/23	4.6	
3	20482100-003BF	20482100-003BF22A	100A - Women's RR - Sink (3)	08/02/23	8.7	
4	20482100-004BF	20482100-004BF22A	100A - Women's RR - South Side Right Sink (4)	08/02/23	6.8	
5	20482100-005BF	20482100-005BF22A	100A - Women's RR - North Side Left Sink (5)	08/02/23	6.8	
6	20482100-006BF	20482100-006BF22A	100A - Women's RR - Sink (6)	08/02/23	12.5	
7	20482100-007BF	20482100-007BF22A	100A - Women's RR - North Side Right Sink (7)	08/02/23	8.9	
8	20482100-165BF	20482100-165BF22A	100B - Men's RR - Left Sink (1)	08/02/23	ND	
9	20482100-166BF	20482100-166BF22A	100B - Men's RR - Sink (2)	08/02/23	1.2	
10	20482100-167BF	20482100-167BF22A	100B - Men's RR - Sink (3)	08/02/23	1.3	
11	20482100-168BF	20482100-168BF22A	100B - Men's RR - Sink (4)	08/02/23	ND	
12	20482100-169BF	20482100-169BF22A	100B - Men's RR - Right Sink (5)	08/02/23	1.3	
13	20482100-170DW	20482100-170DW22A	100C Hall - Drinking Fountain	08/02/23	7.9	
14	20482100-171BF	20482100-171BF22A	104 - Health - Sink	08/02/23	ND	
31	20482100-172BF	20482100-172BF22A	115 - Sink	08/02/23	ND	
32	20482100-173DW	20482100-173DW22A	115 - Drinking Fountain	08/02/23	ND	
33	20482100-009DW	20482100-009DW22A	117 Hall - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
34	20482100-010DW	20482100-010DW22A	117 Hall - Drinking Fountain (Upper)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
35	20482100-011WB	20482100-011WB22A	117 Hall - Drinking Fountain (Lower)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
36	20482100-012SF	20482100-012SF22A	124 - Sink	08/02/23	1.6	
37	20482100-013SF	20482100-013SF22A	124 - Drinking Fountain	08/02/23	ND	
38	20482100-019BF	20482100-019BF22A	130A - Women's RR - Left Sink (1)	09/20/23	0.8	
39	20482100-020BF	20482100-020BF22A	130A - Women's RR - Sink (2)	09/20/23	1.4	
40	20482100-021BF	20482100-021BF22A	130A - Women's RR - Sink (3)	08/02/23	7.5	
41	20482100-022BF	20482100-022BF22A	130A - Women's RR - Right Sink (4)	08/02/23	6.0	
42	20482100-014BF	20482100-014BF22A	130B - Unisex RR - Sink	09/20/23	0.8	
43	20482100-015BF	20482100-015BF22A	130C - Unisex RR - Sink	08/02/23	7.6	
44	20482100-016BF	20482100-016BF22A	130E - Men's RR - Sink (Left)	01/10/24	1.0	
45	20482100-017BF	20482100-017BF22A	130E - Men's RR - Sink (Center)	08/02/23	5.6	
46	20482100-018BF	20482100-018BF22A	130E - Men's RR - Sink (Right)	08/02/23	3.9	
47	20482100-026BF	20482100-026BF22A	Basement - Main Custodial Office RR - Sink	08/02/23	ND	
48	20482100-174BF	20482100-174BF22A	141 - Sink	08/02/23	1.8	
49	20482100-175DW	20482100-175DW22A	141 - Drinking Fountain	08/02/23	ND	
50	20482100-023CF	20482100-023CF22A	143 - Sink	08/02/23	ND	
51	20482100-176DW	20482100-176DW22A	143 - Drinking Fountain	08/02/23	ND	
57	20482100-177CF	20482100-177CF22A	145 - Sink	08/02/23	ND	
58	20482100-178DW	20482100-178DW22A	145 - Drinking Fountain	08/02/23	ND	
63	20482100-027BF	20482100-027BF22A	142C - Women's RR - Sink (Left)	08/02/23	0.6	
64	20482100-028BF	20482100-028BF22A	142C - Women's RR - Sink (Center)	08/02/23	10.7	
65	20482100-029BF	20482100-029BF22A	142C - Women's RR - Sink (Right)	09/20/23	ND	
66	20482100-030DW	20482100-030DW22A	146 Hall - Drinking Fountain	08/02/23	ND	
67	20482100-142CF	20482100-142CF22A	146 - Staff Break - Sink	08/02/23	ND	
72	20482100-147CF	20482100-147CF22A	146A - Staff Break Kitchen - Sink	08/02/23	ND	
73	20482100-154CF	20482100-154CF22A	147 - Sink	08/02/23	ND	
74	20482100-179DW	20482100-179DW22A	147 - Drinking Fountain	08/02/23	ND	
75	20482100-148CF	20482100-148CF22A	148 - Sink	08/02/23	ND	
76	20482100-180DW	20482100-180DW22A	148 - Drinking Fountain	08/02/23	ND	
90	20482100-033CF	20482100-033CF22A	149 - Sink	08/02/23	ND	This sink has a lead filter on it.
91	20482100-181DW	20482100-181DW22A	149 - Drinking Fountain	08/02/23	ND	
99	20482100-038BF	20482100-038BF22A	150 - Men's RR - Left Sink (1)	08/02/23	1.6	
100	20482100-039BF	20482100-039BF22A	150 - Men's RR - Sink (2)	08/02/23	6.5	
101	20482100-182BF	20482100-182BF22A	150 - Men's RR - Sink (3)	09/20/23	0.5	
102	20482100-183BF	20482100-183BF22A	150 - Men's RR - Right Sink (4)	08/02/23	14.1	
103	20482100-184CF	20482100-184CF22A	151 - Art Room NW - Sink	08/02/23	ND	
104	20482100-185DW	20482100-185DW22A	151 - Art Room NW - Drinking Fountain	08/02/23	ND	
105	20482100-035CF	20482100-035CF22A	151 - Art Room NE - Left Sink	08/02/23	ND	
106	20482100-186CF	20482100-186CF22A	151 - Art Room NE - Right Sink	08/02/23	0.7	
108	20482100-037CF	20482100-037CF22A	151 - Art Room South - Sink	08/02/23	ND	
109	20482100-187CF	20482100-187CF22A	153 - Sink	08/02/23	ND	
110	20482100-188DW	20482100-188DW22A	153 - Drinking Fountain	08/02/23	ND	
111	20482100-040SF	20482100-040SF22A	155A - Sink	08/02/23	ND	

112	20482100-041BF	20482100-041BF22A	155B - Unisex RR - Sink	08/02/23	2.6	
114	20482100-043CF	20482100-043CF22A	157 - Sink	08/02/23	ND	
115	20482100-191DW	20482100-191DW22A	157 - Drinking Fountain	08/02/23	ND	
116	20482100-044BF	20482100-044BF22A	157B - Men's RR - Sink	08/02/23	6.8	
117	20482100-045BF	20482100-045BF22A	157C - Women's RR - Sink (Left)	08/02/23	4.2	
118	20482100-046BF	20482100-046BF22A	157C - Women's RR - Sink (Right)	08/02/23	2.7	
119	20482100-192CF	20482100-192CF22A	159 - Sink	08/02/23	ND	
120	20482100-067DW	20482100-067DW22A	160A - In Hall Outside 160A - Drinking Fountain	08/02/23	0.8	
121	20482100-066BF	20482100-066BF22A	162 - Kitchen - Unisex RR - Sink	09/20/23	ND	
122	20482100-062KF	20482100-062KF22A	162 - Kitchen - Pre-rinse - Sink	08/02/23	6.8	
123	20482100-063KF	20482100-063KF22A	162 - Kitchen - Food Prep - South Wall - Sink	08/04/23	1.6	
124	20482100-064KF	20482100-064KF22A	162 - Kitchen - Food Island - Sink	08/02/23	1.7	
125	20482100-065KF	20482100-065KF22A	162A - Kitchen - Hand Wash - Sink	08/02/23	1.0	
126	20482100-194KF	20482100-194KF22A	162A - Kitchen - Dishwasher Hand - Sink	08/24/23	ND	
127	20482100-056IM	20482100-056IM22A	164A - Ice Machine	09/20/23	ND	
128	20482100-057CF	20482100-057CF22A	164A - Sink	08/02/23	0.6	
129	20482100-058CF	20482100-058CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (1)	08/02/23	3.4	
130	20482100-059CF	20482100-059CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (2)	08/02/23	4.4	
131	20482100-060CF	20482100-060CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (3)	08/02/23	3.6	
132	20482100-061CF	20482100-061CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (4)	08/02/23	6.4	
133	20482100-195CF	20482100-195CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (5)	08/02/23	2.1	
134	20482100-196CF	20482100-196CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (6)	09/20/23	ND	
135	20482100-197CF	20482100-197CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (7)	08/02/23	1.6	
136	20482100-198CF	20482100-198CF22A	164 - Culinary Arts (Start at door and go clockwise) - Sink (8)	08/02/23	5.1	
137	20482100-052SF	20482100-052SF22A	164 Hall - Sink	08/02/23	7.6	
138	20482100-199WB	20482100-199WB22A	164 Hall - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
139	20482100-053DW	20482100-053DW22A	164 Hall - Drinking Fountain (Upper)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
140	20482100-054DW	20482100-054DW22A	164 Hall - Drinking Fountain (Lower)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
141	20482100-117WB	20482100-117WB22A	165 - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
143	20482100-118DW	20482100-118DW22A	165 - Drinking Fountain	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
144	20482100-050BF	20482100-050BF22A	166A - Women's RR - Sink (Left)	08/02/23	11.3	
145	20482100-051BF	20482100-051BF22A	166A - Women's RR - Sink (Right)	08/02/23	11.4	
146	20482100-048BF	20482100-048BF22A	166B - Men's RR - Sink (Left)	08/02/23	6.0	
147	20482100-049BF	20482100-049BF22A	166B - Men's RR - Sink (Right)	08/02/23	6.9	
148	20482100-253DW	20482100-253DW22A	Outside Play Area - North - Drinking Fountain	08/04/23	ND	
149	20482100-254DW	20482100-254DW22A	Outside Play Area - South - Drinking Fountain	08/04/23	ND	
151	20482100-200CF	20482100-200CF22A	Below The Stage Near Dressing Rooms - Sink (Left)	09/21/23	6.1	
152	20482100-201CF	20482100-201CF22A	Below The Stage Near Dressing Rooms - Sink (Center)	09/21/23	1.1	
153	20482100-202CF	20482100-202CF22A	Below The Stage Near Dressing Rooms - Sink (Right)	08/02/23	9.9	
155	20482100-203WB	20482100-203WB22A	200 - Hall of Fame - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
156	20482100-068DW	20482100-068DW22A	200 - Hall of Fame - Drinking Fountain (Upper)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
157	20482100-069DW	20482100-069DW22A	200 - Hall of Fame - Drinking Fountain (Lower)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
158	20482100-073BF	20482100-073BF22A	200A - Women's RR - Sink (Left)	09/21/23	8.4	
159	20482100-074BF	20482100-074BF22A	200A - Women's RR - Sink (Center)	08/02/23	6.9	
160	20482100-075BF	20482100-075BF22A	200A - Women's RR - Sink (Right)	10/18/23	ND	10/17/2023 Filter installed.
161	20482100-070BF	20482100-070BF22A	200B - Men's RR - Sink (Left)	08/02/23	14.9	
162	20482100-071BF	20482100-071BF22A	200B - Men's RR - Sink (Center)	08/02/23	3.5	
163	20482100-072BF	20482100-072BF22A	200B - Men's RR - Sink (Right)	08/02/23	5.5	
165	20482100-204CF	20482100-204CF22A	219 - Sink	08/02/23	2.2	
166	20482100-205CF	20482100-205CF22A	222 - Sink	08/02/23	3.6	
167	20482100-206DW	20482100-206DW22A	222 - Drinking Fountain	08/02/23	1.1	
168	20482100-207WB	20482100-207WB22A	224 Hall - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
169	20482100-077DW	20482100-077DW22A	224 Hall - Drinking Fountain (Upper)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
170	20482100-078DW	20482100-078DW22A	224 Hall - Drinking Fountain (Lower)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
171	20482100-208CF	20482100-208CF22A	224 - Sink	08/02/23	0.7	
172	20482100-209DW	20482100-209DW22A	224 - Drinking Fountain	08/02/23	0.7	
173	20482100-210CF	20482100-210CF22A	226 - Sink	08/02/23	1.2	
174	20482100-211DW	20482100-211DW22A	226 - Drinking Fountain	08/02/23	0.6	
175	20482100-212CF	20482100-212CF22A	230 - Sink	08/02/23	1.5	
176	20482100-213CF	20482100-213CF22A	231 - Sink	08/02/23	1.1	
177	20482100-214CF	20482100-214CF22A	233 - Sink	08/02/23	5.0	
178	20482100-215DW	20482100-215DW22A	233 - Drinking Fountain	08/02/23	1.3	
179	20482100-094CF	20482100-094CF22A	239 - Sink	09/21/23	1.0	

180	20482100-216DW	20482100-216DW22A	239 - Drinking Fountain	08/02/23	1.0	
181	20482100-091SF	20482100-091SF22A	240 - Sink	08/02/23	1.5	This fixture has a sediment filter on it.
182	20482100-088BF	20482100-088BF22A	240A - Women's RR - Sink (Left)	09/21/23	3.4	
183	20482100-089BF	20482100-089BF22A	240A - Women's RR - Sink (Center)	09/21/23	2.9	
184	20482100-090BF	20482100-090BF22A	240A - Women's RR - Sink (Right)	08/02/23	6.5	
185	20482100-085BF	20482100-085BF22A	240B - Men's RR - Sink (Left)	09/19/23	ND	Lead filter installed 09/18/2023.
186	20482100-086BF	20482100-086BF22A	240B - Men's RR - Sink (Center)	09/19/23	ND	Lead filter installed 09/18/2023.
187	20482100-087BF	20482100-087BF22A	240B - Men's RR - Sink (Right)	09/19/23	ND	Lead filter installed 09/18/2023.
188	20482100-217CF	20482100-217CF22A	251- Sink	08/02/23	1.4	
189	20482100-218DW	20482100-218DW22A	251- Drinking Fountain	08/02/23	2.4	
190	20482100-219CF	20482100-219CF22A	252 - Sink	08/02/23	0.5	
191	20482100-220DW	20482100-220DW22A	252 - Drinking Fountain	08/02/23	0.9	
192	20482100-079CF	20482100-079CF22A	254 - Sink	08/02/23	0.6	
193	20482100-221DW	20482100-221DW22A	254 - Drinking Fountain	08/02/23	1.1	
194	20482100-084DW	20482100-084DW22A	261 Hall - Drinking Fountain	08/02/23	1.2	
195	20482100-222CF	20482100-222CF22A	261 - Sink	08/02/23	0.6	
196	20482100-223DW	20482100-223DW22A	261 - Drinking Fountain	08/02/23	ND	
197	20482100-080CF	20482100-080CF22A	262A - Unisex RR - Sink	08/02/23	2.6	
198	20482100-224CF	20482100-224CF22A	263 - Sink	08/02/23	0.6	
199	20482100-225DW	20482100-225DW22A	263 - Drinking Fountain	08/02/23	1.3	
200	20482100-226CF	20482100-226CF22A	264 - Sink	08/02/23	0.6	
201	20482100-227DW	20482100-227DW22A	264 - Drinking Fountain	08/02/23	ND	
202	20482100-228CF	20482100-228CF22A	265 - Sink	08/02/23	1.3	
203	20482100-229DW	20482100-229DW22A	265 - Drinking Fountain	08/02/23	0.9	
204	20482100-230CF	20482100-230CF22A	266 - Sink	08/02/23	2.6	
205	20482100-231DW	20482100-231DW22A	266 - Drinking Fountain	08/02/23	8.1	
206	20482100-116DW	20482100-116DW22A	270A Hall - Drinking Fountain	08/02/23	0.7	
207	20482100-113BF	20482100-113BF22A	270A - Women's RR - Sink (Left)	08/02/23	2.1	
208	20482100-114BF	20482100-114BF22A	270A - Women's RR - Sink (Center)	08/02/23	2.0	
209	20482100-115BF	20482100-115BF22A	270A - Women's RR - Sink (Right)	08/02/23	2.2	
210	20482100-232BF	20482100-232BF22A	270B - Men's RR Sink Left	08/02/23	2.8	
211	20482100-233BF	20482100-233BF22A	270B - Men's RR Sink Center	08/02/23	1.8	
212	20482100-234BF	20482100-234BF22A	270B - Men's RR Sink Right	08/02/23	2.1	
213	20482100-235BF	20482100-235BF22A	270D - Unisex RR Sink	08/02/23	0.7	
214	20482100-236CF	20482100-236CF22A	271 - Sink	08/02/23	ND	
215	20482100-237DW	20482100-237DW22A	271 - Drinking Fountain	08/02/23	1.1	
216	20482100-238CF	20482100-238CF22A	272 - Sink	08/02/23	1.4	
217	20482100-239DW	20482100-239DW22A	272 - Drinking Fountain	08/02/23	0.5	
218	20482100-240CF	20482100-240CF22A	273 - Sink	08/02/23	1.2	
219	20482100-241DW	20482100-241DW22A	273 - Drinking Fountain	08/02/23	0.9	
220	20482100-242CF	20482100-242CF22A	274 - Sink	08/02/23	2.0	
221	20482100-243DW	20482100-243DW22A	274 - Drinking Fountain	08/02/23	0.5	
222	20482100-112CF	20482100-112CF22A	275 - Sink	08/02/23	9.2	
223	20482100-244DW	20482100-244DW22A	275 - Drinking Fountain	08/02/23	0.8	
226	20482100-111BF	20482100-111BF22A	276 - Unisex RR - Sink	08/02/23	1.1	
227	20482100-110DW	20482100-110DW22A	276 Hall - Drinking Fountain	08/02/23	0.8	
246	20482100-245CF	20482100-245CF22A	280 - Sink	08/02/23	1.6	
247	20482100-246DW	20482100-246DW22A	280 - Drinking Fountain	08/02/23	1.1	
248	20482100-095CF	20482100-095CF22A	281 - Sink	08/02/23	2.2	
249	20482100-247DW	20482100-247DW22A	281 - Drinking Fountain	08/02/23	0.8	
250	20482100-248WB	20482100-248WB22A	282A Hall - Bottle Filler	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
251	20482100-101DW	20482100-101DW22A	282A Hall - Drinking Fountain (Upper)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
252	20482100-102DW	20482100-102DW22A	282A Hall - Drinking Fountain (Lower)	08/02/23	ND	This drinking fountain has a lead/sediment filter on it.
253	20482100-103BF	20482100-103BF22A	282A - Women's RR - Sink (Left)	08/02/23	3.3	
254	20482100-104BF	20482100-104BF22A	282A - Women's RR - Sink (Center)	08/02/23	4.1	
255	20482100-105BF	20482100-105BF22A	282A - Women's RR - Sink (Right)	08/02/23	2.3	
256	20482100-106BF	20482100-106BF22A	282B - Men's RR - Sink	08/02/23	2.4	
257	20482100-107BF	20482100-107BF22A	282C - Unisex RR - Sink	08/04/23	3.2	
258	20482100-249CF	20482100-249CF22A	283 - Sink	08/02/23	6.5	
259	20482100-250DW	20482100-250DW22A	283 - Drinking Fountain	08/02/23	1.6	
277	20482100-251CF	20482100-251CF22A	289 - Sink	08/03/23	2.7	
278	20482100-252DW	20482100-252DW22A	289 - Drinking Fountain	08/02/23	3.0	

Lead Tests - MSDEC - Gym - # 20482101						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482101-037WB	20482101-037WB22A	Lobby (West Side) - Bottle Filler	08/02/23	ND	This has lead/sediment filter.
2	20482101-002DW	20482101-002DW22A	Lobby (West Side) - Drinking Fountain (Upper)	08/02/23	ND	This has lead/sediment filter.
3	20482101-001DW	20482101-001DW22A	Lobby (West Side) - Drinking Fountain (Lower)	08/02/23	ND	This has lead/sediment filter.
4	20482101-003OT	20482101-003OT22A	Lobby Concession Stand - Sink	08/02/23	2.8	This sink has a lead filter on it.
6	20482101-005BF	20482101-005BF22A	Lobby Men's Restroom - Left Sink (1)	08/02/23	0.5	
7	20482101-006BF	20482101-006BF22A	Lobby Men's Restroom - Sink (2)	08/02/23	1.2	
8	20482101-007BF	20482101-007BF22A	Lobby Men's Restroom - Sink (3)	08/02/23	1.2	
9	20482101-008BF	20482101-008BF22A	Lobby Men's Restroom - Sink (4)	08/02/23	0.6	
10	20482101-009BF	20482101-009BF22A	Lobby Men's Restroom - Right Sink (5)	08/02/23	0.7	
11	20482101-010BF	20482101-010BF22A	Lobby Women's Restroom - Left Sink (1)	08/02/23	1.2	
12	20482101-011BF	20482101-011BF22A	Lobby Women's Restroom - Sink (2)	09/29/23	1.8	
13	20482101-012BF	20482101-012BF22A	Lobby Women's Restroom - Sink (3)	08/02/23	0.9	
14	20482101-013BF	20482101-013BF22A	Lobby Women's Restroom - Sink (4)	08/02/23	0.9	
15	20482101-014BF	20482101-014BF22A	Lobby Women's Restroom - Right Sink (5)	08/02/23	ND	
16	20482101-038WB	20482101-038WB22A	In Main Gym (South East Corner) - Bottle Filler	08/02/23	ND	This has lead/sediment filter.
17	20482101-015DW	20482101-015DW22A	In Main Gym (South East Corner) - Drinking Fountain	08/02/23	ND	This has lead/sediment filter.
18	20482101-016BF	20482101-016BF22A	Girl's Locker Room - Sink (Left)	09/29/23	2.7	
19	20482101-017BF	20482101-017BF22A	Girl's Locker Room - Sink (Center)	08/02/23	2.9	
20	20482101-018BF	20482101-018BF22A	Girl's Locker Room - Sink (Right)	09/29/23	1.3	
21	20482101-019DW	20482101-019DW22A	Girl's Locker Room - Drinking Fountain	08/02/23	0.5	
48	20482101-020SF	20482101-020SF22A	Girl's Locker Room Coach's Area - Sink	08/02/23	3.8	
49	20482101-021IM	20482101-021IM22A	Girl's Locker Room Training Room - Ice Machine	08/02/23	4.6	
50	20482101-022OT	20482101-022OT22A	Girl's Locker Room Training Room - Sink	09/29/23	0.6	
51	20482101-023OT	20482101-023OT22A	Boy's Locker Room Training Room - Sink	08/02/23	3.1	
52	20482101-024BF	20482101-024BF22A	Boy's Locker Room - Left Sink (1)	08/02/23	5.2	
53	20482101-025BF	20482101-025BF22A	Boy's Locker Room - Sink (2)	08/02/23	4.3	
54	20482101-026BF	20482101-026BF22A	Boy's Locker Room - Sink (3)	08/02/23	2.2	
55	20482101-027BF	20482101-027BF22A	Boy's Locker Room - Right Sink (4)	09/29/23	9.3	
56	20482101-028DW	20482101-028DW22A	Boy's Locker Room - Drinking Fountain	08/02/23	2.6	
91	20482101-029SF	20482101-029SF22A	Boy's Locker Room Coach's Area - Sink	08/02/23	3.4	
93	20482101-036DW	20482101-036DW22A	Main Gym NW Corner by Stairs - Drinking Fountain	08/03/23	4.4	
94	20482101-031BF	20482101-031BF22A	Upper Gym Men's Restroom - Sink (Left)	08/02/23	ND	
95	20482101-032BF	20482101-032BF22A	Upper Gym Men's Restroom - Sink (Right)	08/02/23	ND	
96	20482101-033BF	20482101-033BF22A	Upper Gym Women's Restroom - Sink (Left)	08/02/23	1.9	
97	20482101-034BF	20482101-034BF22A	Upper Gym Women's Restroom - Sink (Right)	08/02/23	ND	
98	20482101-035DW	20482101-035DW22A	Upper Gym West - Drinking Fountain	08/02/23	2.3	
99	20482101-036CF	20482101-036CF22A	Wrestling Room Sink	01/10/24	ND	Recently Discovered Fixture!
100	20482101-037DW	20482101-037DW22A	Wrestling Room Fountain	01/10/24	1.0	Recently Discovered Fixture!
Lead Tests - MSDEC - Annex - # 20482102						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482102-001SF	20482102-001SF22A	Facilities Break Room - Sink	04/27/23	3.7	
2	20482102-003DW	20482102-003DW22A	Facilities Office - Bottom of Stairs/Outside Restrooms - Drinking Fountain	04/27/23	0.9	
3	20482102-004BF	20482102-004BF22A	Facilities Office Men's Restroom - Sink (Left)	04/27/23	1.1	
4	20482102-005BF	20482102-005BF22A	Facilities Office Men's Restroom - Sink (Right)	04/27/23	6.1	
5	20482102-006BF	20482102-006BF22A	Facilities Office Women's Restroom - Sink (Left)	04/27/23	5.8	
6	20482102-007BF	20482102-007BF22A	Facilities Office Women's Restroom - Sink (Right)	04/27/23	2.8	
7	20482102-008IM	20482102-008IM22A	Warehouse - Ice Machine	04/27/23	ND	
9	20482102-009BF	20482102-009BF22A	Warehouse Unisex Restroom - Sink	04/27/23	ND	
10	20482102-010SF	20482102-010SF22A	NTS Break Room - Sink	04/27/23	7.0	This sink has a lead filter on it on the cold side.
11	20482102-011BF	20482102-011BF22A	NTS Men's Restroom - Sink	08/03/23	4.0	
12	20482102-012BF	20482102-012BF22A	NTS Women's Restroom - Sink	05/12/23	2.1	
13	20482102-013BF	20482102-013BF22A	Men's Restroom Outside NTS (C2) Entrance - Sink (Left)	06/22/23	9.4	
14	20482102-014BF	20482102-014BF22A	Men's Restroom Outside NTS (C2) Entrance - Sink (Middle)	09/28/23	4.4	Lead Filter Installed 09/28/2023.
15	20482102-015BF	20482102-015BF22A	Men's Restroom Outside NTS (C2) Entrance - Sink (Right)	06/22/23	12.2	
16	20482102-035BF	20482102-035BF22A	Women's Restroom Outside NTS (C2) Entrance - Sink (Left)	06/22/23	8.0	
17	20482102-036BF	20482102-036BF22A	Women's Restroom Outside NTS (C2) Entrance - Sink (Right)	09/29/23	2.0	Lead Filter Installed 09/28/2023.
18	20482102-016SF	20482102-016SF22A	Band Room Office - Sink	08/04/23	14.1	
19	20482102-017SF	20482102-017SF22A	Publications - Sink	04/27/23	2.7	
20	20482102-018SF	20482102-018SF22A	IT Break Room - Sink	04/27/23	ND	
22	20482102-020BF	20482102-020BF22A	Across From IT Break Room Men's Restroom - Sink (Left)	04/27/23	3.5	
23	20482102-021BF	20482102-021BF22A	Across From IT Break Room Men's Restroom - Sink (Right)	04/27/23	4.9	
24	20482102-022BF	20482102-022BF22A	Across From IT Break Room Women's Restroom - Sink	04/27/23	4.6	
25	20482102-023DW	20482102-023DW22A	Upstairs (Dance Room) - Drinking Fountain	04/27/23	4.9	
26	20482102-024DW	20482102-024DW22A	Upstairs (Police Training Room) - Drinking Fountain	04/27/23	2.4	
27	20482102-025OT	20482102-025OT22A	Upstairs (Police Training Room) - Sink	04/27/23	2.1	
28	20482102-026BF	20482102-026BF22A	IT/Paint Shop Men's Restroom - Sink (Left)	04/27/23	4.8	
29	20482102-027BF	20482102-027BF22A	IT/Paint Shop Men's Restroom - Sink (Right)	04/27/23	3.4	
30	20482102-028BF	20482102-028BF22A	IT/Paint Shop Women's Restroom - Sink (Left)	05/12/23	2.7	
31	20482102-029BF	20482102-029BF22A	IT/Paint Shop Women's Restroom - Sink (Right)	04/27/23	4.2	
32	20482102-030OT	20482102-030OT22A	Paint Booth Shop - (Utility) Sink	04/27/23	3.9	
34	20482102-032BF	20482102-032BF22A	Carpenter Shop Men's Restroom - Sink	04/27/23	8.0	

35	20482102-033OT	20482102-033OT22A	Metal Shop - Trough Sink (Left Fixture)	04/27/23	3.3	
36	20482102-034OT	20482102-034OT22A	Metal Shop - Trough Sink (Right Fixture)	04/27/23	3.9	
Lead Tests - MSDEC - Spiegelberg West Grandstands - # 20482103						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482103-001OT	20482103-001OT22A	Home Side South Concession Stand (Blue) - Sink	08/02/23	3.2	
2	20482103-002OT	20482103-002OT22A	Home Side South Concession Stand (Blue) - Coffee Machine	08/02/23	4.6	
4	20482103-004OT	20482103-004OT22A	Home Side South Concession Stand (Blue) - Cappuccino Machine	08/02/23	3.6	
6	20482103-006OT	20482103-006OT22A	Home Side South Concession Stand (Blue) - Soda Machine (Left)	09/26/23	ND	
7	20482103-007OT	20482103-007OT22A	Home Side South Concession Stand (Blue) - Soda Machine (Right)	09/26/23	ND	
8	20482103-008BF	20482103-008BF22A	Home Side South (Blue) Men's Restroom - Sink (Left)	08/02/23	12.5	
9	20482103-009BF	20482103-009BF22A	Home Side South (Blue) Men's Restroom - Sink (Right)	08/02/23	10.6	
10	20482103-010DW	20482103-010DW22A	Home Side In-between South (Blue) Restrooms - Drinking Fountain (Upper)	08/02/23	ND	
11	20482103-011DW	20482103-011DW22A	Home Side In-between South (Blue) Restrooms - Drinking Fountain (Lower)	08/02/23	ND	
12	20482103-012BF	20482103-012BF22A	Home Side South (Blue) Women's Restroom - Sink (Left)	08/02/23	5.5	
13	20482103-013BF	20482103-013BF22A	Home Side South (Blue) Women's Restroom - Sink (Right)	08/02/23	7.6	
14	20482103-014DW	20482103-014DW22A	Home Side South Locker Room - Drinking Fountain	08/02/23	0.8	
15	20482103-015BF	20482103-015BF22A	Home Side South Locker Room - Trough Sink	08/02/23	5.3	
30	20482103-016DW	20482103-016DW22A	Home Side North Locker Room - Drinking Fountain	08/02/23	1.4	
31	20482103-017BF	20482103-017BF22A	Home Side North Locker Room - Sink	08/02/23	6.3	
40	20482103-018OT	20482103-018OT22A	Home Side North Concession Stand (Red) - Sink	08/02/23	7.7	
41	20482103-019OT	20482103-019OT22A	Home Side North Concession Stand (Red) - Coffee Machine	08/02/23	3.4	
42	20482103-020OT	20482103-020OT22A	Home Side North Concession Stand (Red) - Cappuccino Machine	08/02/23	4.6	
43	20482103-021IM	20482103-021IM22A	Home Side North Concession Stand (Red) - Ice Machine	08/02/23	ND	Has Filter.
44	20482103-022OT	20482103-022OT22A	Home Side North Concession Stand (Red) - Soda Machine (Left)	09/26/23	0.5	
45	20482103-023OT	20482103-023OT22A	Home Side North Concession Stand (Red) - Soda Machine (Right)	09/26/23	ND	
46	20482103-024BF	20482103-024BF22A	Home Side North (Red) Men's Restroom - Sink (Left)	08/18/23	1.2	Installed filter 8/18/2023.
47	20482103-025BF	20482103-025BF22A	Home Side North (Red) Men's Restroom - Sink (Right)	08/18/23	1.3	Installed filter 8/18/2023.
48	20482103-026DW	20482103-026DW22A	Home Side In-between North (Red) Restrooms - Drinking Fountain (Upper)	08/02/23	ND	05/31/2023 Replaced with Drinking Fountain With Filter
49	20482103-027DW	20482103-027DW22A	Home Side In-between North (Red) Restrooms - Drinking Fountain (Lower)	08/02/23	ND	05/31/2023 Replaced with Drinking Fountain With Filter
50	20482103-028BF	20482103-028BF22A	Home Side North (Red) Women's Restroom - Sink (Left)	08/18/23	0.6	Installed filter 8/18/2023.
51	20482103-029BF	20482103-029BF22A	Home Side North (Red) Women's Restroom - Sink (Right)	08/18/23	1.1	Installed filter 8/18/2023.
52	20482103-030OT	20482103-030OT22A	VIP Box On Home side Roof Concession Stand - Sink	08/18/23	0.9	
53	20482103-031OT	20482103-031OT22A	VIP Box On Home side Roof Concession Stand - Coffee Machine	08/02/23	2.8	
56	20482103-034BF	20482103-034BF22A	VIP Box On Home side Roof Men's Restroom - Sink	08/02/23	2.8	
57	20482103-035BF	20482103-035BF22A	VIP Box On Home side Roof Women's Restroom - Sink	08/02/23	2.8	
Lead Tests - MSDEC - Spiegelberg East Side Concessions - # 20482104						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482104-001OT	20482104-001OT22A	East Side Visitor Concession Stand - (Utility) Sink	08/02/23	12.4	
2	20482104-002OT	20482104-002OT22A	East Side Visitor Concession Stand - Coffee Machine	08/02/23	9.6	This machine has a lead filter on it.
3	20482104-003OT	20482104-003OT22A	East Side Visitor Concession Stand - Cappuccino Machine	08/02/23	9.5	This machine has a lead filter on it.
4	20482104-004OT	20482104-004OT22A	East Side Visitor Concession Stand - Soda Machine	08/02/23	1.0	This machine has a lead filter on it.
5	20482104-005OT	20482104-005OT22A	East Side Visitor Concession Stand - Ice Machine	08/02/23	1.8	Installed Summer 2023.
Lead Tests - MSDEC - Spiegelberg East Grandstands - # 20482105						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482105-001BF	20482105-001BF22A	East Side Visitor's Locker Room (North End) - Sink	08/18/23	ND	
2	20482105-002DW	20482105-002DW22A	East Side Visitor's Locker Room (North End) - Drinking Fountain	08/02/23	1.4	
3	20482105-003DW	20482105-003DW22A	Tunnel 11 - Drinking Fountain	08/02/23	3.3	
4	20482105-004BF	20482105-004BF22A	Tunnel 11 Men's Restroom - Sink	08/02/23	12.2	
5	20482105-005DW	20482105-005DW22A	Tunnel 12 - Drinking Fountain (Upper)	08/02/23	6.3	
6	20482105-006DW	20482105-006DW22A	Tunnel 12 - Drinking Fountain (Lower)	08/02/23	0.6	
7	20482105-007BF	20482105-007BF22A	Tunnel 12 Women's Restroom - Sink	08/18/23	ND	
8	20482105-008BF	20482105-008BF22A	Tunnel 12 Unisex Restroom - Sink	08/02/23	2.8	
9	20482105-009DW	20482105-009DW22A	East Side Locker Room (South End) - Drinking Fountain	08/02/23	12.8	
10	20482105-010BF	20482105-010BF22A	East Side Locker Room Sink (South End) - Sink	08/18/23	ND	
Lead Tests - MSDEC - Maslow - # 20480001						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480001-001BF	20480001-001BF22A	Unisex Restroom By Front Door - Sink	08/02/23	4.8	
2	20480001-002OT	20480001-002OT22A	Kitchenette (In Common Area) - Sink	08/02/23	1.5	
3	20480001-003KF	20480001-003KF22A	Kitchen - Sink	08/02/23	0.6	
4	20480001-004OT	20480001-004OT22A	North East Corner of Building - Sink (Utility)	08/02/23	11.6	
5	20480001-005BF	20480001-005BF22A	Unisex Staff Restroom (Near Clothes Closet) - Sink	08/02/23	5.0	
6	20480001-006WB	20480001-006WB22A	Elkay Bottler Filler (Upper)	08/02/23	ND	01/15/2023 - Elkay Bottler Filler Installed
7	20480001-007DW	20480001-007DW22A	Elkay Bottle Filler Fountain (Lower)	08/02/23	ND	01/15/2023 - Elkay Bottler Filler Installed

*None Detected (ND) = 0.10 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.