

Lead Tests - Innovation Academy - 20482200						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482200-001KF		Kitchen - Left Sink	08/02/23	1.5	
2	20482200-002KF		Kitchen - Right Sink	08/02/23	3.6	
3	20482200-003BF		Student RR - Male - East Left Sink (1)	08/02/23	2.3	
4	20482200-004BF		Student RR - Male - East Sink (2)	08/02/23	4.0	
5	20482200-005BF		Student RR - Male - East Sink (3)	08/02/23	4.2	
6	20482200-006BF		Student RR - Male - East Right Sink (4)	08/02/23	4.3	
7	20482200-007BF		Student RR - Male - West Left Sink (1)	08/02/23	3.4	
8	20482200-008BF		Student RR - Male - West Sink (2)	08/02/23	1.9	
9	20482200-009BF		Student RR - Male - West Sink (3)	08/02/23	3.7	
10	20482200-010BF		Student RR - Male - West Right Sink (4)	08/02/23	1.1	
11	20482200-011BF		Student RR - Female - East Left Sink (1)	08/02/23	3.7	
12	20482200-012BF		Student RR - Female - East Sink (2)	08/02/23	3.8	
13	20482200-013BF		Student RR - Female - East Sink (3)	08/02/23	2.1	
14	20482200-014BF		Student RR - Female - East Right Sink (4)	08/02/23	2.3	
15	20482200-015BF		Student RR - Female - West Left Sink (1)	08/02/23	1.5	
16	20482200-016BF		Student RR - Female - West Sink (2)	08/02/23	2.1	
17	20482200-017BF		Student RR - Female - West Sink (3)	08/02/23	3.1	
18	20482200-018BF		Student RR - Female - West Sink (4)	08/02/23	2.2	
19	20482200-019BF		Student RR - Female - West Right Sink (5)	08/02/23	1.4	
20	20482200-020DW		Large Hall - Drinking Fountain	08/02/23	0.5	
21	20482200-021SF		Staff Lounge - Sink	08/02/23	1.0	
22	20482200-022BF		Staff RR - Men's - Sink	08/02/23	2.5	
23	20482200-023BF		Staff RR - Women's - Sink	08/02/23	0.8	
24	20482200-024BF		Greenhouse Unisex RR Sink	09/29/23	3.5	
25	20482200-025SF		Greenhouse Office Sink	08/02/23	6.3	

*None Detected (ND) = 0.10 Or Less PPB

*The E.P.A. action level for lead in schools is 20 PPB. Oregon's action level for schools is 15 PPB (Changed in 2019 in accordance with OAR 333-061-0400).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days.