

Lead Sample Test Results and Actions

MOUNTAIN VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 001		No				
FX 002		No				
FX 003	Hall to Gym	Yes	0.0009			No action required
FX 004	Hall to Gym	Yes	0.0009			No action required
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		Yes	0.0009			No action required
FX 010	Room K	No				
FX 011		No				
FX 012	Room K	Yes	0.001			No action required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017	Hall by Office	Yes	0.0009			No action required
FX 018	Hall by Office	Yes	0.0009			No action required
FX 019	Hall by Office	Yes	0.0009			No action required
FX 020	Kitchen	Yes	0.0009			No action required
FX 021	Kitchen	Yes	0.0009			No action required
FX 022	Kitchen	Yes	0.0009			No action required
FX 023		No				
FX 024		No				
FX 025		No				
FX 026	Art Room	Yes	0.002			No action required
FX 027		No				
FX 028		No				
FX 029		No				

Lead Sample Test Results and Actions

MOUNTAIN VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 030		No				
FX 031		No				
FX 032	Computer Lab	Yes	0.001			No action required
FX 033		No				
FX 034		No				
FX 035		No				
FX 036		No				
FX 037	5th/6th Pod	Yes	0.002			No action required
FX 038	5th/6th Pod	Yes	0.002			No action required
FX 039	5th/6th Pod	Yes	0.003			No action required
FX 040	5th/6th Pod	Yes	0.003			No action required
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045	3rd/4th Pod	Yes	0.002			No action required
FX 046	3rd/4th Pod	Yes	0.001			No action required
FX 047		No				
FX 048	3rd/4th Pod	Yes	0.006		Fix, Replace or Remove	
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	1st/2nd Pod	Yes	0.003			No action required
FX 054	1st/2nd Pod	Yes	0.001			No action required
FX 055	1st/2nd Pod	Yes	0.003			No action required
FX 056	1st/2nd Pod	Yes	0.004			No action required
FX 057		No				
FX 058		No				

Lead Sample Test Results and Actions

MOUNTAIN VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 059	Library	Yes	0.001			No action required