

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003	Kitchen	Yes	0.001			No action required
FX 004	Kitchen sink	Yes	0.0009			No action required
FX 005	Kitchen sink	Yes	0.002			No action required
FX 006		No				
FX 007	Bottle filler west hall	Yes	0.0009			No action required
FX 008	Fountain west hall	Yes	0.0009			No action required
FX 009	Fountain west hall	Yes	0.0009			No action required
FX 010		No				
FX 011		No				
FX 012	Fountain cafeteria	Yes	0.0009			No action required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017	Fountain Rm. A1	Yes	0.001			No action required
FX 018		No				
FX 019	Fountain Rm. A2	Yes	0.0009			No action required
FX 020		No				
FX 021	Fountain Rm. A3	Yes	0.0009			No action required
FX 022		No				
FX 023	Fountain Rm. A4	Yes	0.0009			No action required
FX 024		No				
FX 025	Fountain Rm. A5	Yes	0.002			No action required
FX 026		No				
FX 027	Fountain Rm. A6	Yes	0.001			No action required
FX 028		No				
FX 029		No				
FX 030	Fountain Rm. K1	Yes	0.003			No action required

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 031		No				
FX 032	Fountain Rm. K2	Yes	0.0009			No action required
FX 033		No				
FX 034	Fountain Rm. C1	Yes	0.003			No action required
FX 035		No				
FX 036	Fountain Rm. C2	Yes	0.0009			No action required
FX 037		No				
FX 038	Fountain Rm. C3	Yes	0.0009			No action required
FX 039		No				
FX 040	Fountain Rm. C4	Yes	0.001			No action required
FX 041		No				
FX 042	Fountain Rm. C5	Yes	0.0009			No action required
FX 043		No				
FX 044	Fountain Rm. C6	Yes	0.001			No action required
FX 045		No				
FX 046	Fountain S hall boys	Yes	0.0009			No action required
FX 047	Bottle filler S hall boys	Yes	0.0009			No action required
FX 048	Fountain S hall boys	Yes	0.001			No action required
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Fountain S hall girl	Yes	0.003			No action required
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 061	Fountain Rm. B6	Yes	0.001			No action required
FX 062		No				
FX 063	Fountain Rm. B5	Yes	0.0009			No action required
FX 064		No				
FX 065	Fountain Rm. B4	Yes	0.001			No action required
FX 066		No				
FX 067	Fountain Rm. B3	Yes	0.0009			No action required
FX 068	Sink Rm B2	Yes	0.001			No action required
FX 069		No				
FX 070		No				
FX 071	Fountain Rm. B2	Yes	0.0009			No action required
FX 072		No				
FX 073	Fountain B hall	Yes	0.0009			No action required
FX 074	Bottle filler B hall	Yes	0.0009			No action required
FX 075	Fountain B hall	Yes	0.0009			No action required