

# Lead Sample Test Results and Actions

## WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002	Rm 1 fountain	Yes	0.002			No action
FX 003		No				
FX 004	Rm 2 fountain	Yes	0.003			No action
FX 005		No				
FX 006	Rm 3 fountain	Yes	0.007		Must be fixed, replaced or removed	
FX 007		No				
FX 008	Rm 4 fountain	Yes	0.0009			No action
FX 009		No				
FX 010	Rm 5 fountain	Yes	0.002			No action
FX 011	Kitchen sink	Yes	0.0009			No action
FX 012	Kitchen sprayer	Yes	0.001			No action
FX 013	Kitchen sprayer	Yes	0.001			No action
FX 014		No				
FX 015		No				
FX 016	East hall hi fountain	Yes	0.0009			No action
FX 017	East hall low fountain	Yes	0.0009			No action
FX 018	East hall bottle filler	Yes	0.0009			No action
FX 019	East hall hi fnt by girls	Yes	0.0009			No action
FX 020	East hall low fnt by girls	Yes	0.0009			No action
FX 021	EH bottle filler by girl	Yes	0.0009			No action
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028		No				
FX 029	Rm 6 fountain	Yes	0.005		Must be fixed, replaced or removed	
FX 030		No				
FX 031	Rm 7 fountain	Yes	0.004			No action
FX 032		No				
FX 033	Rm 8 fountain	Yes	0.002			No action
FX 034		No				
FX 035	Rm 9 fountain	Yes	0.002			No action

# Lead Sample Test Results and Actions

## WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040	Boiler rm fountain	Yes	0.004			No action
FX 041		No				
FX 042		No				
FX 043	MH fountain high	Yes	0.0009			No action
FX 044	MH fountain low	Yes	0.0009			No action
FX 045	MH bottle filler	Yes	0.0009			No action
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053		No				
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069		No				
FX 070		No				

# Lead Sample Test Results and Actions

## WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ( $\mu\text{g/L}$ ) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 071		No				
FX 072	Main office fountain	Yes	0.005		Must be fixed, replaced or removed	
FX 073		No				
FX 074		No				
FX 075		No				
FX 076		No				
FX 077	Rm 12 fountain	Yes	0.002			No action
FX 078		No				
FX 079	Rm 13 fountain	Yes	0.003			No action
FX 080		No				
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				
FX 085		No				
FX 086		No				
FX 087		No				
FX 088	S hall hi fountain	Yes	0.0009			No action
FX 089	S hall low fountain	Yes	0.0009			No action
FX 090	S hall bottle filler	Yes	0.0009			No action
FX 091	SH by girls hi fount.	Yes	0.002			No action
FX 092	SH by girls low fount.	Yes	0.002			No action
FX 093		No				
FX 094	Rm 15 fountain	Yes	0.005		Must be fixed, replaced or removed	
FX 095		No				
FX 096	Rm 16 fountain	Yes	0.005		Must be fixed, replaced or removed	
FX 097		No				
FX 098	Rm 18 fountain	Yes	0.001			No action
FX 099	Rm 19 sink	Yes	0.001			No action
FX 100		No				
FX 101		No				
FX 102	Rm 20 fountain	Yes	0.001			No action
FX 103		No				
FX 104	Rm 21 fountain	Yes	0.001			No action
FX 105		No				

# Lead Sample Test Results and Actions

## WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 106	Rm 22 fountain	Yes	0.002			No action
FX 107		No				
FX 108	Rm 23 fountain	Yes	0.0009			No action
FX 109		No				
FX 110	Rm 24 fountain	Yes	0.0009			No action
FX 111		No				
FX 112	Rm 25 fountain	Yes	0.001			No action
FX 113		No				
FX 114		No				
FX 115		No				
FX 116		No				
FX 117		No				
FX 118	Rm 26 fountain	Yes	0.0009			No action
FX 119		No				
FX 120	Rm 27 fountain	Yes	0.001			No action
FX 121		No				
FX 122	Rm 28 fountain	Yes	0.0009			No action
FX 123		No				
FX 124	Rm 29 fountain	Yes	0.0009			No action
FX 125		No				
FX 126	Rm 30 fountain	Yes	0.0009			No action
FX 127		No				
FX 128	Rm 31 fountain	Yes	0.002			No action
FX 129		No				
FX 130	Rm 32 fountain	Yes	0.002			No action
FX 131		No				
FX 132	Rm 35 fountain	Yes	0.002			No action
FX 133		No				
FX 134		No				
FX 135		No				
FX 136		No				
FX 137		No				
FX 138		No				
FX 139		No				
FX 140	N hall hi fountain	Yes	0.0009			No action
FX 141	N hall low fountain	Yes	0.0009			No action

## Lead Sample Test Results and Actions

### WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ( $\mu\text{g/L}$ ) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 142	N hall hi fountain	Yes	0.0009			No action
FX 143	N hall low fountain	Yes	0.0009			No action
FX 144	N hall bottle filler	Yes	0.0009			No action