

Lead Sample Test Results and Actions

SKYLINE EARLY LEARNING CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002	Kitchen sink	Yes	0.0009			No action
FX 003	Hand sink kitchen	Yes	0.0009			No action
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008	Fountain by door 1	Yes	0.002			No action
FX 009		No				
FX 010		No				
FX 011		No				
FX 012		No				
FX 013	Sink Room 26	Yes	0.001			No action
FX 014		No				
FX 015	Sink Room 26	Yes	0.003			No action
FX 016		No				
FX 017	Sink Room 26	Yes	0.0009			No action
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023	Sink Room 21	Yes	0.0009			Re-tested after adding filter 4/23/2022; No further action required
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031	Fountain N Pod Hall	Yes	0.001			No action
FX 032	Sink kitchen N pod	Yes	0.0009			No action
FX 033	Sink kitchen N pod	Yes	0.0009			No action
FX 034	Sink kitchen N pod	Yes	0.0009			No action
FX 035		No				

Lead Sample Test Results and Actions

SKYLINE EARLY LEARNING CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042	Sink Room 7	Yes	0.0009			No action
FX 043		No				
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051	Fountain by Room 1	Yes	0.0009			No action
FX 052		No				
FX 053		No				
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060	Sink Room 24	Yes	0.0009			No action
FX 061	Sink Room 22	Yes	0.003			No action
FX 062	Fountain Room 21	Yes	0.021	Fixture immediately REMOVED		
FX 063	Sink Room 21	Yes	0.001			No action
FX 064	Fountain Room 14	Yes	0.005		Fixture was REMOVED	
FX 065	Fountain Room 7	Yes	0.003			No action
FX 066	Fountain W Pod Hall	Yes	0.004			No action