

Lead Sample Test Results and Actions

PARIS GIBSON EDUCATION CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal to or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		No				
FX 010		No				
FX 011		No				
FX 012		No				
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019	Fountain main hall	Yes	0.015		Must be fixed, replaced or removed	
FX 020		No				
FX 021	Fountain main hall	Yes	0.0009			No action required
FX 022		No				
FX 023		No				
FX 024		No				
FX 025	Fountain main hall	Yes	0.004			No action required
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031		No				
FX 032		No				
FX 033		No				
FX 034		No				

Lead Sample Test Results and Actions

PARIS GIBSON EDUCATION CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal to or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 035		No				
FX 036		No				
FX 037		No				
FX 038	Fountain Autoshop	Yes	0.007		Must be fixed, replaced or removed	
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048		No				
FX 049	Sink coffeeshop 119	Yes	0.0009			No action required
FX 050		No				
FX 051		No				
FX 052		No				
FX 053		No				
FX 054		No				
FX 055	Sink C/A Rm 126	Yes	0.001			No action required
FX 056	Sink C/A Rm 126	Yes	0.002			No action required
FX 057	Sink C/A Rm 126	Yes	0.0009			No action required
FX 058	Sink C/A Rm 126	Yes	0.0009			No action required
FX 059	Sink C/A Rm 126	Yes	0.0009			No action required
FX 060	Sink C/A Rm 126	Yes	0.0009			No action required
FX 061	Sink C/A Rm 126	Yes	0.0009			No action required
FX 062	Fountain gym hall	Yes	0.004			No action required
FX 063	Fountain gym hall	Yes	0.003			No action required
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069		No				

Lead Sample Test Results and Actions

PARIS GIBSON EDUCATION CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal to or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 070		No				
FX 071	Fntain girls locker rm	Yes	0.003			No action required
FX 072		No				
FX 073		No				
FX 074		No				
FX 075		No				
FX 076		No				
FX 077		No				
FX 078		No				
FX 079		No				
FX 080	Sink boys locker rm	Yes	0.001			No action required
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				
FX 085		No				
FX 086		No				
FX 087		No				
FX 088	Fountain gym	Yes	0.001			No action required
FX 089	Bottle filler gym	Yes	0.001			No action required
FX 090		No				
FX 091		No				
FX 092		No				
FX 093	Kitchen sink South L	Yes	0.013		Must be fixed, replaced or removed	
FX 094	Kitchen sink South R	Yes	0.001			No action required
FX 095		No				
FX 096		No				
FX 097	Kitchen sink North L	Yes	0.0009			No action required
FX 098	Kitchen sink North R	Yes	0.0009			No action required
FX 099		No				
FX 100		No				
FX 101	Kitchen pot filler	Yes	0.001			No action required
FX 102	Kitchen pot filler	Yes	0.002			No action required
FX 103	Kitchen pot filler	Yes	0.001			No action required
FX 104	Kitchen pot filler	Yes	0.002			No action required

Lead Sample Test Results and Actions

PARIS GIBSON EDUCATION CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal to or greater than 5.0 $\mu\text{g/L}$ up to 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 105		No				
FX 106		No				
FX 107		No				
FX 108		No				
FX 109	Fountain 2/F hall	Yes	0.004			No action required
FX 110		No				
FX 111		No				
FX 112		No				
FX 113	Fountain 2/F hall	Yes	0.002			No action required
FX 114	Sink room 204	Yes	0.002			No action required
FX 115		No				
FX 116		No				
FX 117		No				
FX 118		No				
FX 119		No				
FX 120		No				
FX 121		No				
FX 122		No				
FX 123		No				
FX 124	Fountain 2/F hall	Yes	0.005		Must be fixed, replaced or removed	