

**Charles County Public Schools**  
P.O. Box 2770  
5980 Radio Station Road  
La Plata, MD 20646  
**Attention:**

Wednesday, April 24, 2024  
**Certificate of Analysis**  
**AMENDED**

**Project Information:**

Report for Lab No: 70106.

First Draw samples flushed by Martel on November 5, 2023, sampled by Martel on November 6, 2023.

Project Identification: MD HB 270

School: Westlake HS PSC #08.031

**References and Important Notes:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

This report amends either the original report or the last amended report sent on: 04/22/24

It has been amended for the following reason(s): Fixture list corrected.

**Notices:**

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 70106 1      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:38  
 WHS-1-DC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.21	ug/l	EPA 200.8	2	04/10/2024 12:23 EK

MARTEL NO. 70106 2      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:40  
 WHS-2-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 12:40 EK

MARTEL NO. 70106 3      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:40  
 WHS-3-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.68	ug/l	EPA 200.8	2	04/10/2024 12:42 EK

MARTEL NO. 70106 4      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:41  
 WHS-4-IM

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 12:45 EK

MARTEL NO. 70106 5      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:42  
 WHS-5-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 12:47 EK

MARTEL NO. 70106 6      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:42  
 WHS-6-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 12:50 EK

MARTEL NO. 70106 7      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:42  
 WHS-7-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.87	ug/l	EPA 200.8	2	04/10/2024 12:52 EK

MARTEL NO. 70106 8      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:42  
 WHS-8-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.42	ug/l	EPA 200.8	2	04/10/2024 12:55 EK



MARTEL NO. 70106 9      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:45  
 WHS-9-KK

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:05 EK

MARTEL NO. 70106 11      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:45  
 WHS-11-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.08	ug/l*	EPA 200.8	2	04/10/2024 13:10 EK

MARTEL NO. 70106 12      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:45  
 WHS-12-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:12 EK

MARTEL NO. 70106 13      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:46  
 WHS-13-DC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:14 EK

MARTEL NO. 70106 14      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:00  
 WHS-14-DC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA 200.8	2	11

MARTEL NO. 70106 15      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:21  
 WHS-15-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.08	ug/l	EPA 200.8	2	04/10/2024 13:17 EK

MARTEL NO. 70106 16      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 04:20  
 WHS-16-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.36	ug/l	EPA 200.8	2	04/10/2024 13:19 EK

MARTEL NO. 70106 17      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:22  
 WHS-17-DC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:22 EK



MARTEL NO. 70106 18 WHS-18-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.49	ug/l	EPA 200.8	2	04/10/2024 13:24 EK

MARTEL NO. 70106 19 WHS-19-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:27 EK

MARTEL NO. 70106 20 WHS-20-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:34 EK

MARTEL NO. 70106 21 WHS-21-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:41 EK

MARTEL NO. 70106 22 WHS-22-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:44 EK

MARTEL NO. 70106 23 WHS-23-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:46 EK

MARTEL NO. 70106 24 WHS-24-SG CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.65	ug/l	EPA 200.8	2	04/10/2024 13:49 EK

MARTEL NO. 70106 25 WHS-25-IM CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/19/2024 08:29 EK

MARTEL NO. 70106 26      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:20  
 WHS-26-DC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:54 EK

MARTEL NO. 70106 28      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:30  
 WHS-28-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 13:56 EK

MARTEL NO. 70106 29      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:30  
 WHS-29-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.79	ug/l	EPA 200.8	2	04/10/2024 13:58 EK

MARTEL NO. 70106 31      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:30  
 WHS-31-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:01 EK

MARTEL NO. 70106 32      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:30  
 WHS-32-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:10 EK

MARTEL NO. 70106 33      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:31  
 WHS-33-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:15 EK

MARTEL NO. 70106 34      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:31  
 WHS-34-FC

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.46	ug/l*	EPA 200.8	2	04/10/2024 14:18 EK

MARTEL NO. 70106 35      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 11/06/2023 05:35  
 WHS-35-DH

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:20 EK

MARTEL NO. 70106 36 WHS-36-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:23 EK

MARTEL NO. 70106 37 WHS-37-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:25 EK

MARTEL NO. 70106 38 WHS-38-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:27 EK

MARTEL NO. 70106 39 WHS-39-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:30 EK

MARTEL NO. 70106 40 WHS-40-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:32 EK

MARTEL NO. 70106 42 WHS-42-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA 200.8	2	///

MARTEL NO. 70106 43 WHS-43-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:39 EK

MARTEL NO. 70106 44 WHS-44-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 05:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 14:47 EK

MARTEL NO. 70106 45      CLIENT SAMPLE IDENTIFICATION WHS-45-FC      Sample Date/Time 11/06/2023 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 14:49 EK

MARTEL NO. 70106 46      CLIENT SAMPLE IDENTIFICATION WHS-46-DH      Sample Date/Time 11/06/2023 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 14:52 EK

MARTEL NO. 70106 47      CLIENT SAMPLE IDENTIFICATION WHS-47-FC      Sample Date/Time 11/06/2023 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 14:54 EK

MARTEL NO. 70106 49      CLIENT SAMPLE IDENTIFICATION WHS-49-DC      Sample Date/Time 11/06/2023 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 14:56 EK

MARTEL NO. 70106 50      CLIENT SAMPLE IDENTIFICATION WHS-50-FC      Sample Date/Time 11/06/2023 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.37	ug/l	EPA .200.8	2	04/10/2024 14:59 EK

MARTEL NO. 70106 53      CLIENT SAMPLE IDENTIFICATION WHS-53-FC      Sample Date/Time 11/06/2023 05:01


Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.07	ug/l	EPA .200.8	2	04/10/2024 15:01 EK

MARTEL NO. 70106 55      CLIENT SAMPLE IDENTIFICATION WHS-55-FC      Sample Date/Time 11/06/2023 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.90	ug/l	EPA .200.8	2	04/10/2024 15:11 EK

MARTEL NO. 70106 57      CLIENT SAMPLE IDENTIFICATION WHS-57-FC      Sample Date/Time 11/06/2023 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.16	ug/l	EPA .200.8	2	04/10/2024 15:16 EK



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	58	WHS-58-FC				11/06/2023 05:55	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	8.92	ug/l*	EPA .200.8	2	04/10/2024 15:18 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	59	WHS-59-BU				11/06/2023 26:55	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:21 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	60	WHS-60-BU				11/06/2023 10:55	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:23 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	61	WHS-61-FC				11/06/2023 05:15	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	n/a		EPA .200.8	2	/ /		


MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	62	WHS-62-BU				11/06/2023 05:15	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:26 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	1F	WHS-1-DC				11/06/2023 06:05	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:28 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	2F	WHS-2-FC				11/06/2023 06:05	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:31 EK		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70106	3F	WHS-3-FC				11/06/2023 06:05	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 15:38 EK		





MARTEL NO. 70106 5F WHS-5-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 15:45 EK

MARTEL NO. 70106 6F WHS-6-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	02/08/2024 16:44 BJ

MARTEL NO. 70106 7F WHS-7-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 15:50 EK

MARTEL NO. 70106 8F WHS-8-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 15:53 EK

MARTEL NO. 70106 11F WHS-11-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 15:55 EK

MARTEL NO. 70106 12F WHS-12-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 15:58 EK

MARTEL NO. 70106 15F WHS-15-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 16:00 EK

MARTEL NO. 70106 28F WHS-28-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/10/2024 16:10 EK

MARTEL NO. 70106 29F WHS-29-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 16:15 EK

MARTEL NO. 70106 31F WHS-31-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 16:17 EK

MARTEL NO. 70106 32F WHS-32-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 16:20 EK

MARTEL NO. 70106 33F WHS-33-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/05/2024 15:44 CSG

MARTEL NO. 70106 53F WHS-53-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	04/10/2024 16:24 EK

MARTEL NO. 70106 55F WHS-55-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/05/2024 15:47 CSG

MARTEL NO. 70106 56F WHS-56-SG CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/06/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	11

# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/6/23 5:50 AM End Date/Time: 11/6/23 0635

Sampler/Relinquished By: [Signature] Received at Martel by [Signature] Date/Time: 11/7/23 11 AM

58- Westlake HS PSC #08.031  
**First Draw**

3300 Middleton Road Waldorf, MD 20603

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

70106

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubblers, Water Fountain, Goose-neck Ice Machine, Hose Bibb)</small>	Outlet Key Codes	Room/Location	Consumption <small>C or NG?</small>	Location Codes	Flush <small>Flush Date</small>	Sample Time
1	1	WHS-1-DC	water fountain	DC	Kitchen	C	KI	✓	438
2	2	WHS-2-FC	Sink (near dishwasher) - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	KI	✓	440
3	3	WHS-3-FC	Sink (near dishwasher) - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	KI	✓	441
4	4	WHS-4-IM	Ice Machine	IM	Kitchen	C	KI	X	441
5	5	WHS-5-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	KI	✓	442
6	6	WHS-6-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	KI	✓	442
7	7	WHS-7-FC	Island sink - Left	FC	Kitchen	C	KI	✓	445
8	8	WHS-8-FC	Island sink (R) next to #5 & #6	FC	Kitchen	C	KI	✓	445
9	9	WHS-9-KK	kettle L	KK	Kitchen	C	KI	✓	445
10	11	WHS-11-FC	Island sink next to kettle on right	FC	Kitchen	C	KI	✓	445
11	12	WHS-12-FC	2 comp sink	FC	Kitchen	C	KI	✓	445
12	13	WHS-13-DC	water fountain - Left	DC	corridor	C	HA	✓	446
13	14	WHS-14-DC	water fountain - Right	DC	corridor	C	HA	✗	NOT WORKING
14	15	WHS-15-FC	sink	FC	nurse office	C	NO	✓	21
15	16	WHS-16-FC	sink	FC	guidance office	C	OF	✓	20
16	17	WHS-17-DC	water fountain - Left	DC	corridor	C	HA	✓	24
17	18	WHS-18-DC	water fountain - Right	DC	corridor	C	HA	✓	22
18	19	WHS-19-DC	water fountain	DC	chorus corridor	C	HA	✓	24
19	20	WHS-20-DC	water fountain - Left	DC	corridor	C	HA	✓	510 (Bottle tied)
20	21	WHS-21-DC	water fountain - Right	DC	corridor	C	HA	✓	510
21	22	WHS-22-DC	water fountain	DC	gym	C	GY	✓	512
22	23	WHS-23-DC	water fountain	DC	gym	C	GY	✓	515
23	24	WHS-24-SG	cold tub hose	SG	training room	C	TR	✓	516
24	25	WHS-25-IM	Ice Machine	IM	training room	C	TR	✓	516

NOT WORKING

NOT WORKING

(Bottle tied)

P 11

P 12

58- Westlake HS PSC #08.031

First Draw

3300 Middleton Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

70106

25	26	WHS-26-DC	water fountain	DC	corridor	C	HA	✓	520
26	28	WHS-28-FC	sink - See map	FC	food lab - home ec	C	HE	✓	530
27	29	WHS-29-FC	sink - See map	FC	food lab - home ec	C	HE	✓	
28	31	WHS-31-FC	sink - See map	FC	food lab - home ec	C	HE	✓	
29	32	WHS-32-FC	sink - See map	FC	food lab - home ec	C	HE	✓	
30	33	WHS-33-FC	sink - See map	FC	food lab - home ec	C	HE	✓	
31	34	WHS-34-FC	sink - See map	FC	teachers lounge	C	LO	✓	531
32	35	WHS-35-DH	instant hot	DH	teachers lounge	C	LO	✓	531
33	36	WHS-36-DC	water fountain	DC	corridor - (2nd Floor)	C	HA	✓	535
34	37	WHS-37-DC	water fountain	DC	media center - (2nd Floor)	C	ME	✓	36
35	38	WHS-38-DC	water fountain - Left	DC	corridor - (2nd Floor)	C	HA	✓	542
36	39	WHS-39-DC	water fountain - Right	DC	corridor - (2nd Floor)	C	HA	✓	542
37	40	WHS-40-FC	sink	FC	teachers lounge - (2nd Floor)	C	LO	✓	43
38	41	WHS-41-DH	instant hot	DH	teachers lounge - (2nd Floor)	C	LO	Not sampled	
39	42	WHS-42-DC	water fountain - Left	DC	corridor - (2nd Floor)	C	HA	Not sampled	
40	43	WHS-43-DC	water fountain - Right	DC	corridor - (2nd Floor)	C	HA	✓	543 46
41	44	WHS-44-DC	water fountain	DC	corridor - (2nd Floor)	C	HA	✓	547
42	45	WHS-45-FC	sink	FC	CR 212 (Sp-ED) (2nd Floor) SOAR	C	SE	✓	48
43	46	WHS-46-DH	instant hot	DH	CR 212 (Sp-ED) (2nd Floor) SOAR	C	SE	✓	48
44	47	WHS-47-FC	sink	FC	classroom 211 - (2nd Floor) - Sp.Ed.	C	SE	✓	49
45	49	WHS-49-DC	water fountain	DC	Girls Locker Room	C	LR	✓	505
46	50	WHS-50-FC	sink	FC	Classroom 104	C	CR	✓	528
47	53	WHS-53-FC	sink	FC	Inside Concession	C	CO	✓	501
48	54	WHS-54-DC	Water Fountain - outside	DC	Outside concession stand - see map	C	CO	✓	6:25
49	55	WHS-55-FC	Sink	FC	Outside concession stand - see map	C	CO	✓	6:25
50	56	WHS-56-SG	Hose Bib	SG	Outside concession stand - see map	C	CO	✓	501
51	57	WHS-57-FC	Sink	FC	classroom 105 - Special Education	C	SE	✓	555
52	58	WHS-58-FC	Sink	FC	classroom 107 - Special Education	C	SE	✓	555
53	59	WHS-59-BU	Bottle Filler	BU	Corridor	C	HA	✓	520
54	60	WHS-60-BU	Bottle Filler	BU	Corridor	C	HA	✓	510
55	61	WHS-61-FC	Sink	FC	Classroom 232 - Special Education	C	SE	✓	515
56	62	WHS-62-BU	Bottle Filler	BU	Corridor	C	GY	✓	515
57	1F	WHS-1-DC	water fountain	DC	Kitchen	C	KI	XXX	607

58- Westlake HS PSC #08.031

First Draw

3300 Middleton Road Waldorf, MD 20603

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

Flush

70106

58	2F	WHS-2-FC	Sink (near dishwasher) - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	KI	XXX	Flush at end, record time	6:05
59	3F	WHS-3-FC	Sink (near dishwasher) - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	KI	XXX	Flush at end, record time	6:05
61	5F	WHS-5-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	KI	XXX	Flush at end, record time	06
62	6F	WHS-6-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	KI	XXX	Flush at end, record time	06
63	7F	WHS-7-FC	island sink - Left	FC	Kitchen	C	KI	XXX	Flush at end, record time	07
64	8F	WHS-8-FC	island sink (R)next to #5 & #6	FC	Kitchen	C	KI	XXX	Flush at end, record time	07
66	11F	WHS-11-FC	island sink next to kettle on right	FC	Kitchen	C	KI	XXX	Flush at end, record time	07
67	12F	WHS-12-FC	2 comp sink	FC	Kitchen	C	KI	XXX	Flush at end, record time	07
68	15F	WHS-15-FC	sink	FC	nurse office	C	NO	XXX	Flush at end, record time	21
69	28F	WHS-28-FC	sink - See map	FC	food lab - home ec	C	HE	XXX	Flush at end, record time	11
70	29F	WHS-29-FC	sink - See map	FC	food lab - home ec	C	HE	XXX	Flush at end, record time	11
71	31F	WHS-31-FC	sink - See map	FC	food lab - home ec	C	HE	XXX	Flush at end, record time	11
72	32F	WHS-32-FC	sink - See map	FC	food lab - home ec	C	HE	XXX	Flush at end, record time	11
73	33F	WHS-33-FC	sink - See map	FC	food lab - home ec	C	HE	XXX	Flush at end, record time	11
74	53F	WHS-53-FC	sink	FC	Inside Concession	C	CO	XXX	Flush at end, record time	6:35
75	54F	WHS-54-DC	Water Fountain - outside	DC	Outside concession stand - see map	C	CO	XXX	DO NOT TAKE	
76	55F	WHS-55-FC	Sink	FC	Outside concession stand - see map	C	CO	XXX	Flush at end, record time	6:35
77	56F	WHS-56-SG	Hose Bib	SG	Outside concession stand - see map	C	CO	XXX	Flush at end, record time	

No LABS 60, 65

P 13

P 14