

Lead Tests - Abe Lincoln Elementary School - Main Building - # 20481800

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481800-001NS	20481800-001NS25A	Health Room - Sink	04/09/24	1.3	None.
2	20481800-002BF	20481800-002BF25A	Health Room Restroom - Sink	04/09/24	ND	None.
N/A	N/A	N/A	Health Room - Shower	N/A	N/A	Water should not be consumed from the shower head.
3	20481800-003SF	20481800-003SF25A	Staff Work Room - Sink	04/09/24	1.8	None.
4	20481800-004SF	20481800-004SF25A	Staff Break Room - Sink	04/09/24	ND	None.
5	20481800-005SF	20481800-005SF25A	Staff Break Room - Insta-Hot	04/09/24	ND	None.
6	20481800-006IM	20481800-006IM25A	Staff Break Room Refrigerator - Ice Maker (Left)	04/09/24	ND	This fixture has a lead filter on it for copper.
N/A	N/A	N/A	Staff Break Room Refrigerator - Ice Maker (Right)	ND	ND	This icemaker has been permanently disconnected.
7	20481800-007BF	20481800-007BF25A	Men's Staff Rest Room By The Office - Sink (Left)	04/09/24	2.1	None.
8	20481800-008BF	20481800-008BF25A	Men's Staff Rest Room By The Office - Sink (Right)	04/09/24	0.6	None.
9	20481800-009BF	20481800-009BF25A	Women's Staff Rest Room By The Office - Sink (Left)	04/09/24	2.2	None.
10	20481800-010BF	20481800-010BF25A	Women's Staff Rest Room By The Office - Sink (Right)	04/09/24	9.8	None.
11	20481800-011DW	20481800-011DW25A	Gym - Drinking Fountain	04/09/24	ND	None.
12	20481800-012WB	20481800-012WB25A	In Hallway Outside The Gym - Bottle Filler (Upper)	04/09/24	ND	Changed to Bottle Filler Unit with Filter 01/15/2023.
13	20481800-013DW	20481800-013DW25A	In Hallway Outside The Gym - DW (Lower)	04/09/24	ND	Changed to Bottle Filler Unit with Filter 01/15/2023.
N/A	N/A	N/A	Custodial Office - Sink	N/A	N/A	Water should not be consumed from this sink.
14	20481800-014KF	20481800-014KF25A	Kitchen - Sink (Food Prep Sink - South)	04/09/24	1.7	None.
15	20481800-015KF	20481800-015KF25A	Kitchen - Sink (North - Pre-Rinse)	04/09/24	ND	None.
16	20481800-016KF	20481800-016KF25A	Kitchen - Sink (Hand Wash)	04/09/24	0.8	None.
17	20481800-017BF	20481800-017BF25A	Kitchen Unisex Restroom - Sink	04/09/24	2.8	None.
18	20481800-018BF	20481800-018BF25A	Boy's Rest Room Outside The Cafeteria - Sink (Left)	04/09/24	ND	None.
19	20481800-019BF	20481800-019BF25A	Boy's Rest Room Outside The Cafeteria - Sink (Center)	04/09/24	3.2	None.
20	20481800-020BF	20481800-020BF25A	Boy's Rest Room Outside The Cafeteria - Sink (Right)	04/09/24	0.6	None.
21	20481800-021BF	20481800-021BF25A	Girl's Rest Room Outside The Cafeteria - Sink (Left)	04/09/24	2.9	None.
22	20481800-022BF	20481800-022BF25A	Girl's Rest Room Outside The Cafeteria - Sink (Center)	04/09/24	2.3	None.
23	20481800-023BF	20481800-023BF25A	Girl's Rest Room Outside The Cafeteria - Sink (Right)	04/09/24	ND	None.
24	20481800-024DW	20481800-024DW25A	Playground - Drinking Fountain (Outdoors)	04/09/24	1.1	None.
25	20481800-025SF	20481800-025SF25A	Student Success Services (was Media Center Work Room) - Sink	04/09/24	7.0	None.
26	20481800-026DW	20481800-026DW25A	Room 1 - Drinking Fountain	04/09/24	ND	None.
27	20481800-027CF	20481800-027CF25A	Room 1 - Sink	04/09/24	4.1	None.
28	20481800-028DW	20481800-028DW25A	Room 2 - Drinking Fountain	04/09/24	ND	None.
29	20481800-029CF	20481800-029CF25A	Room 2 - Sink	04/09/24	0.8	None.
30	20481800-030DW	20481800-030DW25A	Room 3 - Drinking Fountain	04/09/24	ND	None.
31	20481800-031CF	20481800-031CF25A	Room 3 - Sink	04/09/24	1.5	None.
32	20481800-032DW	20481800-032DW25A	Room 4 - Drinking Fountain	04/09/24	ND	None.
33	20481800-033CF	20481800-033CF25A	Room 4 - Sink	04/09/24	1.0	None.
34	20481800-034DW	20481800-034DW25A	Room 5 - Drinking Fountain	04/09/24	ND	None.
35	20481800-035CF	20481800-035CF25A	Room 5 - Sink	04/09/24	0.8	None.
36	20481800-036DW	20481800-036DW25A	Room 6 - Drinking Fountain	04/09/24	ND	None.
37	20481800-037CF	20481800-037CF25A	Room 6 - Sink	04/09/24	1.3	None.
38	20481800-038DW	20481800-038DW25A	Room 7 - Drinking Fountain	04/09/24	ND	None.
39	20481800-039CF	20481800-039CF25A	Room 7 - Sink	04/09/24	1.0	None.
40	20481800-040DW	20481800-040DW25A	Room 8 - Drinking Fountain	04/09/24	1.3	None.
41	20481800-041CF	20481800-041CF25A	Room 8 - Sink	04/09/24	ND	None.
42	20481800-042DW	20481800-042DW25A	Room 9 - Drinking Fountain	04/09/24	ND	None.
43	20481800-043CF	20481800-043CF25A	Room 9 - Sink	04/09/24	ND	None.
44	20481800-044DW	20481800-044DW25A	Room 10 - Drinking Fountain	04/09/24	ND	None.
45	20481800-045CF	20481800-045CF25A	Room 10 - Sink	04/09/24	1.3	None.
46	20481800-046BF	20481800-046BF25A	Boy's Restroom (C) - Sink (Left)	04/09/24	3.3	None.
47	20481800-047BF	20481800-047BF25A	Boy's Restroom (C) - Sink (Center)	04/09/24	4.1	None.
48	20481800-048BF	20481800-048BF25A	Boy's Restroom (C) - Sink (Right)	04/09/24	2.3	None.
49	20481800-049BF	20481800-049BF25A	Girl's Restroom (C) - Sink (Left)	04/09/24	1.6	None.
50	20481800-050BF	20481800-050BF25A	Girl's Restroom (C) - Sink (Center)	04/09/24	2.3	None.
51	20481800-051BF	20481800-051BF25A	Girl's Restroom (C) - Sink (Right)	04/09/24	2.3	None.
52	20481800-052BF	20481800-052BF25A	Unisex Restroom (D) - Sink	04/09/24	0.8	None.
53	20481800-053BF	20481800-053BF25A	Unisex Restroom (E) - Sink	04/09/24	0.5	None.
54	20481800-054DW	20481800-054DW25A	Room 11D - Drinking Fountain	04/09/24	ND	None.
55	20481800-055CF	20481800-055CF25A	Room 11D - Sink	04/09/24	1.4	None.
56	20481800-056DW	20481800-056DW25A	Room 11B - Drinking Fountain	04/09/24	ND	None.
57	20481800-057CF	20481800-057CF25A	Room 11B - Sink	04/09/24	ND	None.
58	20481800-058DW	20481800-058DW25A	Room 12 - Drinking Fountain	04/09/24	0.8	None.
59	20481800-059CF	20481800-059CF25A	Room 12 - Sink	04/09/24	0.8	None.
60	20481800-060DW	20481800-060DW25A	Room 13 - Drinking Fountain	04/09/24	ND	None.
61	20481800-061CF	20481800-061CF25A	Room 13 - Sink	04/09/24	ND	None.
62	20481800-062BF	20481800-062BF25A	Boy's Restroom (B) - Sink (Right)	04/09/24	0.9	None.

63	20481800-063BF	20481800-063BF25A	Boy's Restroom (B) - Sink (Center)	04/09/24	2.3	None.
64	20481800-064BF	20481800-064BF25A	Boy's Restroom (B) - Sink (Left)	04/09/24	1.5	None.
65	20481800-065BF	20481800-065BF25A	Girl's Restroom (B) - Sink (Right)	04/09/24	0.9	None.
66	20481800-066BF	20481800-066BF25A	Girl's Restroom (B) - Sink (Center)	04/09/24	2.8	None.
67	20481800-067BF	20481800-067BF25A	Girl's Restroom (B) - Sink (Left)	04/09/24	ND	None.
68	20481800-068DW	20481800-068DW25A	Room 14 - Drinking Fountain	04/09/24	0.5	None.
69	20481800-069CF	20481800-069CF25A	Room 14 - Sink	04/09/24	1.4	None.
70	20481800-070DW	20481800-070DW25A	Room 15 - Drinking Fountain	04/09/24	0.6	None.
71	20481800-071CF	20481800-071CF25A	Room 15 - Sink	04/09/24	0.6	None.
72	20481800-072DW	20481800-072DW25A	Room 16 - Drinking Fountain	04/09/24	ND	None.
73	20481800-073CF	20481800-073CF25A	Room 16 - Sink	04/09/24	1.1	None.
74	20481800-074DW	20481800-074DW25A	Room 17 - Drinking Fountain	04/09/24	ND	None.
75	20481800-075CF	20481800-075CF25A	Room 17 - Sink	04/09/24	2.0	None.
76	20481800-076DW	20481800-076DW25A	Room 18 - Drinking Fountain	04/09/24	ND	None.
77	20481800-077CF	20481800-077CF25A	Room 18 - Sink	04/09/24	0.6	None.
78	20481800-078DW	20481800-078DW25A	Room 19 - Drinking Fountain	04/09/24	0.5	None.
79	20481800-079CF	20481800-079CF25A	Room 19 - Sink	04/09/24	2.8	None.
80	20481800-080DW	20481800-080DW25A	Room 20 - Drinking Fountain	04/09/24	ND	None.
81	20481800-081CF	20481800-081CF25A	Room 20 - Sink	04/09/24	ND	None.
82	20481800-082DW	20481800-082DW25A	Room 21 - Drinking Fountain	04/09/24	ND	None.
83	20481800-083CF	20481800-083CF25A	Room 21 - Sink	04/09/24	0.9	None.
84	20481800-084DW	20481800-084DW25A	Room 22 - Drinking Fountain	04/09/24	ND	None.
85	20481800-085CF	20481800-085CF25A	Room 22 - Sink	04/09/24	2.6	None.
86	20481800-086DW	20481800-086DW25A	Room 23 - Drinking Fountain	04/09/24	ND	None.
87	20481800-087CF	20481800-087CF25A	Room 23 - Sink	04/09/24	ND	None.
88	20481800-088DW	20481800-088DW25A	Room 24 - Drinking Fountain	04/09/24	ND	None.
89	20481800-089CF	20481800-089CF25A	Room 24 - Sink	04/09/24	ND	None.

*None Detected (ND) = 0.10 Or Less PPB

 = Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.