



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

April 19, 2019

Andy Chasteen  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501  
TEL: 541-842-3646  
FAX: 541-842-1160

RE: 18-24 2019 Jackson Lead Testing

Order No.: 19040426

Dear Andy Chasteen:

Neilson Research Corporation received 56 sample(s) on 4/9/2019 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 19040426  
Date: 4/19/2019

---

**CLIENT:** Medford School District  
**Project:** 18-24 2019 Jackson Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-01** Client Sample ID: Cafeteria Boy's RR Sink Left  
 Collection Date: 4/9/2019 6:08:00 AM Collected By:  
 Matrix: Sample Location: Cafeteria Boys RR Sink Left

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00330		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-02** Client Sample ID: Cafeteria Boy's RR Sink Right  
 Collection Date: 4/9/2019 6:08:00 AM Collected By:  
 Matrix: Sample Location: Cafeteria Boys RR Sink Right

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00120		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-03** Client Sample ID: Cafeteria Girl's RR Sink Left  
 Collection Date: 4/9/2019 6:09:00 AM Collected By:  
 Matrix: Sample Location: Cafeteria Girls RR Sink Left

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00102		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-04** Client Sample ID: Cafeteria Girl's RR Sink Right  
 Collection Date: 4/9/2019 6:09:00 AM Collected By:  
 Matrix: Sample Location: Cafeteria Girls RR Sink Right

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00140		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-05** Client Sample ID: Kitchen Sink Pre-Rinse/Dishwasher  
 Collection Date: 4/9/2019 6:11:00 AM Collected By:  
 Matrix: Sample Location: Kitchen Sink Pre-Rinse/Dishwasher

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00138		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-06** Client Sample ID: Kitchen Sink Hand Wash  
 Collection Date: 4/9/2019 6:11:00 AM Collected By:  
 Matrix: Sample Location: Kitchen Sink Hand Wash

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000306		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-07** Client Sample ID: LaClinica RR Sink  
 Collection Date: 4/9/2019 6:15:00 AM Collected By:  
 Matrix: Sample Location: LaClinica RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000328		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-08** Client Sample ID: LaClinica Hallway by Back Door Sink  
 Collection Date: 4/9/2019 6:15:00 AM Collected By:  
 Matrix: Sample Location: LaClinica Hallway by Back Door Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00241		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-09** Client Sample ID: Room 144 Sink  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 144 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000198		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-10** Client Sample ID: Room 144 RR Sink  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 144 RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000199		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-11** Client Sample ID: Room 145 Sink  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 145 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000200		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-12** Client Sample ID: Room 145 RR Sink  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 145 RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000317		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-13** Client Sample ID: Gym Boy's RR Sink  
 Collection Date: 4/9/2019 6:35:00 AM Collected By:  
 Matrix: Sample Location: Gym Boys RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000259		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-14** Client Sample ID: Gym Girl's RR Sink  
 Collection Date: 4/9/2019 6:35:00 AM Collected By:  
 Matrix: Sample Location: Gym Girls RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000352		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-15** Client Sample ID: Health Room Unisex RR Sink  
 Collection Date: 4/9/2019 6:37:00 AM Collected By:  
 Matrix: Sample Location: Health Room Unisex RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000585		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-16** Client Sample ID: Near Office Staff Unisex RR Sink Left  
 Collection Date: 4/9/2019 6:40:00 AM Collected By:  
 Matrix: Sample Location: Near Office Staff Unisex RR Sink Left

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000415		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-17** Client Sample ID: Near Office Staff Unisex RR Sink Right  
 Collection Date: 4/9/2019 6:40:00 AM Collected By:  
 Matrix: Sample Location: Near Office Staff Unisex RR Sink Right

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000396		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-18** Client Sample ID: Room 120 Sink A  
 Collection Date: 4/9/2019 6:47:00 AM Collected By:  
 Matrix: Sample Location: Room 120 Sink A

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000555		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-19** Client Sample ID: Room 120 Sink B  
 Collection Date: 4/9/2019 6:47:00 AM Collected By:  
 Matrix: Sample Location: Room 120 Sink B

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000230		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-20** Client Sample ID: Room 120 Sink C  
 Collection Date: 4/9/2019 6:47:00 AM Collected By:  
 Matrix: Sample Location: Room 120 Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000220		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-21** Client Sample ID: Room 121 Sink  
 Collection Date: 4/9/2019 6:56:00 AM Collected By:  
 Matrix: Sample Location: Room 121 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000154		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-22** Client Sample ID: Room 122 Sink  
 Collection Date: 4/9/2019 6:56:00 AM Collected By:  
 Matrix: Sample Location: Room 122 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000237		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-23** Client Sample ID: Room 123 Sink  
 Collection Date: 4/9/2019 6:56:00 AM Collected By:  
 Matrix: Sample Location: Room 123 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000190		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-24** Client Sample ID: Room 110 Sink A  
 Collection Date: 4/9/2019 6:58:00 AM Collected By:  
 Matrix: Sample Location: Room 110 Sink A

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000950		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-25** Client Sample ID: Room 110 Sink B  
 Collection Date: 4/9/2019 6:58:00 AM Collected By:  
 Matrix: Sample Location: Room 110 Sink B

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00120		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-26** Client Sample ID: Room 110 Boy/Girl RR Trough Sink  
 Collection Date: 4/9/2019 7:00:00 AM Collected By:  
 Matrix: Sample Location: Room 110 Boy/Girl RR Trough Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000672		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-27** Client Sample ID: W Outdoor Closet Outside Rm 110 Sink  
 Collection Date: 4/9/2019 7:03:00 AM Collected By:  
 Matrix: Sample Location: W Outdoor Closet Outside Rm 110 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0119		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-28** Client Sample ID: Room 111 Sink  
 Collection Date: 4/9/2019 6:00:00 AM Collected By:  
 Matrix: Sample Location: Room 111 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000754		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-29** Client Sample ID: Room 112 Sink  
 Collection Date: 4/9/2019 6:01:00 AM Collected By:  
 Matrix: Sample Location: Room 112 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000485		0.000100	mg/L	1	4/10/2019	0.0150	

**Lab ID:** **19040426-30** Client Sample ID: Room 113 Sink  
 Collection Date: 4/9/2019 6:02:00 AM Collected By:  
 Matrix: Sample Location: Room 113 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000604		0.000100	mg/L	1	4/10/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-31** Client Sample ID: Outside Rm 105D Boy's RR Trough Sink  
 Collection Date: 4/9/2019 6:05:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 105D Boys RR TroughSink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000573		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-32** Client Sample ID: Outside Rm 105D Girl's RR Trough Sink  
 Collection Date: 4/9/2019 6:06:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 105D Girls RR TroughSink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00254		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-33** Client Sample ID: Room 141 Sink Hot Side  
 Collection Date: 4/9/2019 6:47:00 AM Collected By:  
 Matrix: Sample Location: Room 141 Sink Hot Side

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00203		0.000100	mg/L	1	4/11/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-34** Client Sample ID: Room 142 Sink  
 Collection Date: 4/9/2019 6:09:00 AM Collected By:  
 Matrix: Sample Location: Room 142 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000568		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-35** Client Sample ID: Room 143 Sink  
 Collection Date: 4/9/2019 6:10:00 AM Collected By:  
 Matrix: Sample Location: Room 143 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000822		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-36** Client Sample ID: Room 220 Sink A  
 Collection Date: 4/9/2019 6:15:00 AM Collected By:  
 Matrix: Sample Location: Room 220 Sink A

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00155		0.000100	mg/L	1	4/11/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-37** Client Sample ID: Room 220 Sink B  
 Collection Date: 4/9/2019 6:15:00 AM Collected By:  
 Matrix: Sample Location: Room 220 Sink B

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00219		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-38** Client Sample ID: Room 220 Sink C  
 Collection Date: 4/9/2019 6:17:00 AM Collected By:  
 Matrix: Sample Location: Room 220 Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000914		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-39** Client Sample ID: Room 221 Sink  
 Collection Date: 4/9/2019 6:19:00 AM Collected By:  
 Matrix: Sample Location: Room 221 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00137		0.000100	mg/L	1	4/11/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-40** Client Sample ID: Room 222 Sink  
 Collection Date: 4/9/2019 6:20:00 AM Collected By:  
 Matrix: Sample Location: Room 222 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000648		0.000100	mg/L	1	4/11/2019	0.0150	

**Lab ID:** **19040426-41** Client Sample ID: Room 223 Sink  
 Collection Date: 4/9/2019 6:21:00 AM Collected By:  
 Matrix: Sample Location: Room 223 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000689		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-42** Client Sample ID: Room 224 Sink  
 Collection Date: 4/9/2019 6:21:00 AM Collected By:  
 Matrix: Sample Location: Room 224 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000669		0.000100	mg/L	1	4/16/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-43** Client Sample ID: Room 211 Sink  
 Collection Date: 4/9/2019 6:27:00 AM Collected By:  
 Matrix: Sample Location: Room 211 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000660		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-44** Client Sample ID: Room 212 Sink  
 Collection Date: 4/9/2019 6:28:00 AM Collected By:  
 Matrix: Sample Location: Room 212 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000655		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-45** Client Sample ID: Room 210 Sink A  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 210 Sink A

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00191		0.000100	mg/L	1	4/16/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-46** Client Sample ID: Room 210 Sink B  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 210 Sink B

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00113		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-47** Client Sample ID: Room 210 Sink C  
 Collection Date: 4/9/2019 6:30:00 AM Collected By:  
 Matrix: Sample Location: Room 210 Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000391		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-48** Client Sample ID: Room 213 Sink  
 Collection Date: 4/9/2019 6:31:00 AM Collected By:  
 Matrix: Sample Location: Room 213 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000540		0.000100	mg/L	1	4/16/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-49** Client Sample ID: Room 214 Sink  
 Collection Date: 4/9/2019 6:22:00 AM Collected By:  
 Matrix: Sample Location: Room 214 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000509		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-50** Client Sample ID: Outside Rm 214 Boy's RR Trough Sink  
 Collection Date: 4/9/2019 6:35:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 214 Boys RR Trough Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00107		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-51** Client Sample ID: Outside Rm 214 Girl's RR Trough Sink  
 Collection Date: 4/9/2019 6:36:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 214 Girls RR Trough Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00419		0.000100	mg/L	1	4/16/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-52** Client Sample ID: Outside Rm 240 Men's RR Sink  
 Collection Date: 4/9/2019 6:38:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 240 Mens RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000561		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-53** Client Sample ID: Outside Rm 240A Women's RR Sink  
 Collection Date: 4/9/2019 6:40:00 AM Collected By:  
 Matrix: Sample Location: Outside Rm 240A Womens RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000488		0.000100	mg/L	1	4/16/2019	0.0150	

**Lab ID:** **19040426-54** Client Sample ID: Room 241 Sink  
 Collection Date: 4/9/2019 6:41:00 AM Collected By:  
 Matrix: Sample Location: Room 241 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00148		0.000100	mg/L	1	4/16/2019	0.0150	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: **19040426**  
 Date Reported: **4/19/2019**

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 19040426  
**Received Date:** 4/9/2019 3:57:00 PM  
**Reported Date:** 4/19/2019 12:57:40 PM

Sample Information:

**Lab ID:** **19040426-55** Client Sample ID: Room 242 Sink  
 Collection Date: 4/9/2019 6:42:00 AM Collected By:  
 Matrix: Sample Location: Room 242 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00160		0.000100	mg/L	1	4/16/2019	0.0150		

**Lab ID:** **19040426-56** Client Sample ID: Room 243 Sink  
 Collection Date: 4/9/2019 6:43:00 AM Collected By:  
 Matrix: Sample Location: Room 243 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: JWC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000858		0.000100	mg/L	1	4/16/2019	0.0150		

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit



Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 19040426  
 19-Apr-19

**Client:** Medford School District  
**Project:** 18-24 2019 Jackson Lead Testing  
**TestCode:** ICPMS\_200.8\_DW

Sample ID: MB-141	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: PBW	Batch ID: 141	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4369						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-141	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: LCSW	Batch ID: 141	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4370						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.0899	0.000100	0.1000	0	89.9	85	115				

Sample ID: 19040426-20AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: Room 120 Sink C	Batch ID: 141	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4393						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.0974	0.000100	0.1000	0.0002200	97.2	70	130				

Sample ID: 19040426-20AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: Room 120 Sink C	Batch ID: 141	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4394						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.102	0.000100	0.1000	0.0002200	101	70	130	0.09739	4.23	20	

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 RL Reporting Detection Limit  
 E Value above quantitation range  
 ND Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceed  
 PL Permit Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 19040426  
 19-Apr-19

**Client:** Medford School District  
**Project:** 18-24 2019 Jackson Lead Testing  
**TestCode:** ICPMS\_200.8\_DW

Sample ID: MB-145	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: PBW	Batch ID: 145	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4397						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-145	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 296						
Client ID: LCSW	Batch ID: 145	TestNo: E200.8	E200.8	Analysis Date: 4/10/2019	SeqNo: 4398						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.0922	0.000100	0.1000	0	92.2	85	115				

Sample ID: 19040426-40AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 371						
Client ID: Room 222 Sink	Batch ID: 145	TestNo: E200.8	E200.8	Analysis Date: 4/11/2019	SeqNo: 5813						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.103	0.000100	0.1000	0.0006480	102	70	130				

Sample ID: 19040426-40AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 371						
Client ID: Room 222 Sink	Batch ID: 145	TestNo: E200.8	E200.8	Analysis Date: 4/11/2019	SeqNo: 5814						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.0935	0.000100	0.1000	0.0006480	92.9	70	130	0.1025	9.14	20	

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 RL Reporting Detection Limit  
 E Value above quantitation range  
 ND Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceed  
 PL Permit Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 19040426  
 19-Apr-19

**Client:** Medford School District  
**Project:** 18-24 2019 Jackson Lead Testing  
**TestCode:** ICPMS\_200.8\_DW

Sample ID: MB-146	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 415						
Client ID: PBW	Batch ID: 146	TestNo: E200.8	E200.8	Analysis Date: 4/16/2019	SeqNo: 6484						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-146	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 415						
Client ID: LCSW	Batch ID: 146	TestNo: E200.8	E200.8	Analysis Date: 4/16/2019	SeqNo: 6485						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.104	0.000100	0.1000	0	104	85	115				

Sample ID: 19040426-56AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 415						
Client ID: Room 243 Sink	Batch ID: 146	TestNo: E200.8	E200.8	Analysis Date: 4/16/2019	SeqNo: 6504						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.109	0.000100	0.1000	0.0008580	108	70	130				

Sample ID: 19040426-56AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/10/2019	RunNo: 415						
Client ID: Room 243 Sink	Batch ID: 146	TestNo: E200.8	E200.8	Analysis Date: 4/16/2019	SeqNo: 6505						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.122	0.000100	0.1000	0.0008580	121	70	130	0.1093	10.8	20	

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 RL Reporting Detection Limit  
 E Value above quantitation range  
 ND Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceed  
 PL Permit Limit

Original



**Environmental Testing Laboratory**  
 245 South Grape Street \* Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>		<b>Section D</b>	
<b>Required Client Information</b>		<b>Required Project Information</b>		<b>Invoice Information</b>		<b>Rush Status (Subject to Scheduling)</b>	
Company: MSD 549C	Project Name: 2019 Lead Testing	Attention: Accounting	Standard 10-14 Days	Address: 815 South Oakdale Avenue Medford, OR 97501		5 Business Days (50% surcharge)	
Address: 815 South Oakdale Avenue Medford, OR 97501	Project Number: 18-24-Jackson	Company Name: Medford School District	3 Business Days (75% surcharge)	Report To <a href="mailto:ron.havnear@medford.k12.or.us">ron.havnear@medford.k12.or.us</a>		24 - 48 hours (100% surcharge)	
Email: <a href="mailto:ron.havnear@medford.k12.or.us">ron.havnear@medford.k12.or.us</a>	Copy To <a href="mailto:andy.chasteen@medford.k12.or.us">andy.chasteen@medford.k12.or.us</a>	P.O. # 61172	Other	P.O. # 61172		Authorized Yes No	

Collected By (Print): Roger Maxwell  
 Collected By (Sign): [Signature]  
 Email Report Yes No Mail Report Yes No  
 Fax Report Yes No

Sample Information	Bottle #	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 111 - Sink		DW	4/9/2019	6:00 AM	1												28A	
Room 112 - Sink		DW	4/9/2019	6:01 AM	1												29A	
Room 113 - Sink		DW	4/9/2019	6:02	1												30A	
Outside Room 105D Boy's Restroom - Trough Sink		DW	4/9/2019	6:05	1												31A	
Outside Room 105D Girl's Restroom - Trough Sink		DW	4/9/2019	6:06	1												32A	
Room 141 - Sink		DW	4/9/2019	6:09	1												33A	
Room 142 - Sink		DW	4/9/2019	6:10	1												34A	
Room 143 - Sink		DW	4/9/2019	6:15	1												35A	
Room 220 - Sink (A)		DW	4/9/2019	6:15	1												36A	
Room 220 - Sink (B)		DW	4/9/2019	6:15	1												37A	
Room 220 - Sink (C)		DW	4/9/2019	6:17	1												38A	
Room 221 - Sink		DW	4/9/2019	6:19	1												39A	
Room 222 - Sink		DW	4/9/2019	6:20	1												40A	
Room 223 - Sink		DW	4/9/2019	6:21	1												41A	
Room 224 - Sink		DW	4/9/2019	6:21	1												42A	
Room 211 - Sink		DW	4/9/2019	6:22	1												43A	
Room 212 - Sink		DW	4/9/2019	6:24	1												44A	
Room 210 - Sink (A)		DW	4/9/2019	6:30	1												45A	
Room 210 - Sink (B)		DW	4/9/2019	6:30	1												46A	
Room 210 - Sink (C)		DW	4/9/2019	6:30	1												47A	
Room 213 - Sink		DW	4/9/2019	6:30	1												48A	
Room 214 - Sink		DW	4/9/2019	6:32	1												49A	
Outside Room 214 Boy's Restroom - Trough Sink		DW	4/9/2019	6:35	1												50A	
Outside Room 214 Girl's Restroom - Trough Sink		DW	4/9/2019	6:36	1												51A	
Outside Room 240 Men's Restroom - Sink		DW	4/9/2019	6:38	1												52A	





**Environmental Testing Laboratory**  
 245 South Grape Street \* Medford, OR 97501  
 (541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>		<b>Section D</b>	
<b>Required Client Information</b>		<b>Required Project Information</b>		<b>Invoice Information</b>		<b>Rush Status (Subject to Scheduling)</b>	
Company: MSD 549C	Project Name: 2019 Lead Testing	Attention: Accounting	Standard 10-14 Days				
Address: 815 South Oakdale Avenue	Project Number: 18-24 Jackson	Company Name: Medford School District	5 Business Days (50% surcharge)				
Medford, OR 97501	Report To: ron.havnear@medford.k12.or.us	Address: 815 South Oakdale Avenue	3 Business Days (75% surcharge)				
Email: ron.havnear@medford.k12.or.us	Copy To: andy.chasteen@medford.k12.or.us	Medford, OR 97501	24 - 48 hours (100% surcharge)				
Phone: 541-840-4315 Fax:		P.O. # 61172	Other				
<b>Collected By (Print):</b>				Authorized Yes <input type="checkbox"/> No <input type="checkbox"/>			
<b>Collected By (Sign):</b>							
Email Report Yes <input type="checkbox"/> No <input type="checkbox"/> Mail Report Yes <input type="checkbox"/> No <input type="checkbox"/>							
Fax Report Yes <input type="checkbox"/> No <input type="checkbox"/>							

Section E		Section F		Section G		Section H		Section I	
Sample Information		Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested		NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Cafeteria Boy's Restroom - Sink (Left)	591644	DW	4/9/2019	6:08	1				190424
Cafeteria Boy's Restroom - Sink (Right)	591645	DW	4/9/2019	6:08	1				02A
Cafeteria Girl's Restroom - Sink (Left)	591641	DW	4/9/2019	6:09	1				02A
Cafeteria Girl's Restroom - Sink (Right)	591645	DW	4/9/2019	6:09	1				02A
Kitchen - Sink (Pre-rinse/Dishwasher)	591639	DW	4/9/2019	6:11	1				02A
Kitchen - Sink (Hand Wash)	591646	DW	4/9/2019	6:11	1				02A
La Clinica Restroom - Sink	591654	DW	4/9/2019	6:15	1				02A
La Clinica Hallway By Back Door - Sink	591677	DW	4/9/2019	6:15	1				02A
Room 144 - Sink	591641	DW	4/9/2019	6:30	1				02A
Room 144 Restroom - Sink	591650	DW	4/9/2019	6:30	1				02A
Room 145 - Sink	591651	DW	4/9/2019	6:30	1				02A
Room 145 Restroom - Sink	591652	DW	4/9/2019	6:30	1				02A
Gym Boy's Restroom - Sink	591647	DW	4/9/2019	6:35	1				02A
Gym Girl's Restroom - Sink	591611	DW	4/9/2019	6:35	1				02A
Health Room Unisex Restroom - Sink	591630	DW	4/9/2019	6:37	1				02A
Near Office Staff Unisex Restroom (Left) - Sink	591621	DW	4/9/2019	6:40	1				02A
Near Office Staff Unisex Restroom (Right) - Sink	591624	DW	4/9/2019	6:40	1				02A
Room 120 - Sink (A)	591624	DW	4/9/2019	6:40	1				02A
Room 120 - Sink (B)	591631	DW	4/9/2019	6:47	1				02A
Room 120 - Sink (C)	591631	DW	4/9/2019	6:47	1				02A
Room 121 - Sink	591657	DW	4/9/2019	6:47	1				02A
Room 122 - Sink	591644	DW	4/9/2019	6:56	1				02A
Room 123 - Sink	591646	DW	4/9/2019	6:56	1				02A
Room 110 - Sink (A)	591610	DW	4/9/2019	6:57	1				02A
Room 110 - Sink (B)	591635	DW	4/9/2019	6:58	1				02A
Room 110 - Sink (B)	591629	DW	4/9/2019	6:58	1				02A

