



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

April 23, 2024

Andy Chasteen  
Medford School District  
900 Kenyon St  
Medford, OR 97501  
TEL: 541-842-3646  
FAX 541-842-1160

RE: Roosevelt Elementary School Leads

Order No.: 24040581

Dear Andy Chasteen:

Neilson Research Corporation received 31 sample(s) on 4/11/2024 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Case Narrative

WO#: 24040581  
Date: 4/23/2024

---

**CLIENT:** Medford School District  
**Project:** Roosevelt Elementary School Leads

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-01      Client Sample ID: Rm 110-S DF (A)  
 Collection Date: 4/11/2024 6:16:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-S DF (A)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-02      Client Sample ID: Rm 110-S Sink (A)  
 Collection Date: 4/11/2024 6:17:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-S Sink (A)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-03      Client Sample ID: Rm 110-NW DF (B)  
 Collection Date: 4/11/2024 6:18:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-NW DF (B)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-04      Client Sample ID: Rm 110-NW Sink (B)  
 Collection Date: 4/11/2024 6:19:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-NW Sink (B)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.25		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-05      Client Sample ID: Rm 110-NE DF (C)  
 Collection Date: 4/11/2024 6:20:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-NE DF (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-06      Client Sample ID: Rm 110-NE Sink (C)  
 Collection Date: 4/11/2024 6:22:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 110-NE Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.630		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-07      Client Sample ID: O/S Rm 110 S O/S Storage Closet  
 Collection Date: 4/11/2024 6:24:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: O/S Rm 110 S O/S Storage Closet

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	15.3	*	0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-08      Client Sample ID: Front of Rm 110-DF  
 Collection Date: 4/11/2024 6:25:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Front of Rm 110-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-09      Client Sample ID: Front of Rm 110-Sink  
 Collection Date: 4/11/2024 6:26:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Front of Rm 110-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.546		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-10      Client Sample ID: Rm 114-DF  
 Collection Date: 4/11/2024 6:27:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 114-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A

**Lab ID:** 24040581-11      Client Sample ID: Rm 114-Sink  
 Collection Date: 4/11/2024 6:28:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 114-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A

**Lab ID:** 24040581-12      Client Sample ID: Rm 113-DF  
 Collection Date: 4/11/2024 6:29:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 113-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-13      Client Sample ID: Rm 113-Sink  
 Collection Date: 4/11/2024 6:30:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 113-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-14      Client Sample ID: Rm 112-DF  
 Collection Date: 4/11/2024 6:30:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 112-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-15      Client Sample ID: Rm 112-Sink  
 Collection Date: 4/11/2024 6:31:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 112-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-16      Client Sample ID: Rm 111-DF  
 Collection Date: 4/11/2024 6:31:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 111-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A

**Lab ID:** 24040581-17      Client Sample ID: Rm 111-Sink  
 Collection Date: 4/11/2024 6:32:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 111-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A

**Lab ID:** 24040581-18      Client Sample ID: Health Rm-Sink (Lt Fixture)  
 Collection Date: 4/11/2024 6:33:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Health Rm-Sink (Lt Fixture)

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.56		0.515	ppb	1	4/18/2024	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-19      Client Sample ID: Health Rm-Sink (Rt Fixture)  
 Collection Date: 4/11/2024 6:34:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Health Rm-Sink (Rt Fixture)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-20      Client Sample ID: Health Rm Unisex RR-Sink  
 Collection Date: 4/11/2024 6:35:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Health Rm Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.732		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-21      Client Sample ID: O/S Main Office Uni RR (Lt)-Sink  
 Collection Date: 4/11/2024 6:36:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: O/S Main Office Uni RR (Lt)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.46		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-22      Client Sample ID: O/S Main Office Uni RR (Rt)-Sink  
 Collection Date: 4/11/2024 6:37:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: O/S Main Office Uni RR (Rt)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.89		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-23      Client Sample ID: Rm 140-W DF (A)  
 Collection Date: 4/11/2024 6:38:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 140-W DF (A)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-24      Client Sample ID: Rm 140-W Sink (A)  
 Collection Date: 4/11/2024 6:39:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 140-W Sink (A)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.44		0.515	ppb	1	4/18/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-25      Client Sample ID: Rm 140-E DF (B)  
 Collection Date: 4/11/2024 6:40:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 140-E DF (B)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-26      Client Sample ID: Rm 140-E Sink (B)  
 Collection Date: 4/11/2024 6:41:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 140-E Sink (B)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.630		0.515	ppb	1	4/18/2024	15.0	A	

**Lab ID:** 24040581-27      Client Sample ID: O/S Rm 140-W O/S Storage  
 Collection Date: 4/11/2024 6:42:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: O/S Rm 140-W O/S Storage

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.68		0.515	ppb	1	4/19/2024	15.0	A	

<b>QUALIFIERS</b>	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-28      Client Sample ID: Rm 141-DF  
 Collection Date: 4/11/2024 6:42:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 141-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A

**Lab ID:** 24040581-29      Client Sample ID: Rm 141-Sink  
 Collection Date: 4/11/2024 6:43:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 141-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.02		0.515	ppb	1	4/19/2024	15.0	A

**Lab ID:** 24040581-30      Client Sample ID: Rm 142-DF  
 Collection Date: 4/11/2024 6:44:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 142-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24040581  
 Date Reported: 4/23/2024

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 24040581  
**Received Date:** 4/11/2024 10:30:00 AM  
**Reported Date:** 4/23/2024 9:21:02 AM

Sample Information:

**Lab ID:** 24040581-31      Client Sample ID: Rm 142-Sink  
 Collection Date: 4/11/2024 6:45:00 AM      Collected By: Seth Barry  
 Matrix: Drinking Water      Sample Location: Rm 142-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.794		0.515	ppb	1	4/19/2024	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 24040581  
 23-Apr-24

**Client:** Medford School District  
**Project:** Roosevelt Elementary School Leads

**TestCode:** LEAD\_DW

Sample ID: <b>MB-24928</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>PBW</b>	Batch ID: <b>24928</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802440</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-24928</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>24928</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802441</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 97.6 0.520 100 0 97.6 85 115

Sample ID: <b>24040579-21AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>24928</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802443</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 94.2 0.520 100 0.474 93.7 70 130

Sample ID: <b>24040579-21AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>24928</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802444</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 96.7 0.520 100 0.474 96.2 70 130 94.2 2.55 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
 RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 24040581  
 23-Apr-24

**Client:** Medford School District  
**Project:** Roosevelt Elementary School Leads

**TestCode:** LEAD\_DW

Sample ID: <b>MB-24929</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>PBW</b>	Batch ID: <b>24929</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802468</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-24929</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>24929</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802469</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 97.2 0.520 100 0 97.2 85 115

Sample ID: <b>24040581-07AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>O/S Rm 110 S O/S St</b>	Batch ID: <b>24929</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802471</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 117 0.520 100 15.3 101 70 130

Sample ID: <b>24040581-07AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48871</b>						
Client ID: <b>O/S Rm 110 S O/S St</b>	Batch ID: <b>24929</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/18/2024</b>	SeqNo: <b>802472</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 110 0.520 100 15.3 94.3 70 130 117 6.39 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
 RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 24040581  
 23-Apr-24

**Client:** Medford School District  
**Project:** Roosevelt Elementary School Leads

**TestCode:** LEAD\_DW

Sample ID: <b>MB-24930</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48917</b>						
Client ID: <b>PBW</b>	Batch ID: <b>24930</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/19/2024</b>	SeqNo: <b>803217</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-24930</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48917</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>24930</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/19/2024</b>	SeqNo: <b>803218</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 96.6 0.520 100 0 96.6 85 115

Sample ID: <b>24040581-27AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48917</b>						
Client ID: <b>O/S Rm 140-W O/S S</b>	Batch ID: <b>24930</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/19/2024</b>	SeqNo: <b>803220</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 99.9 0.520 100 5.68 94.2 70 130

Sample ID: <b>24040581-27AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>4/16/2024</b>	RunNo: <b>48917</b>						
Client ID: <b>O/S Rm 140-W O/S S</b>	Batch ID: <b>24930</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>4/19/2024</b>	SeqNo: <b>803221</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 97.7 0.520 100 5.68 92.0 70 130 99.9 2.26 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
 RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Sample Log-In Check List

Client Name: **MedfordSchoolDist** Work Order Number: **24040581** RcptNo: **1**

Logged by:	<b>Dorie Evans</b>	<b>4/11/2024 10:30:00 AM</b>	
Completed By:	<b>Erin Hernandez</b>	<b>4/12/2024 9:46:00 AM</b>	
Reviewed By:	<b>Ashley Spiegelberg</b>	<b>4/23/2024 9:16:48 AM</b>	

**Chain of Custody**

1. Is Chain of Custody complete? Yes  No  Not Present   
 2. How was the sample delivered? Client

**Log In**

3. Coolers are present? Yes  No  NA   
 4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present   
 No. Seal Date: Signed By:  
 5. Was an attempt made to cool the samples? Yes  No  NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA   
 7. Sample(s) in proper container(s)? Yes  No   
 8. Sufficient sample volume for indicated test(s)? Yes  No   
 9. Are samples (except VOA and ONG) properly preserved? Yes  No   
 10. Was preservative added to bottles? Yes  No  NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  HNO3 pH<2  
 No VOA Vials   
 12. Were any sample containers received broken? Yes  No   
 13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody? Yes  No   
 15. Is it clear what analyses were requested? Yes  No   
 16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

**Special Handling (if applicable)**

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		


18. Additional remarks:

**Cooler Information**

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information	<b>Section B</b> Required Project Information	<b>Section C</b> Invoice Information	<b>Section D</b> Rush Status (Subject to Scheduling)
Company: MSD 549C	Project Name: <b>Roosevelt</b>	Attention: Accounting	<input type="checkbox"/> Standard 10-14 Days
Address: 900 Kenyon	Project Number:	Company Name: Medford School District	<input type="checkbox"/> 5 Business Days (50% surcharge)
Medford, OR 97501	Report <a href="mailto:andy.chasteen@medford.k12.or.us">andy.chasteen@medford.k12.or.us</a>	Address: 900 Kenyon	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <a href="mailto:andy.chasteen@medford.k12.or.us">andy.chasteen@medford.k12.or.us</a>	Copy T <a href="mailto:seth.barry@medford.k12.or.us">seth.barry@medford.k12.or.us</a>	Medford, OR 97501	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: 541-840-4315 Fax:		P.O. # <b>127747</b>	<input type="checkbox"/> Other _____
Collected By (Print): <b>SETH BARRY</b>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): 			

Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section E**  
Sample Information

Sample ID	Matrix*	Date Collected	Time Collect	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)		
Roosevelt Room 110 - South Drinking Fountain (A)	DW	4/11/2024	616	1														01
Roosevelt Room 110 - South Sink (A)	DW	4/11/2024	617	1														02
Roosevelt Room 110 - NW Drinking Fountain (B)	DW	4/11/2024	618	1														03
Roosevelt Room 110 - NW Sink (B)	DW	4/11/2024	619	1														04
Roosevelt Room 110 - NE Drinking Fountain (C)	DW	4/11/2024	620	1														05
Roosevelt Room 110 - NE Sink (C)	DW	4/11/2024	622	1														06
Roosevelt Outside Room 110 In South Outdoor Storage Clc	DW	4/11/2024	624	1														07
Roosevelt Behind Sliding Door Infront of Room 110 - Drink	DW	4/11/2024	625	1														08
Roosevelt Behind Sliding Door Infront of Room 110 - Sink	DW	4/11/2024	626	1														09
Roosevelt Room 114 - Drinking Fountain	DW	4/11/2024	627	1														10
Roosevelt Room 114 - Sink	DW	4/11/2024	628	1														11
Roosevelt Room 113 - Drinking Fountain	DW	4/11/2024	629	1														12
Roosevelt Room 113 - Sink	DW	4/11/2024	630	1														13
Roosevelt Room 112 - Drinking Fountain	DW	4/11/2024	630	1														14
Roosevelt Room 112 - Sink	DW	4/11/2024	631	1														15
Roosevelt Room 111 - Drinking Fountain	DW	4/11/2024	631	1														16
Roosevelt Room 111 - Sink	DW	4/11/2024	632	1														17
Roosevelt Health Room - Sink (Left Fixture)	DW	4/11/2024	633	1														18
Roosevelt Health Room - Sink (Right Fixture)	DW	4/11/2024	634	1														19
Roosevelt Health Room Unisex Restroom - Sink	DW	4/11/2024	635	1														20
Roosevelt Outside Main Office Unisex Restroom (Left) - S	DW	4/11/2024	636	1														21
Roosevelt Outside Main Office Unisex Restroom (Right) - S	DW	4/11/2024	637	1														22
Roosevelt Room 140 - West Drinking Fountain (A)	DW	4/11/2024	638	1														23
Roosevelt Room 140 - West Sink (A)	DW	4/11/2024	639	1														24



- 
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320B-2011.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>