

**CERTIFICATE OF ANALYSIS**

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Marion P. Thomas Select Academy #6712
PAS Project ID : P17-1638

Matrix : Drinking Water
Report Date : 4/25/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1638-01	MA-1-WC-01A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:08	4/19/17 10:40
P17-1638-02	MA-1-WC-02A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:08	4/19/17 10:48
P17-1638-03	MA-1-S-03A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:10	4/19/17 11:01
P17-1638-04	MA-1-S-01A	Lead	3.08	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:13	4/19/17 11:14
P17-1638-05	MA-1-S-02A	Lead	1.97 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:15	4/19/17 11:18
P17-1638-06	MA-2-WC-03A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:18	4/19/17 11:22
P17-1638-07	MA-2-WC-04A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:18	4/19/17 11:26
P17-1638-08	MA-2-S-04A	Lead	0.869 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:20	4/19/17 11:30
P17-1638-09	MA-3-WC-05A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:23	4/19/17 11:35
P17-1638-10	MA-3-WC-06A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:24	4/19/17 11:39
P17-1638-11	MA-3-S-05A	Lead	18.3	ug/L	2	4.00	0.850	15.0 *	SM 3113 B	4/8/17 06:29	4/19/17 12:55
P17-1638-12	MA-3-S-06A	Lead	85.9	ug/L	10	20.0	4.25	15.0 *	SM 3113 B	4/8/17 06:30	4/19/17 13:00
P17-1638-13	MA-3-S-07A	Lead	155	ug/L	20	40.0	8.50	15.0 *	SM 3113 B	4/8/17 06:31	4/19/17 13:04
P17-1638-14	MA-4-8-FBA	Lead	0.593 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 06:34	4/19/17 12:09

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director