



## CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Marion P. Thomas Middle School #6712  
**PAS Project ID :** P17-1637

**Matrix :** Drinking Water  
**Report Date :** 4/25/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1637-01	MMS-B-S-01A	Lead	3.95	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:03	4/18/17 16:39
P17-1637-02	MMS-1-S-02A	Lead	8.05	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:07	4/18/17 16:42
P17-1637-03	MMS-2-WC-02A	Lead	2.58	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:10	4/18/17 16:46
P17-1637-04	MMS-3-WC-03A	Lead	10.3	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:12	4/18/17 16:50
P17-1637-05	MMS-4-8-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:18	4/18/17 16:53

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director