

March 2024

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- A freeze pump for an air handler was replaced by our in house HVAC tech at ARHS.
- Re-lamping of the classroom fixtures at AMSB was completed by our in house electrician.
- A few classroom door locks at ARHS were repaired or replaced by our in house maintainer.
- A broken bathroom sink in one of the boys bathrooms at ARHS was replaced by our in house maintainer.
- A broken bathroom partition at AMSO was repaired by our in house maintainer.

Projects in Process:

- A compressor for the air handler that serves the black box theater at ARHS is being replaced by our in house HVAC tech.
- The underground sump pump discharge line for the well pit at AMSB is being repaired by an outside contractor.
- All of the failed parking lot light fixtures at ARHS have been replaced. We are working on scheduling lift rentals around the weather to finish replacing the remaining fixtures.
- The ticket booth for the Athletic Department is currently being built by the ARHS Tech Ed. Department.
- Various roof leaks at all three schools are being addressed.
- Facilities is working on completing State mandated inspection reports for all of our buildings as part of the Tools for Schools program.
- The District is working with the Town of Woodbridge to address concerns with the fuel cell and microgrid.
- Sample furniture for the ARHS Library Media renovation is in the current library media center; students and staff have an opportunity to try it out and provide feedback on preferences.

Outstanding issues to be addressed:

- Now that the gym floor has been repaired at AMSO, Dalene Flooring is scheduled to return this summer to sand and refinish the entire floor.