



SUBMITTAL
 Curb wall thickness and restraint requirements to be determined by seismic/windload calculations if required.
 Verify roof pitch and direction

Notes:
Standard configuration shown
 1. Material: Galvanized Steel
 2. Insulation: 1 1/2" 3lb. density
 3. Gasket provided
Verify new and existing curb dimensions

Thybar Corporation has a policy of continuous product improvement and reserves the right to change the product design without notice

The information contained in this drawing is the sole property of Thybar Corporation. Any reproduction in part or whole without the written consent of Thybar Corporation is prohibited. (DO NOT SCALE DRAWING) Unless otherwise specified dimensions are in inches tolerances are ± 1/16 ± 0.0625 ± 1°	Retromate Standard New Aeon RN C CAB STD. Existing Carrier 50PQ900221 Curb		Weight lbs. Total Weight 309 lbs.
	Qty.: Tag: Drawn: File: Date: 10/22/2009	Job #: kirkpatrick AN01327CA00104	Rev: C