



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 24, 2024

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Wilson Elementary School Leads

Order No.: 24040619

Dear Andy Chasteen:

Neilson Research Corporation received 33 sample(s) on 4/12/2024 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 24040619
Date: 4/24/2024

CLIENT: Medford School District

Project: Wilson Elementary School Leads

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-01 Client Sample ID: Health Rm-Sink
 Collection Date: 4/12/2024 6:24:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.13		0.515	ppb	1	4/19/2024	15.0	A	

Lab ID: 24040619-02 Client Sample ID: Staff Work Rm-DF
 Collection Date: 4/12/2024 6:25:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Staff Work Rm-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.61		0.515	ppb	1	4/19/2024	15.0	A	

Lab ID: 24040619-03 Client Sample ID: Staff Work Rm-Sink
 Collection Date: 4/12/2024 6:28:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Staff Work Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.22		0.515	ppb	1	4/19/2024	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-04 Client Sample ID: Conf/AP Ofc By Main Ofc-Sink
 Collection Date: 4/12/2024 6:29:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Conf/AP Ofc By Main Ofc-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.42		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-05 Client Sample ID: Rm 26-DF
 Collection Date: 4/12/2024 6:30:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 26-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.700		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-06 Client Sample ID: Rm 26-Sink
 Collection Date: 4/12/2024 6:31:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 26-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.863		0.515	ppb	1	4/19/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-07 Client Sample ID: Rm 27-DF
 Collection Date: 4/12/2024 6:32:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 27-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.685		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-08 Client Sample ID: Rm 27-Sink
 Collection Date: 4/12/2024 6:33:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 27-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.572		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-09 Client Sample ID: Rm 28-DF
 Collection Date: 4/12/2024 6:35:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 28-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.696		0.515	ppb	1	4/19/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-10 Client Sample ID: Rm 28-Sink
 Collection Date: 4/12/2024 6:36:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 28-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.651		0.515	ppb	1	4/19/2024	15.0	A	

Lab ID: 24040619-11 Client Sample ID: Girl's RR Across Rm 21-Sink (Lt)
 Collection Date: 4/12/2024 6:37:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Girl's RR Across Rm 21-Sink (Lt)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.98		0.515	ppb	1	4/19/2024	15.0	A	

Lab ID: 24040619-12 Client Sample ID: Girl's RR Across Rm 21-Sink (Rt)
 Collection Date: 4/12/2024 6:38:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Girl's RR Across Rm 21-Sink (Rt)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-13 Client Sample ID: Boy's RR Across Rm 21-Sink (Lt)
 Collection Date: 4/12/2024 6:39:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Boy's RR Across Rm 21-Sink (Lt)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.521		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-14 Client Sample ID: Boy's RR Across Rm 21-Sink (Rt)
 Collection Date: 4/12/2024 6:40:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Boy's RR Across Rm 21-Sink (Rt)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CBB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.05		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-15 Client Sample ID: Rm 21-Sink
 Collection Date: 4/12/2024 6:40:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 21-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.92		0.500	ppb	1	4/17/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-16 Client Sample ID: Rm 22-DF
 Collection Date: 4/12/2024 6:41:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 22-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-17 Client Sample ID: Rm 22-Sink
 Collection Date: 4/12/2024 6:42:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 22-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.02		0.500	ppb	1	4/17/2024	15.0	A

Lab ID: 24040619-18 Client Sample ID: Rm 23-DF
 Collection Date: 4/12/2024 6:43:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 23-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.52		0.515	ppb	1	4/19/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-19 Client Sample ID: Rm 23-Sink
 Collection Date: 4/12/2024 6:44:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 23-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-20 Client Sample ID: Rm 24-DF
 Collection Date: 4/12/2024 6:44:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 24-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.780		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-21 Client Sample ID: Rm 24-Sink
 Collection Date: 4/12/2024 6:45:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 24-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CBB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/19/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-22 Client Sample ID: Rm 25-DF
 Collection Date: 4/12/2024 6:45:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 25-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.19		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-23 Client Sample ID: Rm 25-Sink
 Collection Date: 4/12/2024 6:46:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 25-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.72		0.515	ppb	1	4/19/2024	15.0	A

Lab ID: 24040619-24 Client Sample ID: Rm 1-DF
 Collection Date: 4/12/2024 6:46:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 1-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.83		0.515	ppb	1	4/23/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-25 Client Sample ID: Rm 1-Sink
 Collection Date: 4/12/2024 6:47:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 1-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.0		0.515	ppb	1	4/23/2024	15.0	A

Lab ID: 24040619-26 Client Sample ID: Rm 2-DF
 Collection Date: 4/12/2024 6:48:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 2-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.36		0.515	ppb	1	4/23/2024	15.0	A

Lab ID: 24040619-27 Client Sample ID: Rm 2-Sink
 Collection Date: 4/12/2024 6:48:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 2-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.93		0.515	ppb	1	4/23/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-28 Client Sample ID: Rm 3-DF
 Collection Date: 4/12/2024 6:49:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 3-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.51		0.515	ppb	1	4/23/2024	15.0	A

Lab ID: 24040619-29 Client Sample ID: Rm 3-Sink
 Collection Date: 4/12/2024 6:50:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 3-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.62		0.515	ppb	1	4/23/2024	15.0	A

Lab ID: 24040619-30 Client Sample ID: Rm 4-DF
 Collection Date: 4/12/2024 6:50:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 4-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.70		0.515	ppb	1	4/23/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24040619
 Date Reported: 4/24/2024

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 24040619
Received Date: 4/12/2024 10:07:00 AM
Reported Date: 4/24/2024 1:17:57 PM

Sample Information:

Lab ID: 24040619-31 Client Sample ID: Rm 4-Sink
 Collection Date: 4/12/2024 6:51:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 4-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.84		0.515	ppb	1	4/23/2024	15.0	A

Lab ID: 24040619-32 Client Sample ID: Rm 5-DF
 Collection Date: 4/12/2024 6:51:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 5-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.78		0.515	ppb	1	4/23/2024	15.0	A


Lab ID: 24040619-33 Client Sample ID: Rm 5-Sink
 Collection Date: 4/12/2024 6:52:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 5-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CBB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.86		0.515	ppb	1	4/23/2024	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PRE Percent RE exceeds the Limit	R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 24040619
 24-Apr-24

Client: Medford School District
Project: Wilson Elementary School Leads

TestCode: LEAD_DW

Sample ID: MB-24938	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/17/2024	RunNo: 48845
Client ID: PBW	Batch ID: 24938	TestNo: E200.8	E200.8	Analysis Date: 4/17/2024	SeqNo: 802038
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-24938	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/17/2024	RunNo: 48845
Client ID: LCSW	Batch ID: 24938	TestNo: E200.8	E200.8	Analysis Date: 4/17/2024	SeqNo: 802039
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.500 100 0 103 85 115

Sample ID: 24040611-01AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/17/2024	RunNo: 48845
Client ID: BatchQC	Batch ID: 24938	TestNo: E200.8	E200.8	Analysis Date: 4/17/2024	SeqNo: 802041
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 70 130

Sample ID: 24040611-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/17/2024	RunNo: 48845
Client ID: BatchQC	Batch ID: 24938	TestNo: E200.8	E200.8	Analysis Date: 4/17/2024	SeqNo: 802042
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 70 130 102 0.402 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 24040619
 24-Apr-24

Client: Medford School District
Project: Wilson Elementary School Leads

TestCode: LEAD_DW

Sample ID: MB-24931	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: PBW	Batch ID: 24931	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803245
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-24931	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: LCSW	Batch ID: 24931	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803246
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.1 0.520 100 0 98.1 85 115

Sample ID: 24040586-16AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: BatchQC	Batch ID: 24931	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803248
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 90.5 0.520 100 0.204 90.3 70 130

Sample ID: 24040586-16AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: BatchQC	Batch ID: 24931	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803249
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 94.3 0.520 100 0.204 94.1 70 130 90.5 4.08 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 24040619
 24-Apr-24

Client: Medford School District
Project: Wilson Elementary School Leads

TestCode: LEAD_DW

Sample ID: MB-24932	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: PBW	Batch ID: 24932	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803273
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-24932	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: LCSW	Batch ID: 24932	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803274
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 95.5 0.520 100 0 95.5 85 115

Sample ID: 24040619-02AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: Staff Work Rm-DF	Batch ID: 24932	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803276
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual


Lead 97.9 0.520 100 1.61 96.3 70 130

Sample ID: 24040619-02AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/16/2024	RunNo: 48917
Client ID: Staff Work Rm-DF	Batch ID: 24932	TestNo: E200.8	E200.8	Analysis Date: 4/19/2024	SeqNo: 803277
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.1 0.520 100 1.61 96.5 70 130 97.9 0.205 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 24040619
 24-Apr-24

Client: Medford School District
Project: Wilson Elementary School Leads

TestCode: LEAD_DW

Sample ID: MB-24980	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/19/2024	RunNo: 48998
Client ID: PBW	Batch ID: 24980	TestNo: E200.8	E200.8	Analysis Date: 4/23/2024	SeqNo: 804513
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-24980	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/19/2024	RunNo: 48998
Client ID: LCSW	Batch ID: 24980	TestNo: E200.8	E200.8	Analysis Date: 4/23/2024	SeqNo: 804514
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 95.4 0.520 100 0 95.4 85 115

Sample ID: 24040619-24AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/19/2024	RunNo: 48998
Client ID: Rm 1-DF	Batch ID: 24980	TestNo: E200.8	E200.8	Analysis Date: 4/23/2024	SeqNo: 804516
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 6.83 94.8 70 130

Sample ID: 24040619-24AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 4/19/2024	RunNo: 48998
Client ID: Rm 1-DF	Batch ID: 24980	TestNo: E200.8	E200.8	Analysis Date: 4/23/2024	SeqNo: 804517
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 6.83 95.2 70 130 102 0.394 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: MSD 549C	Project Name: Wilson	Attention: Accounting	<input type="checkbox"/> Standard 10-14 Days
Address: 900 Kenyon	Project Number:	Company Name: Medford School District	<input type="checkbox"/> 5 Business Days (50% surcharge)
Medford, OR 97501	Report andy.chasteen@medford.k12.or.us	Address: 900 Kenyon	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: andy.chasteen@medford.k12.or.us	Copy T seth.barry@medford.k12.or.us	Medford, OR 97501	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: 541-840-4315 Fax:		P.O. # 127747	<input type="checkbox"/> Other _____
Collected By (Print): <i>SETH BARRY</i>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <i>[Signature]</i>			
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E
Sample Information

Sample ID	Matrix*	Date Collected	Time Collect	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)	
Wilson	Health Room - Sink	4/12/2024	624	1													01
Wilson	Staff Work Room - Drinking Fountain	4/12/2024	625	1													02
Wilson	Staff Work Room - Sink	4/12/2024	628	1													03
Wilson	Conference/AP Office Near Main Office - Sink	4/12/2024	629	1													04
Wilson	Room 26 - Drinking Fountain	4/12/2024	630	1													05
Wilson	Room 26 - Sink	4/12/2024	631	1													06
Wilson	Room 27 - Drinking Fountain	4/12/2024	632	1													07
Wilson	Room 27 - Sink	4/12/2024	633	1													08
Wilson	Room 28 - Drinking Fountain	4/12/2024	635	1													09
Wilson	Room 28 - Sink	4/12/2024	636	1													10
Wilson	Girl's Restroom Across From Room 21 - Sink (Left)	4/12/2024	637	1													11
Wilson	Girl's Restroom Across From Room 21 - Sink (Right)	4/12/2024	638	1													12
Wilson	Boy's Restroom Across From Room 21 - Sink (Left)	4/12/2024	639	1													13
Wilson	Boy's Restroom Across From Room 21 - Sink (Right)	4/12/2024	640	1													14
Wilson	Room 21 - Sink	4/12/2024	646	1													15
Wilson	Room 22 - Drinking Fountain	4/12/2024	641	1													16
Wilson	Room 22 - Sink	4/12/2024	642	1													17
Wilson	Room 23 - Drinking Fountain	4/12/2024	643	1													18
Wilson	Room 23 - Sink	4/12/2024	644	1													19
Wilson	Room 24 - Drinking Fountain	4/12/2024	644	1													20
Wilson	Room 24 - Sink	4/12/2024	645	1													21
Wilson	Room 25 - Drinking Fountain	4/12/2024	645	1													22
Wilson	Room 25 - Sink	4/12/2024	645	1													23
Wilson	Room 1 - Drinking Fountain	4/12/2024	646	1													24

