

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 3/4/2024 12:48:18 AM

JOB DESCRIPTION

Francis Howell School Dist -Francis Howell Middle

JOB NUMBER

810-94457-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
3/4/2024 12:48:18 AM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page 1

Table of Contents 3

Definitions/Glossary 4

Case Narrative 5

Detection Summary 6

Client Sample Results 12

QC Sample Results 23

QC Association Summary 27

Lab Chronicle 30

Certification Summary 41

Method Summary 42

Sample Summary 43

Chain of Custody 45

Receipt Checklists 54



Definitions/Glossary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: St. John Environmental Consulting
Project: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Job ID: 810-94457-1

Eurofins Eaton Analytical South Bend

Job Narrative 810-94457-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 2/20/2024 9:15 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Receipt Exceptions

<Sample FHM-32 was received empty. Samples FHM-38,68,and 69 were not received at all.>

FHM-1 WF (810-94457-1), FHM-2 Sink (810-94457-2), FHM-3 Sink (810-94457-3), FHM-4 Sink (810-94457-4), FHM-5 WF (810-94457-5), FHM-6 WF (810-94457-6), FHM-7 ICE (810-94457-7), FHM-8 Sink (810-94457-8), FHM-9 Sink (810-94457-9), FHM-10 Sink (810-94457-10), FHM-11 WF (810-94457-11), FHM-12 Sink (810-94457-12), FHM-13 WF (810-94457-13), FHM-14 Sink (810-94457-14), FHM-15 WF (810-94457-15), FHM-16 Sink (810-94457-16), FHM-17 Sink (810-94457-17), FHM-18 Sink (810-94457-18), FHM-19 Sink (810-94457-19), FHM-20 Sink (810-94457-20), FHM-21 Sink (810-94457-21), FHM-22 Sink (810-94457-22), FHM-23 Sink (810-94457-23), FHM-24 WF (810-94457-24), FHM-25 WF (810-94457-25), FHM-26 Sink (810-94457-26), FHM-27 Sink (810-94457-27), FHM-28 Sink (810-94457-28), FHM-29 WF (810-94457-29), FHM-30 WF (810-94457-30), FHM-31 WF (810-94457-31), FHM-32 WF (810-94457-32), FHM-33 WF (810-94457-33), FHM-34 WF (810-94457-34), FHM-35 Sink (810-94457-35), FHM-36 Sink (810-94457-36), FHM-37 Sink (810-94457-37), FHM-39 ICE (810-94457-39), FHM-40 Sink (810-94457-40), FHM-41 Sink (810-94457-41), FHM-42 Sink (810-94457-42), FHM-43 Sink (810-94457-43), FHM-44 Sink (810-94457-44), FHM-45 WF (810-94457-45), FHM-46 WF (810-94457-46), FHM-47 Sink (810-94457-47), FHM-48 Sink (810-94457-48), FHM-49 Sink (810-94457-49), FHM-50 Sink (810-94457-50), FHM-51 Sink (810-94457-51), FHM-52 Sink (810-94457-52), FHM-53 Sink (810-94457-53), FHM-54 Sink (810-94457-54), FHM-55 Sink (810-94457-55), FHM-56 Sink (810-94457-56), FHM-57 Sink (810-94457-57), FHM-58 Sink (810-94457-58), FHM-59 Sink (810-94457-59), FHM-60 Sink (810-94457-60), FHM-61 Sink (810-94457-61), FHM-62 Sink (810-94457-62), FHM-63 Sink (810-94457-63), FHM-64 WF (810-94457-64), FHM-65 WF (810-94457-65), FHM-66 Sink (810-94457-66), FHM-67 Sink (810-94457-67), FHM-70 Sink (810-94457-70), FHM-71 Sink (810-94457-71), FHM-72 Sink (810-94457-72), FHM-73 Sink (810-94457-73), FHM-74 Sink (810-94457-74), FHM-75 Sink (810-94457-75), FHM-76 Sink (810-94457-76) and FHM-77 Sink (810-94457-77)

Metals

Method 200.8_SDWA: The continuing calibration verification (CCV) analyzed in 810-89757 was outside the method criteria of + 10 % but within + 15% for Lead. As indicated in the reference method, this continuing calibration verification (CCV) will be used as the closing CCV and previous samples will not be reanalyzed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-1 WF

Lab Sample ID: 810-94457-1

No Detections.

Client Sample ID: FHM-2 Sink

Lab Sample ID: 810-94457-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-3 Sink

Lab Sample ID: 810-94457-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-4 Sink

Lab Sample ID: 810-94457-4

No Detections.

Client Sample ID: FHM-5 WF

Lab Sample ID: 810-94457-5

No Detections.

Client Sample ID: FHM-6 WF

Lab Sample ID: 810-94457-6

No Detections.

Client Sample ID: FHM-7 ICE

Lab Sample ID: 810-94457-7

No Detections.

Client Sample ID: FHM-8 Sink

Lab Sample ID: 810-94457-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.89		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-9 Sink

Lab Sample ID: 810-94457-9

No Detections.

Client Sample ID: FHM-10 Sink

Lab Sample ID: 810-94457-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.57		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-11 WF

Lab Sample ID: 810-94457-11

No Detections.

Client Sample ID: FHM-12 Sink

Lab Sample ID: 810-94457-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-13 WF

Lab Sample ID: 810-94457-13

No Detections.

Client Sample ID: FHM-14 Sink

Lab Sample ID: 810-94457-14

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-15 WF

Lab Sample ID: 810-94457-15

No Detections.

Client Sample ID: FHM-16 Sink

Lab Sample ID: 810-94457-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-17 Sink

Lab Sample ID: 810-94457-17

No Detections.

Client Sample ID: FHM-18 Sink

Lab Sample ID: 810-94457-18

No Detections.

Client Sample ID: FHM-19 Sink

Lab Sample ID: 810-94457-19

No Detections.

Client Sample ID: FHM-20 Sink

Lab Sample ID: 810-94457-20

No Detections.

Client Sample ID: FHM-21 Sink

Lab Sample ID: 810-94457-21

No Detections.

Client Sample ID: FHM-22 Sink

Lab Sample ID: 810-94457-22

No Detections.

Client Sample ID: FHM-23 Sink

Lab Sample ID: 810-94457-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.69		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-24 WF

Lab Sample ID: 810-94457-24

No Detections.

Client Sample ID: FHM-25 WF

Lab Sample ID: 810-94457-25

No Detections.

Client Sample ID: FHM-26 Sink

Lab Sample ID: 810-94457-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-27 Sink

Lab Sample ID: 810-94457-27

No Detections.

Client Sample ID: FHM-28 Sink

Lab Sample ID: 810-94457-28

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-29 WF

Lab Sample ID: 810-94457-29

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-30 WF

Lab Sample ID: 810-94457-30

No Detections.

Client Sample ID: FHM-31 WF

Lab Sample ID: 810-94457-31

No Detections.

Client Sample ID: FHM-33 WF

Lab Sample ID: 810-94457-33

No Detections.

Client Sample ID: FHM-34 WF

Lab Sample ID: 810-94457-34

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.74		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-35 Sink

Lab Sample ID: 810-94457-35

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-36 Sink

Lab Sample ID: 810-94457-36

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-37 Sink

Lab Sample ID: 810-94457-37

No Detections.

Client Sample ID: FHM-39 ICE

Lab Sample ID: 810-94457-39

No Detections.

Client Sample ID: FHM-40 Sink

Lab Sample ID: 810-94457-40

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.4		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: FHM-41 Sink

Lab Sample ID: 810-94457-41

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.58		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-42 Sink

Lab Sample ID: 810-94457-42

No Detections.

Client Sample ID: FHM-43 Sink

Lab Sample ID: 810-94457-43

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-44 Sink

Lab Sample ID: 810-94457-44

No Detections.

Client Sample ID: FHM-45 WF

Lab Sample ID: 810-94457-45

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-46 WF

Lab Sample ID: 810-94457-46

No Detections.

Client Sample ID: FHM-47 Sink

Lab Sample ID: 810-94457-47

No Detections.

Client Sample ID: FHM-48 Sink

Lab Sample ID: 810-94457-48

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-49 Sink

Lab Sample ID: 810-94457-49

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.77		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-50 Sink

Lab Sample ID: 810-94457-50

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-51 Sink

Lab Sample ID: 810-94457-51

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-52 Sink

Lab Sample ID: 810-94457-52

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-53 Sink

Lab Sample ID: 810-94457-53

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.73		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-54 Sink

Lab Sample ID: 810-94457-54

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	13		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-55 Sink

Lab Sample ID: 810-94457-55

No Detections.

Client Sample ID: FHM-56 Sink

Lab Sample ID: 810-94457-56

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	20		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-57 Sink

Lab Sample ID: 810-94457-57

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-58 Sink

Lab Sample ID: 810-94457-58

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-59 Sink

Lab Sample ID: 810-94457-59

No Detections.

Client Sample ID: FHM-60 Sink

Lab Sample ID: 810-94457-60

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.63		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-61 Sink

Lab Sample ID: 810-94457-61

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-62 Sink

Lab Sample ID: 810-94457-62

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-63 Sink

Lab Sample ID: 810-94457-63

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	21		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-64 WF

Lab Sample ID: 810-94457-64

No Detections.

Client Sample ID: FHM-65 WF

Lab Sample ID: 810-94457-65

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.82		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-66 Sink

Lab Sample ID: 810-94457-66

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-67 Sink

Lab Sample ID: 810-94457-67

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-70 Sink

Lab Sample ID: 810-94457-70

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-71 Sink

Lab Sample ID: 810-94457-71

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	18		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-72 Sink

Lab Sample ID: 810-94457-72

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-73 Sink

Lab Sample ID: 810-94457-73

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.51		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-74 Sink

Lab Sample ID: 810-94457-74

No Detections.

Client Sample ID: FHM-75 Sink

Lab Sample ID: 810-94457-75

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.68		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-76 Sink

Lab Sample ID: 810-94457-76

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: FHM-77 Sink

Lab Sample ID: 810-94457-77

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.9		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-1 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-1

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 13:51	1

Client Sample ID: FHM-2 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-2

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.8		0.50		ug/L			02/23/24 13:54	1

Client Sample ID: FHM-3 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-3

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/23/24 14:02	1

Client Sample ID: FHM-4 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-4

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:05	1

Client Sample ID: FHM-5 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-5

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:08	1

Client Sample ID: FHM-6 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-6

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:11	1

Client Sample ID: FHM-7 ICE

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-7

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:14	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-8 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-8

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.89		0.50		ug/L			02/23/24 14:16	1

Client Sample ID: FHM-9 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-9

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:25	1

Client Sample ID: FHM-10 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-10

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.57		0.50		ug/L			02/23/24 14:28	1

Client Sample ID: FHM-11 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-11

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:30	1

Client Sample ID: FHM-12 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-12

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.0		0.50		ug/L			02/23/24 14:33	1

Client Sample ID: FHM-13 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-13

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:36	1

Client Sample ID: FHM-14 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-14

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:45	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-15 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-15

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:47	1

Client Sample ID: FHM-16 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-16

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			02/23/24 14:50	1

Client Sample ID: FHM-17 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-17

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:53	1

Client Sample ID: FHM-18 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-18

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 14:56	1

Client Sample ID: FHM-19 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-19

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:13	1

Client Sample ID: FHM-20 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-20

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:19	1

Client Sample ID: FHM-21 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-21

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:21	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-22 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-22

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:23	1

Client Sample ID: FHM-23 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-23

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.69		0.50		ug/L			02/23/24 11:25	1

Client Sample ID: FHM-24 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-24

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:27	1

Client Sample ID: FHM-25 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-25

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:29	1

Client Sample ID: FHM-26 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-26

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.1		0.50		ug/L			02/23/24 11:35	1

Client Sample ID: FHM-27 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-27

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:37	1

Client Sample ID: FHM-28 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-28

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/23/24 11:39	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-29 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-29

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:41	1

Client Sample ID: FHM-30 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-30

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:43	1

Client Sample ID: FHM-31 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-31

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:49	1

Client Sample ID: FHM-33 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-33

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:51	1

Client Sample ID: FHM-34 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-34

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.74		0.50		ug/L			02/23/24 11:53	1

Client Sample ID: FHM-35 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-35

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/23/24 11:55	1

Client Sample ID: FHM-36 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-36

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/23/24 11:57	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-37 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-37

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:27	1

Client Sample ID: FHM-39 ICE

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-39

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:29	1

Client Sample ID: FHM-40 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-40

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.4		0.50		ug/L		02/29/24 12:00	03/01/24 11:55	1

Client Sample ID: FHM-41 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-41

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.58		0.50		ug/L			02/23/24 12:30	1

Client Sample ID: FHM-42 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-42

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:32	1

Client Sample ID: FHM-43 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-43

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		0.50		ug/L			02/23/24 12:34	1

Client Sample ID: FHM-44 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-44

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:39	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-45 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-45

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:40	1

Client Sample ID: FHM-46 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-46

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:42	1

Client Sample ID: FHM-47 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-47

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:43	1

Client Sample ID: FHM-48 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-48

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		0.50		ug/L			02/23/24 12:45	1

Client Sample ID: FHM-49 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-49

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.77		0.50		ug/L			02/23/24 12:50	1

Client Sample ID: FHM-50 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-50

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		0.50		ug/L			02/23/24 12:52	1

Client Sample ID: FHM-51 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-51

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/23/24 12:53	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-52 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-52

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.5		0.50		ug/L			02/23/24 12:55	1

Client Sample ID: FHM-53 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-53

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.73		0.50		ug/L			02/23/24 12:57	1

Client Sample ID: FHM-54 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-54

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13		0.50		ug/L			02/23/24 12:58	1

Client Sample ID: FHM-55 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-55

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 13:03	1

Client Sample ID: FHM-56 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-56

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	20		0.50		ug/L			02/23/24 13:05	1

Client Sample ID: FHM-57 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-57

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/23/24 13:06	1

Client Sample ID: FHM-58 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-58

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/23/24 13:08	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-59 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-59

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 15:10	1

Client Sample ID: FHM-60 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-60

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.63		0.50		ug/L			02/23/24 15:19	1

Client Sample ID: FHM-61 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-61

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50		ug/L			02/23/24 15:22	1

Client Sample ID: FHM-62 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-62

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.2		0.50		ug/L			02/23/24 15:30	1

Client Sample ID: FHM-63 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-63

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	21		0.50		ug/L			02/23/24 15:33	1

Client Sample ID: FHM-64 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-64

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 15:36	1

Client Sample ID: FHM-65 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-65

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.82		0.50		ug/L			02/23/24 15:39	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-66 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-66

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			02/23/24 15:42	1

Client Sample ID: FHM-67 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-67

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.5		0.50		ug/L			02/23/24 15:45	1

Client Sample ID: FHM-70 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-70

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/23/24 15:47	1

Client Sample ID: FHM-71 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-71

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18		0.50		ug/L			02/23/24 15:56	1

Client Sample ID: FHM-72 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-72

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/23/24 15:58	1

Client Sample ID: FHM-73 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-73

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.51		0.50		ug/L			02/23/24 16:01	1

Client Sample ID: FHM-74 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-74

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 16:04	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-75 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-75

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.68		0.50		ug/L			02/23/24 16:13	1

Client Sample ID: FHM-76 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-76

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		0.50		ug/L			02/23/24 16:16	1

Client Sample ID: FHM-77 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-77

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.9		0.50		ug/L			02/23/24 16:19	1

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-89757/12
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 09:04	1

Lab Sample ID: MB 810-89757/72
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 11:03	1

Lab Sample ID: LCS 810-89757/73
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.7		ug/L		107	85 - 115

Lab Sample ID: LLCS 810-89757/11
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.311	J	ug/L		104	50 - 150

Lab Sample ID: 810-94457-19 MS
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: FHM-19 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	51.1		ug/L		102	70 - 130

Lab Sample ID: 810-94457-19 MSD
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: FHM-19 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	55.3		ug/L		111	70 - 130	8	20

Lab Sample ID: 810-94457-30 MS
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: FHM-30 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	53.1		ug/L		106	70 - 130

Lab Sample ID: 810-94457-30 MSD
Matrix: Drinking Water
Analysis Batch: 89757

Client Sample ID: FHM-30 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	52.7		ug/L		105	70 - 130	1	20

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-89774/12

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 12:24	1

Lab Sample ID: LCS 810-89774/13

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.6		ug/L		101	85 - 115

Lab Sample ID: LLCS 810-89774/11

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.315	J	ug/L		105	50 - 150

Lab Sample ID: 810-94457-43 MS

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: FHM-43 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.4		50.0	56.2		ug/L		108	70 - 130

Lab Sample ID: 810-94457-43 MSD

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: FHM-43 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.4		50.0	55.4		ug/L		106	70 - 130	1	20

Lab Sample ID: 810-94457-54 MS

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: FHM-54 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	13		50.0	66.4		ug/L		107	70 - 130

Lab Sample ID: 810-94457-54 MSD

Matrix: Drinking Water

Analysis Batch: 89774

Client Sample ID: FHM-54 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	13		50.0	67.4		ug/L		109	70 - 130	2	20

Lab Sample ID: MB 810-89825/101

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 13:39	1

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-89825/11

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 09:26	1

Lab Sample ID: MB 810-89825/134

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/23/24 15:13	1

Lab Sample ID: LCS 810-89825/102

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	47.8		ug/L		96	85 - 115

Lab Sample ID: LCS 810-89825/135

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	47.1		ug/L		94	85 - 115

Lab Sample ID: LLCS 810-89825/10

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.300	J	ug/L		100	50 - 150

Lab Sample ID: 810-94457-2 MS

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: FHM-2 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	3.8		50.0	48.6		ug/L		90	70 - 130

Lab Sample ID: 810-94457-2 MSD

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: FHM-2 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	3.8		50.0	49.7		ug/L		92	70 - 130	2	20

Lab Sample ID: 810-94457-13 MS

Matrix: Drinking Water

Analysis Batch: 89825

Client Sample ID: FHM-13 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	47.2		ug/L		94	70 - 130

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-94457-13 MSD
Matrix: Drinking Water
Analysis Batch: 89825

Client Sample ID: FHM-13 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	47.7		ug/L		95	70 - 130	1	20

Lab Sample ID: 810-94457-61 MS
Matrix: Drinking Water
Analysis Batch: 89825

Client Sample ID: FHM-61 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	2.6		50.0	49.7		ug/L		94	70 - 130		

Lab Sample ID: 810-94457-61 MSD
Matrix: Drinking Water
Analysis Batch: 89825

Client Sample ID: FHM-61 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.6		50.0	50.0		ug/L		95	70 - 130	1	20

Lab Sample ID: 810-94457-74 MS
Matrix: Drinking Water
Analysis Batch: 89825

Client Sample ID: FHM-74 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	<0.50		50.0	47.8		ug/L		95	70 - 130		

Lab Sample ID: 810-94457-74 MSD
Matrix: Drinking Water
Analysis Batch: 89825

Client Sample ID: FHM-74 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	48.3		ug/L		96	70 - 130	1	20

Lab Sample ID: MB 810-90499/1-A
Matrix: Drinking Water
Analysis Batch: 90631

Client Sample ID: Method Blank
Prep Type: Total Recoverable
Prep Batch: 90499

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		02/29/24 12:00	03/01/24 11:24	1

Lab Sample ID: LCS 810-90499/6-A
Matrix: Drinking Water
Analysis Batch: 90631

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 90499

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	50.0	53.2		ug/L		106	85 - 115		

Lab Sample ID: LLCS 810-90499/2-A
Matrix: Drinking Water
Analysis Batch: 90631

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 90499

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	0.300	0.317	J	ug/L		106	50 - 150		

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Metals

Analysis Batch: 89757

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-19	FHM-19 Sink	Total/NA	Drinking Water	200.8	
810-94457-20	FHM-20 Sink	Total/NA	Drinking Water	200.8	
810-94457-21	FHM-21 Sink	Total/NA	Drinking Water	200.8	
810-94457-22	FHM-22 Sink	Total/NA	Drinking Water	200.8	
810-94457-23	FHM-23 Sink	Total/NA	Drinking Water	200.8	
810-94457-24	FHM-24 WF	Total/NA	Drinking Water	200.8	
810-94457-25	FHM-25 WF	Total/NA	Drinking Water	200.8	
810-94457-26	FHM-26 Sink	Total/NA	Drinking Water	200.8	
810-94457-27	FHM-27 Sink	Total/NA	Drinking Water	200.8	
810-94457-28	FHM-28 Sink	Total/NA	Drinking Water	200.8	
810-94457-29	FHM-29 WF	Total/NA	Drinking Water	200.8	
810-94457-30	FHM-30 WF	Total/NA	Drinking Water	200.8	
810-94457-31	FHM-31 WF	Total/NA	Drinking Water	200.8	
810-94457-33	FHM-33 WF	Total/NA	Drinking Water	200.8	
810-94457-34	FHM-34 WF	Total/NA	Drinking Water	200.8	
810-94457-35	FHM-35 Sink	Total/NA	Drinking Water	200.8	
810-94457-36	FHM-36 Sink	Total/NA	Drinking Water	200.8	
MB 810-89757/12	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-89757/72	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-89757/73	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-89757/11	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-94457-19 MS	FHM-19 Sink	Total/NA	Drinking Water	200.8	
810-94457-19 MSD	FHM-19 Sink	Total/NA	Drinking Water	200.8	
810-94457-30 MS	FHM-30 WF	Total/NA	Drinking Water	200.8	
810-94457-30 MSD	FHM-30 WF	Total/NA	Drinking Water	200.8	

Analysis Batch: 89774

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-37	FHM-37 Sink	Total/NA	Drinking Water	200.8	
810-94457-39	FHM-39 ICE	Total/NA	Drinking Water	200.8	
810-94457-41	FHM-41 Sink	Total/NA	Drinking Water	200.8	
810-94457-42	FHM-42 Sink	Total/NA	Drinking Water	200.8	
810-94457-43	FHM-43 Sink	Total/NA	Drinking Water	200.8	
810-94457-44	FHM-44 Sink	Total/NA	Drinking Water	200.8	
810-94457-45	FHM-45 WF	Total/NA	Drinking Water	200.8	
810-94457-46	FHM-46 WF	Total/NA	Drinking Water	200.8	
810-94457-47	FHM-47 Sink	Total/NA	Drinking Water	200.8	
810-94457-48	FHM-48 Sink	Total/NA	Drinking Water	200.8	
810-94457-49	FHM-49 Sink	Total/NA	Drinking Water	200.8	
810-94457-50	FHM-50 Sink	Total/NA	Drinking Water	200.8	
810-94457-51	FHM-51 Sink	Total/NA	Drinking Water	200.8	
810-94457-52	FHM-52 Sink	Total/NA	Drinking Water	200.8	
810-94457-53	FHM-53 Sink	Total/NA	Drinking Water	200.8	
810-94457-54	FHM-54 Sink	Total/NA	Drinking Water	200.8	
810-94457-55	FHM-55 Sink	Total/NA	Drinking Water	200.8	
810-94457-56	FHM-56 Sink	Total/NA	Drinking Water	200.8	
810-94457-57	FHM-57 Sink	Total/NA	Drinking Water	200.8	
810-94457-58	FHM-58 Sink	Total/NA	Drinking Water	200.8	
MB 810-89774/12	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-89774/13	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-89774/11	Lab Control Sample	Total/NA	Drinking Water	200.8	

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Metals (Continued)

Analysis Batch: 89774 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-43 MS	FHM-43 Sink	Total/NA	Drinking Water	200.8	
810-94457-43 MSD	FHM-43 Sink	Total/NA	Drinking Water	200.8	
810-94457-54 MS	FHM-54 Sink	Total/NA	Drinking Water	200.8	
810-94457-54 MSD	FHM-54 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 89825

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-1	FHM-1 WF	Total/NA	Drinking Water	200.8	
810-94457-2	FHM-2 Sink	Total/NA	Drinking Water	200.8	
810-94457-3	FHM-3 Sink	Total/NA	Drinking Water	200.8	
810-94457-4	FHM-4 Sink	Total/NA	Drinking Water	200.8	
810-94457-5	FHM-5 WF	Total/NA	Drinking Water	200.8	
810-94457-6	FHM-6 WF	Total/NA	Drinking Water	200.8	
810-94457-7	FHM-7 ICE	Total/NA	Drinking Water	200.8	
810-94457-8	FHM-8 Sink	Total/NA	Drinking Water	200.8	
810-94457-9	FHM-9 Sink	Total/NA	Drinking Water	200.8	
810-94457-10	FHM-10 Sink	Total/NA	Drinking Water	200.8	
810-94457-11	FHM-11 WF	Total/NA	Drinking Water	200.8	
810-94457-12	FHM-12 Sink	Total/NA	Drinking Water	200.8	
810-94457-13	FHM-13 WF	Total/NA	Drinking Water	200.8	
810-94457-14	FHM-14 Sink	Total/NA	Drinking Water	200.8	
810-94457-15	FHM-15 WF	Total/NA	Drinking Water	200.8	
810-94457-16	FHM-16 Sink	Total/NA	Drinking Water	200.8	
810-94457-17	FHM-17 Sink	Total/NA	Drinking Water	200.8	
810-94457-18	FHM-18 Sink	Total/NA	Drinking Water	200.8	
810-94457-59	FHM-59 Sink	Total/NA	Drinking Water	200.8	
810-94457-60	FHM-60 Sink	Total/NA	Drinking Water	200.8	
810-94457-61	FHM-61 Sink	Total/NA	Drinking Water	200.8	
810-94457-62	FHM-62 Sink	Total/NA	Drinking Water	200.8	
810-94457-63	FHM-63 Sink	Total/NA	Drinking Water	200.8	
810-94457-64	FHM-64 WF	Total/NA	Drinking Water	200.8	
810-94457-65	FHM-65 WF	Total/NA	Drinking Water	200.8	
810-94457-66	FHM-66 Sink	Total/NA	Drinking Water	200.8	
810-94457-67	FHM-67 Sink	Total/NA	Drinking Water	200.8	
810-94457-70	FHM-70 Sink	Total/NA	Drinking Water	200.8	
810-94457-71	FHM-71 Sink	Total/NA	Drinking Water	200.8	
810-94457-72	FHM-72 Sink	Total/NA	Drinking Water	200.8	
810-94457-73	FHM-73 Sink	Total/NA	Drinking Water	200.8	
810-94457-74	FHM-74 Sink	Total/NA	Drinking Water	200.8	
810-94457-75	FHM-75 Sink	Total/NA	Drinking Water	200.8	
810-94457-76	FHM-76 Sink	Total/NA	Drinking Water	200.8	
810-94457-77	FHM-77 Sink	Total/NA	Drinking Water	200.8	
MB 810-89825/101	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-89825/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-89825/134	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-89825/102	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-89825/135	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-89825/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-94457-2 MS	FHM-2 Sink	Total/NA	Drinking Water	200.8	
810-94457-2 MSD	FHM-2 Sink	Total/NA	Drinking Water	200.8	
810-94457-13 MS	FHM-13 WF	Total/NA	Drinking Water	200.8	

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Metals (Continued)

Analysis Batch: 89825 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-13 MSD	FHM-13 WF	Total/NA	Drinking Water	200.8	
810-94457-61 MS	FHM-61 Sink	Total/NA	Drinking Water	200.8	
810-94457-61 MSD	FHM-61 Sink	Total/NA	Drinking Water	200.8	
810-94457-74 MS	FHM-74 Sink	Total/NA	Drinking Water	200.8	
810-94457-74 MSD	FHM-74 Sink	Total/NA	Drinking Water	200.8	

Prep Batch: 90499

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-40	FHM-40 Sink	Total Recoverable	Drinking Water	200.8	
MB 810-90499/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-90499/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-90499/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 90631

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-94457-40	FHM-40 Sink	Total Recoverable	Drinking Water	200.8	90499
MB 810-90499/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	90499
LCS 810-90499/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	90499
LLCS 810-90499/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	90499

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-1 WF

Lab Sample ID: 810-94457-1

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 13:51

Client Sample ID: FHM-2 Sink

Lab Sample ID: 810-94457-2

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 13:54

Client Sample ID: FHM-3 Sink

Lab Sample ID: 810-94457-3

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:02

Client Sample ID: FHM-4 Sink

Lab Sample ID: 810-94457-4

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:05

Client Sample ID: FHM-5 WF

Lab Sample ID: 810-94457-5

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:08

Client Sample ID: FHM-6 WF

Lab Sample ID: 810-94457-6

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:11

Client Sample ID: FHM-7 ICE

Lab Sample ID: 810-94457-7

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:14

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-8 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-8

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:16

Client Sample ID: FHM-9 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-9

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:25

Client Sample ID: FHM-10 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-10

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:28

Client Sample ID: FHM-11 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-11

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:30

Client Sample ID: FHM-12 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-12

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:33

Client Sample ID: FHM-13 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:36

Client Sample ID: FHM-14 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:45

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-15 WF

Lab Sample ID: 810-94457-15

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:47

Client Sample ID: FHM-16 Sink

Lab Sample ID: 810-94457-16

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:50

Client Sample ID: FHM-17 Sink

Lab Sample ID: 810-94457-17

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:53

Client Sample ID: FHM-18 Sink

Lab Sample ID: 810-94457-18

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 14:56

Client Sample ID: FHM-19 Sink

Lab Sample ID: 810-94457-19

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:13

Client Sample ID: FHM-20 Sink

Lab Sample ID: 810-94457-20

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:19

Client Sample ID: FHM-21 Sink

Lab Sample ID: 810-94457-21

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:21

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-22 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-22

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:23

Client Sample ID: FHM-23 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-23

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:25

Client Sample ID: FHM-24 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-24

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:27

Client Sample ID: FHM-25 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-25

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:29

Client Sample ID: FHM-26 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-26

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:35

Client Sample ID: FHM-27 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-27

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:37

Client Sample ID: FHM-28 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-28

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:39

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-29 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-29

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:41

Client Sample ID: FHM-30 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-30

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:43

Client Sample ID: FHM-31 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-31

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:49

Client Sample ID: FHM-33 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-33

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:51

Client Sample ID: FHM-34 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-34

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:53

Client Sample ID: FHM-35 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-35

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:55

Client Sample ID: FHM-36 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-36

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89757	CA	EA SB	02/23/24 11:57

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-37 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-37

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:27

Client Sample ID: FHM-39 ICE

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-39

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:29

Client Sample ID: FHM-40 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-40

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			90499	NB	EA SB	02/29/24 12:00
Total Recoverable	Analysis	200.8		1	90631	NB	EA SB	03/01/24 11:55

Client Sample ID: FHM-41 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-41

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:30

Client Sample ID: FHM-42 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-42

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:32

Client Sample ID: FHM-43 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-43

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:34

Client Sample ID: FHM-44 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-44

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:39

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-45 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-45

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:40

Client Sample ID: FHM-46 WF

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-46

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:42

Client Sample ID: FHM-47 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-47

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:43

Client Sample ID: FHM-48 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-48

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:45

Client Sample ID: FHM-49 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-49

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:50

Client Sample ID: FHM-50 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-50

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:52

Client Sample ID: FHM-51 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-51

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:53

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-52 Sink

Lab Sample ID: 810-94457-52

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:55

Client Sample ID: FHM-53 Sink

Lab Sample ID: 810-94457-53

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:57

Client Sample ID: FHM-54 Sink

Lab Sample ID: 810-94457-54

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 12:58

Client Sample ID: FHM-55 Sink

Lab Sample ID: 810-94457-55

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 13:03

Client Sample ID: FHM-56 Sink

Lab Sample ID: 810-94457-56

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 13:05

Client Sample ID: FHM-57 Sink

Lab Sample ID: 810-94457-57

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 13:06

Client Sample ID: FHM-58 Sink

Lab Sample ID: 810-94457-58

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89774	CA	EA SB	02/23/24 13:08

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-59 Sink

Lab Sample ID: 810-94457-59

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:10

Client Sample ID: FHM-60 Sink

Lab Sample ID: 810-94457-60

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:19

Client Sample ID: FHM-61 Sink

Lab Sample ID: 810-94457-61

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:22

Client Sample ID: FHM-62 Sink

Lab Sample ID: 810-94457-62

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:30

Client Sample ID: FHM-63 Sink

Lab Sample ID: 810-94457-63

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:33

Client Sample ID: FHM-64 WF

Lab Sample ID: 810-94457-64

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:36

Client Sample ID: FHM-65 WF

Lab Sample ID: 810-94457-65

Date Collected: 02/16/24 08:00

Matrix: Drinking Water

Date Received: 02/20/24 09:15

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:39

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-66 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-66

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:42

Client Sample ID: FHM-67 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-67

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:45

Client Sample ID: FHM-70 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-70

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:47

Client Sample ID: FHM-71 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-71

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:56

Client Sample ID: FHM-72 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-72

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 15:58

Client Sample ID: FHM-73 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-73

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 16:01

Client Sample ID: FHM-74 Sink

Date Collected: 02/16/24 08:00

Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-74

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 16:04

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Client Sample ID: FHM-75 Sink
Date Collected: 02/16/24 08:00
Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-75
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 16:13

Client Sample ID: FHM-76 Sink
Date Collected: 02/16/24 08:00
Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-76
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 16:16

Client Sample ID: FHM-77 Sink
Date Collected: 02/16/24 08:00
Date Received: 02/20/24 09:15

Lab Sample ID: 810-94457-77
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	89825	NB	EA SB	02/23/24 16:19

Laboratory References:
EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Method Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Project/Site: Francis Howell School Dist -Francis Howell Middle

Job ID: 810-94457-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-94457-1	FHM-1 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-2	FHM-2 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-3	FHM-3 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-4	FHM-4 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-5	FHM-5 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-6	FHM-6 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-7	FHM-7 ICE	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-8	FHM-8 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-9	FHM-9 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-10	FHM-10 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-11	FHM-11 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-12	FHM-12 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-13	FHM-13 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-14	FHM-14 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-15	FHM-15 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-16	FHM-16 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-17	FHM-17 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-18	FHM-18 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-19	FHM-19 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-20	FHM-20 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-21	FHM-21 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-22	FHM-22 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-23	FHM-23 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-24	FHM-24 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-25	FHM-25 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-26	FHM-26 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-27	FHM-27 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-28	FHM-28 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-29	FHM-29 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-30	FHM-30 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-31	FHM-31 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-33	FHM-33 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-34	FHM-34 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-35	FHM-35 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-36	FHM-36 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-37	FHM-37 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-39	FHM-39 ICE	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-40	FHM-40 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-41	FHM-41 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-42	FHM-42 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-43	FHM-43 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-44	FHM-44 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-45	FHM-45 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-46	FHM-46 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-47	FHM-47 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-48	FHM-48 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-49	FHM-49 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-50	FHM-50 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-51	FHM-51 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-52	FHM-52 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-53	FHM-53 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-54	FHM-54 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-55	FHM-55 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-56	FHM-56 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15

Sample Summary

Client: St. John Environmental Consulting

Job ID: 810-94457-1

Project/Site: Francis Howell School Dist -Francis Howell Middle

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-94457-57	FHM-57 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-58	FHM-58 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-59	FHM-59 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-60	FHM-60 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-61	FHM-61 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-62	FHM-62 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-63	FHM-63 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-64	FHM-64 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-65	FHM-65 WF	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-66	FHM-66 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-67	FHM-67 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-70	FHM-70 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-71	FHM-71 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-72	FHM-72 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-73	FHM-73 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-74	FHM-74 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-75	FHM-75 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-76	FHM-76 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15
810-94457-77	FHM-77 Sink	Drinking Water	02/16/24 08:00	02/20/24 09:15

Eurofins Eaton Analytical
110 South Hill Street
South Bend, IN 46817
Phone (574) 233-4777

Chain of Custody Record

eurofins
Environmental Testing
America



Client Information

810-94457 Chain of Custody

Client Contact:
Don Albers

Company:
Francis Howell School Dist.

Address:
4606 Century School Road
St. Charles, MO

Phone:
636-851-6176

Email:
Don.Albers@FHSschools.org

Project Name:
Francis Howell School Dist

Site:
Francis Howell Middle

Due Date Requested:

TAI Requested (days):
Standard

Compliance Project: ☐ Yes ☐ No

PO #:

WFO #:

Project #:

SSOW#:

Lab PM:

E-Mail:

State of Origin:

Carrier Tracking No.:

COC No.:

Job #:

Page 1 of 3

Analysis Requested

Preservation Codes:

Special Instructions/Note:

PH Acceptable

Less than 2

Sample Identification

Sample Date

Sample Time

Sample Type

Matrix

Field Filtered Sample (Yes or No)

Total Number of containers

Empty Kit Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Relinquished by:

Custody Seals Intact:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Custody Seal No.:

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Return To Client

Disposal By Lab

Archive For

Months

Special Instructions/QC Requirements:

Method of Shipment:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Received by:

Eurofins Eaton Analytical: South Bend
 110 South Hill Street
 South Bend, IN 46817
 Phone (574) 233-4177

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab P/N:		Carrier Tracking No(s):		COC No:	
Client Contact: Don Allison		Phone: 314-853-4668		E-Mail: ian@stjohns.com		State of Origin: MO		Page 2 of 3	
Company: Francis Howell School Dist.		Address: 4100 Central School Road		City: St. Charles		State, Zip: MO		Job #:	
Phone: 636-851-6176		TAT Requested (days): Standard		Compliance Project: Δ Yes Δ No		PO #:		Analysis Requested	
Email: Don.Allison@FHSschools.org		MO #:		Project #:		Field Filtered Sample (Yes or No)		Perform MS/MSD	
Project Name: Francis Howell School Dist		SSOW#:		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab, RT=Room, A=Air)	
Site: Francis Howell Middle		Matrix		Preservation Code:		Field Filtered Sample (Yes or No)		Perform MS/MSD	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab, RT=Room, A=Air)		Matrix	
EHM-12 Sink		2/16/24		0800		G		W	
EHM-13 wF									
EHM-14 Sink									
EHM-15 wF									
EHM-16 Sink									
EHM-17									
EHM-18									
EHM-19									
EHM-20									
EHM-21									
EHM-22									
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological ☐		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		Return To Client ☐ Disposal By Lab ☒ Archive For ☐ Months		Special Instructions/Note:	
Deliverable Requested: I, II, III, IV, Other (specify)		Special Instructions/Note:		Special Instructions/Note:		Special Instructions/Note:		Special Instructions/Note:	
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:		Received by:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:		Cooler Temperature(s) °C and Other Remarks:		Cooler Temperature(s) °C and Other Remarks:	

Eurofins Eaton Analytical: South Bend

110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

15th Dec 2024
eurofins
44
Environment Testing
America

Client Information		Sampler: <i>Travis St. John</i>		Lab File:		Carrier Tracking No(s):		COC No:	
Client Contact: <i>Don Allison</i>		Phone: <i>314-853-4668</i>		E-Mail: <i>ina@stjohns-nv.com</i>		State of Origin: <i>MO</i>		F Page 3 of 3	
Company: <i>Francis Howell School Dist.</i>		Due Date Requested:		Analysis Requested					
Address: <i>4606 Central School Road</i>		TAT Requested (days):							
City: <i>St. Charles</i>		Standard							
State, Zip: <i>MO</i>		Compliance Project: ☐ Yes ☒ No							
Phone: <i>636-851-6176</i>		PO #:							
Email: <i>Don.Allison@FHSschools.org</i>		MO #:							
Project Name: <i>Francis Howell School Dist</i>		Project #:							
Site: <i>Francis Howell Middle</i>		SSOWF:							
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Preservation Code:	Matrix (Inorganic, Organic, Semisolid, Other)	Field Filtered Sample (Yes or No)		
							Random MS/MS: ☒ or No		
							Pb in Drinking Water		
							Total Number of containers		
							Special Instructions/Note:		
							Preservation Codes:		
							Other:		
							Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		
							Return To Client ☐ Disposal By Lab ☒ Archive For ☐ Months		
							Special Instructions/QC Requirements:		
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological ☐							
Deliverable Requested: I, II, III, IV, Other (specify)									
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:		Received by:	
Relinquished by: <i>Don Allison</i>		Date/Time: <i>2/16/24</i>		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:					

Chain of Custody Record

Client Information Client Contact: <u>Don Allison</u> Company: <u>Francis Howell School Dist.</u> Address: <u>41006 Central School Road</u> City: <u>St. Charles</u> State, Zip: <u>MO</u> Phone: <u>636-851-6176</u> Email: <u>Don.Allison@FHSschools.org</u> Project Name: <u>Francis Howell School Dist</u> Site: <u>Francis Howell Middle</u>		Sampler: <u>Travis Johnson</u> Phone: <u>314-853-4668</u> PWSID: <u>ina2stjohnear.com</u> State of Origin: <u>MO</u>	Lab P/M: <u>ina2stjohnear.com</u> Carrier Tracking No(s): <u>MO</u> COC No: <u>Page 1 of 2</u>																																																																																																												
Due Date Requested: <u>Standard</u> TAT Requested (days): <u>Standard</u> Compliance Project: <u>Δ Yes Δ No</u> PO #: <u>WO #:</u> Project #: <u>SSOWF:</u>		Analysis Requested Field Filtered Sample (Yes or No) <u>Perform MS/MSD</u> <u>Pb in Drinking Water</u>																																																																																																													
Sample Identification <table border="1"> <thead> <tr> <th>Sample ID</th> <th>Sample Date</th> <th>Sample Time</th> <th>Sample Type (C=Comp, G=grab)</th> <th>Matrix (for metals, Sw=Sw, O=Other, BR=Resin, A=Air)</th> <th>Field Filtered Sample (Yes or No)</th> <th>Perform MS/MSD</th> <th>Total Number of Containers</th> <th>Special Instructions/Note:</th> </tr> </thead> <tbody> <tr> <td>EHM-34</td> <td>2/14/24</td> <td>0800</td> <td>G</td> <td>W</td> <td>X</td> <td></td> <td></td> <td>* 38 not received gsm</td> </tr> <tr> <td>EHM-35</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-36</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-37</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-38</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-39</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-40</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-41</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-42</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-43</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>EHM-44</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		Sample ID	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (for metals, Sw=Sw, O=Other, BR=Resin, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD	Total Number of Containers	Special Instructions/Note:	EHM-34	2/14/24	0800	G	W	X			* 38 not received gsm	EHM-35									EHM-36									EHM-37									EHM-38									EHM-39									EHM-40									EHM-41									EHM-42									EHM-43									EHM-44									Preservation Codes: A - HCl B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Another H - Acetic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - AsHClO2 P - Na2CO3 Q - Na2O4S R - Na2SO3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCA W - pH 4.5 Y - Tizma Z - other (specify)	
Sample ID	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (for metals, Sw=Sw, O=Other, BR=Resin, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD	Total Number of Containers	Special Instructions/Note:																																																																																																							
EHM-34	2/14/24	0800	G	W	X			* 38 not received gsm																																																																																																							
EHM-35																																																																																																															
EHM-36																																																																																																															
EHM-37																																																																																																															
EHM-38																																																																																																															
EHM-39																																																																																																															
EHM-40																																																																																																															
EHM-41																																																																																																															
EHM-42																																																																																																															
EHM-43																																																																																																															
EHM-44																																																																																																															
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological Deliverable Requested: I, II, III, IV, Other (specify)		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☒ Dispose By Lab ☐ Archive For _____ Months																																																																																																													
Empty Kit Requisitioned by: _____ Date: _____ Requisitioned by: _____ Date/Time: _____ Requisitioned by: _____ Date/Time: _____ Requisitioned by: _____ Date/Time: _____		Received by: _____ Date/Time: _____ Received by: _____ Date/Time: _____ Received by: _____ Date/Time: _____ Received by: _____ Date/Time: _____																																																																																																													
Requisitioned by: _____ Date/Time: _____ Requisitioned by: _____ Date/Time: _____ Requisitioned by: _____ Date/Time: _____ Requisitioned by: _____ Date/Time: _____		Cooler Temperature(s) °C and Other Remarks: _____																																																																																																													
Custody Seals Intact: <u>Δ Yes Δ No</u> Custody Seal No.: _____																																																																																																															

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

[Faint handwritten notes, possibly "3/4/2024"]



Chain of Custody Record

Client Information		Sampler: <i>Travis Johnson</i>		Lab Pk:		Carrier Tracking No(s):		COC No:	
Client Contact: <i>Don Allison</i>		Phone: <i>314-853-4668</i>		E-Mail: <i>ina@stjohns-nv.com</i>		State of Origin: <i>MO</i>		Job #: <i>Page 5 of</i>	
Address: <i>Francis Howell School Dist.</i>		Due Date Requested:		Analysis Requested					
City: <i>St. Charles</i>		TAT Requested (day):							
State, Zip: <i>MO</i>		Compliance Project: ☐ Yes ☒ No							
Phone: <i>636-851-6176</i>		PO #:							
Email: <i>Don.Allison@FHSschools.org</i>		WO #:							
Project Name: <i>Francis Howell School Dist</i>		Project #:							
Site: <i>Francis Howell Middle</i>		SSOW:							
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix (Water, Soil, Overstall, Air, etc.)	Field Filtered Sample (Yes or No)		Total Number of Containers	
<i>FHM-45 WF</i>		<i>2/16/24</i>	<i>0800</i>	<i>G</i>	<i>W</i>	<i>X</i>		<i>Pb in Drinking Water</i>	
<i>FHM-46 WF</i>									
<i>FHM-47 Suck</i>									
<i>FHM-48</i>									
<i>FHM-49</i>									
<i>FHM-50</i>									
<i>FHM-51</i>									
<i>FHM-52</i>									
<i>FHM-53</i>									
<i>FHM-54</i>									
<i>FHM-55</i>									
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological ☐		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Deliverable Requested: I, II, III, IV, Other (specify)				☐ Return To Client ☒ Disposal By Lab ☐ Archive For ☐ Months					
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
Relinquished by: <i>Don Allison</i>		Date/Time: <i>2/16/24</i>		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:		Coder Temperature(s) °C and Other Remarks:					

1
2
3
4
5
6
7
8
9
10
11
12
13
14

110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

15+ Years
eurofins
44
Environment Testing
America

Client Information		Sample: <i>Francis Havel School Dist.</i>		Lab P/N:		Carrier Tracking No(s):		COC No:	
Client Contact: <i>Don Altman</i>		Phone: <i>314-853-4668</i>		E-Mail: <i>ian@stjohnsnc.com</i>		State of Origin: <i>MO</i>		Job #: <i>Page 10 of 15</i>	
Company: <i>Francis Havel School Dist.</i>		Due Date Requested:		Analysis Requested					
Address: <i>4606 Central School Road</i>		TAT Requested (days):							
City: <i>St. Charles</i>		Standard							
State, Zip: <i>MO</i>		Compliance Project: ☐ Yes ☒ No							
Phone: <i>636-851-6176</i>		PO #:							
Email: <i>Don.Altman@FHSschools.org</i>		MO #:							
Project Name: <i>Francis Havel School Dist</i>		Project #:							
Site: <i>Francis Havel Middle</i>		SSOW#:							
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab)		Matrix (W=Water, S=Soil, O=Organic, A=Air)	
<i>FHM-56 Sink</i>		<i>2/16/24</i>		<i>0800</i>		<i>G</i>		<i>W</i>	
<i>FHM-57 Sink</i>									
<i>FHM-58</i>									
<i>FHM-59</i>									
<i>FHM-60</i>									
<i>FHM-61</i>									
<i>FHM-62</i>									
<i>FHM-63</i>									
<i>FHM-64 WF</i>									
<i>FHM-65 WF</i>									
<i>FHM-66 Sink</i>									
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological							
Deliverable Requested: I, II, III, IV, Other (specify)									
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
<i>Don Altman</i>		<i>2/16/24</i>							
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
<i>Don Altman</i>		<i>2/16/24</i>							
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:					

110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Client Information

Client Contact: Don Allison

Company: Francis Howell School Dist.

Address: 4606 Central School Road

City: St. Charles

State, Zip: MO

Phone: 636-851-6176

Email: Don.Allison@EHSschools.org

Project Name: Francis Howell School Dist

Site: Francis Howell Middle

Sampler: Frank St. John

Phone: 314-853-4668

Project #: 314-853-4668

Due Date Requested:

TAT Requested (days): Standard

Compliance Project: ☐ Yes ☒ No

PO #:

WO #:

Project #:

SSOW:

Lab Pk:

E-Mail:

State of Origin: MO

Carrier Tracking No(s):

Analysis Requested

COC No:

Job #:

Page 7 of 7

Preservation Codes:

Special Instructions/Note:

Total Number of containers

Special Instructions/Note:

Sample Identification

Sample Date: 2/16/24 Sample Time: 0800 Sample Type: G Matrix: W

Sample ID: FHM-67 Sink

Sample ID: FHM-68 Sink

Sample ID: FHM-69 Sink

Sample ID: FHM-70 Sink

Sample ID: FHM-71 Sink

Sample ID: FHM-72 Sink

Sample ID: FHM-73 Sink

Sample ID: FHM-74 Sink

Sample ID: FHM-75 Sink

Sample ID: FHM-76 Sink

Sample ID: FHM-77 Sink

Sample ID: FHM-78 Sink

Sample ID: FHM-79 Sink

Sample ID: FHM-80 Sink

Sample ID: FHM-81 Sink

Sample ID: FHM-82 Sink

Sample ID: FHM-83 Sink

Sample ID: FHM-84 Sink

Field Filtered Sample (Yes or No)

Pb in Drinking Water

0 of 604 were not retained

2/16/24

2/16/24

2/16/24

2/16/24

2/16/24

2/16/24

2/16/24

2/16/24

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Special Instructions/QC Requirements:

Deliverable Requested: ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Empty Kit Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Relinquished by: Don Allison Date/Time: 2/16/24 Company: Company

Page 53 of 54

3/4/2024

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-94457-1

Login Number: 94457

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Moore, Gary

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	