



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: April 06, 2022
Client: Freehold Borough Board of Education
Address: 280 Park Ave
Freehold, NJ 07728

Analytical Results

PWSID#:
Project Location: 280 Park Ave, Freehold

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-001		
Sample Location:	Trophy Case Fountain 1	Customer Sample Number:			
Sampled By:	C. LeFave				
Sample Date/Time:	3/27/2022 8:00				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	40.2 **	µg/L	15	4/4/2022	12:19	JGW	4	2

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-002		
Sample Location:	Trophy Case Fountain 2	Customer Sample Number:			
Sampled By:	C. LeFave				
Sample Date/Time:	3/27/2022 8:00				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	16.2 **	µg/L	15	4/4/2022	12:24	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-003
Sample Location: Nurse's Office **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:02

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	12:30	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-004
Sample Location: Art Room Fountain 1 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:03

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.14	µg/L	15	4/4/2022	12:35	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-005
Sample Location: Art Room Fountain 2 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:04

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.90	µg/L	15	4/4/2022	12:41	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-006
Sample Location: Old Locker Room Boys **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:06

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	13.4	µg/L	15	4/4/2022	12:58	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-007
Sample Location: Old Locker Room Gilrs **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:07

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	9.61	µg/L	15	4/4/2022	13:09	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-008
Sample Location: Fountian New Gym Hallway **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:10

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:15	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-009
Sample Location: New Locker Room Boys **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:17

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:20	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-010
Sample Location: New Locker Room Girls **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:19

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:26	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-011
Sample Location: Donnelly's Office New Library **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:20

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:31	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-012
Sample Location: Fountain 7th Grade Hallway **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:22

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:37	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-013
Sample Location: FIS Faculty Room **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:23

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:42	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-014
Sample Location: Old Café Fountian 1 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:28

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:48	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-015
Sample Location: Old Café Fountain 2 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:29

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	13:53	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-016
Sample Location: Old Café Fountain 3 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.01	µg/L	15	4/4/2022	14:21	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-017
Sample Location: Old Café Fountain 4 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:31

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	14:53	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-018
Sample Location: Room 53 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:26

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	62.8 **	µg/L	15	4/4/2022	15:04	JGW	8	4

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-019
Sample Location:	Kitchen	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:34		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	15:10	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-020
Sample Location:	Fountain 3rd Grade Hallway	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:36		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	15:15	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-021
Sample Location:	PAE Faculty Room	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:40		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.83	µg/L	15	4/4/2022	15:21	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-022
Sample Location:	Tech Office	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:42		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	37.7 **	µg/L	15	4/4/2022	15:40	JGW	4	2

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-023
Sample Location: Board Office Kitchen **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:44

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	15:46	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-024
Sample Location: 6th Grade Hall 1 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:50

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	14.6	µg/L	15	4/4/2022	15:51	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-025
Sample Location: 6th Grade Hall 2 **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:51

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.37	µg/L	15	4/4/2022	16:02	JGW	2	1

Sample Matrix: Drinking Water **Lab Sample Number:** 220323013-026
Sample Location: Fountain 5th Grade Hallway **Customer Sample Number:**
Sampled By: C. LeFave
Sample Date/Time: 3/27/2022 8:45

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	16:08	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-027
Sample Location:	Field Blank	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:24		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/4/2022	16:13	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220323013-028
Sample Location:	6th Grade Hall 3	Customer Sample Number:	
Sampled By:	C. LeFave		
Sample Date/Time:	3/27/2022 8:52		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	43.0 **	µg/L	15	4/4/2022	16:24	JGW	8	4

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.
 NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

April 06, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220323013
220323013

Customer Name: Freehold Borough Board of Education
 Location: 280 Park Ave, Freehold
 Address: 280 Park Ave
 Freehold, NJ, 07728
 Customer Contact:
 Phone: Work/Cell 732-761-2149 /

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	Na ₂ S ₂ O ₃	Cl ₂ :	
#	HNO ₃	pH:	22
#	H ₂ SO ₄	pH:	
#	NaOH	pH:	
#	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project:	Collection	PWSID#							for laboratory use only	Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220323013-001	Trophy Case Fountain 1	3/27/22	0800	X		DW	1	HNO3	Lead-1st Draw		
220323013-002	Trophy Case Fountain 2		0800	X		DW	1	HNO3	Lead-1st Draw		
220323013-003	Nurse's Office		0802	X		DW	1	HNO3	Lead-1st Draw		
220323013-004	Art Room Fountain 1		0803	X		DW	1	HNO3	Lead-1st Draw		
220323013-005	Art Room Fountain 2		0804	X		DW	1	HNO3	Lead-1st Draw		
220323013-006	Old Locker Room Boys		0805	X		DW	1	HNO3	Lead-1st Draw		
220323013-007	Old Locker Room Girls		0807	X		DW	1	HNO3	Lead-1st Draw		
220323013-008	Fountain New Gym Hallway		0810	X		DW	1	HNO3	Lead-1st Draw		
220323013-009	New Locker Room Boys		0817	X		DW	1	HNO3	Lead-1st Draw		
220323013-010	New Locker Room Girls		0819	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): *C. LeFavelAgra*

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab: *N/A*

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Comments:
<i>[Signature]</i>	3/27/22	1035	<i>[Signature]</i>	3/27/22	1035	water last used 3/26/22 3pm
<i>S. Longstreet - E</i>	3/31/22	1220	<i>Jan Wall</i>	3/31/22	1237	Turbid at Marlboro 3/22/22 CL
						Date Faxed _____ Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220323013
220323013

Customer Name: Freehold Borough Board of Education
 Location: 280 Park Ave, Freehold
 Address: 280 Park Ave
 Freehold, NJ, 07728
 Customer Contact:
 Phone: Work/Cell 732-761-2149 /

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	Na ₂ S ₂ O ₃	Cl ₂ :
#	HNO ₃	pH:
#	H ₂ SO ₄	pH:
#	NaOH	pH:
#	unpreserved	
#	other	
#	other	

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis	
										pH / Temp	Cl ₂ or PO ₄
220323013-011	Donelly's Office New Library	3/27/22	0820	X		DW	1	HNO3	Lead-1st Draw		
220323013-012	Fountian 7th Grade Hallway	3/27/22	0822	X		DW	1	HNO3	Lead-1st Draw		
220323013-013	FIS Faculty Room	3/27/22	0823	X		DW	1	HNO3	Lead-1st Draw		
220323013-014	Old Café Fountain 1	3/27/22	0828	X		DW	1	HNO3	Lead-1st Draw		
220323013-015	Old Café Fountain 2	3/27/22	0829	X		DW	1	HNO3	Lead-1st Draw		
220323013-016	Old Café Fountain 3	3/27/22	0830	X		DW	1	HNO3	Lead-1st Draw		
220323013-017	Old Café Fountain 4	3/27/22	0831	X		DW	1	HNO3	Lead-1st Draw		
220323013-018	Room 53	3/27/22	0826	X		DW	1	HNO3	Lead-1st Draw		
220323013-019	Kitchen	3/27/22	0834	X		DW	1	HNO3	Lead-1st Draw		
220323013-020	Fountain 3rd Grade Hallway	3/27/22	0836	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): C. LeFave/Agra Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Indicate laboratory location where analysis request was performed: _____
 Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: <u>[Signature]</u>	Date: <u>3/27/22</u>	Time: <u>1035</u>	Received By: <u>[Signature]</u>	Date: <u>3/27/22</u>	Time: <u>1035</u>	Comments: Date Faxed _____ Invoice Number _____ Is sample known to be hazardous? (circle one) Yes or No
Relinquished By: <u>S. Konstaut - A</u>	Date: <u>3/31/22</u>	Time: <u>1220</u>	Received By: <u>[Signature]</u>	Date: <u>3/31/22</u>	Time: <u>1237</u>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220323013
220323013

Customer Name: Freehold Borough Board of Education	Agra Environmental Services	# Asc./HCl Vials pH: _____
Location: 280 Park Ave, Freehold	90 1/2 West Blackwell Street	# HCl Vials pH: _____
Address: 280 Park Ave	Dover, NJ 07801	# Na ₂ S ₂ O ₃ Cl ₂ : _____
Freehold, NJ, 07728	Phone: (973) 989-0010	# HNO ₃ pH: _____
Customer Contact: _____	Fax: (973) 989-0156	# H ₂ SO ₄ pH: _____
Phone: Work/Cell 732-761-2149 /		# NaOH pH: _____
		# unpreserved _____
		# other _____
		# other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 3 of 3

Project: Park Ave Complex	Collection	PWSID#			for laboratory use only		Field Analysis				
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220323013-021	PAE Faculty Room	3/27/22	0840	X		DW	1	HNO3	Lead-1st Draw		
220323013-022	Tech Office		0842	X		DW	1	HNO3	Lead-1st Draw		
220323013-023	Board Office Kitchen		0844	X		DW	1	HNO3	Lead-1st Draw		
220323013-024	Board Hallway Fountain 1		0850	X		DW	1	HNO3	Lead-1st Draw		
220323013-025	Board Office Hallway Fountain		0851	X		DW	1	HNO3	Lead-1st Draw		
220323013-026	Fountain 5th Grade Hallway		0845	X		DW	1	HNO3	Lead-1st Draw		
220323013-027	Field Blank		0824	X		DW	1	HNO3	Lead-1st Draw		
L-028	6 th grade Hall 3		0852	X		DW	1	HNO3	1		

Sampled By (name/company): <i>C. LeFavel/Agra</i>	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard	NJ Reduced
		Other (Specify)
		Cooler Temperature Upon Receipt at lab: <i>N/A</i>

Sample Custody Exchanges (Please use full legal signature)						Comments: <i>Board Hall fountains out of service - Alt. sites used. *6th grade</i>	
Relinquished By: <i>[Signature]</i>	Date: 3/27/22	Time: 1035	Received By: <i>[Signature]</i>	Date: 3/27/22	Time: 1035		
Relinquished By: <i>S. Longstreet - S</i>	Date: 3/31/22	Time: 1220	Received By: <i>Jan Wall</i>	Date: 3/31/22	Time: 1237		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	