

AHERA THREE YEAR RE-INSPECTION LOG



LEA NAME:		Brownsville ISD					
SCHOOL BUILDING NAME:		Castaneda Elementary School					
ADDRESS:		3201 Lima Street					
DATE:		05-01-2023					
HA No.	Material Type / Description	Material Location	Condition	Friability	Category	Classification	Results
001	12" x 12" Floor Tile with mastic White tile with tan streaks.	Rooms 127 & 130	Good	Non-Friable	5	Miscellaneous	Presumed ACM
002	12" x 12" Floor Tile with mastic Brown tile with black streaks.	Rooms 127 & 130	Good	Non-Friable	5	Miscellaneous	Presumed ACM
003	Cement flooring	Gym Area	Good	Non-Friable	5		
004	12" x 12" Floor Tile with mastic White tile with tan streaks.	Throughout the School	Good	Non-Friable	5	Miscellaneous	Presumed ACM
005	2" x 2" Ceramic tile (White, Blue, and Brown)	Boys Restroom	Good	Non-Friable	5	Miscellaneous	Non Suspect
006	2" x 2" Ceramic tile (White, and Pink)	Girls Restroom	Good	Non-Friable	5	Miscellaneous	Non Suspect
007	12" x 12" Ceramic tile (Tan, Green, Blue, and Light red)	Hallways	Good	Non-Friable	5	Miscellaneous	Non Suspect
100	2' x 2' Ceiling tile with small pinholes.	Rooms 127 & 130	Good	Friable	5	Miscellaneous	Presumed ACM
101	2' x 2' Ceiling tile with small pinholes.	All hallways, and cafeteria	Good	Friable	5	Miscellaneous	Presumed ACM
102	2' x 2' Ceiling tile with small pinholes.	Every room throughout the school	Good	Friable	5	Miscellaneous	Presumed ACM
103	2' x 2' Ceiling tile with small pinholes.	All restrooms	Good	Friable	5	Miscellaneous	Presumed ACM
200	HVAC Mastic White	Throughout building	Good	Non-Friable	5	Miscellaneous	Presumed ACM
300	Sheet Rock and Joint Compound	Throughout the School	Good	Non-Friable	5	Surfacing	Presumed ACM

AHERA THREE YEAR RE-INSPECTION LOG



301	White cinder block	Gym area	Good	Non-Friable	5	Miscellaneous	Non-Asbestos
400	White, Orange, Green, and Purple cinder block.	All the Hallways	Good	Non-Friable	5	Miscellaneous	Non Suspect
401	Sheet Rock and Joint Compound	All the Hallways	Good	Non-Friable	5	Surfacing	Presumed ACM
402	Ceramic Wall Tile 5"x 5" White, Blue, and Navy-Blue tile	All Boys Restrooms	Good	Non-Friable	5	Miscellaneous	Non Suspect
403	Ceramic Wall Tile 5"x 5" White, and Pink tile	All Girls Restrooms	Good	Non-Friable	5	Miscellaneous	Non Suspect

Category:	1 Damaged/significantly damaged thermal insulation, 2 Damaged friable surfacing 3 Significantly damaged friable surfacing 4 Damaged/Significantly damaged friable miscellaneous 5 Potential for damage 6 Potential for significant damage 7 Remaining ACBM
Inspector Name	Eloy Palacios
Signature:	
Date:	5.31.23
Accreditation:	Asbestos Consultant 105727
PREVENTATIVE MEASURES (to keep undamaged from becoming damaged)	
Do not subject material to cutting, drilling, grinding, abrading, or burning. Prevent further damage by protecting from impact or vibration. Minimize entry to area by personnel.	
RESPONSE ACTIONS:	
Follow response action section of the management plan for maintenance activities. Follow response action section of the management plan for renovation and remodeling activities. Follow response action section of the management plan for emergency response procedures.	