

AHERA THREE YEAR RE-INSPECTION LOG



LEA NAME:		Brownsville ISD					
SCHOOL BUILDING NAME:		Canales Elementary School					
ADDRESS:		1811 International Boulevard					
DATE:		05-01-2023					
HA No.	Material Type / Description	Material Location	Condition	Friability	Category	Classification	Results
101	12" x 12" Floor Tile with mastic White Tile W/ Brown Flecks	Throughout Main Office, Classrooms 1-162, Library, Portables	Good	Non-Friable	5	Miscellaneous	Presumed ACM
102	12" x 12" Floor Tile with mastic White Floor Tile	Cafeteria	Good	Non-Friable	5	Miscellaneous	Presumed ACM
103	Ceramic Square Tile White Ceramic	Restrooms Throughout School	Good	Non-Friable	5	Miscellaneous	Presumed ACM
104	Blue Carpet	Library	Good	Non-Friable	5	Miscellaneous	Presumed ACM
105	Cement Flooring Grey Cement	Gym	Good	Non-Friable	5	Surfacing	Presumed ACM
106	Hardwood Wood	Gym	Good	Non-Friable	5	Miscellaneous	Presumed ACM
201	2' x 4' Ceiling Tile Off White, Medium Fissure Small Holes	Throughout Main Office, Library, Ceiling Tile, Classrooms 1-162	Good	Friable	5	Miscellaneous	Presumed ACM
301	Chalkboard Mastic Black	Classrooms	Good	Non-Friable	5	Miscellaneous	Presumed ACM
302	Stage Curtains	Cafeteria	Good	Non-Friable	5	Miscellaneous	Presumed ACM
303	Cove Base Mastic	Throughout School	Good	Non-Friable	5	Miscellaneous	Presumed ACM
401	Sheet Rock and Joint Compound	Throughout School	Good	Non-Friable	5	Surfacing	Presumed ACM
402	Cinder Block	Throughout School	Good	Non-Friable	5	Miscellaneous	Non-Asbestos

Category:	<ul style="list-style-type: none"> 1 Damaged/significantly damaged thermal insulation, 2 Damaged friable surfacing 3 Significantly damaged friable surfacing 4 Damaged/Significantly damaged friable miscellaneous 5 Potential for damage 6 Potential for significant damage 7 Remaining ACBM
-----------	--

AHERA THREE YEAR RE-INSPECTION LOG



Inspector Name	Eloy Palacios
Signature:	
Date:	5.31.23
Accreditation:	Asbestos Consultant 105727
PREVENTATIVE MEASURES (to keep undamaged from becoming damaged)	
Do not subject material to cutting, drilling, grinding, abrading, or burning. Prevent further damage by protecting from impact or vibration. Minimize entry to area by personnel.	
RESPONSE ACTIONS:	
Follow response action section of the management plan for maintenance activities. Follow response action section of the management plan for renovation and remodeling activities. Follow response action section of the management plan for emergency response procedures.	