

AHERA THREE YEAR RE-INSPECTION LOG



LEA NAME:		Brownsville ISD					
SCHOOL BUILDING NAME:		Brite Elementary School					
ADDRESS:		450 S. Browne Avenue					
DATE:		05-01-2023					
HA No.	Material Type / Description	Material Location	Condition	Friability	Category	Classification	Results
101	12" x 12" Floor Tile with mastic  White Tile W/ Specks	Main Office, Classrooms	Good	Non-Friable	5	Miscellaneous	Presumed ACM
102	12" x 12" Floor Tile with mastic  Multi-Color	100 Wing, Cafeteria, Stage	Good	Non-Friable	5	Miscellaneous	Presumed ACM
103	Marble Floor	Hallways	Good	Non-Friable	5	Miscellaneous	Presumed ACM
104	Blue Carpet	Library, Classrooms	Good	Non-Friable	5	Miscellaneous	Presumed ACM
201	2' x 4' Ceiling Tile  Off White, Medium Fissure Small Holes	Throughout School	Good	Friable	5	Miscellaneous	Presumed ACM
301	Stage Curtains	Cafeteria	Good	Non-Friable	5	Miscellaneous	Presumed ACM
302	Cove Base Brown	Throughout School	Good	Non-Friable	5	Miscellaneous	Presumed ACM
401	Sheet Rock and Joint Compound	Throughout School	Good	Non-Friable	5	Surfacing	Presumed ACM
402	Cinder Block	*No location noted	Good	Non-Friable	5	Surfacing	Non-Asbestos

Category:	1 Damaged/significantly damaged thermal insulation, 2 Damaged friable surfacing 3 Significantly damaged friable surfacing 4 Damaged/Significantly damaged friable miscellaneous 5 Potential for damage 6 Potential for significant damage 7 Remaining ACBM
Inspector Name	Eloy Palacios
Signature:	
Date:	5.31.23
Accreditation:	Asbestos Consultant 105727
<b>PREVENTATIVE MEASURES (to keep undamaged from becoming damaged)</b>	
Do not subject material to cutting, drilling, grinding, abrading, or burning. Prevent further damage by protecting from impact or vibration. Minimize entry to area by personnel.	
<b>RESPONSE ACTIONS:</b>	
Follow response action section of the management plan for maintenance activities. Follow response action section of the management plan for renovation and remodeling activities. Follow response action section of the management plan for emergency response procedures.	