St. Helens School District

Water Testing Results - District Office

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result (ppb)	
Entrance Drinking Fountain	19480000-001DW24A	1/31/2024	ND	
Entrance Bottle Filler	19480000-002WB24A	1/31/2024	ND	
Coffee Maker	19480000-003KF24A	1/31/2024	0.469	
Women's RR Faucet	19480000-004BF24A	1/31/2024	0.407	
Men's RR Faucet	19480000-005BF24A	1/31/2024	ND	
Kitchenet Sink Faucet	19480000-006KF24A	1/31/2024	**31.8**	(temporarily removed from service)
Kitchenet Sink Faucet	19480000-006KF24B	5/3/2024	1.34	(post mitigation)
Kitchen Sink Faucet	19480000-007KF24A	1/31/2024	0.412	