

9800-520 McNair Bus Duct Replacement

RFI #2 2024-05-03

1. Is there Federal Money on this project.

No

2. When will the sign in sheet be out?

5/6/24

3. Liquidated Damages: on page 20 Item #5; It title Liquidated Damages.

No terms; N/A?

Strike N/A as stated in contract.

RFI #1 2024-05-01

1. Do you have a PG&E contact for this project.

Phil Pennino

Brad Joaquin

2. Will there be any PG&E Fee.

We will assume payment of all PG&E fees.

3. Dose the secondary side of the transformer need repair or service.

No

4. Who will dispose of the DOL cable and plywood with support brackets.

The awarded contractor

Also, will the damaged buss duct be disposed of at the same time the same way.

The awarded contractor

9800-520 McNair Bus Duct Replacement

5. Eaton is requesting a significant dollar amount to take official factory measurements of the buss Duct for McNair project.

The awarded contractor will be responsible for the associated cost of maintenance if any.

Has LUSD already had this done once it exploded?

No

Or how was the BOM in the scope of work derived.

The quote was provided by Eaton on the original installation specifications.

6. Prevailing wage; The new rate goes into effect June 1st 2024

That is no problem if project is completed before June 1st 2025

This is the plan. But there was mention on the job walk for school schedule this project would be OK to go into next summer. Except labor rates change on June 1st 2025. Question; Should we have an AlterNet price for the labor rate in June 1st 2025

The buss duct has a 12 week ordering timeline from discussions with Eaton

This project could possibly be scheduled during 6/25 (Summer Break) The bidding contractor will need to determine the price/quote