

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 30 water taps at Burke High School and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example "BHS-WC1" refers to a water cooler at Burke High School, "IM" refers to an ice machine, and "S" refers to a sink. There is a "Key" at the top of the table to explain these abbreviations.

We are pleased to report the results from this testing found that Burke High School's drinking water was at or below the recommended level of 15 parts per billion (ppb) for "first draw" testing in all cases.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at Burke High School. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page ([www.ccsdschools.com/watersampling](http://www.ccsdschools.com/watersampling)). If you have additional questions, you may contact our staff at (843) 566-1835 or [facilities@ccsdschools.com](mailto:facilities@ccsdschools.com).

## Burke HS

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink, WC=Water Cooler

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
BHS-A500-ER1-S51	Clinic	2/15/2020	1.3 ppb					
BHS-A500-ER2-S52	Clinic	2/15/2020	Non-detect					
BHS-A500-I-S.1	Room A127	2/15/2020	Non-detect					
BHS-A500A-S50	Clinic	2/15/2020	2.1 ppb					
BHS-A500K-S55	Work Room Rm A500K	2/15/2020	Non-detect					
BHS-GS16-E-S49	Guidance Office	2/15/2020	1 ppb					
BHS-PR802-IM1	Kitchen	2/15/2020	Non-detect					
BHS-PR802-S.1	Kitchen	2/15/2020	Non-detect					
BHS-PR802-S.2	Kitchen	2/15/2020	1.8 ppb					
BHS-S517-S60	Media Center	2/15/2020	Non-detect					
BHS-WC1	Hallway across from Room C739	2/15/2020	Non-detect					
BHS-WC10	Between restrooms near the Auditorium	2/15/2020	Non-detect					
BHS-WC11	Between restrooms near the Auditorium	2/15/2020	Non-detect					
BHS-WC12	Between restrooms near the Auditorium	2/15/2020	Non-detect					
BHS-WC13	Between restrooms near Room C604	2/15/2020	Non-detect					
BHS-WC14	Between restrooms near Room C604	2/15/2020	Non-detect					
BHS-WC15	Between restrooms near Room C604	2/15/2020	Non-detect					
BHS-WC16	Between restrooms next to Room C632	2/15/2020	Non-detect					
BHS-WC17	Between restrooms next to Room C632	2/15/2020	Non-detect					
BHS-WC18	Between restrooms next to Room C632	2/15/2020	Non-detect					
BHS-WC2	Hallway across from Room C739	2/15/2020	Non-detect					
BHS-WC3	Hallway across from Room A701	2/15/2020	Non-detect					
BHS-WC4	Hallway across from Room A701	2/15/2020	Non-detect					
BHS-WC5	Between restrooms next to Room C510	2/15/2020	Non-detect					
BHS-WC6	Between restrooms next to Room C510	2/15/2020	Non-detect					
BHS-WC6.1	Between restrooms next to Room C510	2/15/2020	Non-detect					
BHS-WC7	Between restrooms across from Room C520	2/15/2020	Non-detect					
BHS-WC8	Between restrooms across from Room C520	2/15/2020	Non-detect					
BHS-WR-369-S152	Teachers' Workroom Rm WR639	2/15/2020	0.69 ppb					
BHS-WR608-S131	Teachers' Workroom Rm WR608	2/15/2020	Non-detect					
BHS-WR614-S142	Teachers' Workroom Rm WR614	2/15/2020	Non-detect					