

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 135 water taps at Carolina Park Elementary School and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example "CPS S-137" refers to a sink at Carolina Park Elementary School, "F" refers to fountain, and "IM" refers to ice machine. There is a "Key" at the top of the table to explain these abbreviations.

We are pleased to report the results from this testing found that Carolina Park Elementary School's drinking water was at or below the recommended level of 15 parts per billion (ppb) for "first draw" testing in all cases.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at Carolina Park Elementary School. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page (www.ccsdschools.com/watersampling). If you have additional questions, you may contact our staff at (843) 566-1835 or facilities@ccsdschools.com.

Carolina Park ES

Notes: Threshold for action is 15 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
CPS-S-133A	Media Center Work Room	2/15/2020	Non-detect					
CPS-S-137	Room 137	2/15/2020	2.1 ppb					
CPS-F-100.1	Hallway across from Room 131	2/15/2020	Non-detect					
CPS-BF-100.1	Hallway across from Room 131	2/15/2020	Non-detect					
CPS-F-100.2	Hallway across from Room 131	2/15/2020	Non-detect					
CPS-S-134.1	Room 134	2/15/2020	Non-detect					
CPS-S-134.2	Room 134	2/15/2020	Non-detect					
CPS-FS-134	Room 134	2/15/2020	Non-detect					
CPS-S-129.1	Room 129	2/15/2020	Non-detect					
CPS-FS-129	Room 129	2/15/2020	Non-detect					
CPS-S-129.2	Room 129	2/15/2020	Non-detect					
CPS-S-132.1	Room 132	2/15/2020	Non-detect					
CPS-FS-132	Room 132	2/15/2020	Non-detect					
CPS-S-132.2	Room 132	2/15/2020	2.3 ppb					
CPS-S-130.1	Room 130	2/15/2020	Non-detect					
CPS-FS-130	Room 130	2/15/2020	Non-detect					
CPS-S-130.2	Room 130	2/15/2020	Non-detect					
CPS-S-127.1	Room 127	2/15/2020	Non-detect					
CPS-S-127.2	Room 127	2/15/2020	Non-detect					
CPS-FS-127	Room 127	2/15/2020	Non-detect					
CPS-S-125.1	Room 125	2/15/2020	Non-detect					
CPS-FS-125	Room 125	2/15/2020	Non-detect					
CPS-S-125.2	Room 125	2/15/2020	Non-detect					
CPS-S-123.1	Room 123	2/15/2020	Non-detect					
CPS-S-123.2	Room 123	2/15/2020	Non-detect					
CPS-FS-123	Room 123	2/15/2020	Non-detect					
CPS-F-100.3	Hallway next to Room 128	2/15/2020	Non-detect					
CPS-F-100.4	Hallway next to Room 128	2/15/2020	Non-detect					
CPS-S-104	Room 104	2/15/2020	Non-detect					
CPS-S-108.2	Room 108	2/15/2020	Non-detect					
CPS-FS-108	Room 108	2/15/2020	Non-detect					
CPS-S-108.3	Room 108	2/15/2020	Non-detect					
CPS-S-108.1	Room 108	2/15/2020	Non-detect					
CPS-S-109.1	Room 109	2/15/2020	Non-detect					
CPS-S-109.2	Room 109	2/15/2020	Non-detect					
CPS-FS-109	Room 109	2/15/2020	Non-detect					
CPS-S-109.3	Room 109	2/15/2020	Non-detect					
CPS-S-111.1	Room 111	2/15/2020	Non-detect					
CPS-S-111.2	Room 111	2/15/2020	Non-detect					
CPS-FS-111	Room 111	2/15/2020	Non-detect					
CPS-S-111.3	Room 111	2/15/2020	Non-detect					
CPS-S-110.1	Room 110	2/15/2020	Non-detect					
CPS-S-110.2	Room 110	2/15/2020	Non-detect					
CPS-FS-110	Room 110	2/15/2020	Non-detect					
CPS-S-110.3	Room 110	2/15/2020	Non-detect					
CPS-S-113.1	Room 113	2/15/2020	Non-detect					
CPS-S-113.2	Room 113	2/15/2020	Non-detect					
CPS-FS-113	Room 113	2/15/2020	Non-detect					
CPS-S-113.3	Room 113	2/15/2020	Non-detect					
CPS-S-112.1	Room 112	2/15/2020	Non-detect					
CPS-S-112.2	Room 112	2/15/2020	Non-detect					
CPS-FS-112	Room 112	2/15/2020	Non-detect					
CPS-S-112.3	Room 112	2/15/2020	Non-detect					
CPS-S-114.1	Room 114	2/15/2020	Non-detect					
CPS-S-114.2	Room 114	2/15/2020	Non-detect					
CPS-FS-114	Room 114	2/15/2020	Non-detect					
CPS-S-114.3	Room 114	2/15/2020	Non-detect					

Carolina Park ES

Notes: Threshold for action is 15 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
CPS-S-115.1	Room 115	2/15/2020	Non-detect					
CPS-S-115.2	Room 115	2/15/2020	Non-detect					
CPS-FS-115	Room 115	2/15/2020	Non-detect					
CPS-S-115.3	Room 115	2/15/2020	Non-detect					
CPS-S-152	Nurse's Office	2/15/2020	Non-detect					
CPS-F-102	Main Office	2/15/2020	Non-detect					
CPS-S-158	Mail Room	2/15/2020	Non-detect					
CPS-S-153.1	Room 153	2/15/2020	1.4 ppb					
CPS-FS-153	Room 153	2/15/2020	Non-detect					
CPS-S-153.2	Room 153	2/15/2020	Non-detect					
CPS-S-155.1	Room 155	2/15/2020	2.1 ppb					
CPS-S-155.2	Room 155	2/15/2020	Non-detect					
CPS-FS-155	Room 155	2/15/2020	Non-detect					
CPS-S-160.1	Room 160	2/15/2020	Non-detect					
CPS-FS-160	Room 160	2/15/2020	Non-detect					
CPS-S-160.2	Room 160	2/15/2020	2.8 ppb					
CPS-S-157.1	Room 157	2/15/2020	Non-detect					
CPS-FS-157	Room 157	2/15/2020	Non-detect					
CPS-S-157.2	Room 157	2/15/2020	Non-detect					
CPS-S-159.1	Room 159	2/15/2020	Non-detect					
CPS-S-159.2	Room 159	2/15/2020	Non-detect					
CPS-FS-159	Room 159	2/15/2020	Non-detect					
CPS-S-164.1	Room 164	2/15/2020	Non-detect					
CPS-FS-164	Room 164	2/15/2020	Non-detect					
CPS-S-164.2	Room 164	2/15/2020	Non-detect					
CPS-S-162.1	Room 162	2/15/2020	Non-detect					
CPS-FS-162	Room 162	2/15/2020	Non-detect					
CPS-S-162.2	Room 162	2/15/2020	Non-detect					
CPS-S-161.1	Room 161	2/15/2020	Non-detect					
CPS-S-161.2	Room 161	2/15/2020	Non-detect					
CPS-FS-161	Room 161	2/15/2020	Non-detect					
CPS-S-166.1	Room 166	2/15/2020	Non-detect					
CPS-S-166.2	Room 166	2/15/2020	Non-detect					
CPS-FS-166	Room 166	2/15/2020	Non-detect					
CPS-S-163	Room 163	2/15/2020	Non-detect					
CPS-CS-172.1	Kitchen	2/15/2020	Non-detect					
CPS-CS-172.2	Kitchen	2/15/2020	Non-detect					
CPS-IM-172	Kitchen	2/15/2020	Non-detect					
CPS-S-172.1	Kitchen	2/15/2020	Non-detect					
CPS-S-172.2	Kitchen	2/15/2020	Non-detect					
CPS-F-172.1	Cafeteria	2/15/2020	Non-detect					
CPS-BF-172.1	Cafeteria	2/15/2020	Non-detect					
CPS-F-172.2	Cafeteria	2/15/2020	Non-detect					
CPS-F-100.5	Hallway across from Room 179	2/15/2020	Non-detect					
CPS-F-100.6	Hallway across from Room 179	2/15/2020	Non-detect					
CPS-F-100.7	Hallway across from Room 179	2/15/2020	Non-detect					
CPS-F-100.8	Hallway next to Room 177	2/15/2020	Non-detect					
CPS-F-100.9	Hallway next to Room 177	2/15/2020	Non-detect					
CPS-F-100.10	Hallway next to Room 177	2/15/2020	Non-detect					
CPS-F-100.11	Hallway next to Room 177	2/15/2020	Non-detect					
CPS-S-178	Room 178	2/15/2020	Non-detect					
CPS-S-128	Room 128	2/15/2020	Non-detect					
CPS-S-226	Room 226	2/15/2020	9.2 ppb					
CPS-S-224	Room 224	2/15/2020	1.2 ppb					
CPS-S-225	Room 225	2/15/2020	Non-detect					
CPS-S-223	Room 223	2/15/2020	1 ppb					
CPS-S-221	Room 221	2/15/2020	Non-detect					

Carolina Park ES

Notes: Threshold for action is 15 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
CPS-S-220	Room 220	2/15/2020	Non-detect					
CPS-S-218	Room 218	2/15/2020	1 ppb					
CPS-S-214	Room 214	2/15/2020	Non-detect					
CPS-S-217	Room 127	2/15/2020	1.2 ppb					
CPS-F-200.1	Hallway across from Room 212	2/15/2020	Non-detect					
CPS-F-200.2	Hallway across from Room 212	2/15/2020	Non-detect					
CPS-F-200.3	Hallway across from Room 212	2/15/2020	Non-detect					
CPS-F-200.4	Hallway across from Room 233	2/15/2020	Non-detect					
CPS-BF-200.4	Hallway across from Room 233	2/15/2020	Non-detect					
CPS-S-233	Room 233	2/22/2020	Non-detect					
CPS-F-200.6	Hallway across from Room 233	2/22/2020	Non-detect					
CPS-F-200.5	Hallway across from Room 233	2/22/2020	Non-detect					
CPS-S-235	Room 235	2/22/2020	Non-detect					
CPS-S-242	Room 242	2/22/2020	Non-detect					
CPS-S-247	Room 247	2/22/2020	Non-detect					
CPS-S-246	Room 246	2/22/2020	Non-detect					
CPS-S-239	Room 239	2/22/2020	Non-detect					
CPS-S-243	Room 243	2/22/2020	Non-detect					
CPS-S-248	Room 248	2/22/2020	Non-detect					
CPS-S-250	Room 250	2/22/2020	Non-detect					
CPS-S-249	Room 249	2/22/2020	1.3 ppb					
CPS-S-236.1	Room 236	2/22/2020	6.6 ppb					
CPS-S-236.2	Room 236	2/22/2020	Non-detect					
CPS-S-236.3	Room 236	2/22/2020	3.7 ppb					
CPS-S-236.4	Room 236	2/22/2020	4.9 ppb					