

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 75 water taps at Harbor View Elementary School and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example "HVE-S10-119" refers to a sink at Harbor View, "F" refers to fountain, and "IM" refers to ice machine. There is a "Key" at the top of the table to explain these abbreviations.

The results from this testing found that Harbor View Elementary School's drinking water was at or below the recommended level of 15 parts per billion (ppb) for "first draw" testing except for one faucet at a sink in room 133. Our staff immediately turned off the faucet. The faucet was retested and found to be below the recommended level following typical use and flushing. Out of an abundance of caution, the faucet was replaced, a filter certified to remove lead was installed, and the water has been turned back on.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at Harbor View Elementary School. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page (www.ccsdschools.com/watersampling). If you have additional questions, you may contact our staff at (843) 566-1835 or facilities@ccsdschools.com.

Harbor View ES

Notes: Threshold for action is 15 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
HVE-F1-H100	Hallway across from Computer Lab first floor	4/9/2020	Non-detect					
HVE-F2-H100	Hallway across from Computer Lab first floor	4/9/2020	Non-detect					
HVE-F3-140	Room 140	4/9/2020	Non-detect					
HVE-F4-140	Room 140	4/9/2020	Non-detect					
HVE-F5-H100	Hallway outside Cafeteria	4/9/2020	Non-detect					
HVE-F6-H100	Hallway outside Cafeteria	4/9/2020	Non-detect					
HVE-F7-H200	Hallway across from Computer Lab second floor	4/9/2020	Non-detect					
HVE-F8-H200	Hallway across from Computer Lab second floor	4/9/2020	Non-detect					
HVE-FS-12-132	Room 132	4/9/2020	Non-detect					
HVE-FS1-106	Room 106	4/9/2020	Non-detect					
HVE-FS10-137	Room 137	4/9/2020	Non-detect					
HVE-FS11-128	Room 128	4/9/2020	Non-detect					
HVE-FS13-157	Room 157	4/9/2020	Non-detect					
HVE-FS14-161	Room 161	4/9/2020	Non-detect					
HVE-FS15-165	Room 165	4/9/2020	Non-detect					
HVE-FS16-174	Room 174	4/9/2020	Non-detect					
HVE-FS17-170	Room 170	4/9/2020	Non-detect					
HVE-FS18-166	Room 166	4/9/2020	Non-detect					
HVE-FS2-112	Room 112	4/9/2020	Non-detect					
HVE-FS3-113	Room 113	4/9/2020	Non-detect					
HVE-FS4-115	Room 115	4/9/2020	Non-detect					
HVE-FS5-119	Room 119	4/9/2020	Non-detect					
HVE-FS6-114	Room 114	4/9/2020	Non-detect					
HVE-FS7-118	Room 118	4/9/2020	Non-detect					
HVE-FS8-129	Room 129	4/9/2020	Non-detect					
HVE-FS9-133	Room 133	4/9/2020	Non-detect					
HVE-IM9-148B	Kitchen	4/9/2020	Non-detect					
HVE-IM5-154	Clinic	4/9/2020	Non-detect					
HVE-S-35-161	Room 161	4/9/2020	Non-detect					
HVE-S1-103B	Media Center Office	4/9/2020	0.70 ppb					
HVE-S10-119	Room 119	4/9/2020	Non-detect					
HVE-S11-114	Room 114	4/9/2020	Non-detect					
HVE-S12-114	Room 114	4/9/2020	Non-detect					
HVE-S13-118	Room 118	4/9/2020	Non-detect					
HVE-S14-118	Room 118	4/9/2020	Non-detect					
HVE-S15-129	Room 129	4/9/2020	Non-detect					
HVE-S16-129	Room 129	4/9/2020	Non-detect					
HVE-S17-133	Room 133	4/9/2020	Non-detect					
HVE-S18-133	Sink in Room 133	4/9/2020	55.9 ppb	Temporarily terminated service	4/23/2020	Non-detect	Non-detect	N/A
HVE-S19-137	Room 137	4/9/2020	Non-detect					
HVE-S2-106	Room 106	4/9/2020	Non-detect					
HVE-S20-128	Room 128	4/9/2020	Non-detect					
HVE-S20-137	Room 137	4/9/2020	Non-detect					
HVE-S21-128	Room 128	4/9/2020	Non-detect					
HVE-S22-132	Room 132	4/9/2020	Non-detect					
HVE-S23-132	Room 132	4/9/2020	Non-detect					
HVE-S24-140	Room 140	4/9/2020	Non-detect					
HVE-S25-148B	Kitchen	4/9/2020	Non-detect					
HVE-S26-148B	Kitchen	4/9/2020	Non-detect					
HVE-S27-148B	Kitchen	4/9/2020	Non-detect					
HVE-S28-152	Clinic	4/9/2020	1.1 ppb					
HVE-S29-154	Clinic	4/9/2020	Non-detect					
HVE-S3-112	Room 112	4/9/2020	Non-detect					
HVE-S30-156	Room 156	4/9/2020	Non-detect					
HVE-S31-102E	Conference Room Main Office	4/9/2020	Non-detect					
HVE-S32-157	Room 157	4/9/2020	Non-detect					
HVE-S33-157	Room 157	4/9/2020	0.70 ppb					
HVE-S34-161	Room 161	4/9/2020	Non-detect					
HVE-S36-165	Room 165	4/9/2020	<0.64 ppb					
HVE-S37-165	Room 165	4/9/2020	<0.64 ppb					
HVE-S38-174	Room 174	4/9/2020	Non-detect					
HVE-S39-174	Room 174	4/9/2020	4.0 ppb					
HVE-S4-113	Room 113	4/9/2020	Non-detect					
HVE-S40-170	Room 170	4/9/2020	Non-detect					
HVE-S41-170	Room 170	4/9/2020	Non-detect					
HVE-S42-166	Room 166	4/9/2020	0.76 ppb					
HVE-S43-166	Room 166	4/9/2020	Non-detect					
HVE-S44-202	Room 202	4/9/2020	2.3 ppb					
HVE-S45-202	Room 202	4/9/2020	2.4 ppb					
HVE-S46-202	Room 202	4/9/2020	1.8 ppb					
HVE-S47-202	Room 202	4/9/2020	1.4 ppb					
HVE-S48-217	Room 217	4/9/2020	0.72 ppb					
HVE-S5-113	Room 113	4/9/2020	Non-detect					
HVE-S53-112	Room 112	4/9/2020	Non-detect					
HVE-S54-123A	Room 123A Teacher Workroom	4/9/2020	0.65 ppb					

Harbor View ES

Notes: Threshold for action is 15 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
HVE-S6-113	Room 113	4/9/2020	Non-detect					
HVE-S7-115	Room 115	4/9/2020	Non-detect					
HVE-S8-115	Room 115	4/9/2020	Non-detect					
HVE-S9-119	Room 119	4/9/2020	Non-detect					