

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 60 water taps at Lambs Elementary School and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example “LMB-S-8” refers to a sink at Lambs Elementary School, “F” refers to fountain, and “IM” refers to ice machine. There is a “Key” at the top of the table to explain these abbreviations.

We are pleased to report the results from this testing found that Lambs Elementary School’s drinking water was at or below the recommended level of 15 parts per billion (ppb) for “first draw” testing in all cases.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at Lambs Elementary School. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page ([www.ccsdschools.com/watersampling](http://www.ccsdschools.com/watersampling)). If you have additional questions, you may contact our staff at (843) 566-1835 or [facilities@ccsdschools.com](mailto:facilities@ccsdschools.com).

## Lambs ES

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
LMB-S-8	Room 213	11/2/19	Non-detect					
LMB-S-10	Room 112	11/2/19	Non-detect					
LMB-S-11	Clinic	11/2/19	Non-detect					
LMB-S-13	Room 123	11/2/19	Non-detect					
LMB-S-14	Room 123	11/2/19	Non-detect					
LMB-S-21	Room 310 Media Center	11/2/19	5.98 ppb					
LMB-S-24	Room 315	11/2/19	10.7 ppb					
LMB-S-25	Room 315	11/2/19	7.62 ppb					
LMB-S-26	Room 315	11/2/19	4.63 ppb					
LMB-S-27	Room 315	11/2/19	8.95 ppb					
LMB-S-28	Room 315	11/2/19	9.14 ppb					
LMB-S-29	Room 315	11/2/19	3.98 ppb					
LMB-S-30	Room 315	11/2/19	4.89 ppb					
LMB-S-45	Room 108	11/2/19	6.4 ppb					
LMB-S-46	Room 100	11/2/19	3.76 ppb					
LMB-S-47	Room 104	11/2/19	8.43 ppb					
LMB-S-48	Room 107	11/2/19	4.34 ppb					
LMB-S-49	Room 109	11/2/19	5.79 ppb					
LMB-F-1.1	Hallway across from Guidance Room	11/2/19	Non-detect					
LMB-F-1.2	Hallway across from Guidance Room	11/2/19	Non-detect					
LMB-F-2.1	Hallway across from Room 207	11/2/19	1.28 ppb					
LMB-F-2.2	Hallway across from Room 207	11/2/19	Non-detect					
LMB-F-2.3	Hallway across from Room 207	11/2/19	Non-detect					
LMB-F-3.1	Hallway across from Room 120	11/2/19	Non-detect					
LMB-F-3.2	Hallway across from Room 120	11/2/19	Non-detect					
LMB-F-3.3	Hallway across from Room 120	11/2/19	Non-detect					
LMB-F-4.1	Hallway across from Clinic	11/2/19	0.622 ppb					
LMB-F-4.2	Hallway across from Clinic	11/2/19	Non-detect					
LMB-F-5.1	Hallway across from Room 318	11/2/19	Non-detect					
LMB-F-5.2	Hallway across from Room 318	11/2/19	Non-detect					
LMB-F-5.3	Hallway across from Room 318	11/2/19	Non-detect					
LMB-F-6.1	Hallway adjacent to Room 325	11/2/19	Non-detect					
LMB-F-6.2	Hallway adjacent to Room 325	11/2/19	Non-detect					
LMB-F-7.1	Hallway across from Room 111	11/2/19	0.658 ppb					
LMB-F-7.2	Hallway across from Room 111	11/2/19	0.778 ppb					
LMB-FS-1F	Room 110	11/2/19	4.72 ppb					
LMB-FS-1S	Room 110	11/2/19	5.09 ppb					
LMB-FS-2F	Room 108	11/2/19	0.583 ppb					
LMB-FS-2S	Room 108	11/2/19	1.93 ppb					
LMB-FS-3F	Room 106	11/2/19	3.3 ppb					
LMB-FS-3S	Room 106	11/2/19	7.33 ppb					
LMB-FS-4F	Room 105	11/2/19	2.54 ppb					
LMB-FS-4S	Room 105	11/2/19	7.1 ppb					
LMB-FS-5F	Room 103	11/2/19	3.86 ppb					
LMB-FS-5S	Room 103	11/2/19	3.38 ppb					
LMB-FS-6F	Room 101	11/2/19	2.61 ppb					
LMB-FS-6S	Room 101	11/2/19	2.63 ppb					
LMB-FS-7F	Room 100	11/2/19	2.54 ppb					
LMB-FS-7S	Room 100	11/2/19	3.41 ppb					
LMB-FS-8F	Room 107	11/2/19	2.96 ppb					
LMB-FS-8S	Room 107	11/2/19	4.29 ppb					
LMB-FS-9F	Room 109	11/2/19	2.47 ppb					
LMB-FS-9S	Room 109	11/2/19	6.89 ppb					
LMB-FS-10F	Room 111	11/2/19	5.96 ppb					
LMB-FS-10S	Room 111	11/2/19	7.77 ppb					
LMB-FS-11F	Room 113	11/2/19	4.19 ppb					
LMB-FS-11S	Room 113	11/2/19	4.56 ppb					

## Lambs ES

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
LMB-IM-1	Room 213	11/2/19	0.787 ppb					
LMB-IM-2	Kitchen	11/2/19	Non-detect					
LMB-2CS	Kitchen Sanitizer	11/2/19	2.93 ppb					
LMB-3CS	Kitchen Pre-prep	11/2/19	2.64 ppb					