

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 85 water taps at North Charleston Creative Arts and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example "NCCA-F-186.3" refers to a fountain in the dining hall at North Charleston Creative Arts, "IM" refers to an ice machine, and "S" refers to a sink. There is a "Key" at the top of the table to explain these abbreviations.

We are pleased to report the results from this testing found that North Charleston Creative Art's drinking water was at or below the recommended level of 15 parts per billion (ppb) for "first draw" testing in all cases.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at North Charleston Creative Arts. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page ([www.ccsdschools.com/watersampling](http://www.ccsdschools.com/watersampling)). If you have additional questions, you may contact our staff at (843) 566-1835 or [facilities@ccsdschools.com](mailto:facilities@ccsdschools.com).

## North Charleston Creative Arts ES

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
NCCA-S-185D.1	Work Room 191B	5/7/20	non-detect					
NCCA-F-186.1	Multi Prpose Room	5/7/20	non-detect					
NCCA-F-186.2	Multi Prpose Room	5/7/20	non-detect					
NCCA-F-186.3	Dining Hall	5/7/20	non-detect					
NCCA-F-186.4	Dining Hall	5/7/20	non-detect					
NCCA-S-197B.1	Kitchen	5/7/20	non-detect					
NCCA-IM-197B.1	Kitchen	5/7/20	2					
NCCA-F-100.1	Dining Hall Hallway	5/7/20	non-detect					
NCCA-F-100.2	Dining Hall Hallway	5/7/20	non-detect					
NCCA-FS-181.1	Room 181	5/7/20	non-detect					
NCCA-FS-181.2	Room 182	5/7/20	non-detect					
NCCA-S-181.1	Room 181	5/7/20	non-detect					
NCCA-FS-182.1	Room 182	5/7/20	non-detect					
NCCA-FS-182.2	Room 182	5/7/20	non-detect					
NCCA-S-182.1	Room 182	5/7/20	non-detect					
NCCA-S-178.1	Room 178	5/7/20	non-detect					
NCCA-FS-178.1	Room 178	5/7/20	non-detect					
NCCA-FS-178.2	Room 178	5/7/20	non-detect					
NCCA-S-179.1	Room 179	5/7/20	non-detect					
NCCA-FS-179.1	Room 179	5/7/20	non-detect					
NCCA-FS-179.2	Room 179	5/7/20	non-detect					
NCCA-FS-176.1	Room 176	5/7/20	non-detect					
NCCA-FS-176.2	Room 176	5/7/20	non-detect					
NCCA-S-176.1	Room 176	5/7/20	non-detect					
NCCA-S-171.1	Room 171	5/7/20	non-detect					
NCCA-S-109A.1	Volunteer Room 109	5/7/20	non-detect					
NCCA-S-107T.1	Clinic	5/7/20	non-detect					
NCCA-S-107.1	Clinic	5/7/20	non-detect					
NCCA-IM-107.1	Clinic	5/7/20	2.7					
NCCA-S-101.1	Room 101	5/7/20	non-detect					
NCCA-S-104.1	Mailroom 104	5/7/20	non-detect					
NCCA-IM-104.1	Mailroom 104	5/7/20	4.9					
NCCA-IM-104.2	Mailroom 104	5/7/20	3.9					
NCCA-S-145.1	Room 145	5/7/20	non-detect					
NCCA-FS-145.1	Room 145	5/7/20	non-detect					
NCCA-FS-145.2	Room 145	5/7/20	non-detect					
NCCA-FS-146.1	Room 146	5/7/20	non-detect					
NCCA-FS-146.2	Room 146	5/7/20	non-detect					
NCCA-S-146.1	Room 146	5/7/20	non-detect					
NCCA-FS-147.1	Room 147	5/7/20	non-detect					
NCCA-FS-147.2	Room 147	5/7/20	non-detect					
NCCA-S-147.1	Room 147	5/7/20	non-detect					
NCCA-S-151.1	Room 151	5/7/20	non-detect					
NCCA-FS-151.1	Room 151	5/7/20	non-detect					
NCCA-FS-151.2	Room 151	5/7/20	non-detect					
NCCA-S-148.1	Room 148	5/7/20	non-detect					
NCCA-FS-148.1	Room 148	5/7/20	non-detect					
NCCA-FS-148.2	Room 148	5/7/20	non-detect					
NCCA-S-154.1	Room 154	5/7/20	non-detect					
NCCA-FS-154.1	Room 154	5/7/20	non-detect					
NCCA-FS-154.2	Room 154	5/7/20	non-detect					
NCCA-S-156.1	Room 156	5/7/20	non-detect					
NCCA-FS-156.2	Room 156	5/7/20	non-detect					
NCCA-S-156.1	Room 156	5/7/20	non-detect					
NCCA-S-158A.1	Room 158	5/7/20	non-detect					
NCCA-FS-162.1	Room 162	5/7/20	non-detect					
NCCA-FS-162.2	Room 162	5/7/20	non-detect					
NCCA-S-162.1	Room 162	5/7/20	non-detect					
NCCA-S-163.1	Room 163	5/7/20	non-detect					
NCCA-S-164.1	Room 164	5/7/20	non-detect					
NCCA-FS-164.1	Room 164	5/7/20	non-detect					



## North Charleston Creative Arts ES

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
NCCA-FS-164.2	Room 164	5/7/20	non-detect					
NCCA-FS-165.1	Room 165	5/7/20	non-detect					
NCCA-FS-165.2	Room 165	5/7/20	non-detect					
NCCA-S-165.1	Room 165	5/7/20	non-detect					
NCCA-F-CR120.1	Near Mens RR outside of Room 126	5/7/20	non-detect					
NCCA-F-CR120.2	Near Mens RR outside of Room 126	5/7/20	non-detect					
NCCA-F-CR120.3	Near Womens RR Outside of Room 129	5/7/20	non-detect					
NCCA-F-CR120.4	Near Womens RR Outside of Room 129	5/7/20	non-detect					
NCCA-S-239.1	Room 239	5/7/20	non-detect					
NCCA-S-235.1	Room 235	5/7/20	non-detect					
NCCA-S-233.1	Room 233	5/7/20	non-detect					
NCCA-S-224.1	Room 224	5/7/20	non-detect					
NCCA-F-200.2	Hallway Outside of Room 212	5/7/20	non-detect					
NCCA-S-250.1	Room 250	5/7/20	non-detect					
NCCA-S-212.1	Room 212	5/7/20	non-detect					
NCCA-S-209.1	Room 209	5/7/20	non-detect					
NCCA-F-200.1	Hallway Outside of Room 212	5/7/20	non-detect					
NCCA-S-202.1	Room 202	5/7/20	non-detect					
NCCA-S-241.1	Room 41	5/7/20	non-detect					
NCCA-S-200S.1	Work Room Off of Room 200	5/7/20	non-detect					
NCCA-F-200.3	Hallway Outside of Room 241	5/7/20	non-detect					
NCCA-S-210.1	Room 210	5/7/20	non-detect					
NCCA-S-200.1	Work Room 209	5/7/20	non-detect					
NCCA-S-245.1	Room 245	5/7/20	non-detect					
NCCA-S-248.1	Room 248	5/7/20	5.3					
NCCA-F-200.4	Hallway Outside of Room 241	5/7/20	non-detect					
NCCA-S-254.1	Room 254	5/7/20	non-detect					