



3/15/2017 12:13

Kingsway Regional School District
213 Kings Highway
Woolwich, NJ 08085
Attn: Larry

Sample # Q1181
Sample Received: 3/5/17
Sampled by: Kingsway Regional SD

Kingsway Regional Middle School

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/(ppm) unless otherwise noted

Sample #	Sample Location	Date/Time Sampled	FD / FL	Lead Results mg/L	Date/Time Analyzed
Q1181-1	01-KMS-FP-N-Kitchen	3/5/2017 8:46	FD	0.0051	3/7/17 10:15
Q1181-2	02-KMS-FP-E-Kitchen	3/5/2017 8:46	FD	0.005	3/7/17 10:18
Q1181-3	03-KMS-FP-S-Kitchen	3/5/2017 8:47	FD	0.0214	3/7/17 10:22
Q1181-4	04-KMS-IM-Kitchen	3/5/2017 8:48	FD	<0.002	3/7/17 10:25
Q1181-5	05-KMS-CT-FacilityOR	3/5/2017 8:53	FD	<0.002	3/7/17 10:27
Q1181-6	06-KMS-WC-CWing1	3/5/2017 8:58	FD	<0.002	3/7/17 10:32
Q1181-7	07-KMS-WC-CWing2	3/5/2017 8:59	FD	<0.002	3/7/17 10:58
Q1181-8	08-KMS-TL-RmC1/C2	3/5/2017 9:02	FD	0.0033	3/7/17 11:01
Q1181-9	09-KMS-WC-EWing1	3/5/2017 9:10	FD	<0.002	3/7/17 11:05
Q1181-10	10-KMS-WC-EWing2	3/5/2017 9:10	FD	<0.002	3/7/17 11:08
Q1181-11	11-KMS-WC-EWing3	3/5/2017 9:10	FD	<0.002	3/7/17 11:12
Q1181-12	12-KMS-WC-EWing4	3/5/2017 9:11	FD	<0.002	3/7/17 11:16
Q1181-13	13-KMS-WC-EGLR1	3/5/2017 9:13	FD	<0.002	3/7/17 11:19
Q1181-14	14-KMS-WC-EGLR2	3/5/2017 9:13	FD	<0.002	3/7/17 11:23
Q1181-15	15-KMS-WC-EBLR1	3/5/2017 9:16	FD	<0.002	3/7/17 11:27
Q1181-16	16-KMS-WC-EBLR2	3/5/2017 9:17	FD	<0.002	3/7/17 11:30
Q1181-17	17-KMS-WC-WGLob1	3/5/2017 9:20	FD	<0.002	3/7/17 14:13
Q1181-18	18-KMS-WC-WGLob2	3/5/2017 9:20	FD	<0.002	3/7/17 14:17
Q1181-19	19-KMS-WC-WGCor1	3/5/2017 9:24	FD	<0.002	3/7/17 14:20
Q1181-20	20-KMS-WC-WGCor2	3/5/2017 9:24	FD	<0.002	3/7/17 14:24
Q1181-21	21-KMS-WC-BWing1	3/5/2017 9:27	FD	<0.002	3/7/17 14:27
Q1181-22	22-KMS-WC-BWing2	3/5/2017 9:27	FD	<0.002	3/7/17 14:31
Q1181-23	23-KMS-EC-RME01-1	3/5/2017 9:31	FD	<0.002	3/7/17 14:34
Q1181-24	24-KMS-EC-RME01-2	3/5/2017 9:31	FD	<0.002	3/7/17 14:38
Q1181-25	25-KMS-NS-Faucet	3/5/2017 9:35	FD	<0.002	3/7/17 14:42
Q1181-26	26-KMS-TL-MediaCtr	3/5/2017 9:40	FD	0.0162	3/7/17 14:45
Q1181-27	27-KMS-TL-MainOfc	3/5/2017 9:44	FD	0.003	3/7/17 15:10
Q1181-28	28-KMS-WC-AWing1	3/5/2017 9:48	FD	<0.002	3/7/17 15:14
Q1181-29	29-KMS-WC-AWing2	3/5/2017 9:49	FD	<0.002	3/7/17 15:18

Note: FD represents First Draw and FL represents Flushed sample


Latish Menghani
Laboratory Director