

Oak Grove Elementary School

Lead Tests - Oak Grove Elementary School - Main Building - # 20480800

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480800-001BF	20480800-001BF22A	North Side of Kitchen Men's Restroom - Sink (Left)	09/22/21	4.2	None.
2	20480800-002BF	20480800-002BF22A	North Side of Kitchen Men's Restroom - Sink (Right)	09/22/21	5.1	None.
3	20480800-003BF	20480800-003BF22A	North Side of Kitchen Women's Restroom - Sink (Left)	09/22/21	2.9	None.
4	20480800-004BF	20480800-004BF22A	North Side of Kitchen Women's Restroom - Sink (Right)	05/01/24	ND	None.
5	20480800-005DW	20480800-005DW22A	North Side of Kitchen - Drinking Fountain (Outside)	09/22/21	1.3	None.
	20480800-006DW	20480800-006DW22A	East Side of Kitchen - Portable Drinking Fountain (Outside)	07/21/16	9.6	Removed from site 09/24/21.
	20480800-007BF	20480800-007BF22A	Inside Kitchen Unisex Restroom (East) (Now Storage) - Sink	10/15/21	11.4	"Non-Potable Water" Sign Installed 23 Jan 2020. Disconnected May 2022.
8	20480800-008KF	20480800-008KF22A	Kitchen - Sink (Food Prep - Triple Sink)	12/22/21	ND	Sink does not have a shut off so it is problematic to work on.
9	20480800-009KF	20480800-009KF22A	Kitchen - Sink (Food Prep - Island)	09/22/21	1.4	None.
10	20480800-010KF	20480800-010KF22A	Kitchen - Sink (Pre-rinse/Dishwasher)	09/22/21	6.2	None.
	20480800-061KF	20480800-061KF22A	Kitchen - Hood Faucet			Discovered 5/9/2022 by Gary. Removed Fall 2022.
11	20480800-011OT	20480800-011OT22A	Office C - Utility Sink	09/22/21	2.5	New sink installed in Aug 2021.
12	20480800-012DW	20480800-012DW22A	Cafeteria - Drinking Fountain	09/22/21	1.0	This drinking fountain has a sediment filter on it. Shared?
13	20480800-013WB	20480800-013WB22A	Cafeteria - Bottle Filler	09/22/21	1.4	This drinking fountain has a sediment filter on it. Shared?
14	20480800-014NS	20480800-014NS22A	Health Room - Sink	09/22/21	4.1	None.
15	20480800-015BF	20480800-015BF22A	Health Room - Unisex Restroom - Sink	09/22/21	2.0	None.
16	20480800-016BF	20480800-016BF22A	Staff Work Room - Unisex Restroom - Sink	09/22/21	1.6	None.
17	20480800-017SF	20480800-017SF22A	Staff Break Room - Sink	09/22/21	0.8	None.
18	20480800-018SF	20480800-018SF22A	Staff Break Room - Insta Hot	09/22/21	0.2	None.
19	20480800-019DW	20480800-019DW22A	Multipurpose Room - Drinking Fountain	09/22/21	1.8	None.
20	20480800-020CF	20480800-020CF22A	Multipurpose Room - Sink	09/22/21	1.3	None.
21	20480800-021OT	20480800-021OT22A	South of Office Behind Sliding Door - Sink	09/22/21	3.6	None.
22	20480800-022BF	20480800-022BF22A	Girl's Restroom Near Multipurpose Room - Sink (Left)	09/22/21	4.7	None.
23	20480800-023BF	20480800-023BF22A	Girl's Restroom Near Multipurpose Room - Sink (Right)	09/22/21	3.7	None.
24	20480800-024BF	20480800-024BF22A	Boy's Restroom Near Multipurpose Room - Sink (Left)	09/22/21	1.3	None.
25	20480800-025BF	20480800-025BF22A	Boy's Restroom Near Multipurpose Room - Sink (Right)	09/22/21	2.1	None.
26	20480800-026WB	20480800-026WB22A	Gym Entrance - Bottle Filler (Upper)	05/18/23	ND	02/21/2023 - Installed Elkay Bottle Filler Unit with Filter.
27	20480800-027DW	20480800-027DW22A	Gym Entrance - Drinking Fountain (Lower)	05/18/23	ND	02/21/2023 - Installed Elkay Bottle Filler Unit with Filter.
28	20480800-028BF	20480800-028BF22A	Media Center Unisex Restroom - Sink	09/22/21	3.2	None.
29	20480800-029BF	20480800-029BF22A	Near Room 1 Men's Restroom - Sink (1) L	09/22/21	4.5	None.
30	20480800-030BF	20480800-030BF22A	Near Room 1 Men's Restroom - Sink (2) M	09/22/21	6.8	None.
31	20480800-031BF	20480800-031BF22A	Near Room 1 Men's Restroom - Sink (3) R	09/22/21	5.6	None.
32	20480800-032BF	20480800-032BF22A	Near Room 1 Women's Restroom - Sink (1) L	09/22/21	3.9	None.
33	20480800-033BF	20480800-033BF22A	Near Room 1 Women's Restroom - Sink (2) M	09/22/21	4.8	None.
34	20480800-034BF	20480800-034BF22A	Near Room 1 Women's Restroom - Sink (3) R	09/22/21	4.7	None.
35	20480800-035DW	20480800-035DW22A	Near Room 1 / Women's Restroom - Drinking Fountain	09/22/21	1.2	None.
36	20480800-036DW	20480800-036DW22A	Room 1 - Drinking Fountain	09/22/21	3.7	None.
37	20480800-037CF	20480800-037CF22A	Room 1 - Sink	09/22/21	1.9	None.
38	20480800-038DW	20480800-038DW22A	Room 2 - Drinking Fountain	09/22/21	3.1	None.
39	20480800-039CF	20480800-039CF22A	Room 2 - Sink	09/22/21	2.8	None.
40	20480800-040DW	20480800-040DW22A	Room 3 - Drinking Fountain	09/22/21	5.7	None.
41	20480800-041CF	20480800-041CF22A	Room 3 - Sink	09/22/21	4.0	None.
42	20480800-042DW	20480800-042DW22A	Room 4 - Drinking Fountain	09/22/21	4.2	None.
43	20480800-043CF	20480800-043CF22A	Room 4 - Sink	09/22/21	2.4	None.
44	20480800-044DW	20480800-044DW22A	Room 6 - Drinking Fountain	09/22/21	5.1	None.
45	20480800-045CF	20480800-045CF22A	Room 6 - Sink	09/22/21	5.1	None.
46	20480800-046BF	20480800-046BF22A	Outside Room 6 Staff Unisex Restroom - Sink	09/22/21	ND	None.
47	20480800-047DW	20480800-047DW22A	Room 7 - Drinking Fountain	11/18/21	2.7	None.
48	20480800-048CF	20480800-048CF22A	Room 7 - Sink	09/22/21	2.1	None.
49	20480800-049DW	20480800-049DW22A	Room 8 - Drinking Fountain	09/22/21	5.3	None.
50	20480800-050CF	20480800-050CF22A	Room 8 - Sink	09/22/21	1.4	None.
51	20480800-051DW	20480800-051DW22A	Room 9 - Drinking Fountain	09/22/21	4.4	None.
52	20480800-052CF	20480800-052CF22A	Room 9 - Sink	09/22/21	1.3	None.
53	20480800-053DW	20480800-053DW22A	Room 10 - Drinking Fountain	09/22/21	4.1	None.
54	20480800-054CF	20480800-054CF22A	Room 10 - Sink	09/22/21	1.4	None.
55	20480800-055BF	20480800-055BF22A	Near Room 10 Girl's Restroom - Sink (Left)	09/22/21	4.7	None.
56	20480800-056BF	20480800-056BF22A	Near Room 10 Girl's Restroom - Sink (Right)	09/22/21	4.2	None.
57	20480800-057BF	20480800-057BF22A	Near Room 10 Boy's Restroom - Sink (Left)	09/22/21	2.5	None.
58	20480800-058BF	20480800-058BF22A	Near Room 10 Boy's Restroom - Sink (Right)	09/22/21	5.1	None.
59	20480800-059KF	20480800-059KF22A	Inside Kitchen Unisex Restroom (West) - Sink	10/15/21	13.8	"Non-Potable Water" Sign Installed 23 Jan 2020. Sign Removed 05/05/2022.
60	20480800-060KF	20480800-060KF22A	Kitchen - Sink (Hand Wash)	09/22/21	10.8	"Non-Potable Water" Sign Installed 23 Jan 2020. Sign Removed 05/05/2022.

Lead Tests - Oak Grove Elementary School - North Wing - # 20480801

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480801-001DW	20480801-001DW22A	Room 18 - Drinking Fountain	09/22/21	0.1	None.

2	20480801-002CF	20480801-002CF22A	Room 18 - Sink	09/22/21	1.9	None.
3	20480801-003DW	20480801-003DW22A	Room 19 - Drinking Fountain	09/22/21	0.8	None.
4	20480801-004CF	20480801-004CF22A	Room 19 - Sink	09/22/21	1.8	None.
5	20480801-005DW	20480801-005DW22A	Room 20 - Drinking Fountain	09/22/21	0.6	None.
6	20480801-006CF	20480801-006CF22A	Room 20 - Sink	09/22/21	1.3	None.
7	20480801-007DW	20480801-007DW22A	Room 21 - Drinking Fountain	09/22/21	1.5	None.
8	20480801-008CF	20480801-008CF22A	Room 21 - Sink	09/22/21	2.3	None.
9	20480801-009DW	20480801-009DW22A	Room 22 - Drinking Fountain	09/22/21	ND	None.
10	20480801-010CF	20480801-010CF22A	Room 22 - Sink	09/22/21	0.8	None.
11	20480801-011DW	20480801-011DW22A	Room 23 - Drinking Fountain	09/22/21	ND	None.
12	20480801-012CF	20480801-012CF22A	Room 23 - Sink	09/22/21	1.5	None.
13	20480801-013DW	20480801-013DW22A	Room 24 - Drinking Fountain	09/22/21	1.9	None.
14	20480801-014CF	20480801-014CF22A	Room 24 - Sink	09/22/21	2.6	None.
15	20480801-015DW	20480801-015DW22A	Room 25 - Drinking Fountain	09/22/21	0.9	None.
16	20480801-016CF	20480801-016CF22A	Room 25 - Sink	09/22/21	2.1	None.
17	20480801-017DW	20480801-017DW22A	Room 26 - Drinking Fountain	09/22/21	0.9	None.
18	20480801-018CF	20480801-018CF22A	Room 26 - Sink	09/22/21	1.9	None.
19	20480801-019BF	20480801-019BF22A	Outside Room 26 Boy's Restroom - Sink (1) North	09/22/21	6.6	None.
20	20480801-020BF	20480801-020BF22A	Outside Room 26 Boy's Restroom - Sink (2)	09/22/21	2.1	None.
21	20480801-021BF	20480801-021BF22A	Outside Room 26 Boy's Restroom - Sink (3)	09/22/21	3.2	None.
22	20480801-022BF	20480801-022BF22A	Outside Room 26 Boy's Restroom - Sink (4)	09/22/21	7.2	None.
23	20480801-023BF	20480801-023BF22A	Outside Room 26 Boy's Restroom - Sink (5)	09/22/21	ND	None.
24	20480801-024BF	20480801-024BF22A	Outside Room 26 Boy's Restroom - Sink (6)	09/22/21	1.6	None.
25	20480801-025BF	20480801-025BF22A	Outside Room 26 Boy's Restroom - Sink (7)	09/22/21	6.0	None.
26	20480801-026BF	20480801-026BF22A	Outside Room 26 Boy's Restroom - Sink (8)	09/22/21	7.3	None.
27	20480801-027BF	20480801-027BF22A	Outside Room 26 Boy's Restroom - Sink (9) South	09/22/21	3.4	None.
28	20480801-028BF	20480801-028BF22A	Outside Room 26 Women's Restroom - Sink (1) North	09/22/21	2.6	None.
29	20480801-029BF	20480801-029BF22A	Outside Room 26 Women's Restroom - Sink (2)	09/22/21	2.6	None.
30	20480801-030BF	20480801-030BF22A	Outside Room 26 Women's Restroom - Sink (3)	09/22/21	4.9	None.
31	20480801-031BF	20480801-031BF22A	Outside Room 26 Women's Restroom - Sink (4)	09/22/21	3.6	None.
32	20480801-032BF	20480801-032BF22A	Outside Room 26 Women's Restroom - Sink (5)	09/22/21	3.6	None.
33	20480801-033BF	20480801-033BF22A	Outside Room 26 Women's Restroom - Sink (6)	12/21/21	ND	None.
34	20480801-034BF	20480801-034BF22A	Outside Room 26 Women's Restroom - Sink (7)	09/22/21	1.7	None.
35	20480801-035BF	20480801-035BF22A	Outside Room 26 Women's Restroom - Sink (8)	09/22/21	5.8	None.
36	20480801-036BF	20480801-036BF22A	Outside Room 26 Women's Restroom - Sink (9) South	09/22/21	7.2	None.

Lead Tests - Oak Grove Elementary School - West Wing - # 20480802

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480802-001DW	20480802-001DW22A	Room 14 - Drinking Fountain	09/22/21	1.1	None.
2	20480802-002CF	20480802-002CF22A	Room 14 - Sink	09/22/21	1.1	None.
3	20480802-003DW	20480802-003DW22A	Room 15 - Drinking Fountain	09/22/21	1.3	None.
4	20480802-004CF	20480802-004CF22A	Room 15 - Sink	09/22/21	1.2	None.
5	20480802-005DW	20480802-005DW22A	Room 16 - Drinking Fountain	09/22/21	1.0	None.
6	20480802-006CF	20480802-006CF22A	Room 16 - Sink	09/22/21	0.6	None.
7	20480802-007DW	20480802-007DW22A	Room 17 - Drinking Fountain	09/22/21	0.7	None.
8	20480802-008CF	20480802-008CF22A	Room 17 - Sink	09/22/21	ND	None.

Lead Tests - Oak Grove Elementary School - Central Wing - # 20480803

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480803-001DW	20480803-001DW22A	Room 11 - Drinking Fountain	09/22/21	2.6	None.
2	20480803-002CF	20480803-002CF22A	Room 11 - Sink	09/22/21	5.3	None.
3	20480803-003DW	20480803-003DW22A	Room 12 - Drinking Fountain	09/22/21	4.0	None.
4	20480803-004CF	20480803-004CF22A	Room 12 - Sink	09/22/21	2.4	None.
5	20480803-005DW	20480803-005DW22A	Room 13 - Drinking Fountain	09/22/21	7.5	None.
6	20480803-006CF	20480803-006CF22A	Room 13 - Sink	09/22/21	4.0	None.

Lead Tests - Oak Grove Elementary School - Modular - # 20480804

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480804-001NS	20480804-001NS22A	La Clinica Exam Room # 1 - Sink	09/22/21	2.1	None.
2	20480804-002NS	20480804-002NS22A	La Clinica Exam Room # 2 - Sink	09/22/21	3.0	None.
3	20480804-003NS	20480804-003NS22A	La Clinica Lab Room - Sink	09/22/21	2.3	None.
4	20480804-004BF	20480804-004BF22A	La Clinica Restroom - Sink	09/22/21	2.2	None.

*None Detected (ND) = 0.515 Or Less PPB

Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.