

UC LABORATORY  
PO BOX 551  
JANESVILLE, MN 56048

## Laboratory Results

PHONE- (507)234-5835

REPORT TO: Jill Courtney  
220 17th Ave NE  
Waseca, MN 56093

Date Received: 6/21/2018 13:35  
Date Printed: 7/5/2018  
As Received Temperature: 7 Deg C

Client: Team Academy

### Laboratory Report # 43263.341

ANALYSES	Sample ID	Result	Units	Method	RL	Date/Time Sampled	Date/Time Analyzed	Lab #	Analyst
Lead	Fruit/Veggie Sink	< 1.0	ug/L	EPA 200.8	1.0	6/21/18 8:00	6/27/18 23:58	43263.341	TestAmerica

The as received temperature did not meet thermal preservation requirements as described by NELAP (TNI Standard EL-V1M4-2009, 1.7.5)

The sample(s) was sampled by the client.

Current state and federal guidelines call for a maximum amount of lead in drinking water of 15 ug/L.

TestAmerica, 10 Hazelwood Dr, Amherst, NY 14228-2298 (MDH Lab ID 036-999-337).

This report contains data that were produced by a subcontracted laboratory certified for the fields of testing performed.

Approved by \_\_\_\_\_

*JK*

7/5/2018



This report cannot be reproduced, except in full, without written approval from UC Laboratory.  
The results in this report apply to the samples analyzed in accordance with the Chain-of-Custody record.

UC Laboratory certifies that the test results meet all of the requirements of NELAC.

Unless otherwise noted in the report, the sample conditions at time of receipt met the laboratory's acceptance policy and regulatory requirements.

Your contact person is Amy Schreder

IA Certification # 180 MN Certification # 027-161-186 EPA ID # MN00068