

December 14, 2020

Kevin Storszberg
Whitesboro Central School District
65 Oriskany Boulevard
Suite 1
Whitesboro, NY 13492

RE: Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Dear Kevin Storszberg:

Enclosed are the analytical results for sample(s) received by the laboratory on December 03, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Brian Bellair, Whitesboro Central School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS1		Lab ID: 70155659001	Collected: 11/25/20 06:58	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS3		Lab ID: 70155659002	Collected: 11/25/20 06:59	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 16:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS6		Lab ID: 70155659003	Collected: 11/25/20 07:01	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS8		Lab ID: 70155659004	Collected: 11/25/20 07:02	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS9		Lab ID: 70155659005	Collected: 11/25/20 07:03	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	86.4	ug/L	1.0	1		12/10/20 16:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS10		Lab ID: 70155659006		Collected: 11/25/20 07:13	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS17		Lab ID: 70155659007		Collected: 11/25/20 07:42	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	19.8	ug/L	1.0	1		12/10/20 16:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS18		Lab ID: 70155659008	Collected: 11/25/20 07:46	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		12/10/20 16:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS19		Lab ID: 70155659009	Collected: 11/25/20 07:38	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/10/20 16:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS21	Lab ID: 70155659010	Collected: 11/25/20 07:54	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	56.9	ug/L	1.0	1		12/10/20 16:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS22	Lab ID: 70155659011	Collected: 11/25/20 07:55	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	20.9	ug/L	1.0	1		12/10/20 16:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS23		Lab ID: 70155659012		Collected: 11/25/20 07:56	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.8	ug/L	1.0	1		12/10/20 16:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS24		Lab ID: 70155659013		Collected: 11/25/20 08:01	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		12/10/20 16:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS25		Lab ID: 70155659014	Collected: 11/25/20 08:02	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	79.2	ug/L	1.0	1		12/10/20 16:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS26		Lab ID: 70155659015		Collected: 11/25/20 08:03	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 16:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS27		Lab ID: 70155659016		Collected: 11/25/20 08:04	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/10/20 16:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS31		Lab ID: 70155659017	Collected: 11/25/20 08:09	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		12/10/20 16:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS33		Lab ID: 70155659018		Collected: 11/25/20 08:14	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		12/10/20 16:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS38	Lab ID: 70155659019	Collected: 11/25/20 08:27	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	64.6	ug/L	1.0	1		12/10/20 16:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS39		Lab ID: 70155659020	Collected: 11/25/20 08:28	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS44	Lab ID: 70155659021	Collected: 11/25/20 08:35	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS47		Lab ID: 70155659022	Collected: 11/25/20 08:40	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 16:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS48		Lab ID: 70155659023		Collected: 11/25/20 08:47	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	31.5	ug/L	1.0	1		12/10/20 17:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS54		Lab ID: 70155659024	Collected: 11/25/20 08:58	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	14.6	ug/L	1.0	1		12/10/20 17:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS55		Lab ID: 70155659025	Collected: 11/25/20 08:59	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	22.3	ug/L	1.0	1		12/10/20 17:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS56		Lab ID: 70155659026	Collected: 11/25/20 09:00	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	30.9	ug/L	1.0	1		12/10/20 17:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS57		Lab ID: 70155659027	Collected: 11/25/20 09:01	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.7	ug/L	1.0	1		12/10/20 17:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS58		Lab ID: 70155659028	Collected: 11/25/20 09:02	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	29.6	ug/L	1.0	1		12/10/20 17:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS59		Lab ID: 70155659029	Collected: 11/25/20 09:03	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.4	ug/L	1.0	1		12/10/20 17:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS60		Lab ID: 70155659030	Collected: 11/25/20 09:04	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.9	ug/L	1.0	1		12/10/20 17:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS61		Lab ID: 70155659031	Collected: 11/25/20 09:05	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.8	ug/L	1.0	1		12/10/20 17:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS62		Lab ID: 70155659032	Collected: 11/25/20 09:06	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	25.1	ug/L	1.0	1		12/10/20 17:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS63		Lab ID: 70155659033	Collected: 11/25/20 09:18	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.2	ug/L	1.0	1		12/10/20 17:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS64		Lab ID: 70155659034	Collected: 11/25/20 09:19	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.3	ug/L	1.0	1		12/10/20 17:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS65		Lab ID: 70155659035		Collected: 11/25/20 09:20	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		12/10/20 17:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS66		Lab ID: 70155659036	Collected: 11/25/20 09:21	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	18.0	ug/L	1.0	1		12/10/20 17:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS67		Lab ID: 70155659037	Collected: 11/25/20 09:26	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.0	ug/L	1.0	1		12/10/20 17:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS68		Lab ID: 70155659038		Collected: 11/25/20 09:27	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.2	ug/L	1.0	1		12/10/20 17:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS69		Lab ID: 70155659039		Collected: 11/25/20 09:28	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.7	ug/L	1.0	1		12/10/20 17:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS70		Lab ID: 70155659040	Collected: 11/25/20 09:29	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	54.7	ug/L	1.0	1		12/10/20 17:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS71		Lab ID: 70155659041	Collected: 11/25/20 09:30	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	21.4	ug/L	1.0	1		12/10/20 17:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS72		Lab ID: 70155659042		Collected: 11/25/20 09:31	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.2	ug/L	1.0	1		12/10/20 17:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS73	Lab ID: 70155659043	Collected: 11/25/20 09:32	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.7	ug/L	1.0	1		12/10/20 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS74		Lab ID: 70155659044	Collected: 11/25/20 09:33	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	33.3	ug/L	1.0	1		12/10/20 17:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS75		Lab ID: 70155659045	Collected: 11/25/20 09:34	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	28.4	ug/L	1.0	1		12/10/20 17:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS76	Lab ID: 70155659046	Collected: 11/25/20 09:50	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HS77								
Lab ID: 70155659047								
Collected: 11/25/20 09:39								
Received: 12/03/20 11:10								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		12/10/20 17:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS78		Lab ID: 70155659048	Collected: 11/25/20 09:40	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/10/20 17:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS79		Lab ID: 70155659049	Collected: 11/25/20 09:41	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 17:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS81		Lab ID: 70155659050		Collected: 11/25/20 09:53	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS82		Lab ID: 70155659051	Collected: 11/25/20 09:56	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 17:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS83		Lab ID: 70155659052	Collected: 11/25/20 09:58	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 17:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS84		Lab ID: 70155659053	Collected: 11/25/20 09:59	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		12/10/20 17:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS85		Lab ID: 70155659054	Collected: 11/25/20 10:00	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		12/10/20 17:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS86		Lab ID: 70155659055	Collected: 11/25/20 10:01	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS87		Lab ID: 70155659056	Collected: 11/25/20 10:02	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS88	Lab ID: 70155659057	Collected: 11/25/20 10:03	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS89		Lab ID: 70155659058		Collected: 11/25/20 10:04	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/10/20 17:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS90		Lab ID: 70155659059	Collected: 11/25/20 10:05	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 17:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Sample: HS91		Lab ID: 70155659060	Collected: 11/25/20 10:06	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/10/20 17:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS92		Lab ID: 70155659061	Collected: 11/25/20 10:07	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS93		Lab ID: 70155659062	Collected: 11/25/20 10:08	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		12/10/20 17:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS94		Lab ID: 70155659063	Collected: 11/25/20 10:09	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 17:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS95		Lab ID: 70155659064	Collected: 11/25/20 10:10	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS96		Lab ID: 70155659065	Collected: 11/25/20 10:11	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS97	Lab ID: 70155659066	Collected: 11/25/20 10:18	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS98	Lab ID: 70155659067	Collected: 11/25/20 10:26	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 18:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS99		Lab ID: 70155659068	Collected: 11/25/20 10:27	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		12/10/20 18:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS100		Lab ID: 70155659069		Collected: 11/25/20 10:28	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		12/10/20 18:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS101		Lab ID: 70155659070		Collected: 11/25/20 10:29	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.1	ug/L	1.0	1		12/10/20 18:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS102		Lab ID: 70155659071	Collected: 11/25/20 10:30	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		12/10/20 18:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS103	Lab ID: 70155659072	Collected: 11/25/20 10:31	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS104		Lab ID: 70155659073		Collected: 11/25/20 10:32	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS105		Lab ID: 70155659074	Collected: 11/25/20 10:33	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		12/10/20 18:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS106		Lab ID: 70155659075	Collected: 11/25/20 10:34	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		12/10/20 18:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS107		Lab ID: 70155659076		Collected: 11/25/20 10:35	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.5	ug/L	1.0	1		12/10/20 18:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS108		Lab ID: 70155659077		Collected: 11/25/20 10:36	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		12/10/20 18:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS109		Lab ID: 70155659078		Collected: 11/25/20 10:37	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.8	ug/L	1.0	1		12/10/20 18:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS110		Lab ID: 70155659079		Collected: 11/25/20 10:38	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 18:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS111		Lab ID: 70155659080		Collected: 11/25/20 10:39	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 18:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS112		Lab ID: 70155659081	Collected: 11/25/20 10:40	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 18:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS113		Lab ID: 70155659082		Collected: 11/25/20 10:41	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 18:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS114		Lab ID: 70155659083	Collected: 11/25/20 10:44	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		12/10/20 18:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS115	Lab ID: 70155659084	Collected: 11/25/20 10:50	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/10/20 18:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS116		Lab ID: 70155659085	Collected: 11/25/20 10:51	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/10/20 18:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS117	Lab ID: 70155659086	Collected: 11/25/20 10:52	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/10/20 18:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS118		Lab ID: 70155659087		Collected: 11/25/20 10:53	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Sample: HS119		Lab ID: 70155659088	Collected: 11/25/20 10:54	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS120	Lab ID: 70155659089	Collected: 11/25/20 10:55	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 18:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS121		Lab ID: 70155659090		Collected: 11/25/20 10:56	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		12/10/20 18:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS122		Lab ID: 70155659091	Collected: 11/25/20 10:57	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		12/10/20 18:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS123		Lab ID: 70155659092	Collected: 11/25/20 10:58	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 18:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS124		Lab ID: 70155659093		Collected: 11/25/20 10:59	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Sample: HS125		Lab ID: 70155659094	Collected: 11/25/20 11:00	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS126	Lab ID: 70155659095	Collected: 11/25/20 11:01	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS127	Lab ID: 70155659096	Collected: 11/25/20 11:02	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS128		Lab ID: 70155659097	Collected: 11/25/20 11:03	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 18:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS129		Lab ID: 70155659098		Collected: 11/25/20 11:05	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		12/10/20 18:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS130		Lab ID: 70155659099	Collected: 11/25/20 11:06	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.6	ug/L	1.0	1		12/10/20 18:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS131	Lab ID: 70155659100	Collected: 11/25/20 11:07	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.7	ug/L	1.0	1		12/10/20 18:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS132		Lab ID: 70155659101	Collected: 11/25/20 11:08	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		12/10/20 18:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS133		Lab ID: 70155659102	Collected: 11/25/20 11:20	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.0	ug/L	1.0	1		12/10/20 18:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS135		Lab ID: 70155659103	Collected: 11/25/20 11:21	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 18:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS136	Lab ID: 70155659104	Collected: 11/25/20 11:15	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 18:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS137	Lab ID: 70155659105	Collected: 11/25/20 11:23	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS138		Lab ID: 70155659106		Collected: 11/25/20 11:24		Received: 12/03/20 11:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 19:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS142		Lab ID: 70155659107		Collected: 11/25/20 11:28	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS143		Lab ID: 70155659108	Collected: 11/25/20 11:36	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 19:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS144		Lab ID: 70155659109		Collected: 11/25/20 11:37	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS145		Lab ID: 70155659110	Collected: 11/25/20 11:31	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS146		Lab ID: 70155659111	Collected: 11/25/20 11:33	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		12/10/20 19:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS147		Lab ID: 70155659112	Collected: 11/25/20 11:34	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		12/10/20 19:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS148		Lab ID: 70155659113	Collected: 11/25/20 11:39	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/10/20 19:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS151	Lab ID: 70155659114	Collected: 11/25/20 11:41	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 19:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS155		Lab ID: 70155659115		Collected: 11/25/20 12:01	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 19:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS156		Lab ID: 70155659116		Collected: 11/25/20 12:02	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 19:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS157	Lab ID: 70155659117	Collected: 11/25/20 12:03	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	1.9	ug/L	1.0	1		12/10/20 19:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS158		Lab ID: 70155659118	Collected: 11/25/20 12:04	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		12/10/20 19:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS159	Lab ID: 70155659119	Collected: 11/25/20 12:05	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS160		Lab ID: 70155659120		Collected: 11/25/20 12:06	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/10/20 19:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS161	Lab ID: 70155659121	Collected: 11/25/20 12:07	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/10/20 19:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS162		Lab ID: 70155659122	Collected: 11/25/20 12:08	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/10/20 19:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS163	Lab ID: 70155659123	Collected: 11/25/20 12:09	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 19:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS164		Lab ID: 70155659124	Collected: 11/25/20 12:10	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		12/10/20 19:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS165	Lab ID: 70155659125	Collected: 11/25/20 12:11	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS166	Lab ID: 70155659126	Collected: 11/25/20 12:12	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS167		Lab ID: 70155659127	Collected: 11/25/20 12:13	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 19:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS168		Lab ID: 70155659128	Collected: 11/25/20 12:14	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS169		Lab ID: 70155659129		Collected: 11/25/20 12:15	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		12/10/20 19:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS170		Lab ID: 70155659130	Collected: 11/25/20 12:16	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS171		Lab ID: 70155659131	Collected: 11/25/20 12:17	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	100	ug/L	1.0	1		12/10/20 19:39	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS173		Lab ID: 70155659132		Collected: 11/25/20 12:35	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 19:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS174		Lab ID: 70155659133	Collected: 11/25/20 12:35	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		12/10/20 19:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS175		Lab ID: 70155659134	Collected: 11/25/20 12:36	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.3	ug/L	1.0	1		12/10/20 19:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS176		Lab ID: 70155659135	Collected: 11/25/20 12:37	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.4	ug/L	1.0	1		12/10/20 19:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HS177								
Lab ID: 70155659136								
Collected: 11/25/20 12:38								
Received: 12/03/20 11:10								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		12/10/20 19:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS178		Lab ID: 70155659137		Collected: 11/25/20 12:39	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		12/10/20 19:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS179		Lab ID: 70155659138		Collected: 11/25/20 12:40	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		12/10/20 19:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS180		Lab ID: 70155659139		Collected: 11/25/20 12:41	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 19:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS181		Lab ID: 70155659140	Collected: 11/25/20 12:42	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		12/10/20 19:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS182		Lab ID: 70155659141	Collected: 11/25/20 12:44	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		12/10/20 19:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS183		Lab ID: 70155659142	Collected: 11/25/20 12:45	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		12/10/20 19:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS184		Lab ID: 70155659143		Collected: 11/25/20 12:46	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		12/10/20 19:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS185	Lab ID: 70155659144	Collected: 11/25/20 12:47	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		12/10/20 20:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS186		Lab ID: 70155659145	Collected: 11/25/20 12:48	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		12/10/20 20:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS187		Lab ID: 70155659146		Collected: 11/25/20 12:49	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.7	ug/L	1.0	1		12/10/20 20:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS188	Lab ID: 70155659147	Collected: 11/25/20 12:56	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.4	ug/L	1.0	1		12/10/20 20:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS189		Lab ID: 70155659148	Collected: 11/25/20 12:51	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		12/10/20 20:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS190		Lab ID: 70155659149		Collected: 11/25/20 12:52		Received: 12/03/20 11:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	133	ug/L	1.0	1		12/10/20 20:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS191		Lab ID: 70155659150	Collected: 11/25/20 12:53	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	36.2	ug/L	1.0	1		12/10/20 20:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS192		Lab ID: 70155659151	Collected: 11/25/20 12:58	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS193		Lab ID: 70155659152		Collected: 11/25/20 12:59	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/10/20 20:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS194	Lab ID: 70155659153	Collected: 11/25/20 13:00	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.2	ug/L	1.0	1		12/10/20 20:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS195		Lab ID: 70155659154		Collected: 11/25/20 13:01	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/10/20 20:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS196		Lab ID: 70155659155	Collected: 11/25/20 13:02	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.6	ug/L	1.0	1		12/10/20 20:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS197		Lab ID: 70155659156	Collected: 11/25/20 13:03	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS198	Lab ID: 70155659157	Collected: 11/25/20 13:04	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/20 20:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS199	Lab ID: 70155659158	Collected: 11/25/20 13:05	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS200		Lab ID: 70155659159	Collected: 11/25/20 13:06	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		12/10/20 20:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS201	Lab ID: 70155659160	Collected: 11/25/20 13:07	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS202		Lab ID: 70155659161	Collected: 11/25/20 13:08	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS203	Lab ID: 70155659162	Collected: 11/25/20 13:09	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/10/20 20:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS204		Lab ID: 70155659163		Collected: 11/25/20 13:10	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 20:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS205	Lab ID: 70155659164	Collected: 11/25/20 13:11	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	26.6	ug/L	1.0	1		12/10/20 20:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS206		Lab ID: 70155659165	Collected: 11/25/20 13:12	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		12/10/20 20:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS207		Lab ID: 70155659166		Collected: 11/25/20 13:13	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS208		Lab ID: 70155659167	Collected: 11/25/20 13:14	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	119	ug/L	1.0	1		12/10/20 20:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS210		Lab ID: 70155659168	Collected: 11/25/20 13:14	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS211		Lab ID: 70155659169	Collected: 11/25/20 13:21	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS212		Lab ID: 70155659170	Collected: 11/25/20 13:22	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS213		Lab ID: 70155659171	Collected: 11/25/20 13:23	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		12/10/20 20:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS214	Lab ID: 70155659172	Collected: 11/25/20 13:25	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		12/10/20 20:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS216		Lab ID: 70155659173	Collected: 11/25/20 13:30	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 20:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS217		Lab ID: 70155659174	Collected: 11/25/20 13:31	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		12/10/20 20:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS218		Lab ID: 70155659175		Collected: 11/25/20 13:32	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/10/20 20:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS219		Lab ID: 70155659176		Collected: 11/25/20 13:33	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/10/20 20:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS220		Lab ID: 70155659177	Collected: 11/25/20 13:34	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		12/10/20 20:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS221		Lab ID: 70155659178		Collected: 11/25/20 13:35	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/10/20 20:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Sample: HS222		Lab ID: 70155659179	Collected: 11/25/20 13:36	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/10/20 20:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS224		Lab ID: 70155659181		Collected: 11/25/20 13:39	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		12/10/20 20:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HS225								
Lab ID: 70155659182								
Collected: 11/25/20 13:40								
Received: 12/03/20 11:10								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		12/10/20 20:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS226		Lab ID: 70155659183		Collected: 11/25/20 13:41	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.3	ug/L	1.0	1		12/10/20 20:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HS232								
Lab ID: 70155659184								
Collected: 11/25/20 13:48								
Received: 12/03/20 11:10								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		12/10/20 20:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS234		Lab ID: 70155659185		Collected: 11/25/20 13:49	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS235		Lab ID: 70155659186		Collected: 11/25/20 13:55	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/10/20 21:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS236	Lab ID: 70155659187	Collected: 11/25/20 14:02	Received: 12/03/20 11:10	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.5	ug/L	1.0	1		12/10/20 21:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS242		Lab ID: 70155659188		Collected: 11/25/20 14:07		Received: 12/03/20 11:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.6	ug/L	1.0	1		12/10/20 21:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS243		Lab ID: 70155659189		Collected: 11/25/20 14:08	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

Sample: HS244		Lab ID: 70155659190	Collected: 11/25/20 14:09	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS245		Lab ID: 70155659191	Collected: 11/25/20 14:10	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS248		Lab ID: 70155659192	Collected: 11/25/20 14:19	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		12/10/20 21:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS249		Lab ID: 70155659193		Collected: 11/25/20 14:20	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS250		Lab ID: 70155659194	Collected: 11/25/20 14:22	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS251		Lab ID: 70155659195		Collected: 11/25/20 14:25	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS252		Lab ID: 70155659196		Collected: 11/25/20 14:26	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		12/10/20 21:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS253		Lab ID: 70155659197	Collected: 11/25/20 14:27	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HS254								
Lab ID: 70155659198								
Collected: 11/25/20 14:28								
Received: 12/03/20 11:10								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	7.4	ug/L	1.0	1		12/10/20 21:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS255		Lab ID: 70155659199		Collected: 11/25/20 14:32	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.5	ug/L	1.0	1		12/10/20 21:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS256		Lab ID: 70155659200		Collected: 11/25/20 14:33	Received: 12/03/20 11:10	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/10/20 21:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Sample: HS227		Lab ID: 70155659201	Collected: 11/25/20 13:41	Received: 12/03/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/10/20 21:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

QC Batch:	189064	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155659001, 70155659002, 70155659003, 70155659004, 70155659005, 70155659006, 70155659007, 70155659008, 70155659009, 70155659010, 70155659011, 70155659012, 70155659013, 70155659014, 70155659015, 70155659016, 70155659017, 70155659018, 70155659019, 70155659020		

METHOD BLANK:	927644	Matrix:	Water
Associated Lab Samples:	70155659001, 70155659002, 70155659003, 70155659004, 70155659005, 70155659006, 70155659007, 70155659008, 70155659009, 70155659010, 70155659011, 70155659012, 70155659013, 70155659014, 70155659015, 70155659016, 70155659017, 70155659018, 70155659019, 70155659020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 16:23	

LABORATORY CONTROL SAMPLE:	927645					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.9	102	85-115	

MATRIX SPIKE SAMPLE:	927648						
Parameter	Units	70155659001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.1	119	70-130	

MATRIX SPIKE SAMPLE:	927650						
Parameter	Units	70155659011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	20.9	4	25.0	102	70-130	

SAMPLE DUPLICATE:	927647				
Parameter	Units	70155659001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	927649				
Parameter	Units	70155659011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	20.9	20.9	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

QC Batch:	189065	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155659021, 70155659022, 70155659023, 70155659024, 70155659025, 70155659026, 70155659027, 70155659028, 70155659029, 70155659030, 70155659031, 70155659032, 70155659033, 70155659034, 70155659035, 70155659036, 70155659037, 70155659038, 70155659039, 70155659040		

METHOD BLANK:	927653	Matrix:	Water
Associated Lab Samples:	70155659021, 70155659022, 70155659023, 70155659024, 70155659025, 70155659026, 70155659027, 70155659028, 70155659029, 70155659030, 70155659031, 70155659032, 70155659033, 70155659034, 70155659035, 70155659036, 70155659037, 70155659038, 70155659039, 70155659040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 16:53	

LABORATORY CONTROL SAMPLE:	927654					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	927656						
Parameter	Units	70155659021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.3	116	70-130	

MATRIX SPIKE SAMPLE:	927658						
Parameter	Units	70155659031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	10.8	4	15.6	118	70-130	

SAMPLE DUPLICATE:	927655				
Parameter	Units	70155659021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	927657				
Parameter	Units	70155659031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	10.8	10.7	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189066	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659041, 70155659042, 70155659043, 70155659044, 70155659045, 70155659046, 70155659047, 70155659048, 70155659049, 70155659050, 70155659051, 70155659052, 70155659053, 70155659054, 70155659055, 70155659056, 70155659057, 70155659058, 70155659059, 70155659060

METHOD BLANK: 927659 Matrix: Water
Associated Lab Samples: 70155659041, 70155659042, 70155659043, 70155659044, 70155659045, 70155659046, 70155659047, 70155659048, 70155659049, 70155659050, 70155659051, 70155659052, 70155659053, 70155659054, 70155659055, 70155659056, 70155659057, 70155659058, 70155659059, 70155659060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 17:23	

LABORATORY CONTROL SAMPLE: 927660

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE: 927662

Parameter	Units	70155659041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	21.4	4	25.9	112	70-130	

MATRIX SPIKE SAMPLE: 927664

Parameter	Units	70155659051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.8	111	70-130	

SAMPLE DUPLICATE: 927661

Parameter	Units	70155659041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	21.4	21.3	1	

SAMPLE DUPLICATE: 927663

Parameter	Units	70155659051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

QC Batch:	189067	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155659061, 70155659062, 70155659063, 70155659064, 70155659065, 70155659066, 70155659067, 70155659068, 70155659069, 70155659070, 70155659071, 70155659072, 70155659073, 70155659074, 70155659075, 70155659076, 70155659077, 70155659078, 70155659079, 70155659080		

METHOD BLANK:	927665	Matrix:	Water
Associated Lab Samples:	70155659061, 70155659062, 70155659063, 70155659064, 70155659065, 70155659066, 70155659067, 70155659068, 70155659069, 70155659070, 70155659071, 70155659072, 70155659073, 70155659074, 70155659075, 70155659076, 70155659077, 70155659078, 70155659079, 70155659080		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 17:52	

LABORATORY CONTROL SAMPLE:	927666					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE:	927668						
Parameter	Units	70155659061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.1	112	70-130	

MATRIX SPIKE SAMPLE:	927670						
Parameter	Units	70155659071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.9	4	6.3	111	70-130	

SAMPLE DUPLICATE:	927667				
Parameter	Units	70155659061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	927669				
Parameter	Units	70155659071 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.9	1.9	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189068	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659081, 70155659082, 70155659083, 70155659084, 70155659085, 70155659086, 70155659087, 70155659088, 70155659089, 70155659090, 70155659091, 70155659092, 70155659093, 70155659094, 70155659095, 70155659096, 70155659097, 70155659098, 70155659099, 70155659100

METHOD BLANK: 927671 Matrix: Water

Associated Lab Samples: 70155659081, 70155659082, 70155659083, 70155659084, 70155659085, 70155659086, 70155659087, 70155659088, 70155659089, 70155659090, 70155659091, 70155659092, 70155659093, 70155659094, 70155659095, 70155659096, 70155659097, 70155659098, 70155659099, 70155659100

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 18:22	

LABORATORY CONTROL SAMPLE: 927672

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.2	102	85-115	

MATRIX SPIKE SAMPLE: 927674

Parameter	Units	70155659081 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.2	114	70-130	

MATRIX SPIKE SAMPLE: 927676

Parameter	Units	70155659091 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.2	4	7.0	118	70-130	

SAMPLE DUPLICATE: 927673

Parameter	Units	70155659081 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 927675

Parameter	Units	70155659091 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.2	2.3	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189069	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659101, 70155659102, 70155659103, 70155659104, 70155659105, 70155659106, 70155659107, 70155659108, 70155659109, 70155659110, 70155659111, 70155659112, 70155659113, 70155659114, 70155659115, 70155659116, 70155659117, 70155659118, 70155659119, 70155659120

METHOD BLANK: 927677 Matrix: Water

Associated Lab Samples: 70155659101, 70155659102, 70155659103, 70155659104, 70155659105, 70155659106, 70155659107, 70155659108, 70155659109, 70155659110, 70155659111, 70155659112, 70155659113, 70155659114, 70155659115, 70155659116, 70155659117, 70155659118, 70155659119, 70155659120

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 18:53	

LABORATORY CONTROL SAMPLE: 927678

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.9	102	85-115	

MATRIX SPIKE SAMPLE: 927680

Parameter	Units	70155659101 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.6	4	8.3	118	70-130	

MATRIX SPIKE SAMPLE: 927682

Parameter	Units	70155659111 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.2	4	7.7	112	70-130	

SAMPLE DUPLICATE: 927679

Parameter	Units	70155659101 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.6	3.6	1	

SAMPLE DUPLICATE: 927681

Parameter	Units	70155659111 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.2	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

QC Batch:	189070	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155659121, 70155659122, 70155659123, 70155659124, 70155659125, 70155659126, 70155659127, 70155659128, 70155659129, 70155659130, 70155659131, 70155659132, 70155659133, 70155659134, 70155659135, 70155659136, 70155659137, 70155659138, 70155659139, 70155659140		

METHOD BLANK:	927684	Matrix:	Water
Associated Lab Samples:	70155659121, 70155659122, 70155659123, 70155659124, 70155659125, 70155659126, 70155659127, 70155659128, 70155659129, 70155659130, 70155659131, 70155659132, 70155659133, 70155659134, 70155659135, 70155659136, 70155659137, 70155659138, 70155659139, 70155659140		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 19:22	

LABORATORY CONTROL SAMPLE:	927685					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE:	927687						
Parameter	Units	70155659121 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.5	4	6.4	124	70-130	

MATRIX SPIKE SAMPLE:	927689						
Parameter	Units	70155659131 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	4	106	134	70-130	M1

SAMPLE DUPLICATE:	927686					
Parameter	Units	70155659121 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.5	1.5	0		

SAMPLE DUPLICATE:	927688					
Parameter	Units	70155659131 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	100	102	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189072	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659141, 70155659142, 70155659143, 70155659144, 70155659145, 70155659146, 70155659147, 70155659148, 70155659149, 70155659150, 70155659151, 70155659152, 70155659153, 70155659154, 70155659155, 70155659156, 70155659157, 70155659158, 70155659159, 70155659160

METHOD BLANK: 927694 Matrix: Water

Associated Lab Samples: 70155659141, 70155659142, 70155659143, 70155659144, 70155659145, 70155659146, 70155659147, 70155659148, 70155659149, 70155659150, 70155659151, 70155659152, 70155659153, 70155659154, 70155659155, 70155659156, 70155659157, 70155659158, 70155659159, 70155659160

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 19:52	

LABORATORY CONTROL SAMPLE: 927695

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.2	102	85-115	

MATRIX SPIKE SAMPLE: 927697

Parameter	Units	70155659141 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.3	4	7.1	120	70-130	

MATRIX SPIKE SAMPLE: 927699

Parameter	Units	70155659151 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.8	124	70-130	

SAMPLE DUPLICATE: 927696

Parameter	Units	70155659141 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.3	2.2	3	

SAMPLE DUPLICATE: 927698

Parameter	Units	70155659151 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189073	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659161, 70155659162, 70155659163, 70155659164, 70155659165, 70155659166, 70155659167, 70155659168, 70155659169, 70155659170, 70155659171, 70155659172, 70155659173, 70155659174, 70155659175, 70155659176, 70155659177, 70155659178, 70155659179, 70155659181

METHOD BLANK: 927701 Matrix: Water

Associated Lab Samples: 70155659161, 70155659162, 70155659163, 70155659164, 70155659165, 70155659166, 70155659167, 70155659168, 70155659169, 70155659170, 70155659171, 70155659172, 70155659173, 70155659174, 70155659175, 70155659176, 70155659177, 70155659178, 70155659179, 70155659181

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 20:21	

LABORATORY CONTROL SAMPLE: 927702

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE: 927704

Parameter	Units	70155659161 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.7	123	70-130	

MATRIX SPIKE SAMPLE: 927706

Parameter	Units	70155659171 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.8	4	7.5	117	70-130	

SAMPLE DUPLICATE: 927703

Parameter	Units	70155659161 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 927705

Parameter	Units	70155659171 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.8	2.8	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: HIGH SCHOOL 11/25
Pace Project No.: 70155659

QC Batch:	189075	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70155659182, 70155659183, 70155659184, 70155659185, 70155659186, 70155659187, 70155659188, 70155659189, 70155659190, 70155659191, 70155659192, 70155659193, 70155659194, 70155659195, 70155659196, 70155659197, 70155659198, 70155659199, 70155659200, 70155659201

METHOD BLANK: 927710 Matrix: Water

Associated Lab Samples: 70155659182, 70155659183, 70155659184, 70155659185, 70155659186, 70155659187, 70155659188, 70155659189, 70155659190, 70155659191, 70155659192, 70155659193, 70155659194, 70155659195, 70155659196, 70155659197, 70155659198, 70155659199, 70155659200, 70155659201

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/20 20:52	

LABORATORY CONTROL SAMPLE: 927711

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE: 927713

Parameter	Units	70155659182 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.0	115	70-130	

MATRIX SPIKE SAMPLE: 927715

Parameter	Units	70155659192 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.6	4	7.2	116	70-130	

SAMPLE DUPLICATE: 927712

Parameter	Units	70155659182 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 927714

Parameter	Units	70155659192 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.6	2.8	6	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155659001	HS1	EPA 200.8	189064		
70155659002	HS3	EPA 200.8	189064		
70155659003	HS6	EPA 200.8	189064		
70155659004	HS8	EPA 200.8	189064		
70155659005	HS9	EPA 200.8	189064		
70155659006	HS10	EPA 200.8	189064		
70155659007	HS17	EPA 200.8	189064		
70155659008	HS18	EPA 200.8	189064		
70155659009	HS19	EPA 200.8	189064		
70155659010	HS21	EPA 200.8	189064		
70155659011	HS22	EPA 200.8	189064		
70155659012	HS23	EPA 200.8	189064		
70155659013	HS24	EPA 200.8	189064		
70155659014	HS25	EPA 200.8	189064		
70155659015	HS26	EPA 200.8	189064		
70155659016	HS27	EPA 200.8	189064		
70155659017	HS31	EPA 200.8	189064		
70155659018	HS33	EPA 200.8	189064		
70155659019	HS38	EPA 200.8	189064		
70155659020	HS39	EPA 200.8	189064		
70155659021	HS44	EPA 200.8	189065		
70155659022	HS47	EPA 200.8	189065		
70155659023	HS48	EPA 200.8	189065		
70155659024	HS54	EPA 200.8	189065		
70155659025	HS55	EPA 200.8	189065		
70155659026	HS56	EPA 200.8	189065		
70155659027	HS57	EPA 200.8	189065		
70155659028	HS58	EPA 200.8	189065		
70155659029	HS59	EPA 200.8	189065		
70155659030	HS60	EPA 200.8	189065		
70155659031	HS61	EPA 200.8	189065		
70155659032	HS62	EPA 200.8	189065		
70155659033	HS63	EPA 200.8	189065		
70155659034	HS64	EPA 200.8	189065		
70155659035	HS65	EPA 200.8	189065		
70155659036	HS66	EPA 200.8	189065		
70155659037	HS67	EPA 200.8	189065		
70155659038	HS68	EPA 200.8	189065		
70155659039	HS69	EPA 200.8	189065		
70155659040	HS70	EPA 200.8	189065		
70155659041	HS71	EPA 200.8	189066		
70155659042	HS72	EPA 200.8	189066		
70155659043	HS73	EPA 200.8	189066		
70155659044	HS74	EPA 200.8	189066		
70155659045	HS75	EPA 200.8	189066		
70155659046	HS76	EPA 200.8	189066		
70155659047	HS77	EPA 200.8	189066		
70155659048	HS78	EPA 200.8	189066		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155659049	HS79	EPA 200.8	189066		
70155659050	HS81	EPA 200.8	189066		
70155659051	HS82	EPA 200.8	189066		
70155659052	HS83	EPA 200.8	189066		
70155659053	HS84	EPA 200.8	189066		
70155659054	HS85	EPA 200.8	189066		
70155659055	HS86	EPA 200.8	189066		
70155659056	HS87	EPA 200.8	189066		
70155659057	HS88	EPA 200.8	189066		
70155659058	HS89	EPA 200.8	189066		
70155659059	HS90	EPA 200.8	189066		
70155659060	HS91	EPA 200.8	189066		
70155659061	HS92	EPA 200.8	189067		
70155659062	HS93	EPA 200.8	189067		
70155659063	HS94	EPA 200.8	189067		
70155659064	HS95	EPA 200.8	189067		
70155659065	HS96	EPA 200.8	189067		
70155659066	HS97	EPA 200.8	189067		
70155659067	HS98	EPA 200.8	189067		
70155659068	HS99	EPA 200.8	189067		
70155659069	HS100	EPA 200.8	189067		
70155659070	HS101	EPA 200.8	189067		
70155659071	HS102	EPA 200.8	189067		
70155659072	HS103	EPA 200.8	189067		
70155659073	HS104	EPA 200.8	189067		
70155659074	HS105	EPA 200.8	189067		
70155659075	HS106	EPA 200.8	189067		
70155659076	HS107	EPA 200.8	189067		
70155659077	HS108	EPA 200.8	189067		
70155659078	HS109	EPA 200.8	189067		
70155659079	HS110	EPA 200.8	189067		
70155659080	HS111	EPA 200.8	189067		
70155659081	HS112	EPA 200.8	189068		
70155659082	HS113	EPA 200.8	189068		
70155659083	HS114	EPA 200.8	189068		
70155659084	HS115	EPA 200.8	189068		
70155659085	HS116	EPA 200.8	189068		
70155659086	HS117	EPA 200.8	189068		
70155659087	HS118	EPA 200.8	189068		
70155659088	HS119	EPA 200.8	189068		
70155659089	HS120	EPA 200.8	189068		
70155659090	HS121	EPA 200.8	189068		
70155659091	HS122	EPA 200.8	189068		
70155659092	HS123	EPA 200.8	189068		
70155659093	HS124	EPA 200.8	189068		
70155659094	HS125	EPA 200.8	189068		
70155659095	HS126	EPA 200.8	189068		
70155659096	HS127	EPA 200.8	189068		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155659097	HS128	EPA 200.8	189068		
70155659098	HS129	EPA 200.8	189068		
70155659099	HS130	EPA 200.8	189068		
70155659100	HS131	EPA 200.8	189068		
70155659101	HS132	EPA 200.8	189069		
70155659102	HS133	EPA 200.8	189069		
70155659103	HS135	EPA 200.8	189069		
70155659104	HS136	EPA 200.8	189069		
70155659105	HS137	EPA 200.8	189069		
70155659106	HS138	EPA 200.8	189069		
70155659107	HS142	EPA 200.8	189069		
70155659108	HS143	EPA 200.8	189069		
70155659109	HS144	EPA 200.8	189069		
70155659110	HS145	EPA 200.8	189069		
70155659111	HS146	EPA 200.8	189069		
70155659112	HS147	EPA 200.8	189069		
70155659113	HS148	EPA 200.8	189069		
70155659114	HS151	EPA 200.8	189069		
70155659115	HS155	EPA 200.8	189069		
70155659116	HS156	EPA 200.8	189069		
70155659117	HS157	EPA 200.8	189069		
70155659118	HS158	EPA 200.8	189069		
70155659119	HS159	EPA 200.8	189069		
70155659120	HS160	EPA 200.8	189069		
70155659121	HS161	EPA 200.8	189070		
70155659122	HS162	EPA 200.8	189070		
70155659123	HS163	EPA 200.8	189070		
70155659124	HS164	EPA 200.8	189070		
70155659125	HS165	EPA 200.8	189070		
70155659126	HS166	EPA 200.8	189070		
70155659127	HS167	EPA 200.8	189070		
70155659128	HS168	EPA 200.8	189070		
70155659129	HS169	EPA 200.8	189070		
70155659130	HS170	EPA 200.8	189070		
70155659131	HS171	EPA 200.8	189070		
70155659132	HS173	EPA 200.8	189070		
70155659133	HS174	EPA 200.8	189070		
70155659134	HS175	EPA 200.8	189070		
70155659135	HS176	EPA 200.8	189070		
70155659136	HS177	EPA 200.8	189070		
70155659137	HS178	EPA 200.8	189070		
70155659138	HS179	EPA 200.8	189070		
70155659139	HS180	EPA 200.8	189070		
70155659140	HS181	EPA 200.8	189070		
70155659141	HS182	EPA 200.8	189072		
70155659142	HS183	EPA 200.8	189072		
70155659143	HS184	EPA 200.8	189072		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155659144	HS185	EPA 200.8	189072		
70155659145	HS186	EPA 200.8	189072		
70155659146	HS187	EPA 200.8	189072		
70155659147	HS188	EPA 200.8	189072		
70155659148	HS189	EPA 200.8	189072		
70155659149	HS190	EPA 200.8	189072		
70155659150	HS191	EPA 200.8	189072		
70155659151	HS192	EPA 200.8	189072		
70155659152	HS193	EPA 200.8	189072		
70155659153	HS194	EPA 200.8	189072		
70155659154	HS195	EPA 200.8	189072		
70155659155	HS196	EPA 200.8	189072		
70155659156	HS197	EPA 200.8	189072		
70155659157	HS198	EPA 200.8	189072		
70155659158	HS199	EPA 200.8	189072		
70155659159	HS200	EPA 200.8	189072		
70155659160	HS201	EPA 200.8	189072		
70155659161	HS202	EPA 200.8	189073		
70155659162	HS203	EPA 200.8	189073		
70155659163	HS204	EPA 200.8	189073		
70155659164	HS205	EPA 200.8	189073		
70155659165	HS206	EPA 200.8	189073		
70155659166	HS207	EPA 200.8	189073		
70155659167	HS208	EPA 200.8	189073		
70155659168	HS210	EPA 200.8	189073		
70155659169	HS211	EPA 200.8	189073		
70155659170	HS212	EPA 200.8	189073		
70155659171	HS213	EPA 200.8	189073		
70155659172	HS214	EPA 200.8	189073		
70155659173	HS216	EPA 200.8	189073		
70155659174	HS217	EPA 200.8	189073		
70155659175	HS218	EPA 200.8	189073		
70155659176	HS219	EPA 200.8	189073		
70155659177	HS220	EPA 200.8	189073		
70155659178	HS221	EPA 200.8	189073		
70155659179	HS222	EPA 200.8	189073		
70155659181	HS224	EPA 200.8	189073		
70155659182	HS225	EPA 200.8	189075		
70155659183	HS226	EPA 200.8	189075		
70155659184	HS232	EPA 200.8	189075		
70155659185	HS234	EPA 200.8	189075		
70155659186	HS235	EPA 200.8	189075		
70155659187	HS236	EPA 200.8	189075		
70155659188	HS242	EPA 200.8	189075		
70155659189	HS243	EPA 200.8	189075		
70155659190	HS244	EPA 200.8	189075		
70155659191	HS245	EPA 200.8	189075		
70155659192	HS248	EPA 200.8	189075		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HIGH SCHOOL 11/25

Pace Project No.: 70155659

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155659193	HS249	EPA 200.8	189075		
70155659194	HS250	EPA 200.8	189075		
70155659195	HS251	EPA 200.8	189075		
70155659196	HS252	EPA 200.8	189075		
70155659197	HS253	EPA 200.8	189075		
70155659198	HS254	EPA 200.8	189075		
70155659199	HS255	EPA 200.8	189075		
70155659200	HS256	EPA 200.8	189075		
70155659201	HS227	EPA 200.8	189075		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 70155659



70155659

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately. 23 pages total

Section C

Invoice Information:

Report To: Kevin Storsberg
 Company Name: Whitesboro Central School District
 Address: 65 Oriskany Boulevard
 Whitesboro, NY 13492
 Email: kstorsberg@wboro.org
 Phone: 315-266-3312
 Fax: [Blank]
 Project Name: High School
 Project #: [Blank]
 Purchase Order #: [Blank]
 Pace Quote: [Blank]
 Pace Project Manager: nicole.lovati@pacerlabs.com
 Pace Profile #: 8638
 Requested Dup Date: [Blank]

Page: 1 Of 23

ITEM #	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G-RAB C-COMP)	COLLECTED		DATE	TIME	SAMPLER TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES							ANALYSES TEST Y/N	LEAD	RESIDUAL CHLORINE (Y/N)	SAMPLE CONDITIONS
			START DATE	END DATE					UNPRESERVED	H2SO4	HNO3	HCl	NaOH	Na2SO3	Methanol				
1	HS1	DW	11-25	0658														001	
2	HS2	DW																002	
3	HS3	DW																	
4	HS4	DW																	
5	HS5	DW																	
6	HS6	DW																003	
7	HS7	DW																004	
8	HS8	DW																005	
9	HS9	DW																006	
10	HS10	DW																	
11	HS11	DW																	
12	HS12	DW																	

ADDITIONAL COMMENTS
 Some rooms inaccessible due to no key in others used as storage. Making access to faucets.
 Inaccessible

RELINQUISHED BY / AFFILIATION
 Chris Peters / P120

DATE
 12-2

TIME
 0750

ACCEPTED BY / AFFILIATION
 Chris Peters

DATE
 12-2

TIME
 1700

TEMP IN C
 19.6

DATE SIGNED
 12-1-2023

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: Chris Peters
 SIGNATURE of SAMPLER: Chris Peters

+ 1 bag (7 samples)



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	Whitesboro Central School District	Report To:	Kevin Storszberg	Attention:	
Address:	65 Oriskany Boulevard	Copy To:		Company Name:	
Whitesboro, NY 13492		Purchase Order #:		Address:	
Email:	kstorszberg@wboro.org	Project Name:	High School	Pace Quote:	
Phone:	315-266-3312	Fax:		Pace Project Manager:	nicolette.lovati@pacelabs.com
Requested Due Date:		Project #:		Pace Profile #:	8638
Regulatory Agency		Regulatory Agency		State / Location	
				NY	

ITEM #	MATRIX	CODE	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G-GRAB C-COMP)	COLLECTED		DATE	TIME	DATE	TIME	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	DATE	TIME	SAMPLE CONDITIONS	
					START	END													
13	DW	DW	DW	DW			11-25												
14	DW	DW	DW	DW															
15	DW	DW	DW	DW															
16	DW	DW	DW	DW															
17	DW	DW	DW	DW															
18	DW	DW	DW	DW															
19	DW	DW	DW	DW															
20	DW	DW	DW	DW															
21	DW	DW	DW	DW															
22	DW	DW	DW	DW															
23	DW	DW	DW	DW															
24	DW	DW	DW	DW															

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME		DATE		TIME		SAMPLE CONDITIONS	
HS13 & HS14 removed according to teacher in music department								H.C. [Signature]		11/20/10				11/10				1966 N 4 Y	
TEMP in C		Received on		Ice (Y/N)		Custody Sealed (Y/N)		Cooler (Y/N)		Samples Intact (Y/N)									
SAMPLER NAME AND SIGNATURE		PRINT Name of SAMPLER:		SIGNATURE of SAMPLER:		DATE Signed:													
		Chris Pate		[Signature]		12-7-10													



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section B
Required Client Information:
 Company: Whitesboro Central School District
 Address: 65 Oriskany Boulevard
 Whitesboro, NY 13492
 Email: kstorszberg@wboto.org
 Phone: 315-266-3312
 Requested Due Date:

Section C
Invoice Information:
 Report To: Kevin Storszberg
 Copy To:
 Attention: Company Name:
 Address:
 Purchase Order #: High School
 Project Name: nicole.lovat@pacelabs.com
 Project #: 8638
 Pace Quote:
 Pace Project Manager:
 Pace Profile #:

Regulatory Agency
 State / Location
 NY

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-RAB C-COMP)	MATRIX CODE (see valid codes to left)	SAMPLER TEMP AT COLLECTION		# OF CONTAINERS	PRESERVATIVES							ANALYSES TEST Y/N	LEAD	RESIDUAL CHLORINE (Y/N)
			START DATE	START TIME			END DATE	END TIME		UNPRESERVED	HSO4	HNO3	HCl	NaOH	Na2S2O3	Methanol			
25	Drinking Water	DW	11-25	0802		DW													014
26	Waste Water	WW		0803		DW													015
27	Product	P		0804		DW													016
28	Oil	OL		-		DW													
29	Wipe	WP		-		DW													
30	Air	AR		-		DW													
31	Other	OT		0809		DW													017
32	Tissue	TS		-		DW													018
33				-		DW													
34				-		DW													
35				-		DW													
36				-		DW													

ADDITIONAL COMMENTS

RELINQUISHED BY / AFFILIATION: HDO
 DATE: 12/30/11
 TIME: 10:16 AM

ACCEPTED BY / AFFILIATION:
 DATE:
 TIME:

SAMPLE CONDITIONS
 Received on: []
 Ice (Y/N): []
 Custody (Y/N): []
 Sealed (Y/N): []
 Cooler (Y/N): []
 Samples Intact (Y/N): []

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Chris Pize
 SIGNATURE of SAMPLER: [Signature]
 DATE Signed: 12-10-20



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	Whitesboro Central School District	Report To:	Kevin Storszberg	Attention:	
Address:	65 Oriskany Boulevard	Copy To:		Company Name:	
Whitesboro, NY 13492		Purchase Order #:		Address:	
Email: kstorszberg@wboro.org		Project Name:	High School	Pace Project Manager:	nicolette.lovari@pacelabs.com
Phone: 315-266-3312	Fax:	Project #:		Pace Profile #:	8638
Requested Due Date:					

Regulatory Agency	
State / Location	
NY	

ITEM #	MATRIX	CODE	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		DATE	TIME	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on	Ice (Y/N)	Custody (Y/N)	Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)	
					START	END															
241	DW	189	DW		11-25			1407													
242	DW	190	DW					1408													
243	DW	191	DW					1409													
244	DW	192	DW					1410													
245	DW		DW																		
246	DW		DW																		
247	DW		DW																		
248	DW	193	DW					1419													
249	DW	194	DW					1420													
250	DW	195	DW					1422													
251	DW	196	DW					1425													
252	DW	197	DW					1426													

Requested Analysis Filtered (Y/N)	Lead	Residual Chlorine (Y/N)
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	
X	X	

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	Chris Pitzer
SIGNATURE of SAMPLER:	<i>[Signature]</i>
DATE Signed:	12-1-20



Sample Condition Upon Receipt

WO#: 70155659

Client Name:

Project

PM: NML

Due Date: 12/17/20

CLIENT: WBCSD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 7722 4202 6526

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091

Correction Factor: 1.2

Cooler Temperature(°C): 19.6

Cooler Temperature Corrected(°C): 19.4

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: HRP/12/13/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for	<input type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12. See "Comments"
-Includes date/time/ID, Matrix: SL, WT, OIL		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # HC904495		Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

Chain states sample "HS2" is off, but sample was received. Sample "HS3" is missing, nothing was noted on Chain.