

May 14, 2021

Kevin Storszberg  
Whitesboro Central School District  
65 Oriskany Boulevard  
Suite 1  
Whitesboro, NY 13492

RE: Project: WHITEBORO MIDDLE SCHOOL 4/28  
Pace Project No.: 70171606

Dear Kevin Storszberg:

Enclosed are the analytical results for sample(s) received by the laboratory on May 03, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari  
nicolette.lovari@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Brian Bellair, Whitesboro Central School District  
Patricia Cerio, Utica City School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

---

### **Pace Analytical Services Long Island**

Virginia Certification # 460302

Delaware Certification # NY10478

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS2		Lab ID: 70171606001	Collected: 04/28/21 05:11	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.8</b>	ug/L	1.0	1		05/13/21 09:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS3		Lab ID: 70171606002	Collected: 04/28/21 05:11	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		05/13/21 09:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS4		Lab ID: 70171606003	Collected: 04/28/21 05:11	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>6.9</b>	ug/L	1.0	1		05/13/21 09:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS5		Lab ID: 70171606004	Collected: 04/28/21 05:11	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		05/13/21 09:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS6		Lab ID: 70171606005	Collected: 04/28/21 05:19	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.5</b>	ug/L	1.0	1		05/13/21 09:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS9		Lab ID: 70171606006	Collected: 04/28/21 05:19	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		05/13/21 09:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS12		Lab ID: 70171606007	Collected: 04/28/21 05:29	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS13		Lab ID: 70171606008	Collected: 04/28/21 05:30	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS15		Lab ID: 70171606009		Collected: 04/28/21 05:34	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>12.5</b>	ug/L	1.0	1		05/13/21 09:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS16		Lab ID: 70171606010		Collected: 04/28/21 05:35	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.4</b>	ug/L	1.0	1		05/13/21 09:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS16A		Lab ID: 70171606011	Collected: 04/28/21 05:35	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		05/13/21 09:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS16B		Lab ID: 70171606012	Collected: 04/28/21 05:35	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/13/21 09:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS16C		Lab ID: 70171606013	Collected: 04/28/21 05:35	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS19		Lab ID: 70171606014		Collected: 04/28/21 05:44	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

<b>Sample: MS19B</b>		<b>Lab ID: 70171606015</b>		Collected: 04/28/21 05:44	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS19C		Lab ID: 70171606016		Collected: 04/28/21 05:44	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS20		Lab ID: 70171606017	Collected: 04/28/21 05:50	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 09:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS21		Lab ID: 70171606018		Collected: 04/28/21 05:53	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.8</b>	ug/L	1.0	1		05/13/21 09:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS22		Lab ID: 70171606019	Collected: 04/28/21 05:53	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.3</b>	ug/L	1.0	1		05/13/21 09:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS23		Lab ID: 70171606020		Collected: 04/28/21 05:53	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		05/13/21 09:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS24		Lab ID: 70171606021	Collected: 04/28/21 05:53	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS25		Lab ID: 70171606022		Collected: 04/28/21 05:56	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>726</b>	ug/L	1.0	1		05/13/21 10:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS26		Lab ID: 70171606023		Collected: 04/28/21 05:56	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		05/13/21 10:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS28		Lab ID: 70171606024		Collected: 04/28/21 06:01	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS60		Lab ID: 70171606025		Collected: 04/28/21 06:12	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS61		Lab ID: 70171606026	Collected: 04/28/21 06:15	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.8</b>	ug/L	1.0	1		05/13/21 10:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS81		Lab ID: 70171606027	Collected: 04/28/21 06:20	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS82		Lab ID: 70171606028		Collected: 04/28/21 06:06	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS84		Lab ID: 70171606029	Collected: 04/28/21 06:08	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/13/21 10:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28  
Pace Project No.: 70171606

Sample: MS84B		Lab ID: 70171606030	Collected: 04/28/21 06:08	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS84C		Lab ID: 70171606031	Collected: 04/28/21 06:08	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS85		Lab ID: 70171606032	Collected: 04/28/21 06:10	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	21.7	ug/L	1.0	1		05/13/21 10:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS87		Lab ID: 70171606033		Collected: 04/28/21 06:21	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS88		Lab ID: 70171606034	Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>34.3</b>	ug/L	1.0	1		05/13/21 10:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS89		Lab ID: 70171606035	Collected: 04/28/21 06:26	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28  
Pace Project No.: 70171606

Sample: MS91		Lab ID: 70171606036		Collected: 04/28/21 06:27	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>11.0</b>	ug/L	1.0	1		05/13/21 10:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS93		Lab ID: 70171606037	Collected: 04/28/21 07:20	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS94		Lab ID: 70171606038	Collected: 04/28/21 06:30	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>184</b>	ug/L	1.0	1		05/13/21 10:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS95		Lab ID: 70171606039	Collected: 04/28/21 06:30	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS96		Lab ID: 70171606040		Collected: 04/28/21 07:15	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>12.9</b>	ug/L	1.0	1		05/13/21 10:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS98		Lab ID: 70171606041	Collected: 04/28/21 07:10	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS99		Lab ID: 70171606042	Collected: 04/28/21 07:10	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>104</b>	ug/L	1.0	1		05/13/21 10:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS100		Lab ID: 70171606043		Collected: 04/28/21 07:02	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS100A	Lab ID: 70171606044	Collected: 04/28/21 07:02	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		05/13/21 10:36	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS100B	Lab ID: 70171606045	Collected: 04/28/21 07:02	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		05/13/21 10:38	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS100C		Lab ID: 70171606046	Collected: 04/28/21 07:02	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS101		Lab ID: 70171606047		Collected: 04/28/21 07:00	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS103		Lab ID: 70171606048		Collected: 04/28/21 07:06	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.7</b>	ug/L	1.0	1		05/13/21 10:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS104		Lab ID: 70171606049		Collected: 04/28/21 07:06	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.5</b>	ug/L	1.0	1		05/13/21 10:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS105		Lab ID: 70171606050		Collected: 04/28/21 06:55	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>442</b>	ug/L	1.0	1		05/13/21 10:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS106		Lab ID: 70171606051		Collected: 04/28/21 06:55	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>620</b>	ug/L	1.0	1		05/13/21 10:44	7439-92-1	M1

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS107		Lab ID: 70171606052		Collected: 04/28/21 06:55	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.2</b>	ug/L	1.0	1		05/13/21 10:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS108	Lab ID: 70171606053	Collected: 04/28/21 06:53	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>19.8</b>	ug/L	1.0	1		05/13/21 10:50	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS123		Lab ID: 70171606054	Collected: 04/28/21 06:53	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/13/21 10:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS125		Lab ID: 70171606055		Collected: 04/28/21 06:50	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>10.2</b>	ug/L	1.0	1		05/13/21 10:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS126		Lab ID: 70171606056		Collected: 04/28/21 06:45	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.1</b>	ug/L	1.0	1		05/13/21 10:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

**Sample: MS127**      **Lab ID: 70171606057**      Collected: 04/28/21 06:45      Received: 05/03/21 12:00      Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>1.2</b>	ug/L	1.0	1		05/13/21 10:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS128		Lab ID: 70171606058		Collected: 04/28/21 06:47	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.5</b>	ug/L	1.0	1		05/13/21 10:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Sample: MS129		Lab ID: 70171606059		Collected: 04/28/21 06:49	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>14.7</b>	ug/L	1.0	1		05/13/21 10:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: WHITEBORO MIDDLE SCHOOL 4/28  
Pace Project No.: 70171606

QC Batch:	208363	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70171606001, 70171606002, 70171606003, 70171606004, 70171606005, 70171606006, 70171606007, 70171606008, 70171606009, 70171606010, 70171606011, 70171606012, 70171606013, 70171606014, 70171606015, 70171606016, 70171606017, 70171606018, 70171606019, 70171606020

METHOD BLANK: 1037681 Matrix: Water  
Associated Lab Samples: 70171606001, 70171606002, 70171606003, 70171606004, 70171606005, 70171606006, 70171606007, 70171606008, 70171606009, 70171606010, 70171606011, 70171606012, 70171606013, 70171606014, 70171606015, 70171606016, 70171606017, 70171606018, 70171606019, 70171606020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/13/21 09:31	

LABORATORY CONTROL SAMPLE: 1037682

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.8	100	85-115	

MATRIX SPIKE SAMPLE: 1037684

Parameter	Units	70171606001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.8	50	61.0	106	70-130	

MATRIX SPIKE SAMPLE: 1037686

Parameter	Units	70171606011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	50	52.2	102	70-130	

SAMPLE DUPLICATE: 1037683

Parameter	Units	70171606001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.8	7.7	2	

SAMPLE DUPLICATE: 1037685

Parameter	Units	70171606011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

QC Batch:	208364	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70171606021, 70171606022, 70171606023, 70171606024, 70171606025, 70171606026, 70171606027, 70171606028, 70171606029, 70171606030, 70171606031, 70171606032, 70171606033, 70171606034, 70171606035, 70171606036, 70171606037, 70171606038, 70171606039, 70171606040		

METHOD BLANK:	1037687	Matrix:	Water
Associated Lab Samples:	70171606021, 70171606022, 70171606023, 70171606024, 70171606025, 70171606026, 70171606027, 70171606028, 70171606029, 70171606030, 70171606031, 70171606032, 70171606033, 70171606034, 70171606035, 70171606036, 70171606037, 70171606038, 70171606039, 70171606040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/13/21 09:59	

LABORATORY CONTROL SAMPLE:	1037688					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE:	1037690						
Parameter	Units	70171606021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.0	112	70-130	

MATRIX SPIKE SAMPLE:	1037692						
Parameter	Units	70171606031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.5	104	70-130	

SAMPLE DUPLICATE:	1037689				
Parameter	Units	70171606021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	1037691				
Parameter	Units	70171606031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

QC Batch:	208365	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70171606041, 70171606042, 70171606043, 70171606044, 70171606045, 70171606046, 70171606047, 70171606048, 70171606049, 70171606050, 70171606051, 70171606052, 70171606053, 70171606054, 70171606055, 70171606056, 70171606057, 70171606058, 70171606059		

METHOD BLANK:	1037693	Matrix:	Water
Associated Lab Samples:	70171606041, 70171606042, 70171606043, 70171606044, 70171606045, 70171606046, 70171606047, 70171606048, 70171606049, 70171606050, 70171606051, 70171606052, 70171606053, 70171606054, 70171606055, 70171606056, 70171606057, 70171606058, 70171606059		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/13/21 10:29	

LABORATORY CONTROL SAMPLE:	1037694					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.7	99	85-115	

MATRIX SPIKE SAMPLE:	1037696						
Parameter	Units	70171606041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.3	114	70-130	

MATRIX SPIKE SAMPLE:	1037698						
Parameter	Units	70171606051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	620	50	642	43	70-130	M1

SAMPLE DUPLICATE:	1037695					
Parameter	Units	70171606041 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1037697					
Parameter	Units	70171606051 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	620	620	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### WORKORDER QUALIFIERS

WO: 70171606

[1] Sample not received: MS17

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70171606001	MS2	EPA 200.8	208363		
70171606002	MS3	EPA 200.8	208363		
70171606003	MS4	EPA 200.8	208363		
70171606004	MS5	EPA 200.8	208363		
70171606005	MS6	EPA 200.8	208363		
70171606006	MS9	EPA 200.8	208363		
70171606007	MS12	EPA 200.8	208363		
70171606008	MS13	EPA 200.8	208363		
70171606009	MS15	EPA 200.8	208363		
70171606010	MS16	EPA 200.8	208363		
70171606011	MS16A	EPA 200.8	208363		
70171606012	MS16B	EPA 200.8	208363		
70171606013	MS16C	EPA 200.8	208363		
70171606014	MS19	EPA 200.8	208363		
70171606015	MS19B	EPA 200.8	208363		
70171606016	MS19C	EPA 200.8	208363		
70171606017	MS20	EPA 200.8	208363		
70171606018	MS21	EPA 200.8	208363		
70171606019	MS22	EPA 200.8	208363		
70171606020	MS23	EPA 200.8	208363		
70171606021	MS24	EPA 200.8	208364		
70171606022	MS25	EPA 200.8	208364		
70171606023	MS26	EPA 200.8	208364		
70171606024	MS28	EPA 200.8	208364		
70171606025	MS60	EPA 200.8	208364		
70171606026	MS61	EPA 200.8	208364		
70171606027	MS81	EPA 200.8	208364		
70171606028	MS82	EPA 200.8	208364		
70171606029	MS84	EPA 200.8	208364		
70171606030	MS84B	EPA 200.8	208364		
70171606031	MS84C	EPA 200.8	208364		
70171606032	MS85	EPA 200.8	208364		
70171606033	MS87	EPA 200.8	208364		
70171606034	MS88	EPA 200.8	208364		
70171606035	MS89	EPA 200.8	208364		
70171606036	MS91	EPA 200.8	208364		
70171606037	MS93	EPA 200.8	208364		
70171606038	MS94	EPA 200.8	208364		
70171606039	MS95	EPA 200.8	208364		
70171606040	MS96	EPA 200.8	208364		
70171606041	MS98	EPA 200.8	208365		
70171606042	MS99	EPA 200.8	208365		
70171606043	MS100	EPA 200.8	208365		
70171606044	MS100A	EPA 200.8	208365		
70171606045	MS100B	EPA 200.8	208365		
70171606046	MS100C	EPA 200.8	208365		
70171606047	MS101	EPA 200.8	208365		
70171606048	MS103	EPA 200.8	208365		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: WHITEBORO MIDDLE SCHOOL 4/28

Pace Project No.: 70171606

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70171606049	MS104	EPA 200.8	208365		
70171606050	MS105	EPA 200.8	208365		
70171606051	MS106	EPA 200.8	208365		
70171606052	MS107	EPA 200.8	208365		
70171606053	MS108	EPA 200.8	208365		
70171606054	MS123	EPA 200.8	208365		
70171606055	MS125	EPA 200.8	208365		
70171606056	MS126	EPA 200.8	208365		
70171606057	MS127	EPA 200.8	208365		
70171606058	MS128	EPA 200.8	208365		
70171606059	MS129	EPA 200.8	208365		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

WO#: 70171606

**CHAIN-OF-CUSTODY**  
The Chain-of-Custody is a

**Section A**  
Required Client Information:  
Company: Whitesboro CSD  
Address: 65 Oriskany Blvd, Suite 1 Whitesboro, NY 13492  
C/O Pace Analytical Services LLC  
Email: [www.pacelabs.com](http://www.pacelabs.com)  
Phone: (631) 694-3040 Fax: Standard  
Requested Due Date: Standard

**Section B**  
Required Project Information:  
Report To: Whitesboro CSD  
Copy To:  
Purchase Order #: Whitesboro Middle School  
Project #: Standard

**Section C**  
Invoice Information:  
Attention: Whitesboro CSD  
Company Name:  
Address:  
Pace Project Manager:  
Pace Profile #:

Page: 1 Of 6

Regulatory Agency  
State / Location  
NY

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES	ANALYSES TEST Y/N	EPA 200.8 Pb in DW	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	END DATE								
1	MS	DW	4/28/2021	5:11	DW G		1					
2	MS	DW	4/28/2021		DW G		1					
3	MS	DW	4/28/2021		DW G		1					
4	MS	DW	4/28/2021		DW G		1					
5	MS	DW	4/28/2021	5:19	DW G		1					
6	MS	DW	4/28/2021	5:19	DW G		1					
7	MS	DW	4/28/2021	5:25	DW G		1					
8	MS	DW	4/28/2021	5:30	DW G		1					
9	MS	DW	4/28/2021	5:34	DW G		1					
10	MS	DW	4/28/2021	5:55	DW G		1					
11	MS	DW	4/28/2021		DW G		1					
12	MS	DW	4/28/2021		DW G		1					

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	4/28/21		<i>[Signature]</i>	4/28/21	12:00	Sealed Custody (Y/N) Cooler (Y/N) Samples Intact (Y/N)
	<i>[Signature]</i>	5/13/21		<i>[Signature]</i>	5/13/21	12:00	Sealed Custody (Y/N) Cooler (Y/N) Samples Intact (Y/N)

**SAMPLER NAME AND SIGNATURE**  
PRINT Name of SAMPLER: William A. Kotias  
SIGNATURE of SAMPLER: *[Signature]*  
DATE Signed: 4/26/2021







# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b>		<b>Section B</b>	
<b>Required Client Information:</b>		<b>Required Project Information:</b>	
Company: <b>Whitesboro CSD</b>	Report To: <b>Whitesboro CSD</b>	Company Name: <b>Whitesboro CSD</b>	Attention: <b>Whitesboro CSD</b>
Address: <b>65 Oriskany Blvd, Suite 1 Whitesboro, NY 13492</b>	Copy To:	Address:	
C/O Pace Analytical Services LLC		Face Project Manager:	
Email: <b>www.pacelabs.com</b>		Face Profile #:	
Phone: <b>(631) 694-3040</b>	Fax:		
Requested Due Date: <b>Standard</b>			

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Preservatives						EPA 200.8 Pb in DW	Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	START TIME				END DATE	END TIME	Unpreserved	H2SO4	HNO3	HCl				
1	MS	DW	4/28/2021	6:26	1	DW G	1		X								
2	MS	DW	4/28/2021	-	1	DW G	1		X								
3	MS	DW	4/28/2021	6:27	1	DW G	1		X								
4	MS	DW	4/28/2021	7:20	1	DW G	1		X								
5	MS	DW	4/28/2021	6:30	1	DW G	1		X								
6	MS	DW	4/28/2021	6:30	1	DW G	1		X								
7	MS	DW	4/28/2021	7:15	1	DW G	1		X								
8	MS	DW	4/28/2021	7:10	1	DW G	1		X								
9	MS	DW	4/28/2021	7:10	1	DW G	1		X								
10	MS	DW	4/28/2021	7:02	1	DW G	1		X								
11	MS	DW	4/28/2021	J	1	DW G	1		X								
12	MS	DW	4/28/2021	J	1	DW G	1		X								

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	4/28/21	11:35	<i>[Signature]</i>	4/28/21	12:05	Sealed Cooler Custody (Y/N) Received on TEMP in C
	<i>[Signature]</i>	5/13/21		<i>[Signature]</i>	5/13/21	12:00	Sealed Cooler Custody (Y/N) Received on TEMP in C

**SAMPLER NAME AND SIGNATURE**  
 PRINT Name of SAMPLER: **William A. Kotas**  
 SIGNATURE of SAMPLER: *[Signature]*  
 DATE Signed: **4/26/2021**







# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b>		<b>Section B</b>	
<b>Required Client Information:</b>		<b>Required Project Information:</b>	
Company: Whitesboro CSD	Report To: Whitesboro CSD	Company Name: Whitesboro CSD	Attention: Whitesboro CSD
Address: 65 Oriskany Blvd, Suite 1 Whitesboro, NY 13492	Copy To:	Address:	
C/O Pace Analytical Services LLC		Pace Quote:	
Email: www.pacelabs.com		Pace Project Manager:	
Phone: (631) 694-3040	Fax:	Pace Profile #:	
Requested Due Date: Standard			

ITEM #	MATRIX	CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES							ANALYSES TEST Y/N	EPA 200.8 Pb in DW	Residual Chlorine (Y/N)
				START DATE	END TIME			H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other			
1	MS	DW	G	4/28/2021	6:47	1	1	X									
2	MS	DW	G	4/28/2021	6:49	1	1	X									
3	MS	DW	G	4/28/2021		1	1	X									
4	MS	DW	G	4/28/2021		1	1	X									
5	MS	DW	G	4/28/2021		1	1	X									
6	MS	DW	G	4/28/2021		1	1	X									
7	MS	DW	G	4/28/2021		1	1	X									
8	MS	DW	G	4/28/2021		1	1	X									
9	MS	DW	G	4/28/2021		1	1	X									
10	MS	DW	G	4/28/2021		1	1	X									
11	MS	DW	G	4/28/2021		1	1	X									
12	MS	DW	G	4/28/2021		1	1	X									

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	4/28/21	12:05	<i>[Signature]</i>	4/29/21	12:05	Received on ice (Y/N) Custody Sealed (Y/N) Cooler (Y/N) Samples Intact (Y/N)
	<i>[Signature]</i>	5/13/21	11:35	<i>[Signature]</i>	5/13/21	12:00	Temp in C Received on ice (Y/N) Custody Sealed (Y/N) Cooler (Y/N) Samples Intact (Y/N)

<b>SAMPLER NAME AND SIGNATURE</b>	
PRINT Name of SAMPLER:	William A. Kotas
SIGNATURE of SAMPLER:	<i>[Signature]</i>
DATE Signed:	4/26/2021



# Sample Condition Upon Receipt

## WO#: 70171606

Client Name: \_\_\_\_\_

Project \_\_\_\_\_

PM: NML

Due Date: 05/17/21

CLIENT: WBCSD

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No    Seals intact:  Yes  NoPacking Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TH091

Correction Factor: +0.0Cooler Temperature(°C): Amb 20.1Cooler Temperature Corrected(°C): Amb 20.1Temperature Blank Present:  Yes  NoType of Ice: Wet Blue None Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)Date and Initials of person examining contents: CHS/4/21Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  NoDid samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12. <u>Missing Samples</u>
-Includes date/time/ID, Matrix: <u>SLURRY OIL</u>		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HCL48594</u>		Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide? Lead Acetate Strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution: \_\_\_\_\_

Field Data Required? \_\_\_\_\_

Y / N

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_

Samples "MS 17, MS 53" were not provided.