

ADDENDUM TO THE BID DOCUMENTS		Page: 1	Total Pages: 1
Addendum No: # 2		Date this Addendum Issued: February 2, 2024	
<u>Issuing Office:</u> Matanuska-Susitna Borough School District (MSBSD) Purchasing Department 690 Cope Industrial Way Palmer, Alaska 99645 Phone: (907) 861-5120 Facsimile: (907) 861-5184		<u>Previous Addenda Issued:</u> None <u>1</u> <u>January 30, 2024</u> _____ _____ _____ _____	
<u>Return Acknowledgment To:</u> Issuing Department <u>Bid Title:</u> Upgrade Wells at Knik and Goose Bay Elementary School <u>Bid No:</u> B24-04		<u>Date and Hour of Bid Due Date:</u> February 12, 2024 at 2:00 P.M. <u>As Advertised (Frontiersman):</u> January 12 and 14, 2024 <u>As Advertised (ADN):</u> January 12 and 14, 2024	
<p>The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence. The bidder must acknowledge receipt of this addendum in the space provided on Appendix #1. Failure to do so may subject the bidder to disqualification.</p> <p>Clarifications</p> <p>1. Q: Looking at addendum 1 dated 1-30-24. Page 9 section 2.12 A "water service pipe" states "flared fittings". Splicing into existing 2 & 2.5 in copper with flair fittings is EXTREMELY difficult. Can we consider "sweat" slip couplers?</p> <p>A: Yes. Specification Section 33 11 13, Article 2.12 provides specifications for proposed 2-inch copper water service pipe. Methods and materials of connection to existing pipe shall be submitted for approval as part of Section 33 11 13, Article 1.3 B. Alternative methods of pipe joining will be considered.</p>			
END OF ADDENDUM #2			

APPROVED BY: Signature on File	DATE: February 2, 2024
---	---